

9-140



# Plant Status Report

**Plant: Point Beach Nuclear Plant**

**Date: Thursday, April 29, 2004**

**Operations Report (Summary of Last 24 Hours of Operations):**  
 Unit 1 is in refueling shutdown (Mode 6). Unit 2 is at 100% power.

**Days Without LTA: 585** **Homeland Security Condition: Yellow**

Unit 1				Unit 2			
PWR Mode	PWR Level	MWE (Gross)	MWE (Net)	PWR Mode	PWR Level	MWE (Gross)	MWE (Net)
6	0%	0	0	1	100%	543.3	521.3

**Days On Line: 0** **Days Since Last Reactor Trip: 286** **Days On Line: 160** **Days Since Last Reactor Trip: 292**

Technical Specification Action Conditions										
Item	Unit	Condition	Out of Service		Length (Hr/Days)	Tech Spec Number	Expires		Responsibility	Equip Expected RTS Date
			Date	Time			Date	Time		
2RC-508, U2C RMW Supply	2	Out of service.	11/9/03	0749	31 Days	3.6.3.A	5/23/04	1600	M. Rosseau	8/27/04

Major Equipment Out of Service or Degraded							
Item	Unit	Condition	Date	Time	Work Order Number	Due Date	Responsibility
NONE							

Operational Problems / Concerns					
Item	Unit	Condition	Actions Needed	Due Date	Responsibility
2RC-508, U2C Reactor Makeup Supply	2	Valve comes off shut seat momentarily when RMW pump starts.	Provide decision tree to Plant Manager.	4/30/04	K. Krause
Unit 2, Excess Letdown Flow	2	Inadequate excess letdown flow.	Open and inspect, 2CV-285.	5/7/04	N. Stuart
2RE-215, 2HX-46 Air Ejector Gas Monitor	2	Elevated indication, temperature related.	4 step action plan is developed. Scheduled completion is 5/14/04.	5/14/04	B. Carberry
2P-2A, Charging Pump	2	Excessive seal leakage/prevents continuous use of pump.	WO 0400329, Priority 3. Work Scheduled 4/29/04.	4/29/04	R. Brittingham

Aggregate Review of Issues					
Item	Unit	Condition	Actions Planned	Due Date	Responsibility
NONE					

Reportable Events
NONE

AOP FOR HIGH WIND (> 35 MPH)

7K-13

Information in this record was deleted in accordance with the Freedom of Information Act, exemptions 4  
 FOIA/PA-2004-0282

# Plant Status Report

<b>Outstanding Operability Determinations</b>
NONE
<b>Protected Equipment</b>
<b>Load Changes (Planned or Unplanned)</b>
NONE

et4

<b>Reactor Coolant System Leakage</b>		
	<b>Unit 1</b>	<b>Unit 2</b>
<b>Unidentified (gpm)</b>	0 (No leak rate determined due to draindown)	0.04
<b>Identified (gpm)</b>	0	0.04
<b>Major Tests and Evolutions Scheduled in Next 24 Hours</b>		
IX-04, 13.8 KV – 4160 V transformer out of service. (Pending procedure resolutions)		