

9-165 NKC

PBNP SHUTDOWN SAFETY ASSESSMENT AND FIRE CONDITION CHECKLIST

Date: May 4, 2004 Time: 0300 Preparer: T. R. Branam U 1 R 28

NOTE: Refer to base procedure NP 10.3.6 for safety assessment checklist KSF definitions.

NOTE: Whenever fuel has been removed from the reactor vessel and refueling cavity, all key safety functions are GREEN except spent fuel pool cooling.

KEY SAFETY FUNCTION CRITERIA: No/False = 0, Yes/True = 1 through 4

REACTIVITY				Subtotal	Condition
1.	RCS Boron concentration = 3012 ppm				
a.)	For RSD, RCS boron > Refueling boron concentration specified in unit-specific COLR (TRM 2.1) > 2200 ppm				
b.)	For CSD and prior to RSD no fuel motion, RCS boron > boron concentration required by OP 3C	(0-1)	1	0-1	RED
2.	Number of boration paths	(0-2)	2	2	ORANGE
3.	No fuel motion	(0-1)	1	3-4	YELLOW
4.	SR instrumentation operable	(0-1)	1	5	GREEN
	Cavity Boron concentration = 3015 ppm				
Subtotal =				5	

CORE COOLING				Subtotal	Condition
1.	Number of SG available for DHR	(0-2)	0	0-1	RED
2.	Refueling cavity filled	(0-1)	1	2	ORANGE
3.	Number of trains RHR available	(0-2)	1	3	YELLOW
4.	RCS level above REDUCED INVENTORY	(0-1)	1	4-5	GREEN

RCS TEMP = 83°F; 31 days shutdown, Subtotal = 3  
RCS Level = Refueling Height  
RCS Time to Boil 33 hrs (Applicable at Cold or Refueling Shutdown)

POWER AVAILABILITY				Subtotal	Condition
1.	Independent off-site power sources available to A-05 and A-06 (totally independent at the 4160 V, 13.8 kV, and 345 kV levels)			1	RED
				2	ORANGE
				3	YELLOW
		(0-2)	2	4-5	GREEN
2.	G-01 or G-02/A-05/B-03 available	(0-1)	1		
	G-03 or G-04/A-06/B-04 available	(0-1)	1		
3.	G-05 available, Reactor Cavity filled to ≥ 23 ft above the top of the reactor vessel flange, upper internals removed and RCS time to boil ≥ 12 hours.	(0-1)	1		
Subtotal =				5	

INVENTORY				Subtotal	Condition
1.	Pressurizer level ≥ 20 percent w/head on			0-1	RED
		(0-1)	0	2	ORANGE
2.	Refueling Cavity filled (see definition)	(0-3)	3	3	YELLOW
3.	RCS level above REDUCED INVENTORY	(0-1)	1	4	GREEN
4.	Makeup from VCT/BLENDER and/or RWST available	(0-2)	0		
Subtotal =				4	

Information in this record was deleted in accordance with the Freedom of Information Act, exemptions 4

Point Beach Nuclear Plant  
**PBNP SHUTDOWN SAFETY ASSESSMENT AND FIRE CONDITION CHECKLIST**

		Subtotal	Condition
<b>CONTAINMENT</b>			
1. Containment integrity (TS 15.1.D) {Containment Operable} {ITS TS 3.6.1} set	(0 or 4) <u>0</u>	0	RED
2. Containment Closure CL-1E maintained <u>and</u> closure < time to boil	(0 or 2) <u>2</u>	1	ORANGE
3. No fuel motion	(0-1) <u>1</u>	2-3	YELLOW
4. DHR Capability:		4-5-6	<b>GREEN</b>
- cavity flooded and internals out			
<u>OR</u>			
- at least one SG available			
<u>OR</u>			
- one fan cooler <u>with</u> Equip hatch installed and personnel hatches capable of being shut	(0-1) <u>1</u>		
Subtotal =		<u>4</u>	

**SPENT FUEL POOL COOLING**  
**(ONLY APPLICABLE when starting AND during FULL CORE OFFLOADS)**

**NOTE:** Take credit for only one P-12 independent offsite power source during periods of single X-03 or X-04 availability (\*).

		Subtotal	Condition
1. "A" SFP cooling pump available with power available from:		0-1	RED
- G-02 or G-01 via 2B-32	(0-1) <u>NA</u>	2	ORANGE
- (*) an independent off-site power source different than that for Train B below	(0-1) <u>NA</u>	3	YELLOW
2. "B" SFP cooling pump available with power available from:		4-5	GREEN
- G-03 or G-04 via 1B-42	(0-1) <u>NA</u>		
- (*) an independent off-site power source different than that for Train A above	(0-1) <u>NA</u>		
3. Temporary power available to one SFP cooling pump, G-05 available, and SFP time to boil ≥ 12 hours.	(0-1) <u>NA</u>		
Subtotal =		<u>NA</u>	

SFP Temperatures:

NW NA °F

SE NA °F

SFP Average Temp NA °F

SFP Time to Boil NA

**GIVE A BRIEF EXPLANATION OF ANY CHANGE IN SAFETY ASSESSMENT THAT TOOK PLACE:**

1P-10A returned to service.  
 Containment Sump B Screen re-installed.

Point Beach Nuclear Plant  
PBNP SHUTDOWN SAFETY ASSESSMENT AND FIRE CONDITION CHECKLIST

OUTAGE SAFETY ASSESSMENT

UNIT: 1

DATE: May 4, 2004

TIME: 0300

KEY SAFETY FUNCTIONS:

REACTIVITY: GREEN

CORE COOLING: YELLOW

POWER AVAILABLE: GREEN

INVENTORY: GREEN

CONTAINMENT: GREEN

SFP COOLING: NA.

PROTECTED EQUIPMENT:

COMMENTS:

RCS Time to Boil is 33 hours

Fire Protection Condition IV: Credit is taken for fire rounds as fire prevention contingency

ex4