

July 12, 2005

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555-0001

**SUBJECT: San Onofre Nuclear Generating Station, Units 2 and 3  
Docket Nos. 50-361 and 50-362  
Additional Information Regarding  
Proposed Change Number (PCN) 561  
Degraded Voltage Setpoints**

- References:
1. Letter from Brian Katz (SCE) to Document Control Desk (NRC), dated May 27, 2005, Subject: "San Onofre Nuclear Generating Station, Units 2 and 3, Docket Nos. 50-361 and 50-362, Proposed Change Number (PCN) 561, Degraded Voltage Setpoints"
  2. Letter from Bo M. Pham (NRC) to Harold B. Ray (SCE), dated July 1, 2005, Subject: "San Onofre Nuclear Generating Station, Units 2 and 3 – Issuance of Amendments on Degraded Voltage Setpoints (TAC Nos. MC7190 and MC7191)"

Dear Sir or Madam:

Reference 1 (PCN-561) requested changes to Technical Specification (TS) Surveillance Requirement (SR) 3.3.7.3.a to revise the allowable values for the degraded voltage relays. This license amendment request described several modifications that Southern California Edison (SCE) would need to complete prior to implementation of PCN 561.

On July 1, 2005, the NRC issued license amendments (Reference 2) that approved PCN-561. On page 6 of the associated Safety Evaluation Report, the NRC described SCE's commitment to notify the NRC staff once the modifications necessary for implementation of the license amendment are completed.

This letter provides notification that all of the modifications necessary prior to implementation of the license amendments were completed on July 1, 2005.


AX001

July 12, 2005

Degraded voltage setpoint changes consistent with 218 kV in the switchyard (final proposed option) were started on July 5, 2005 and completed on July 6, 2005. The Grid Control Center (GCC) was notified that plant modifications had been completed such that the minimum required switchyard voltage has been returned to 218 kV. The GCC has revised their procedure governing "SONGS Voltage" to 218 kV on July 6, 2005.

If you have any questions or require additional information, please contact Jack Rainsberry at (949) 368-7420.

Sincerely,

A handwritten signature in black ink, appearing to read "Brian Katz". The signature is written in a cursive, flowing style.

cc: B. S. Mallett, Regional Administrator, NRC Region IV  
C. C. Osterholtz, NRC Senior Resident Inspector, San Onofre Units 2 & 3  
B. M. Pham, NRC Project Manager, San Onofre Units 2 and 3