

May 13, 2004

		OUTAC	GE	GOALS		н н <u>е</u> е <u>е</u> По в е с
NUCLEAR SAFETY PERFORMANCE	GOAL	ACTUAL		HUMAN PERFORMANCE	GOAL	ACTUAL
Unplanned orange/red paths	None	None		Security Violations	≤ 12 loggable events	2
Reactor trips (either unit)	None	None		Station human performance clock resets	None	40
Safeguards actuation (either unit)	None	None		Rework	≤1%	On Goal
Loss of shutdown cooling	None	None	1	SCHEDULE PERFORMANCE	ويجاد سؤير المردين ورقا والمعار سواجر الم	Billion and Barth
Loss of Rx vessel level control	None	None		Outage Duration (excludes extensions due to extended head or BMI inspections)	≤ 30 days	Off Goal
INDUSTRIAL SAFETY PERFORMANCE			•	Mod Implementation	100% of Rev 0	On Goal
Lost time accidents	None	None		Schedule Compliance	> 85% schedule compliance with outage milestone	Off Goal
Personnel Injuries (OSHA recordable)	None	1		Emergent work (during implementation)	≤ 2% late additions ≤ 5% Emergent	On Goal
RADIOLOGICAL PERFORMANCE			· .	Scope	Complete ≥ 95% of . Rev 0 scope	On Goal
Radiation exposure (Excludes additional dose from any head or BMI repair contingencies)	≤ 75 R	54.448 R		Operator Burdens	100% of Scheduled Operator Burdens complete	On Goal
Personnel contaminations	≤ 18 w / >5K CPM	9	•	Post Outage availability	≥ 150 days of continuous operation	Available at a later date
Radiological events (defined as unplanned uptake w/assigned dose >10 mrem or dose event based on ED alarms	≤1 event			BUDGET PERFORMANCE	Within -2% to 0% of outage budget	Seriously Challenged
Radmaterial event (defined as any rad material outside RCA ≥ 100 CPM)	≤1 event	0				

Operating Experience

OE10467 - Personnel Received a Radiation Dose Higher Than Planned

On Saturday, November 27, during the Unit 2 13th refueling outage, work was begun to move the reactor vessel lower Internals back into the reactor vessel. A laser/camera system was in place to monitor the internals' elevation, and a mini-sub camera was to be used as a backup to the laser/camera system. It was later determined that the mini sub operator did not understand his role as backup to the laser/camera system for monitoring internals elevation. During the move, the laser/camera system failed, however the internals move was continued. As the move progressed, Health Physics personnel noted dose rates increasing to values higher than expected. The internals were determined to be positioned higher out of the water than was normal, and as a result the polar crane operator received approximately 700mR. The reactor vessel internals move was completed and dose rates returned to expected levels.

Lessons Learned: Initial review of this event indicates that poor communication, poor job scope delineation, an inadequate pre-lob briefing, and lack of contingency planning may have been the primary causes.

, Human Performance

Place Keeping - Not Just for Procedures

Sec. 79.54

Place keeping is a form of action tracking and can be used in situations other than executing procedures. Some recent events where action-tracking failures occurred are:

- A worker failed to complete the review of a document in the required time frame after he had been notified that the document was ready for review.
- An Individual missed training because he got involved in resolving a plant problem.
- A manager failed to approve an overtime extension because he became involved in outage activities.

When critical tasks need to be performed by a specified time (Time Pressure), that is an indication that action tracking (Place Keeping) should be used to avoid an error-likely situation.