

NRC

8-260

## Point Beach Nuclear Plant

## PBNP SHUTDOWN SAFETY ASSESSMENT AND FIRE CONDITION CHECKLIST

Date: May 22, 2004 Time: 0230 Preparer: Mike Meyer U 1 R 28

NOTE: Refer to base procedure NP 10.3.6 for safety assessment checklist KSF definitions.

NOTE: Whenever fuel has been removed from the reactor vessel and refueling cavity, all key safety functions are GREEN except spent fuel pool cooling.

## KEY SAFETY FUNCTION CRITERIA: No/False = 0, Yes/True = 1 through 4

REACTIVITY				Subtotal	Condition
1.	RCS Boron concentration = 3012 ppm				
a.)	For RSD, RCS boron > Refueling boron concentration specified in unit-specific COLR (TRM 2.1) > 2200 ppm				
b.)	For CSD and prior to RSD no fuel motion, RCS boron > boron concentration required by OP 3C	(0-1)	<u>1</u>	0-1	RED
2.	Number of boration paths	(0-2)	<u>2</u>	2	ORANGE
3.	No fuel motion	(0-1)	<u>1</u>	3-4	YELLOW
4.	SR instrumentation operable	(0-1)	<u>1</u>	5	GREEN
Subtotal =				<u>5</u>	

CORE COOLING				Subtotal	Condition
1.	Number of SG available for DHR	(0-2)	<u>0</u>	0-1	RED
2.	Refueling cavity filled	(0-1)	<u>1</u>	2	ORANGE
3.	Number of trains RHR available	(0-2)	<u>2</u>	3	YELLOW
4.	RCS level above REDUCED INVENTORY	(0-1)	<u>1</u>	4-5	GREEN
RCS Temperature = 81°F; 48 days shutdown					
RCS Level = Rod Latch Height					
RCS Time to Boil <u>30 hrs</u> (Applicable at Cold or Refueling Shutdown)					
Subtotal =				<u>4</u>	

POWER AVAILABILITY				Subtotal	Condition
1.	Independent off-site power sources available to A-05 and A-06 (totally independent at the 4160 V, 13.8 kV, and 345 kV levels)			1	RED
				2	ORANGE
				3	YELLOW
		(0-2)	<u>2</u>	4-5	GREEN
2.	G-01 or G-02/A-05/B-03 available	(0-1)	<u>1</u>		
	G-03 or G-04/A-06/B-04 available	(0-1)	<u>1</u>		
3.	G-05 available, Reactor Cavity filled to ≥ 23 ft above the top of the reactor vessel flange, upper internals removed and RCS time to boil ≥ 12 hours.	(0-1)	<u>0</u>		
Subtotal =				<u>4</u>	

INVENTORY				Subtotal	Condition
1.	Pressurizer level ≥ 20 percent w/head on	(0-1)	<u>0</u>	0-1	RED
2.	Refueling Cavity filled (see definition)	(0-3)	<u>2</u>	2	ORANGE
3.	RCS level above REDUCED INVENTORY	(0-1)	<u>1</u>	3	YELLOW
4.	Makeup from VCT/BLENDER and/or RWST available	(0-2)	<u>2</u>	4	GREEN
Subtotal =				<u>5</u>	

Information in this record was deleted  
in accordance with the Freedom of Information  
Act, exemptions 4

Point Beach Nuclear Plant  
**PBNP SHUTDOWN SAFETY ASSESSMENT AND FIRE CONDITION CHECKLIST**

<b>CONTAINMENT</b>			Subtotal	Condition
1.	Containment integrity (TS 15.1.D) {Containment Operable} {ITS TS 3.6.1} set	(0 or 4) <u>0</u>	0	RED
2.	Containment Closure CL-1E maintained and closure < time to boil	(0 or 2) <u>2</u>	1	ORANGE
3.	No fuel motion	(0-1) <u>1</u>	2-3	<del>YELLOW</del>
4.	DHR Capability:		4-5-6	<b>GREEN</b>
	- cavity flooded and internals out			
	<u>OR</u>			
	- at least one SG available			
	<u>OR</u>			
	- one fan cooler with Equip hatch installed and personnel hatches capable of being shut	(0-1) <u>1</u>		
Subtotal =			<u>4</u>	

**SPENT FUEL POOL COOLING**  
(ONLY APPLICABLE when starting AND during FULL CORE OFFLOADS)

**NOTE:** Take credit for only one P-12 independent offsite power source during periods of single X-03 or X-04 availability (\*).

		Subtotal	Condition
1.	"A" SFP cooling pump available with power available from:	0-1	RED
	- G-02 or G-01 via 2B-32	2	ORANGE
	-(*) an independent off-site power source different than that for Train B below	3	YELLOW
		4-5	GREEN
	(0-1) <u>NA</u>		
2.	"B" SFP cooling pump available with power available from:		
	- G-03 or G-04 via 1B-42	(0-1) <u>NA</u>	
	-(*) an independent off-site power source different than that for Train A above	(0-1) <u>NA</u>	
3.	Temporary power available to one SFP cooling pump, G-05 available, and SFP time to boil $\geq$ 12 hours.	(0-1) <u>NA</u>	
Subtotal =		<u>NA</u>	

SFP Temperatures:

NW NA °F

SE NA °F

SFP Average Temp NA °F

SFP Time to Boil NA

**GIVE A BRIEF EXPLANATION OF ANY CHANGE IN SAFETY ASSESSMENT THAT TOOK PLACE:**

None

Point Beach Nuclear Plant  
**PBNP SHUTDOWN SAFETY ASSESSMENT AND FIRE CONDITION CHECKLIST**  
**OUTAGE SAFETY ASSESSMENT**

UNIT: 1                      DATE: May 22, 2004                      TIME: 0230

**KEY SAFETY FUNCTIONS:**

REACTIVITY:	GREEN
CORE COOLING:	GREEN
POWER AVAILABLE:	GREEN
INVENTORY:	GREEN
CONTAINMENT:	GREEN
SFP COOLING:	NA

**PROTECTED EQUIPMENT:**

**COMMENTS:**

- AFW Motor Driven Pump, P-38A, now PROTECTED following completion of ICP 6.86
- RCS Time to Boil is 30 hours. Using NP 10.3.6 Time To Boil curves and curve for core reload complete.
- Fire Protection Condition IV: Credit is taken for fire rounds as fire prevention contingency.