				~) ~
Committed to Nuclear Excellence Point Beach Refueling		DAY 51		DAV
		or A the		
		EXIV		May 24, 2004
		CON Control Room EMT Pager 644 Work Control 6 OCC - x 7190 - Lessons Learr Plant Status - 2 Accomplishme Drained RCS to Replaced RV H	TACT INFOR Emergency – x2 42 Center – x6703 Option 1 ned - x7190 - Option 3 x7190 - Option 3 ents o 70% Reactor Ves lead O-Rings	MATION 2911 tion 2 sel Level
		 Set Reactor Ve Drain RCS to 2 Nozzle Dam Re Move 1P-1B Re Schedule Focu Reactor He Issues Upper Cavi 	2% Reactor Vesse emoval CP Motor s Areas/Priorit ead Penetration #/	l Level (Midloop) ies 26 Relief Request
		 Primary Ma Exit Midloo Remove Ca Commence 	p and Reduced Inv avity Seal Ring Reactor Head Ass	entory Orange Path sembly
		Personnel Safety	Last 24 Hours Recordable - 0 Disabling - 0	Outage to Date Recordable - 1* Disabling - 0
	, `	+OSHA Recordab	le - Back strain.	
Information in this record was deleted in accordance with the Freedom of Information Act, exemptions <u>4</u> FOIA <u>3004</u> - 0383		ALARA Dose as of the en	Last 24 Hours 1.034 d of Day 49	Outage to Date 74.083 R /- /8

ACTUAL 3 4 On Goal

Off Goal

On Goal

Off Goal

On Goal

On Goal Available at a later date Seriously Challenged

OUTAGE GOALS						
NUCLEAR SAFETY PERFORMANCE	GOAL	ACTUAL	HUMAN PERFORMANCE	GOAL		
Unplanned orange/red paths	None	None	Security Violations	< 12 loggable events		
Reactor trips (either unit)	None	None	Station human performance clock resets	None		
Safeguards actuation (either unit)	None	None	Rework	≤ 1%		
Loss of shutdown cooling	None	None	SCHEDULE PERFORMANCE			
Loss of Rx vessel level control	None	None	Outage Duration (excludes extensions due to extended head or BMI inspections)	≤ 30 days		
INDUSTRIAL SAFETY PERFORMANCE			Mod Implementation	100% of Rev 0		
Lost time accidents	None	None	Schedule Compliance	> 85% schedule compliance with outage milestone		
Personnel injuries (OSHA recordable)	None	1	Emergent work (during implementation)	≤ 2% late additions ≤ 5% Emergent		
RADIOLOGICAL PERFORMANCE			Scope	Complete ≥ 95% of Rev 0 scope		
Radiation exposure (Excludes additional lose from any head or BMI repair contingencies)	≤ 92 R	74.083 R	Operator Burdens	100% of Scheduled Operator Burdens complete		
Personnel contaminations	≤ 18 w / >5K CPM	10	Post Outage availability	≥ 150 days of continuous operation		
Radiological events (defined as unplanned uptake w/assigned dose >10 mrem or dose event based on ED alarms	≤1 event	1	BUDGET PERFORMANCE	Within –2% to 0% of outage budget		
Radmaterial event (defined as any rad material outside RCA ≥ 100 CPM)	≤1 event	0				

Human Performance

What are Job Observations?

Job observations take a look at how we are performing work. Some things that people might look for during job observations include use of human error reduction tools, the presence of obstacles to performance, ability to identify error-likely situations, checking worker skill level, safe work habits, and to verify that expectations are being met. Job observations are also used to see if the ACEMAN Principles are being performed in the field.

Safety Snippet

OE12357 January 2001, River Bend – A worker focused on a moving load and did not pay attention to the movement of the crane. He ended up being forced against a handrail by the cab of the crane, luckily resulting only in minor injuries. The entire crew was focused on the load with no one person having oversight of the whole evolution. During crane operations, do we designate an individual to "watch the big picture?"

Operating Experience

OE10173 - Overdrain Of Unit 1 RCS While Draining to the Top of the Hot Legs

Inventory reduction of Unit 1 reactor vessel, for installation of Steam Generator (SG) nozzle dams, was being performed. The RCS had been drained to the 728'6" elevation, 1 foot below the vessel flange, per 1C4.1, RCS Inventory Control -Pre-Refueling. Preparations were in progress to continue draining in accordance with 1D2, RCS Reduced Inventory Operation. The purpose of this procedure is to clear the RCS water from the SG U-tubes, and to drain the reactor vessel down to the tops of the hot legs, the 724'6" elevation. Due to the cumulative affects of a number of human performance and procedural adequacy issues, the system was over drained. This necessitated 46 minutes of charging pump operation and the addition of approximately 1500 gallons of makeup to establish RCS level at the top of the hot legs.

Lessons Learned: Supervisory Methods – The assigned SRO and NLPERO for the draindown did not allocate manpower to ensure that all personnel involved with the draindown were in attendance at the pre-job brief. The SRO in charge of the draindown did not adequately track progress, and lost oversight of the evolution. He became involved in the discussions, and allowed the draining to recommence prior to level stabilization. Written communications and training/qualification also contributed to the event.