



Point Beach Nuclear Plant U1R28 Refueling Outage

Safety Topic for week of May 30 – June 5, 2004
Theme for the week
This week's focus is looking back at our reported injuries so far in 2004. There were 52 injuries to workers on the site so far this year. That's almost more than we typically see in 2 years! That's an injury every 3 days! Our goal is NONE . <u>Let's review what going on and discuss how to prevent anything else from occurring in 2004.</u>
Daily Safety Snippets
Sunday
"Twist and strains are no one's gains"
Mechanic Electrician was removing a temporary rigging fixture from a roof beam and felt a strain in the upper back. <i>Remember your Save A Back training!</i>
Monday
"Stretching before you work may reduce the strains that lurk."
An engineer experienced severe back pain upon exiting containment. The employee was bending in order to exit the accident fan coolers prior to the incident. Medical treatment was necessary and this was an OSHA recordable event.
Tuesday
"If your backfield is in motion, use a zone defense."
Contract electrician was pulling wire for a conduit through a junction box for the security upgrade project. While bending over to retrieve a pull string, the wind caught the junction box door. It swung and struck the employee in the back.
Wednesday
"It's too late for learning when your skin is already burning."
There have been 3 incidents in the past month where individuals contacted hot equipment and minor burns resulted. Two in maintenance – one was during welding activity, the second was when an employee came in contact with a hot muffler on a pump. The third was when one of the M&M Lunch employees placed her hand on a hot grill. <i>What human performance barriers are we missing here?</i>
Thursday
"Where danger lingers, watch your fingers"
What is the most likely injury the site has? Given the age of the work force, it should be strains. But it's hand injuries! 22 injuries so far this year! Example – chem. tech was removing a glass funnel from tygon tubing. The funnel separated from the stem, resulting in a minor finger laceration. <i>The wrong technique was used for doing this work.</i>
Friday
"Never gamble with more than you can handle"
Two situations to review here. One was a RP worker and contractor trying to maneuver material through a security door. Rather than calling security, they figured they could "beat the door." They beat it all right. And the contractor suffered a leg injury from the steel hitting him. The second was an OAll carrying a large box through a door. She ended up catching hitting her hand on the doorframe. <i>How can we prevent these injuries?</i>
Saturday
"The brain is mightier than the brawn"
Contract insulator struck his head on an I-beam while reaching for material. He was wearing the right PPE, but felt neck discomfort from the hit. The worker knew the beam was a potential hazard, but did not take the time to soften it prior to beginning his work.

Point Beach Nuclear Plant Outage 1R28

DAY 57

Path



Picture

Meets



Doesn't Meet Exceeds

Supporting Operational Excellence

Outage Radiation Performance

Definition/Goal

Analysis and Actions

This indicator measures cumulative dose radiation exposure and total number of personnel-contamination events (PCE's > 5000 cpm) during refueling outages. The dose indicator is measured in Rem and individual PCE events.


Day 57 - May 30
 Actual = 0.217
 Cumulative = 85.325
 Cumulative Forecast = 90.831

Meets:	<=92 Rem	Actual Cum.	
Exceeds:	<=88 Rem	Dose:	85.325 Rem
Meets: <= 18	Exceeds: <= 12	Actual PCE's:	11


Responsible Manager/Owner

Stu Thomas

Personnel Contamination Events



Cummulative Dose Exposure



Outage Status Report

Plant: Point Beach Unit 1 Day: Monday Today's Date / Time: 5/31/04 1500

Outage Duration: Day 58 Of Refueling Outage Number U1R28

Safety Status

Industrial - Within the last 12 hours
 OSHA Recordables 0 First Aid cases 0 Near misses 0
 Total for this outage 1

Summary:

Radiological
 Dose to date 85.325 Projected to date *90.831 Outage Goal ≤92 R
 Difference -5.506 * Reforecast on 5/23 Number of PCEs 11

Summary:

Nuclear
 Significant human performance errors and events in last 24 hours 0

Summary:

Plant Status

Mode: Hot Standby (Mode 3) Hot Shutdown (Mode 4) Cold Shutdown (Mode 5) Refueling Shutdown (Mode 6)
 RCS: Temperature: 99 Pressure: 350 psig RV Level: Pressurizer Solid
 Time to Boil: > 7 Hours

Shutdown Safety Assessment Protected Equipment:

- None

Major Activities Completed in Last 24 Hours

- Completed RCS Fill & Vent Activities IAW OP-4A
- 1P-1A Reactor Coolant Pump Balance Weight Move
- Restored Containment Upper Hatch Interlocks
- Post Fill and Vent Valve Line Up
- Started 1P-1A Reactor Coolant Pump
- Started 1W-3B Control Rod Drive Shroud Fan

Critical Path and Near Critical Path Activities (Next 24 Hours)

- Silica Dilution and Heat Up RCS to 165°F
- Continue Containment Purge Work
- IT-3B Low Head Safety Injection Valve
- Start 1P-1B Reactor Coolant Pump
- TS-30 High & Low Head SI Check Valve Test

Significant Outstanding Issues

Date	Issue	Due	Responsibility
5/17/04	Rx Head Relief Request	6/01/04	Jim Schweitzer

Upcoming Major Milestones

	Scheduled		Actual			Scheduled		Actual	
	Date	Time	Date	Time		Date	Time	Date	Time
Cooldown <200°	4/03/04	2100	4/03/04	2230	RCS Fill & Vent	4/23/04	1500	5/31/04	0653
Head Lift	4/09/04	0900	4/21/04	1550	Heatup >200°	4/25/04	0900		
Refueled	4/14/04	0300	5/02/04	1848	Reactor Critical	4/28/04	0800		
RV Headset	4/18/04	1900	5/23/04	1338	On-Line	4/30/04	0100		

Point Beach Nuclear Plant
PBNP SHUTDOWN SAFETY ASSESSMENT AND FIRE CONDITION CHECKLIST

OUTAGE SAFETY ASSESSMENT

UNIT: 1


DATE: May 31, 2004

TIME: 1430

KEY SAFETY FUNCTIONS:

REACTIVITY:	GREEN
CORE COOLING:	GREEN
POWER AVAILABLE:	GREEN
INVENTORY:	GREEN
CONTAINMENT:	GREEN
SFP COOLING:	NA

PROTECTED EQUIPMENT:



COMMENTS:

- RCS Time to Boil is >7 hours

Ex4

Defined Critical Path

J	ID	DESCRIPTION	OD	RD	Cal	U	SYS	EQID	TF	MAY					JUN									
										31					1					2				
										4	6	8	10	12	14	16	18	20	22	0	2	4	6	8
1MAY04 00:00											31MAY04 00:00													
1	OI64-040	CLN & LUBE PURGE SUPPLY VNPSE-3245	4	1	1	1	VNPSE	VNPSE-3245	2	OI64-040	CLN & LUBE PURGE SUPPLY VNPSE-3245	31MAY04 12:59	31MAY04 09:00A											
1	MM0214187B	RESTORE C-2 UPPER HATCH INTERLOCKS	6	3	1	1	CONT	C-2	0	MM0214187B	RESTORE C-2 UPPER HATCH INTERLOCKS	31MAY04 14:59	31MAY04 09:00A											
1	T-7589-H	1 VNPSE TM 04-001 (3244) MMV REV0-1	2	2	1	1	VNPSE	VNPSE-3244	2	T-7589-H	1 VNPSE TM 04-001 (3244) MMV REV0-1	31MAY04 14:59	31MAY04 13:00											
1	T-0696-H	1 VNPSE VNPSE-3212/3213 OI-64 OPS REV0-1	1	1	1	1	VNPSE	VNPSE-3212	0	T-0696-H	1 VNPSE VNPSE-3212/3213 OI-64 OPS REV0-1	31MAY04 15:00	31MAY04 15:59											
1	T-0697-H	1 VNPSE VNPSE-3213 OI-64 OPS REV0-1	1	1	1	1	VNPSE	VNPSE-3213	0	T-0697-H	1 VNPSE VNPSE-3213 OI-64 OPS REV0-1	31MAY04 15:00	31MAY04 15:59											
1	MM0400322	1VNPSE-3244, REMOVE OPERATOR & EQUIP., TM	10	10	1	1	VNPSE	VNPSE-0324	2	MM0400322	1VNPSE-3244, REMOVE OPERATOR & EQUIP., TM 04-001	31MAY04 16:00	01JUN04 00:59											
1	OI64-020	CLN & LUBE PURGE EXHAUST VNPSE-3213	4	4	1	1	VNPSE	VNPSE-3213	0	OI64-020	CLN & LUBE PURGE EXHAUST VNPSE-3213	31MAY04 16:00	31MAY04 19:59											
1	T-7588-H	1 VNPSE TM 04-001 (3212) MMV REV0-1	1	1	1	1	VNPSE	TM 04-001	0	T-7588-H	1 VNPSE TM 04-001 (3212) MMV REV0-1	31MAY04 20:00	31MAY04 20:59											
2	MM0400324	1VNPSE-3212, REMOVE OPERATOR & EQUIP., TM	10	10	1	1	VNPSE	VNPSE-0321	0	MM0400324	1VNPSE-3212, REMOVE OPERATOR & EQUIP., TM 04-001	31MAY04 21:00	01JUN04 06:59											
01JUN04 00:00											01JUN04 00:00													
1	MM0400322A	1VNPSE-3244, REMOVE VALVE & INSTALL BLANK	4	4	1	1	VNPSE	VNPSE-0324	2	MM0400322A	1VNPSE-3244, REMOVE VALVE & INSTALL BLANK FLANGE	01JUN04 01:00	01JUN04 04:59											
1	MM0400324B	1VNPSE-3212, REMOVE VALVE & INSTALL BLANK	4	4	1	1	VNPSE	VNPSE-0321	0	MM0400324B	1VNPSE-3212, REMOVE VALVE & INSTALL BLANK FLANGE	01JUN04 07:00	01JUN04 10:59											
1	MM0400324C	1VNPSE-3212, COMPLETE TEMP MOD INSTALLATION	10	10	1	1	VNPSE	VNPSE-0321	0	MM0400324C	1VNPSE-3212, COMPLETE TEMP MOD INSTALLATION	01JUN04 11:00	01JUN04 20:59											
2	CSD6	SIGN MODE CHANGE CHECKLIST TO EXIT MODE 5	0	0	1	2	XX	MILESTONE	4	CSD6	SIGN MODE CHANGE CHECKLIST TO EXIT MODE 5	01JUN04 21:00	01JUN04 20:59											
1	T-7588-R	1 VNPSE TM 04-001 (3212) MMV REV0-1	2	2	1	1	VNPSE	TM 04-001	2	T-7588-R	1 VNPSE TM 04-001 (3212) MMV REV0-1	01JUN04 21:00	01JUN04 22:59											
1	TS-035.2-B	TS-35.2, CONTAINMENT PURGE EXHAUST LLRT	4	4	1	1	CONT	O-TS-035.2	0	TS-035.2-B	TS-35.2, CONTAINMENT PURGE EXHAUST LLRT	01JUN04 21:00	02JUN04 00:59											
1	CL01B020	ESTABLISH CONTAINMENT OPERABILITY	0	0	1	1	CONT	CL-1B & OP	2	CL01B020	ESTABLISH CONTAINMENT OPERABILITY	01JUN04 23:00	01JUN04 22:59											
1	OP1A200F	HEATUP RCS TO 200 DEGREES	2	2	1	1	RC	OP-1A	0	OP1A200F	HEATUP RCS TO 200 DEGREES	01JUN04 23:00	02JUN04 00:59											

Defined Critical Path

J	ID	DESCRIPTION	OD	RD	Cal	U	SYS	EQID	TF	MAY							JUN													
										31							1							2						
										4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20
02JUN04 00:00											02JUN04 00:00																			
1	COLDSDN	RCS ENTERS HOT SHUTDOWN	0	0	1	1	XX	MILESTONE	0															COLDSDN	RCS ENTERS HOT SHUTDOWN	02JUN04 00:59				
1	CONTX03Z	CLOSE CTMT PURGE/EXHAUST WORK	0	0	1	1	VPSE	MILESTONE	0															CONTX03Z	CLOSE CTMT PURGE/EXHAUST WORK WINDOW	02JUN04 01:00				
1	OPMM5Z	END OPERATIONS COLD SHUTDOWN WORK	0	0	1	1	XX	ADMIN MS	0															OPMM5Z	END OPERATIONS COLD SHUTDOWN WORK	02JUN04 01:00				
1	OP1A250F	HEATUP RCS TO 250 - 270 deg F	3	3	1	1	RC	OP-1A	0															OP1A250F	HEATUP RCS TO 250 - 270 deg F	02JUN04 01:00				
1	OP1A-050	HEATUP PRESSURIZER	4	4	1	1	RC	OP-1A	0															OP1A-050	HEATUP PRESSURIZER	02JUN04 04:00				
1	OP1A-060	ESTABLISH PZR BUBBLE	1	1	1	1	RC	OP-1A	0															OP1A-060	ESTABLISH PZR BUBBLE	02JUN04 08:00				
1	OP7B-010	SECURE OPERATING RHR PUMPS	1	1	1	1	RH	OP-7B	0															OP7B-010	SECURE OPERATING RHR PUMPS	02JUN04 08:00				
1	OP1A-080	ESTABLISH NORMAL PZR LEVEL	1	1	1	1	CV	OP-1A	4															OP1A-080	ESTABLISH NORMAL PZR LEVEL	02JUN04 09:00				
1	OP7B-020	COOLDOWN AND BORATE RHR	6	6	1	1	RH	OP-7B	0															OP7B-020	COOLDOWN AND BORATE RHR	02JUN04 09:00				
1	OP1A300F	HEATUP RCS TO 295 - 305 deg F	1	1	1	1	RC	OP-1A	4															OP1A300F	HEATUP RCS TO 295 - 305 deg F	02JUN04 10:00				
1	TS-030C	TS-30 (SECTION 5.23) TEST OF SI-867B	1	1	1	1	SI	O-TS-030	0															TS-030C	TS-30 (SECTION 5.23) TEST OF SI-867B	0216005 - 02JUN04 15:59				
1	T-0482-H	1 SI SI-852A EM REV0-1	2	2	1	1	SI	SI-852A	0															T-0482-H	1 SI SI-852A EM REV0-1	0010482 - 02JUN04 16:59				
1	OP1A-090	DISABLE LTOP	1	1	1	1	RC	OP-1A	0															OP1A-090	DISABLE LTOP	02JUN04 16:59				
1	OP1A350F	HEATUP RCS TO 340 - 345 deg F	1	1	1	1	RC	OP-1A	0															OP1A350F	HEATUP RCS TO 340 - 345 deg F	02JUN04 17:59				
1	IT-290B	IT-290B, 1P-29 AFP OVERSPEED TEST	4	4	1	1	AF	O-IT-0290B	3															IT-290B	IT-290B, 1P-29 AFP OVERSPEED TEST	0215901 - 02JUN04 20:59				
1	MM0214127A	MM SUPPORT FOR P-29-T OVERSPEED TRIP TEST	4	4	1	1	AF	P-029	3															MM0214127A	MM SUPPORT FOR P-29-T OVERSPEED TRIP TEST	0214127 - 02JUN04 20:59				
1	EM0403305	SI-852A-O PERFORM STEM LUBE AND FBJ INSPECTION	10	10	1	1	SI	SI-00852A-	0															EM0403305	SI-852A-O PERFORM STEM LUBE AND FBJ INSPECTION	0403305 - 03JUN04 02:59				

Work Activity Risk Assignment

ACT ID	WO ST	GRP	HPE RISK	EQUIPMENT	Activity Description	Cal ID	DUR	START	FINISH	Gantt Chart																			
										MAY			JUN																
										30	M 31	T 1	W 2	T 3	F 4	S 5	S 6	M 7	T 8	W 9	T 10	F 11	S 12						
CONSTRUCTION ENGINEERING GROUP																													
CE0307011G	76	CE	DR-N ML-Y ORT3-N R-M	D-105	INSTALL NEW D-105 JARS IN D-105 BATTERY ROOM	1	19	30MAY04 14:00A	01JUN04 06:59	125V DC STATION BATTERY 030701 - B09A1																			
ELECTRICAL MAINTENANCE																													
EM0305129	76	EM	DR-Y ML-Y ORT3-Y R-M	U2A-LV RELAYS	TEST U2 TRAIN A UNDERVOLTAGE AND	1	5	01JUN04 20:00*	02JUN04 00:59	TRAIN A 4.16 KV AND 480 V SWITCHGEAR RELAY TEST 0305129 - B11A2																			
OPERATIONS																													
IT-003B	77	OPS	DR-N ML-N ORT3-N R-M	O-IT-0003B	IT-3B, LOW HEAD SAFETY INJECTION VALVE	1	1	31MAY04 15:00	31MAY04 15:59	LOW HEAD SI VALVE EXERCISE TEST IN COLD SHUTDOWN 0215887 - 128OP																			
TS-030	77	OPS	DR-N ML-N ORT3-N R-M	O-TS-030	HIGH & LOW HEAD SI CHECK VLV TEST	1	12	31MAY04 18:00	01JUN04 05:59	U1 HIGH/LOW HEAD SI CHECK VLV LEAKAGE TEST (CSD) 0216005 - 128OP																			
TS-10A		OPS	DR-N ML-N ORT3-N R-M	O-TS-010AB.1	TS-10A, U1C AIR LOCK DOOR SEAL TEST	1	2	01JUN04 00:00	01JUN04 01:59	U1 CONT AIR LOCK DOOR SEAL TEST 128OP																			

UN

Early Bar
 Progress Bar
 Critical Activity

NMC / WE
PBNP U1 Refueling 28 Outage

LT-81 HUMAN ERROR RISK BARCHART
FL-81 HUMAN ERROR POTENTIAL

U1R28 WORKING SCHEDULE

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN					
											Mon 31			Tue 1			Wed 2		
											8	10	12, 14, 16, 18, 20, 22	0	2	4, 6, 8, 10, 12, 14, 16, 18, 20, 22	0	2	4, 6, 8, 10, 12, 14, 16, 18
ADMINISTRATIVE SERVICES												ADM							
1	0	EMPFOR4A	ADM		MEETING	EMPLOYEE FORUM	2	02JUN04 08:00*	02JUN04 09:59	478						EMPFOR4A EMPLOYEE FORUM			
2	0	EMPFOR4B	ADM		MEETING	EMPLOYEE FORUM	2	02JUN04 10:00*	02JUN04 11:59	476						EMPFOR4B EMPLOYEE FORUM			
3	0	EMPFOR4C	ADM		MEETING	EMPLOYEE FORUM	2	02JUN04 12:00*	02JUN04 13:59	474						EMPFOR4C EMPLOYEE FORUM			
APPLETON METERING GROUP												APM							
4	1	AP0216539	APM	76	TG-01-VARM	PERFORM RETEST FOR T-MOD 02-052 REMOVAL	2	31MAY04 10:00A	31MAY04 13:59	12	AP0216539	PERFORM RETEST FOR T-MOD 02-052 REMOVAL							
													1TG-01 TURBINE GENERATOR OUTPUT VARMETER 0216539						
5	1	AP0215133	APM	76	TG-01-G	GENERATOR METERS ON C-01 CALIBRATION	14	31MAY04 10:00A	01JUN04 16:59	0	AP0215133	GENERATOR METERS ON C-01 CALIBRATION				ELECTRICAL GENERATOR 0215133			
APPLETON RELAY GROUP												APR							
6	1	AP0215126	APR	75	F52-122	TRIP F52-122 FROM PROTECTIVE RELAYING	5	01JUN04 09:00*	01JUN04 13:59	0			AP0215126	TRIP F52-122 FROM PROTECTIVE RELAYING					
													0215126	1TG-01 TG OUTPUT BREAKER					
7	1	AP0303688A	APR	76	A-01	(CONT) CALIBRATE 1A-01 NON-TECH SPEC	50	02JUN04 08:00*	07JUN04 12:59	130			AP0303688A	(CONT) CALIBRATE 1A-01 NON-TECH SPEC RELAYS		4.16 KV BUS SWITCHGEAR 0303688			
APPLETON STATION GROUP												APS							
8	2	AP0307284	APS	76	X-01-A	COOLING SYSTEM INSPECTION/CLEANING	30	01JUN04 08:00*	04JUN04 10:59	159			AP0307284	COOLING SYSTEM INSPECTION/CLEANING					
BOP MECHANICAL ENGINEERING												BMS							
9	2	BM0300125	BMS	77	RE-PC 46.1	VERIFY RTO AS CALCULATED BY PPCS	1	01JUN04 07:00*	01JUN04 07:59	120			BM0300125	VERIFY RTO AS CALCULATED BY PPCS					
													0300125	CALORIMETRIC					
10	0	BM307011JJ	BMS	76	D-105	ENGINEERING SUPPORT: W-85/86	0	01JUN04 19:00	01JUN04 18:59	351			BM307011JJ	ENGINEERING SUPPORT: W-85/86 DAMPER ADJUSTMENTS		0307011 125V DC STATION BATTERY			
CONSTRUCTION ENGINEERING GROUP												CE							
11	0	CE0307011G	CE	76	D-105	INSTALL NEW D-105 JARS IN D-105 BATTERY	19	30MAY04 14:00A	01JUN04 06:59	0	CE0307011G	INSTALL NEW D-105 JARS IN D-105 BATTERY ROOM				125V DC STATION BATTERY 0307011			
12	0	CE0400802	CE	77	SERVICE	CE FLAMMABLE STORAGE LOCKER INSP	4	01JUN04 07:00*	01JUN04 10:59	117			CE0400802	CE FLAMMABLE STORAGE LOCKER INSP		MISC EQUIPMENT REPAIR/SERVICE			
13	0	CE0406128	CE	76	M-2005-6-4	M-2005-6-40-E05 REPAIR PENETRATION	8	01JUN04 07:00*	01JUN04 14:59	113			CE0406128	M-2005-6-40-E05 REPAIR PENETRATION		FIRE BARRIER PENETRATION			
14	0	CE0307011H	CE	76	D-105	RE-TERMINATE D-105 BUS WORK &	12	01JUN04 07:00	01JUN04 18:59	0			CE0307011H	RE-TERMINATE D-105 BUS WORK & CONNECTORS		0307011 125V DC STATION BATTERY			
15	2	CSD9	CE		MILESTONE	SIGN MODE CHANGE CHECKLIST TO EXIT	0	01JUN04 11:00	01JUN04 10:59	14						CSD9 SIGN MODE CHANGE CHECKLIST TO EXIT MODE 5 (END MISCELLANEOUS COLD SHUTDOWN WORK			
16	0	CE307011FF	CE	76	D-105	INSTALL DOOR 458	1	01JUN04 19:00	01JUN04 19:59	0			CE307011FF	INSTALL DOOR 458		0307011 125V DC STATION BATTERY			

U1R28 WORKING SCHEDULE

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN					
											Mon 31			Tue 1			Wed 2		
											8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22			
INSULATION - NPS - D. CHERNEY												CE3							
17	1	CE44TGATI	CE3	87	IST-SISI	REINSULATE - FAC PROG - TRB HALL 44 FT GEN AREA	110	17MAY04 14:00A	09JUN04 20:59	2	CE44TGATI	REINSULATE - FAC PROG - TRB HALL 44 FT GEN AREA							
18	0	CE213075TI	CE3	77	SERVICE	INSTALL INSULATION FOR 1FD-38	3	25MAY04 07:00A	01JUN04 09:59	88	CE213075TI	INSTALL INSULATION FOR 1FD-38							
19	1	TG-30950	CE3	82	TG-01-T	REINSTALL HP TURBINE INSULATION	91	26MAY04 15:00A	16JUN04 09:59	0	TG-30950	REINSTALL HP TURBINE INSULATION							
20	1	CE300867TI	CE3	87	ICP-05.047	INSTALL INSULATION FOR LS-2377A/B	16	01JUN04 07:00*	02JUN04 14:59	75	CE300867TI	INSTALL INSULATION FOR LS-2377A/B							
21	0	CE303887TI	CE3	77	IST-PISI	INSTALL INSULATION FOR ISI-PRI-1133	2	01JUN04 08:00*	01JUN04 09:59	21	CE303887TI	INSTALL INSULATION FOR ISI-PRI-1133							
22	0	CE216332TI	CE3	77	SERVICE	INSTALL INSULATION FOR 1FD-204B	25	01JUN04 08:00*	04JUN04 08:59	65	CE216332TI	INSTALL INSULATION FOR 1FD-204B							
SCAFFOLDING - NPS - J. HAESE												CE4							
23	1	CE212978SR	CE4	76	SA-00027	REMOVE SCAFFOLDING FOR 1SA-27	4	01JUN04 07:00*	01JUN04 10:59	20	CE212978SR	REMOVE SCAFFOLDING FOR 1SA-27							
24	1	CE214031SR	CE4	82	CV-00257	REMOVE SCAFFOLDING FOR CV-257	8	01JUN04 07:00*	01JUN04 14:59	83	CE214031SR	REMOVE SCAFFOLDING FOR CV-257							
25	1	CE300869SR	CE4	87	ICP-05.049	REMOVE SCAFFOLDING FOR ICP-5.49	40	01JUN04 07:00*	07JUN04 14:59	51	CE300869SR	REMOVE SCAFFOLDING FOR ICP-5.49							
CONSTRUCTION ENG - S. CARTER												CE6							
26	0	CE0210986	CE6	77	SEC	SEC SUPPORT MR 99-011*B	104	05APR04 07:00A	17JUN04 14:59	17	CE0210986	SEC SUPPORT MR 99-011*B							
27	0	CE0210989	CE6	76	SEC	SEC, INSTALL NEW EQUIP MR 99-011*E	104	05APR04 08:00A	17JUN04 14:59	17	CE0210989	SEC, INSTALL NEW EQUIP MR 99-011*E							
28	0	CE0210990	CE6	76	SEC	SEC REM ABANDONED EQUIP MR 99-011*F	120	03MAY04 08:00A	21JUN04 14:59	1	CE0210990	SEC REM ABANDONED EQUIP MR 99-011*F							
CONSTRUCTION ENG - L. GAUTHIER												CE8							
29	1	CE1600R035	CE8	76	R-1	RX HEAD REPAIR CLOSEOUT ACTIVITY	54	22MAY04 07:00A	02JUN04 17:59	10	CE1600R035	RX HEAD REPAIR CLOSEOUT ACTIVITY							
CHEMISTRY												CH							
30	1	CH0300364	CH	77	CHEM-SAMPL	RCS CL TSR 3.4.5.2	55	30MAY04 05:00A	05JUN04 11:59	183	CH0300364	RCS CL TSR 3.4.5.2							
31	1	CH0300377	CH	77	CHEM-SAMPL	RCS DO TSR 3.4.5.1	55	30MAY04 05:00A	05JUN04 11:59	183	CH0300377	RCS DO TSR 3.4.5.1							
32	1	CH0300407	CH	77	CHEM-SAMPL	RCS BORON SR 3.9.1.1	55	30MAY04 05:00A	05JUN04 11:59	183	CH0300407	RCS BORON SR 3.9.1.1							

U1R28 WORKING SCHEDULE

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN			
											Mon 31	Tue 1	Wed 2	Thu 3	Fri 4	Sat 5	Sun 6
CHEMISTRY												CH					
33	0	CH0300201	CH	77	CHEM-SAMPL	BAST BORON TSR 3.5.1.2	29	31MAY04 07:00A	04JUN04 11:59	92	CH0300201 BAST BORON TSR 3.5.1.2						
34	1	CH0300391	CH	77	CHEM-SAMPL	SGBDFO GAMMA SCAN	29	31MAY04 07:00A	04JUN04 11:59	92	CH0300391 SGBDFO GAMMA SCAN						
35	1	CH0300448	CH	77	CHEM-SAMPL	RE-229 ISOTOPIC	29	31MAY04 07:00A	04JUN04 11:59	92	CH0300448 RE-229 ISOTOPIC						
36	2	CH0300487	CH	77	CHEM-SAMPL	RCS BORON SR 3.9.1.1	29	31MAY04 07:00A	04JUN04 11:59	92	CH0300487 RCS BORON SR 3.9.1.1						
37	2	CH0300504	CH	77	CHEM-SAMPL	RCS CL TSR 3.4.5.2	29	31MAY04 07:00A	04JUN04 11:59	92	CH0300504 RCS CL TSR 3.4.5.2						
38	2	CH0300517	CH	77	CHEM-SAMPL	RCS DO TSR 3.4.5.1	29	31MAY04 07:00A	04JUN04 11:59	92	CH0300517 RCS DO TSR 3.4.5.1						
39	2	CH0300530	CH	77	CHEM-SAMPL	SGBDFO GAMMA SCAN	29	31MAY04 07:00A	04JUN04 11:59	92	CH0300530 SGBDFO GAMMA SCAN						
40	2	CH0300556	CH	77	CHEM-SAMPL	RE-229 ISOTOPIC	29	31MAY04 07:00A	04JUN04 11:59	92	CH0300556 RE-229 ISOTOPIC						
41	1	CAMP-600B2	CH		CAMP-600.1	RESTORE RCS SAMPLE LINE-UP	1	31MAY04 15:00	31MAY04 15:59	31	CAMP-600B2 RESTORE RCS SAMPLE LINE-UP						
42	1	OP1A-031	CH		OP-1A	SAMPLE VCT FOR OXYGEN	2	31MAY04 18:00	31MAY04 19:59	0	OP1A-031 SAMPLE VCT FOR OXYGEN						
43	1	OP1A-025	CH		OP-1A	SAMPLE/VERIFY RCS TSS < 350 ppb.	3	31MAY04 18:00	31MAY04 20:59	0	OP1A-025 SAMPLE/VERIFY RCS TSS < 350 ppb. VERIFY RCS TSS < 350 ppb.						
44	1	OP1A-027	CH		OP-1A	SECOND SAMPLE OF RCS FOR TSS	3	31MAY04 21:00	31MAY04 23:59	0	OP1A-027 SECOND SAMPLE OF RCS FOR TSS						
45	1	OP1A-032	CH		OP-1A	VERIFY RCS OXYGEN IN SPEC	1	01JUN04 13:00	01JUN04 13:59	1	OP1A-032 VERIFY RCS OXYGEN IN SPEC VERIFY RCS OXYGEN CONCENTRATION IN-SPEC						
46	1	OP1A-033	CH		OP-1A	VERIFY CL/F/SO4 IS SPEC PER NP 3.2.2	1	01JUN04 14:00	01JUN04 14:59	8	OP1A-033 VERIFY CL/F/SO4 IS SPEC PER NP 3.2.2						
47	1	CAMP-113AF	CH		CAMP-113	SAMPLE SG1A STEAM GENERATOR	3	02JUN04 01:00	02JUN04 03:59	29	CAMP-113AF SAMPLE SG1A STEAM GENERATOR						
48	1	CAMP-113BF	CH		CAMP-113	SAMPLE SG1B STEAM GENERATOR	3	02JUN04 01:00	02JUN04 03:59	37	CAMP-113BF SAMPLE SG1B STEAM GENERATOR						
49	2	CH0300570	CH	77	CHEM-SAMPL	RCS GROSS ACTIVITY SR 3.04.16.01	6	02JUN04 07:00	02JUN04 12:59	107	CH0300570 RCS GROSS ACTIVITY SR 3.04.16.01 MISC CHEMISTRY SAMPLING 0300570						

ENGINEERING - PREDICTIVE MAINTENANCE												EEP					
50	1	EE0212845	EEP	76	W-003B-M	W-3B-M MOTOR POST MAINTENANCE	1	31MAY04 18:00	31MAY04 18:59	16	EE0212845 W-3B-M MOTOR POST MAINTENANCE VIBRATION CHECKS 0212845 CONTAINMENT CONTROL ROD DRIVE SHROUD FAN MOTOR						

U1R28 WORKING SCHEDULE

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY				JUN														
											Mon 31				Tue 1				Wed 2										
											8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20
ELECTRICAL MAINTENANCE												EM																	
51	1	EM0215224	EM	78	W-003B-M	PERFORM MCE W-003B-M	1	31MAY04 09:00A	31MAY04 12:59	2	PERFORM MCE W-003B-M					CONTAINMENT CONTROL ROD DRIVE SHROUD FAN MOTOR													
52	1	EM-8480U	EM	78	R-1	CONNECT AND TEST SHROUD DRIVE FANS	3	31MAY04 09:00A	31MAY04 14:59	0	CONNECT AND TEST SHROUD DRIVE FANS					REACTOR VESSEL AND ASSEMBLY													
53	1	EM0215201B	EM	78	P-001A-M	ADJUST BALANCE WEIGHTS	1	31MAY04 10:00A	31MAY04 12:59	0	EM0215201B ADJUST BALANCE WEIGHTS					REACTOR COOLANT PUMP MOTOR 0215201													
54	1	EM0216168B	EM	87	E-02	RMP 9375 LAND LEADS FOR VOLTAGE REG CAB	1	31MAY04 11:00A	31MAY04 12:59	0	EM0216168B RMP 9375 LAND LEADS FOR VOLTAGE REG CAB					TG-01 TG VOLTAGE REGULATOR/EXCITATION EQUIPMENT 0216168													
55	2	EM0305122	EM	77	TG-01	TG-01 GROUNDING STRAPS	2	31MAY04 12:00*	31MAY04 13:59	522	EM0305122 TG-01 GROUNDING STRAPS					TURBINE GENERATOR (GENERIC; SEE COMPONENTS) 0305122													
56	1	EM0305144	EM	78	P-030A-M	DRAW OIL SAMPLE FROM CIRCULATING	2	31MAY04 12:00	31MAY04 13:59	522	EM0305144 DRAW OIL SAMPLE FROM CIRCULATING					CIRCULATING WATER PUMP MOTOR 0305144													
57	2	EM0305107	EM	76	D-205	MONTHLY NON-SAFETY 125V DC STATION	4	31MAY04 12:00*	31MAY04 15:59	520	EM0305107 MONTHLY NON-SAFETY 125V DC STATION					125V DC STATION BATTERY 0305107													
58	1	EM0216166	EM	78	E-01	CHECK EXCITER GROUND DETECTION	2	31MAY04 14:00*	31MAY04 15:59	26	EM0216166 CHECK EXCITER GROUND DETECTION					TG-01 TURBINE GENERATOR EXCITER													
59	1	EM0213480A	EM	78	480V	(PERFORM PMT) 480V TM POWER TO RV HEAD	1	31MAY04 15:00*	31MAY04 15:59	0	EM0213480A (PERFORM PMT) 480V TM POWER TO RV HEAD					480V SYSTEM MULTI AND/OR NON-NUMBERED EQUIPMENT													
60	1	EM0212645A	EM	78	W-003B-M	1W-3B-M PERFORM BUMP FOR ROTATION	3	31MAY04 15:00	31MAY04 17:59	0	EM0212645A 1W-3B-M PERFORM BUMP FOR ROTATION					CONTAINMENT CONTROL ROD DRIVE SHROUD FAN MOTOR													
61	1	EM0400408	EM	78	VNPSE-0324	1VNPSE-3244 INSTALL TM 04-001 "ELECT	10	31MAY04 15:00	01JUN04 00:59	0	EM0400408 1VNPSE-3244 INSTALL TM 04-001 "ELECT SUPPORT"					W-2A/B U1C PURGE SUPPLY FAN DISCHARGE													
62	2	CSD8	EM		MILESTONE	SIGN MODE CHANGE CHECKLIST TO EXIT	0	31MAY04 16:00	31MAY04 15:59	33						CSD8 SIGN MODE CHANGE CHECKLIST TO EXIT MODE 5 END MISCELLANEOUS COLD SHUTDOWN WORK													
63	1	EM0302207	EM	78	G-06	GREASE GENERATOR BEARINGS	2	31MAY04 20:00*	31MAY04 21:59	0	EM0302207 GREASE GENERATOR BEARINGS					ROD CONTROL MG SET													
64	0	EM0310873	EM	78	P-033-M	P-33-M MCE ANALYZE MOTOR (0B52-432H)	4	31MAY04 20:00*	31MAY04 23:59	512	EM0310873 P-33-M MCE ANALYZE MOTOR (0B52-432H)					REFUELING WATER CIRC PUMP MOTOR													
65	1	EM0301236	EM	78	TE-00031	TE-31 NOISY/OSCILL SEVERAL DEGREES	6	31MAY04 20:00*	01JUN04 01:59	86	EM0301236 TE-31 NOISY/OSCILL SEVERAL DEGREES					INCORE THERMOCOUPLE AT H-10													
66	1	EM0215232	EM	78	Z-013	Z-013 INSPECT, MAINTAIN AND	13	31MAY04 20:00*	01JUN04 08:59	0	EM0215232 Z-013 INSPECT, MAINTAIN AND					CONTAINMENT CRANE													
67	1	EM0302209	EM	78	G-07	GREASE GENERATOR BEARINGS	2	31MAY04 22:00*	31MAY04 23:59	512	EM0302209 GREASE GENERATOR BEARINGS					ROD CONTROL MG SET													
68	1	EM0400407	EM	78	VNPSE-0321	1VNPSE-3212 INSTALL TM 04-001 "ELECT	10	31MAY04 23:00	01JUN04 08:59	0	EM0400407 1VNPSE-3212 INSTALL TM 04-001 "ELECT SUPPORT"					W-6A/B U1C PURGE EXHAUST FAN SUCTION													
69	0	EM0406383	EM	78	D-305	INSPECT CELLS FOR ELECTROLYTE	1	01JUN04 07:00*	01JUN04 07:59	0						EM0406383 INSPECT CELLS FOR ELECTROLYTE													
																SWING STATION BATTERY													

U1R28 WORKING SCHEDULE

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN					
											Mon 31			Tue 1			Wed 2		
											8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22						
ELECTRICAL MAINTENANCE												EM							
70	0	EM0305208	EM	76	125V	STATION TECH SPEC BATTERIES WEEKLY	6	01JUN04 07:00*	01JUN04 12:59	499							EM0305208 STATION TECH SPEC BATTERIES WEEKLY 0305208 ██████████ 125V SYSTEM MULTI AND/OR NON-NUMBERED EQUIPME		
71	0	EM0408083	EM	76	EL-LTG IV	INSPECT, TEST, CLEAN AND ADD WATER	15	01JUN04 07:00*	02JUN04 10:59	0							EM0408083 INSPECT, TEST, CLEAN AND ADD WATER 0408083 ██████████ EMERGENCY L		
72	0	EM_TRNB11A	EM		TRAINING	EM OJT/TPE TRAINING, 2 EM'S	24	01JUN04 07:00*	03JUN04 14:59	97							EM_TRNB11A EM OJT/TPE TRAINING, 2 EM'S ██████████		
73	2	EM0406413	EM	76	D-205	INSPECT CELLS FOR ELECTROLYTE	1	01JUN04 08:00	01JUN04 08:59	503							EM0406413 INSPECT CELLS FOR ELECTROLYTE 0406413 ██████████ 125V DC STATION BATTERY		
74	1	EM0215231B	EM	76	Z-013	REMOVE Z-13 RADIO CONTROLS	3	01JUN04 09:00	01JUN04 11:59	0							EM0215231B REMOVE Z-13 RADIO CONTROLS 0215231 ██████████ CONTAINMENT CRANE		
75	1	EM0215247A	EM	76	62/A02	RE-PERFORM CAL AND TEST 62/A02 RELAY	6	01JUN04 12:00	01JUN04 17:59	0							EM0215247A RE-PERFORM CAL AND TEST 62/A02 RELAY 1RMP 9302-2 0215247 ██████████ 1A-02 BUS TIME DELAY RELAY		
76	1	EMGNDOUT	EM		X-01	ELECTRICAL REMOVE GROUNDS FOR MAIN	1	01JUN04 15:00	01JUN04 15:59	104							EMGNDOUT ELECTRICAL REMOVE GROUNDS FOR MAIN XFORMER ██████████		
77	0	EM0301792A	EM	76	A52-DHVR-3	(A52-01) BKR MAINT. PORTION AT CUBICLE	4	01JUN04 15:00*	01JUN04 18:59	101							EM0301792A (A52-01) BKR MAINT. PORTION AT CUBICLE (3000-01) 0301792 ██████████ 4.16 KV/3000 AMP VACUUM BREAKER		
78	0	EM0305372	EM	77	EL-LTG	TSC/SBCC/MTN SHOP EMERGENCY LIGHTING	24	01JUN04 18:00*	03JUN04 19:59	0							EM0305372 TSC/SBCC/MTN SHOP EMERGENCY LIGHTING EMERGENCY LIGHTING 0305372 ██████████		
79	0	EM0305374	EM	77	EL-LTG	INSPECT, TEST, CLEAN AND ADD WATER	24	01JUN04 18:00*	03JUN04 19:59	10							EM0305374 INSPECT, TEST, CLEAN AND ADD WATER EMERGENCY LIGHTING 0305374 ██████████		
80	0	EM0307011I	EM	76	D-105	PERFORM RMP 9046 12 MONTH CHECKS	4	01JUN04 19:00	01JUN04 22:59	0							EM0307011I PERFORM RMP 9046 12 MONTH CHECKS 0307011 ██████████ 125V DC STATION BATTERY		
81	2	EM0305129	EM	76	U2A-UV REL	TEST U2 TRAIN A UNDERVOLTAGE AND	5	01JUN04 20:00*	02JUN04 00:59	0							EM0305129 TEST U2 TRAIN A UNDERVOLTAGE AND TRAIN A 4.16 KV AND 480 V SWITCHGEAR RELAY TEST 0305129 ██████████		
82	1	EM0407740Z	EM		P-001B-M	P-001B-M OBTAIN OIL SAMPLES	2	01JUN04 21:00	01JUN04 22:59	347							EM0407740Z P-001B-M OBTAIN OIL SAMPLES 0407740 ██████████		
83	0	EM0307011J	EM	76	D-105	PERFORM RMP 9046 92 DAY CHECKS	4	01JUN04 23:00	02JUN04 02:59	0							EM0307011J PERFORM RMP 9046 92 DAY CHECKS 0307011 ██████████ 125V DC STATION BATTERY		
84	2	EM0305134	EM	76	U2B-UV REL	TEST U2 TRAIN B UNDERVOLTAGE AND	5	02JUN04 01:00	02JUN04 05:59	0							EM0305134 TEST U2 TRAIN B UNDERVOLTAGE AND TRAIN B 4.16 KV AND 480 V SWITCHGEAR RELAY TEST 0305134 ██████████		
85	1	EM0301549A	EM	77	O-TS-043	SUPPORT TS-43 AMP READINGS	5	02JUN04 04:00	02JUN04 08:59	479							EM0301549A SUPPORT TS-43 AMP READINGS PRESSURIZER HEATER GROUP ENERGY INPUT TEST 0301549 ██████████		
86	0	EM0307011K	EM	76	D-105	SU D-107 AND PLACE ON D-105	2	02JUN04 05:00	02JUN04 06:59	0							EM0307011K SU D-107 AND PLACE ON D-105 125V DC STATION BATTERY 0307011 ██████████		
87	0	EM0210793	EM	76	EL-LTG I	TWO YEAR TEST OF EMERGENCY LIGHTING	24	02JUN04 08:00*	04JUN04 07:59	198							EM0210793 TWO YEAR TEST OF EMERGENCY LIGHTING EMERGENCY LIGHTING (GROUP I) 0210793 ██████████		
88	2	EM0302203	EM	76	G-06	GREASE GENERATOR BEARINGS	2	02JUN04 07:00*	02JUN04 08:59	0							EM0302203 GREASE GENERATOR BEARINGS ROD CONTROL MG SET 0302203 ██████████		

U1R28 WORKING SCHEDULE

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN					
											Mon 31			Tue 1			Wed 2		
											8	10	12, 14, 16, 18, 20, 22	0	2	4, 6, 8	10	12	14, 16, 18, 20, 22
ELECTRICAL MAINTENANCE												EM							
89	0	EM0305219	EM	76	D-48	MONTHLY COMMUNICATION BATTERY INSP	4	02JUN04 07:00*	02JUN04 10:59	0							EM0305219 MONTHLY COMMUNICATION BATTERY INSP TELEPHONE EQUIPMENT BATTERY 0305219		
90	0	EM0307011L	EM	76	D-105	INITIAL EQUALIZE CHARGE ON D-105	48	02JUN04 07:00	04JUN04 06:59	0							EM0307011L INITIAL EQUALIZE CHARGE ON D-105 125V DC STATION BATTERY 0307011		
91	0	EM0309665	EM	76	W-183B-M	MCE ANALYZE MOTOR (1B52-401B/1B-40)	4	02JUN04 08:00*	02JUN04 11:59	0							EM0309665 MCE ANALYZE MOTOR (1B52-401B/1B-40)		
92	2	EM0302205	EM	76	G-07	GREASE GENERATOR BEARINGS	2	02JUN04 09:00*	02JUN04 10:59	477							G-03 EDG RM SMALL CAPACITY EXHAUST FAN MOTOR 0309665		
93	0	EM0309140	EM	76	D-106	STATION BATTERY INSP PER RMP 9046-1	3	02JUN04 11:00*	02JUN04 13:59	474							EM0302205 GREASE GENERATOR BEARINGS ROD CONTROL MG SET 0302205		
94	0	EM0305373	EM	77	EL-LTG	INSPECT, TEST, CLEAN AND ADD WATER	24	02JUN04 11:00*	04JUN04 12:59	193							EM0309140 STATION BATTERY INSP PER RMP 9046-1 125V DC STATION BATTERY 0309140		
95	0	EM0309669	EM	76	W-185A-M	MCE ANALYZE MOTOR (1B52-403B/1B-40)	2	02JUN04 12:00	02JUN04 13:59	474							EM0305373 INSPECT, TEST, CLEAN AND ADD WATER EMERGENCY LIGHTING 0305373		
												EMV							
96	1	EM0302205A	EMV	76	RH-00701	1RH-701 PACKING LEAK, ADJUST(RHR SECURED)	4	02JUN04 09:00	02JUN04 12:59	0							EM0309669 MCE ANALYZE MOTOR (1B52-403B/1B-40) G-03 EDG SWGR RM OPERATING EXHAUST FAN MOTOR 0309669		
97	1	EM0215176	EMV	76	RH-00700-O	RH-700 MOV ACTUATOR CHECK-OUT	12	02JUN04 10:00	02JUN04 21:59	0							EM0302205A 1RH-701 PACKING LEAK, ADJUST(RHR SECURED) RCS TO P-10A/B RHR PUMP SUCTION HEADER 0302505		
98	1	EM0213737A	EMV	76	RH-00720	1RH-720 PACKING LEAK, ADJUST(RHR SECURED)	4	02JUN04 13:00	02JUN04 16:59	0							EM0215176 RH-700 MOV ACTUATOR CHECK-OUT RCS TO P-10A/B RHR PUMP SUCTION HEADER OPERATOR 0215176		
99	1	B52-424ME	EMV	76	B-42	BUS STAB PMT "1RH-701"	1	02JUN04 15:00	02JUN04 15:59	13							EM0213737A 1RH-720 PACKING LEAK, ADJUST(RHR SECURED) RHR RETURN TO RCS 0213737		
100	1	EM0403305	EMV	76	SI-00852A-	SI-852A-O PERFORM STEM LUBE AND FBJ INSPECTION	10	02JUN04 17:00	03JUN04 02:59	0							B52-424ME BUS STAB PMT "1RH-701" 480V MOTOR CONTROL CENTER PAB SAFEGUARDS 0202527		
EMERGENCY PLANNING												EP							
101	0	ERDSTEST2	EP		EPMP 2.1D	2ND QUARTER ERDS TEST	5	01JUN04 07:00*	01JUN04 11:59	116							EM0403305 SI-852A-O PERFORM STEM LUBE AND FBJ INSPECTION LOW HEAD SI CORE DELUGE ISOLATION OPERATOR 0403305		
ENGINEERING PROGRAMS - INSPECTION SERVICES												EPI							
102	0	EP0405867	EPI	77	BALCM	VT-2 EXAMINATION FOR LEAKAGE (BALCM)	8	01JUN04 07:00*	01JUN04 14:59	113							ERDSTEST2 2ND QUARTER ERDS TEST		
FACILITIES GROUP												FG							
103	0	FG0302014	FG	77	Z-115	ROUTINE MAINTENANCE OF PAPER DRILL	4	02JUN04 07:00*	02JUN04 10:59	109							EP0405867 VT-2 EXAMINATION FOR LEAKAGE (BALCM) 0405867 BORIC ACID LEAKAGE AND CORROSION MONITORING		
FACILITIES GROUP - UTILITY GROUP												FG1							
104	1	CTMT-040	FG1		SUMMARY	CTMT INTEGRITY HATCH OPERATION	106*	28MAY04 23:00A	04JUN04 21:59	0							FG0302014 ROUTINE MAINTENANCE OF PAPER DRILL THREE SPINDLE PAPER DRILL 0302014		
												FG1							
												FG1							
												FG1							

U1R28 WORKING SCHEDULE

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN			
											Mon 31	Tue 1	Wed 2	Mon 31	Tue 1	Wed 2	
											8, 10, 12, 14, 16, 18, 20, 22	0, 2, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22	0, 2, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22	8, 10, 12, 14, 16, 18, 20, 22	0, 2, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22	0, 2, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22	
FACILITIES GROUP - BOB WIENSCH												FG3					
105	1	FG213478SR	FG3	87	CPP-58	CPP-58 REMOVE SCAFFOLDING	5	31MAY04 10:00A	31MAY04 16:59	519	FG213478SR	CPP-58 REMOVE SCAFFOLDING					
												U1C PIPE PENETRATION - CONTAINMENT TEST CONNECTION 0213478					
RADIATION PROTECTION (OLD)												HP					
106	0	HP0301854	HP	77	HP RMS	QUARTERLY FUNCTIONAL TEST OF	3	26MAY04 08:00A	31MAY04 14:59	202	HP0301854	QUARTERLY FUNCTIONAL TEST OF RMS					
												HEALTH PHYSICS RADIATION MONITORING SYSTEM 0301854					
107	0	HP0301847	HP	77	HP RMS	MONTHLY RMS OPERATIONAL TEST	22	30MAY04 11:00A	02JUN04 15:59	172	HP0301847	MONTHLY RMS OPERATIONAL TEST					
												HEALTH PHYSICS RADIATION MONITORING SYSTEM 0301847					
108	0	RE-234-B11	HP		HP RMS	RE-234/235 AIR SAMPLE CHANGE OUT	1	02JUN04 08:00*	02JUN04 08:59	111							
												RE-234-B11 RE-234/235 AIR SAMPLE CHANGE OUT					
I&C MAINTENANCE												IC					
109	0	IC0300717	IC	76	ICP-06.013	FUEL OIL INSTRUMENTS	102	30MAY04 19:00A	04JUN04 17:59	422	IC0300717	FUEL OIL INSTRUMENTS					
												FUEL OIL INSTRUMENTS					
110	1	ICRDCSTLGT	IC	76	RDC	RDC STATUS LIGHT BULB CHECK	3	31MAY04 11:00A	31MAY04 14:59	88	ICRDCSTLGT	RDC STATUS LIGHT BULB CHECK					
												RDC SYSTEM MULTI AND/OR NON-NUMBERED EQUIPMENT 0300935					
111	1	IC10.46	IC	76	ICP-10.046	ICP 10.46 RDC POWER SUPPLY CHECK	5	31MAY04 11:00A	31MAY04 16:59	15	IC10.46	ICP 10.46 RDC POWER SUPPLY CHECK					
												ROD DRIVE SYSTEM POWER SUPPLY CHECK 0300895					
112	1	ICPRE-CRD	IC		RESP 3.1	CLEAR RX TRIP SIGNALS FOR CRD	2	01JUN04 06:00	01JUN04 07:59	0							
												ICPRE-CRD CLEAR RX TRIP SIGNALS FOR CRD PRIMARY SYSTEM TESTS					
113	0	IC0300669	IC	76	YR-05832	REPLACE DATA DISK	1	01JUN04 07:00*	01JUN04 07:59	120							
												IC0300669 REPLACE DATA DISK 0300669 MET/FOREBAY LEVEL RECORDER					
114	0	IC0302218	IC	76	LI-05857	F-235 MOVE LEVEL INDICATORS	8	01JUN04 07:00*	01JUN04 14:59	0							
												IC0302218 F-235 MOVE LEVEL INDICATORS 0302218 F-235 WASTE WATER EFFLUENT FILTER LEVEL INDICATORS					
115	1	IC0307357A	IC	79	RDC-1BD	RDC-1BD POST REPAIR PMT	2	01JUN04 08:00*	01JUN04 09:59	69							
												IC0307357A RDC-1BD POST REPAIR PMT 0307357 RDC BANKS B/D GROUP 1 CIRCUIT CABINET					
116	1	IC10.1SUP	IC	76	ICP-10.001	ICP 10.1 RESTORE SAFEGUARDS SYSTEM	2	01JUN04 11:00	01JUN04 12:59	0							
												IC10.1SUP ICP 10.1 RESTORE SAFEGUARDS SYSTEM LOGIC 0300882 SAFEGUARDS SYSTEM BYPASS					
117	2	CSD7	IC		MILESTONE	SIGN MODE CHANGE CHECKLIST TO EXIT	0	01JUN04 13:00	01JUN04 12:59	12							
												CSD7 SIGN MODE CHANGE CHECKLIST TO EXIT MODE 5 END MISCELLANEOUS COLD SHUTDOWN WORK					
118	1	ICPRE-COMP	IC		REI 10.1	MOVE REACTIVITY COMPUTER TO	10	02JUN04 01:00*	02JUN04 10:59	33							
												ICPRE-COMP MOVE REACTIVITY COMPUTER TO CONTROL ROOM ADVANCED DIGITAL REACTIVITY COMPUTER INSTRUCTION					
119	0	IC0403277	IC	76	RE-00240	RE-240 FAILED HIGH	8	02JUN04 07:00*	02JUN04 14:59	0							
												IC0403277 RE-240 FAILED HIGH TSC ASSEMBLY ROOM GAMMA DETECTION MONITOR 0403277					
120	0	IC0407569	IC	76	RE-00238	SPURIOUS ALARMS. TROUBLESHOOT/REPAIR	8	02JUN04 07:00*	02JUN04 14:59	105							
												IC0407569 SPURIOUS ALARMS. TROUBLESHOOT/REPAIR TSC NOBLE GAS MONITOR 0407569					
121	1	ICSGLVLBFL	IC	76	SG LEVEL X	BACKFILL NARROW/WIDE	8	02JUN04 09:00	02JUN04 16:59	0							
												ICSGLVLBFL BACKFILL NARROW/WIDE EQUIP ID TO SUPPORT CALLUP 0300946					

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN			
											Mon 31	Tue 1	Wed 2	Mon 31	Tue 1	Wed 2	
											8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22	8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22	
I&C - R. YOUNG												IC4			IC4		
122	1	ICTOOL-PST	IC4	77	I&C MISC	TOOL BOX INVENTORY - POST OUTAGE	12	30MAY04 19:00A	01JUN04 18:59	164	ICTOOL-PST TOOL BOX INVENTORY - POST OUTAGE						MISC IC WORK ACTIVITIES 0300798
I&C - M. KENNETT												IC5			IC5		
123	1	IC0307343	IC5	76	PPCS-009	PPCS-009 IS TEMPERATURE	2	30MAY04 09:00A	01JUN04 08:59	167	IC0307343 PPCS-009 IS TEMPERATURE SENSITIVE						PPCS COMPUTER RM UNIT 1 YELLOW RTP DATA LINK SER
124	0	IC0300685	IC5	76	C-025	MONTHLY PM ON DMIMS SYSTEM	2	02JUN04 07:00*	02JUN04 08:59	111							IC0300685 MONTHLY PM ON DMIMS SYSTEM UNIT 1/2 LOOSE PARTS MONITORING CONTROL PANEL 0300685
MECHANICAL MAINTENANCE MM1 RIDINGS/ BRITTINGHAM												MM1			MM1		
125	1	MM0408666	MM1	76	W-043A	W-043A REPLACE DISCHARGE DAMPER	10	29MAY04 21:00A	31MAY04 21:59	0	MM0408666 W-043A REPLACE DISCHARGE DAMPER						CONTAINMENT CLEANUP FAN 0408666
126	1	MM0214187B	MM1	76	C-2	RESTORE C-2 UPPER HATCH INTERLOCKS	3	31MAY04 09:00A	31MAY04 14:59	0	RESTORE C-2 UPPER HATCH INTERLOCKS						PERSONNEL ACCESS AIR LOCK
127	1	MM0214187C	MM1	76	C-2	RESTORE UPPER HATCH ALARMS	1	31MAY04 15:00	31MAY04 15:59	0	MM0214187C RESTORE UPPER HATCH ALARMS						PERSONNEL ACCESS AIR LOCK
128	1	MM0407618	MM1	76	RH-00720	1RH-720 PERFORM VT OF STUD	3	02JUN04 14:00	02JUN04 18:59	329							MM0407618 1RH-720 PERFORM VT OF STUD RHR RETURN TO RCS 0407618
MECHANICAL MAINTENANCE MM2 BONENFANT (BOP)												MM2			MM2		
129	1	MM0408498	MM2	76	Z-104A	1Z-104A REPAIR STRAINER	15	29MAY04 08:00A	01JUN04 02:59	0	MM0408498 1Z-104A REPAIR STRAINER						TB1 SERVICE WATER ZURN STRAINER 0408498
130	1	MM0400322	MM2	76	VNPSE-0324	1VNPSE-3244, REMOVE OPERATOR & EQUIP., TM	10	31MAY04 15:00	01JUN04 00:59	0	MM0400322 1VNPSE-3244, REMOVE OPERATOR & EQUIP., TM 04-001						W-2A/B U1C PURGE SUPPLY FAN DISCHARGE
131	2	MM0407307	MM2	76	P-029-T	2P-29-T SAMPLE & REPLACE OIL AFTER	1	31MAY04 16:00	31MAY04 16:59	0	MM0407307 2P-29-T SAMPLE & REPLACE OIL AFTER PUMP RUN						2P-29 AUX FEEDWATER TURBINE-DRIVEN PUMP TURBINE
132	1	MM0400324	MM2	76	VNPSE-0321	1VNPSE-3212, REMOVE OPERATOR & EQUIP., TM	10	31MAY04 21:00	01JUN04 06:59	0	MM0400324 1VNPSE-3212, REMOVE OPERATOR & EQUIP., TM 04-001						W-6A/B U1C PURGE EXHAUST FAN SUCTION
133	1	MM0400322A	MM2	76	VNPSE-0324	1VNPSE-3244, REMOVE VALVE & INSTALL BLANK	4	01JUN04 01:00	01JUN04 04:59	0	MM0400322A 1VNPSE-3244, REMOVE VALVE & INSTALL BLANK FLANGE						W-2A/B U1C PURGE SUPPLY FAN DISCHARGE
134	1	MM0400322B	MM2	76	VNPSE-0324	1VNPSE-3244, COMPLETE TEMP MOD	10	01JUN04 05:00	01JUN04 14:59	0	MM0400322B 1VNPSE-3244, COMPLETE TEMP MOD INSTALLATION						W-2A/B U1C PURGE SUPPLY FAN DISCHARGE
135	2	MM0301196	MM2	76	P-041	2P-41, GREASE PUMP	2	01JUN04 06:00	01JUN04 07:59	0	MM0301196 2P-41, GREASE PUMP						VACUUM PRIMING PUMP
136	1	MM0400324B	MM2	76	VNPSE-0321	1VNPSE-3212, REMOVE VALVE & INSTALL BLANK	4	01JUN04 07:00	01JUN04 10:59	0	MM0400324B 1VNPSE-3212, REMOVE VALVE & INSTALL BLANK FLANGE						W-6A/B U1C PURGE EXHAUST FAN SUCTION
137	1	MM0400324C	MM2	76	VNPSE-0321	1VNPSE-3212, COMPLETE TEMP MOD	10	01JUN04 11:00	01JUN04 20:59	0	MM0400324C 1VNPSE-3212, COMPLETE TEMP MOD INSTALLATION						W-6A/B U1C PURGE EXHAUST FAN SUCTION
138	0	MM0201620	MM2	76	K-002B	SEMIANNUAL COMPRESSOR	8	01JUN04 18:00	02JUN04 01:59	0	MM0201620 SEMIANNUAL COMPRESSOR MAINTENANCE						INSTRUMENT AIR COMPRESSOR 0201620

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN					
											Mon 31			Tue 1			Wed 2		
											8	10	12, 14, 16, 18, 20, 22	0	2	4, 6, 8, 10, 12, 14, 16, 18, 20, 22	0	2	4, 6, 8, 10, 12, 14, 16, 18, 20, 22
MECHANICAL MAINTENANCE MM2 BONENFANT (BOP)												MM2							
139	0	MM0405759	MM2	76	K-002B	K-2B OIL LEAK	8	01JUN04 18:00	02JUN04 01:59	0							MM0405759 K-2B OIL LEAK INSTRUMENT AIR COMPRESSOR 0405759		
140	0	MM0400519	MM2	73	IA-00229	IA-229 REPLACE VALVE	8	01JUN04 23:00	02JUN04 19:59	0							MM0400519 IA-229 REPLACE VALVE K-2B IA COMPRESSOR TOTAL CLOSURE 0400519		
141	0	MM0301076	MM2	76	F-235	BIMONTHLY MAIN DRIVE LUBRICATION	3	02JUN04 07:00*	02JUN04 09:59	0							MM0301076 BIMONTHLY MAIN DRIVE LUBRICATION WASTE WATER EFFLUENT FILTER 0301076		
142	0	MM0301089	MM2	76	HX-366	CLEAN UNIT AND FILTERS	4	02JUN04 07:00*	02JUN04 10:59	0							MM0301089 CLEAN UNIT AND FILTERS SEC-HUT 01 SECURITY HUT AIR CONDITIONER 0301089		
143	2	MM0400544	MM2	77	MS-05958	2MS-5958 REPLACE STEM - SHOP WORK	8	02JUN04 07:00*	02JUN04 14:59	213							MM0400544 2MS-5958 REPLACE STEM - SHOP WORK HX-1B SG BLOWDOWN ISOLATION 0400544		
144	0	MM0301078	MM2	76	F-237	BIMONTHLY MAIN DRIVE LUBRICATION	3	02JUN04 10:00	02JUN04 12:59	0							MM0301078 BIMONTHLY MAIN DRIVE LUBRICATION UNIT 1/2 FACADE SUMP EFFLUENT FILTER 0301078		
145	1	MM0214127A	MM2	76	P-029	MM SUPPORT FOR P-29-T OVERSPEED TRIP	4	02JUN04 17:00	02JUN04 20:59	0							MM0214127A MM SUPPORT FOR P-29-T OVERSPEED TRIP TEST AUX FEEDWATER TURBINE-DRIVEN PUMP 0214127		
NON-DESTRUCTIVE TESTING												NDE							
146	0	EP9927269A	NDE	77	S	CONDUCT CIVIL/STRUCTURAL	32	24MAY04 10:00A	04JUN04 14:59	89	EP9927269A	CONDUCT CIVIL/STRUCTURAL INSPECTION							
147	0	EP9927270A	NDE	77	S	CONDUCT CIVIL/STRUCTURAL	32	24MAY04 10:00A	04JUN04 14:59	89	EP9927270A	CONDUCT CIVIL/STRUCTURAL INSPECTION							
OPERATIONS RELIEFS												OP0							
148	0	OP0301243	OP0	77	O-PC-021.4	WEEKLY MISCELLANEOUS DATA	5	01JUN04 07:00*	01JUN04 11:59	500							OP0301243 WEEKLY MISCELLANEOUS DATA READINGS 0301243 WEEKLY MISCELLANEOUS DATA READINGS		
149	0	OP0301238	OP0	77	O-PC-073.4	FP VALVE POSITION VERIFICATION CHECK	32	01JUN04 07:00*	04JUN04 14:59	89							OP0301238 FP VALVE POSITION VERIFICATION CHECK 0301238		
150	0	OP0301278	OP0	77	PT-FP-006	FP CONTROL VALVE POSITION	32	01JUN04 07:00*	04JUN04 14:59	89							OP0301278 FP CONTROL VALVE POSITION 0301278		
151	0	OP0311110	OP0	77	O-IT-0007A	IT-07A, P-32A SERVICE WATER PUMP	4	02JUN04 06:00*	02JUN04 09:59	19							OP0311110 IT-07A, P-32A SERVICE WATER PUMP P-32A SERVICE WATER PUMP TEST 0311110		
152	0	OP0308991	OP0	77	O-PC-078.7	TRN/NES BLDG FP WET PIPE SYS CHECK	5	02JUN04 07:00*	02JUN04 11:59	476							OP0308991 TRN/NES BLDG FP WET PIPE SYS CHECK TRAINING/NES BLDG AUTO WET PIPE FIRE SUPPRESSION 0308991		
OPERATIONS MIDSHIFT												OP1							
153	0	OP0301295	OP1	76	O-PC-MIDS	OPERATIONS MID SHIFT WEEKLY ROUTINE	25	28MAY04 00:00A	04JUN04 03:59	129	OP0301295	OPERATIONS MID SHIFT WEEKLY ROUTINE							
154	2	OP0301602	OP1	76	O-TS-034	TS-34, U2C ACCIDENT FAN COOLER UNITS	2	01JUN04 00:00*	01JUN04 01:59	26							OP0301602 TS-34, U2C ACCIDENT FAN COOLER UNITS 0301602 UNIT 2 CONT ACCIDENT FAN COOLER UNITS SURV TEST		
155	2	OP0310118	OP1	77	PT-RMS-001	TEST RMS FUNCTION OF SGBD VALVES	1	02JUN04 01:00*	02JUN04 01:59	145							OP0310118 TEST RMS FUNCTION OF SGBD VALVES MAIN STEAM VALVES FUNCTIONAL UNIT 2 (QUARTERLY) 0310118		

U1R28 WORKING SCHEDULE

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN					
											Mon 31			Tue 1			Wed 2		
											8, 10, 12, 14, 16, 18, 20, 22	0, 2, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22	0, 2, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22						
OPERATIONS MIDSHIFT												OP1							
156	2	OP0301600	OP1	77	O-IT-0085	IT-85, UNIT 2 MAIN STEAM VALVES	2	02JUN04 02:00*	02JUN04 03:59	143						OP0301600 IT-85, UNIT 2 MAIN STEAM VALVES 0301600 UNIT 2 MAIN STEAM VALVES			
OPERATIONS DAYSHIFT												OP2							
157	0	OP0301335	OP2	76	O-PC-DAYS	OPERATIONS DAY SHIFT WEEKLY ROUTINE	42	01JUN04 08:00*	06JUN04 14:59	105						OP0301335 OPERATIONS DAY SHIFT WEEKLY ROUTINE 0301335			
158	1	OP0301547	OP2	77	TS-ECCS-00	SAFEGUARD SYSTEMS VALVE AND LOCK	1	01JUN04 13:00	01JUN04 13:59	0						OP0301547 SAFEGUARD SYSTEMS VALVE AND LOCK 0301547 SAFEGUARD SYSTEMS VALVE AND LOCK CHECKLIST			
OPERATIONS SWINGSHIFT												OP3							
159	1	OP0301550	OP3	77	O-PC-001.2	TB1 MONTHLY HEATING/VENTILATION	3	19MAY04 18:00A	31MAY04 18:59	151						OP0301550 TB1 MONTHLY HEATING/VENTILATION TB1 MONTHLY HEATING/VENTILATION SYSTEM CHECKS 0301550			
160	0	OP0301397	OP3	77	O-PC-SWING	OPS SWING SHIFT WEEKLY ROUTINE	42	30MAY04 16:00A	05JUN04 22:59	112						OP0301397 OPS SWING SHIFT WEEKLY ROUTINE			
161	0	OP0301405	OP3	76	P-118	MONTHLY OPERATIONAL CHECK	1	31MAY04 16:00*	31MAY04 18:59	153						OP0301405 MONTHLY OPERATIONAL CHECK OF PUMP 0301405 SUBSOL SEEPAGE SUMP PUMP			
162	2	OP0301630	OP3	76	O-PC-025	PURIFY RWST	1	31MAY04 16:00*	31MAY04 18:59	153						OP0301630 PURIFY RWST 0301630 RECIRCULATION OR PURIFICATION OF RWST			
163	2	OP0301633	OP3	76	O-PC-058	H2 SEAL OIL SYSTEM TEST	1	31MAY04 16:00*	31MAY04 18:59	153						OP0301633 H2 SEAL OIL SYSTEM TEST 0301633 HYDROGEN SEAL OIL SYSTEM			
164	0	OP0301412	OP3	77	O-PC-029	LOAD TEST G-05, G-501	3	01JUN04 14:00*	01JUN04 18:59	495						OP0301412 LOAD TEST G-05, G-501 0301412 GAS TURBINE, AUXILIARIES AND LOAD TESTS			
165	2	U2GNDR024	OP3		TG-01	DRAIN U2 MAIN ELECTRICAL	1	01JUN04 18:00	01JUN04 18:59	0						U2GNDR024 DRAIN U2 MAIN ELECTRICAL GENERATOR PER PC 21.3 U2 MAIN GENERATOR			
166	2	OP0301636	OP3	77	O-PC-025A	SECURE RECIRC OF RWST/RESTORE SFP	1	02JUN04 16:00*	02JUN04 16:59	139						OP0301636 SECURE RECIRC OF RWST/RESTORE SFP SECURING RECIRC OF RWST/RESTORE SFP PURIFICATION 0301636			
167	0	OP0308223	OP3	77	O-PC-045.1	BLOWDOWN AIR RECEIVERS	1	02JUN04 16:00*	02JUN04 16:59	139						OP0308223 BLOWDOWN AIR RECEIVERS PERIODIC BLOWDOWN OF AIR RECEIVERS AND PIPING 0308223			
OPERATIONS												OPS							
168	1	CL01B010	OPS		CL-1B	CONTAINMENT INTEGRITY CHECKLIST	11	30MAY04 00:00A	31MAY04 22:59	24						CL01B010 CONTAINMENT INTEGRITY CHECKLIST CONTAINMENT INTEGRITY CHECKLIST			
169	1	OI64-040	OPS		VNPSE-3245	CLN & LUBE PURGE SUPPLY VNPSE-3245	1	31MAY04 09:00A	31MAY04 12:59	0						CLN & LUBE PURGE SUPPLY VNPSE-3245			
170	2	UNIT2DWNA	OPS			REDUCE UNIT 2 POWER 2% FOR 2P-29 OIL	1	31MAY04 12:00	31MAY04 12:59	0						UNIT2DWNA REDUCE UNIT 2 POWER 2% FOR 2P-29 OIL CHANGE			
171	1	RF-390	OPS	87	O-RF-390	CONTROL ROOM ALARMS VERIFICATION	2	31MAY04 12:00	31MAY04 13:59	98						RF-390 CONTROL ROOM ALARMS VERIFICATION CONTROL ROOM ALARMS 0215942			
172	2	OP0301604	OPS	77	O-IT-0009A	IT-09A, 2P-29 AFP COLD START TEST/	2	31MAY04 13:00	31MAY04 14:59	0						OP0301604 IT-09A, 2P-29 AFP COLD START TEST/ 2P-29 AFW/TURB-DRIVEN PUMP COLD START TEST/MLVS 0301604			

U1R28 WORKING SCHEDULE

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY							JUN																				
											Mon 31							Tue 1							Wed 2													
											8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	0	1	2	3	4	5	6	7	8	9	10	11	12
OPERATIONS												OPS																										
192	0	OP0301196A	OPS		P-041	PLACE P-41 INSERVICE FOR 2P-41	2	01JUN04 01:00*	01JUN04 02:59	0	OP0301196A PLACE P-41 INSERVICE FOR 2P-41 VACUUM PRIMING PUMP																											
193	1	OP0301544A	OPS	77	O-TS-032	TS-32, Partial - PURGE VALVE SECTION 5.3	2	01JUN04 01:00*	01JUN04 02:59	22	OP0301544A TS-32, Partial - PURGE VALVE SECTION 5.3 0301544 MISCELLANEOUS EQUIPMENT CHECKS (MONTHLY)																											
194	1	IT-380	OPS		O-IT-0380	IT-380, PURGE VALVE AIR SYSTEM CHECK	5	01JUN04 01:00	01JUN04 05:59	9	IT-380 IT-380, PURGE VALVE AIR SYSTEM CHECK VALVE																											
195	1	OP1A190F	OPS		OP-1A	HEATUP RCS TO 190 DEG F	1	01JUN04 06:00	01JUN04 06:59	0	OP1A190F HEATUP RCS TO 190 DEG F HEATUP RCS FROM 160 TO 180 DEG F																											
196	1	SI-008	OPS		RC	ALIGN EVENT V SPOOL PIECES PER 1-PT-SI-008	2	01JUN04 06:00	01JUN04 07:59	15	SI-008 ALIGN EVENT V SPOOL PIECES PER 1-PT-SI-008 RC SYSTEM MULTI AND/OR NON-NUMBERED EQUIPMENT																											
197	1	TS-30X	OPS		TS-30	CHECK VALVE TEST RECOVERY	4	01JUN04 06:00	01JUN04 09:59	15	TS-30X CHECK VALVE TEST RECOVERY POST EVENT 5 CHECK VALVE TEST RECOVERY																											
198	1	OP1A-021	OPS		OP-1A	VERIFY AFW FLOW TO S/G'S PER OI 62A	1	01JUN04 07:00	01JUN04 07:59	17	OP1A-021 VERIFY AFW FLOW TO SG'S PER OI 62A																											
199	1	IT-001A	OPS	77	O-IT-0001A	IT-01A, HIGH HEAD SI PUMPS & VALVES	4	01JUN04 07:00	01JUN04 10:59	14	IT-001A IT-01A, HIGH HEAD SI PUMPS & VALVES 0215885 HIGH HEAD SAFETY INJECTION PUMPS/VALVES (COLD SH																											
200	2	OP0301196B	OPS		P-041	RESTORE 2P-41 TO SERVICE	2	01JUN04 09:00	01JUN04 10:59	501	OP0301196B RESTORE 2P-41 TO SERVICE VACUUM PRIMING PUMP																											
201	1	CAMP-112	OPS		CAMP-112	RCS OXYGEN REMOVAL WITH HYDRAZINE	3	01JUN04 11:00	01JUN04 13:59	0	CAMP-112 RCS OXYGEN REMOVAL WITH HYDRAZINE ADDITION OF HYDRAZINE TO THE PRIMARY SYSTEM																											
202	1	OP0301513	OPS	77	TS-CONT-00	CONT ISOL VALVE AND FLANGE CHECKS	2	01JUN04 13:00	01JUN04 14:59	0	OP0301513 CONT ISOL VALVE AND FLANGE CHECKS 0301513 CONT ISOL VALVE AND FLANGE VERIFICATION (OUT																											
203	1	TS-035.2-A	OPS	70	O-TS-035.2	TS-35.2, CONTAINMENT PURGE SUPPLY LLRT	4	01JUN04 15:00	01JUN04 18:59	6	TS-035.2-A TS-35.2, CONTAINMENT PURGE SUPPLY LLRT 0216006 UNIT 1 CONTAINMENT PURGE VALVES LOCAL																											
204	0	OP307011GG	OPS	76	D-105	RESTORE D-105 ROOM VENTILATION IAW OI-39	0	01JUN04 19:00	01JUN04 18:59	0	OP307011GG RESTORE D-105 ROOM VENTILATION IAW OI-39 0307011 125V DC STATION BATTERY																											
205	0	OP307011HH	OPS	76	D-105	SECURE D-105 FIRE ROUNDS	1	01JUN04 20:00	01JUN04 20:59	491	OP307011HH SECURE D-105 FIRE ROUNDS 0307011 125V DC STATION BATTERY																											
206	1	TS-035.2-B	OPS	70	O-TS-035.2	TS-35.2, CONTAINMENT PURGE EXHAUST LLRT	4	01JUN04 21:00	02JUN04 00:59	0	TS-035.2-B TS-35.2, CONTAINMENT PURGE EXHAUST LLRT 0216006 UNIT 1 CONTAINMENT PURGE VALVES LOCAL																											
207	1	CL01B020	OPS		CL-1B & OP	ESTABLISH CONTAINMENT	0	01JUN04 23:00	01JUN04 22:59	0	CL01B020 ESTABLISH CONTAINMENT OPERABILITY ESTABLISH CONTAINMENT INTEGRITY (CL-1B & CP-1)																											
208	1	OP1A200F	OPS		OP-1A	HEATUP RCS TO 200 DEGREES	2	01JUN04 23:00	02JUN04 00:59	0	OP1A200F HEATUP RCS TO 200 DEGREES HEATUP RCS FROM 180 TO 200 DEG F																											
209	1	OI32-020	OPS		OI-32	ESTABLISH H2 ATMOSPHERE IN GEN	20	02JUN04 00:00*	02JUN04 19:59	0	OI32-020 ESTABLISH H2 ATMOSPHERE IN GENERATOR ESTABLISH HYDROGEN ATMOSPHERE IN GENERATOR																											
210	1	OP1A250F	OPS		OP-1A	HEATUP RCS TO 250 - 270 deg F	3	02JUN04 01:00	02JUN04 03:59	0	OP1A250F HEATUP RCS TO 250 - 270 deg F HEATUP RCS FROM 200 TO 250 DEG F																											

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN					
											Mon 31			Tue 1			Wed 2		
											8, 10, 12, 14, 16, 18, 20, 22	0, 2, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22	0, 2, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22						
OPERATIONS												OPS							
211	1	OI79-030	OPS		OI-79	ESTABLISH VACUUM	12	02JUN04 01:00	02JUN04 12:59	76						OI79-030 ESTABLISH VACUUM ESTABLISH VACUUM PER OI-79			
212	1	OP1A-050	OPS		OP-1A	HEATUP PRESSURIZER	4	02JUN04 04:00	02JUN04 07:59	0						OP1A-050 HEATUP PRESSURIZER HEATUP PRESSURIZER			
213	1	OP0301549	OPS	77	O-TS-043	TS-43, PZR HEATER GROUP ENERGY INPUT	5	02JUN04 04:00*	02JUN04 08:59	0						OP0301549 TS-43, PZR HEATER GROUP ENERGY INPUT PRESSURIZER HEATER GROUP ENERGY INPUT TEST 0301549			
214	1	TS-043	OPS		T-001	PRESSURIZER HEATER TEST	5	02JUN04 04:00	02JUN04 08:59	0						TS-043 PRESSURIZER HEATER TEST			
215	1	OP1A-060	OPS		OP-1A	ESTABLISH PZR BUBBLE	1	02JUN04 08:00	02JUN04 08:59	0						OP1A-060 ESTABLISH PZR BUBBLE ESTABLISH PZR BUBBLE			
216	1	OP7B-010	OPS		OP-7B	SECURE OPERATING RHR PUMPS	1	02JUN04 08:00	02JUN04 08:59	0						OP7B-010 SECURE OPERATING RHR PUMPS SECURE AND COOLDOWN RHR			
217	1	OP0300941	OPS	82	RH-00626-O	PMT STROKE OF RH-626 PER IT-390	1	02JUN04 09:00	02JUN04 09:59	19						OP0300941 PMT STROKE OF RH-626 PER IT-390 HX-11A/B RHR HX BYPASS FLOW CONTROL OPERATOR 0300941			
218	1	OP1A-080	OPS		OP-1A	ESTABLISH NORMAL PZR LEVEL	1	02JUN04 09:00	02JUN04 09:59	0						OP1A-080 ESTABLISH NORMAL PZR LEVEL RESTORE NORMAL PZR LEVEL AND ALIGN CVCS			
219	1	PC-023.5	OPS		O-PC-023.5	CHARGING PUMP ROTATION/PM	3	02JUN04 09:00	02JUN04 11:59	476						PC-023.5 CHARGING PUMP ROTATION/PM CHARGING PUMP ROTATION/PREVENTIVE MAINTENANCE			
220	1	OP7B-020	OPS		OP-7B	COOLDOWN AND BORATE RHR	6	02JUN04 09:00	02JUN04 14:59	0						OP7B-020 COOLDOWN AND BORATE RHR SECURE AND COOLDOWN RHR			
221	2	OP0301567B	OPS		W-043A	START U2 CLEANUP FAN	24	02JUN04 09:00	03JUN04 08:59	455						OP0301567B START U2 CLEANUP FAN			
222	1	OP1A300F	OPS		OP-1A	HEATUP RCS TO 295 - 305 deg F	1	02JUN04 10:00	02JUN04 10:59	4						OP1A300F HEATUP RCS TO 295 - 305 deg F HEATUP RCS FROM 250 TO 340 DEG F			
223	1	OP1A-210	OPS		OP-1A	RCS LITHIUM ADDITIONS	2	02JUN04 11:00	02JUN04 12:59	42						OP1A-210 RCS LITHIUM ADDITIONS RCS CHEMISTRY LITHIUM EVALUATION			
224	1	TS-030C	OPS	77	O-TS-030	TS-30 (SECTION 5.23) TEST OF SI-867B	1	02JUN04 15:00	02JUN04 15:59	0						TS-030C TS-30 (SECTION 5.23) TEST OF SI-867B U1 HIGH/LOW HEAD SI CHECK VLV LEAKAGE TEST (CSD) 0216005			
225	1	B52-424M	OPS	76	B-42	BUS STAB PMT "1RH-701"	2	02JUN04 15:00	02JUN04 16:59	0						B52-424M BUS STAB PMT "1RH-701" 480V MOTOR CONTROL CENTER PAB SAFEGUARDS 0202527			
226	1	OP0301566	OPS	77	O-IT-0012	IT-12, 1P-11A/B CCW PUMPS/VALVES,	2	02JUN04 15:00*	02JUN04 16:59	471						OP0301566 IT-12, 1P-11A/B CCW PUMPS/VALVES, 1P-11A/B COMPONENT COOLING WATER PUMPS/VALVES 0301566			
227	1	SOPCC002G	OPS		SOP-CC-002	VERIFY CCW FLOWS TO RCPS AND XSLTDN HX	2	02JUN04 15:00	02JUN04 16:59	12						SOPCC002G VERIFY CCW FLOWS TO RCPS AND XSLTDN HX			
228	1	OP1A-070	OPS		OP-1A	ALIGN MAIN & AUX FEED AUTO OPS	1	02JUN04 16:00	02JUN04 16:59	12						OP1A-070 ALIGN MAIN & AUX FEED AUTO OPS ALIGN MAIN & AUX FEED FOR AUTOMATIC LO-LO START			
229	1	OP1A-090	OPS		OP-1A	DISABLE LTOP	1	02JUN04 16:00	02JUN04 16:59	0						OP1A-090 DISABLE LTOP DISABLE LOW TEMPERATURE OVER PRESSURE PROTECTION			

U1R28 WORKING SCHEDULE

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN			
											Mon 31	Tue 1	Wed 2	Mon 31	Tue 1	Wed 2	
OPERATIONS												OPS					
230	1	PT-SI-8A	OPS		SI-00845A	LINE UP EVENT V TEST RIG PER 1-PT-SI-8	2	02JUN04 16:00	02JUN04 17:59	28							PT-SI-8A LINE UP EVENT V TEST RIG PER 1-PT-SI-8
231	1	OP1A350F	OPS		OP-1A	HEATUP RCS TO 340 - 345 deg F	1	02JUN04 17:00	02JUN04 17:59	0							OP1A350F HEATUP RCS TO 340 - 345 deg F HEATUP RCS FROM 340 TO 350 DEG F
232	1	OP0301544	OPS	77	O-TS-032	TS-32, MISCELLANEOUS EQUIPMENT	3	02JUN04 17:00	02JUN04 19:59	9							OP0301544 TS-32, MISCELLANEOUS EQUIPMENT MISCELLANEOUS EQUIPMENT CHECKS (MONTHLY) 0301544
233	1	IT-290B	OPS	70	O-IT-0290B	IT-290B, 1P-29 AFP OVERSPEED TEST	4	02JUN04 17:00	02JUN04 20:59	0							IT-290B IT-290B, 1P-29 AFP OVERSPEED TEST 1P-29 AUX FW TURBINE-DRIVEN PUMP OVERSPEED TEST 0215901
PRODUCTION PLANNING												PPG					
234	1	CL20-010	PPG		CL-20	INITIAL CONTAINMENT CLOSEOUT INSPECTION	7	27MAY04 15:00A	31MAY04 18:59	30	CL20-010	INITIAL CONTAINMENT CLOSEOUT INSPECTION					INITIAL CONTAINMENT CLOSEOUT INSPECTION
235	1	CSB12Z	PPG		MILESTONE	END FEED PUMP P28B WORK WINDOW	0	31MAY04 13:00	31MAY04 12:59	79	CSB12Z	END FEED PUMP P28B WORK WINDOW					END FEED PUMP P28B WORK WINDOW (MAIN FEED PUMP P-28B)
236	1	ADMIN-81	PPG		ADMIN	Startup Readiness Meeting to Exit Cold Shutdown	4	01JUN04 13:00	01JUN04 16:59	0							ADMIN-81 Startup Readiness Meeting to Exit Cold Shutdown Startup Readiness Meeting
237	1	TUX01Z	PPG		MILESTONE	CLOSE MAIN TURB & AUXILIARIES WORK	0	01JUN04 18:00	01JUN04 17:59	95							TUX01Z CLOSE MAIN TURB & AUXILIARIES WORK WINDOW (MAIN TURBINE & AUXILIARIES)
238	2	CSD6	PPG		MILESTONE	SIGN MODE CHANGE CHECKLIST TO EXIT	0	01JUN04 21:00	01JUN04 20:59	4							CSD6 SIGN MODE CHANGE CHECKLIST TO EXIT MODE 5 END MISCELLANEOUS COLD SHUTDOWN WORK
239	1	CTMTIGHT	PPG		MILESTONE	CONTAINMENT OPERABILITY	0		01JUN04 22:59	489							CTMTIGHT CONTAINMENT OPERABILITY ESTABLISHED CONTAINMENT OPERABILITY ESTABLISHED
240	1	COLDS0NY	PPG		MILESTONE	RCS ENTERS HOT SHUTDOWN	0		02JUN04 00:59	487							COLDS0NY RCS ENTERS HOT SHUTDOWN EXIT COLD SHUTDOWN
241	1	CONTX03Z	PPG		MILESTONE	CLOSE CTMT PURGE/EXHAUST WORK	0	02JUN04 01:00	02JUN04 00:59	0							CONTX03Z CLOSE CTMT PURGE/EXHAUST WORK WINDOW CONTAINMENT PURGE AND EXHAUST SYSTEM
242	1	ENFPC01U	PPG		MILESTONE	ENTER S/D FIRE PROT COND 1	0	02JUN04 01:00	02JUN04 00:59	345							ENFPC01U ENTER S/D FIRE PROT COND 1
243	1	OPMMSZ	PPG		ADMIN MS	END OPERATIONS COLD SHUTDOWN WORK	0	02JUN04 01:00	02JUN04 00:59	0							OPMMSZ END OPERATIONS COLD SHUTDOWN WORK SYSTEMS OPERABLE TO SUPPORT EXITING COLD S/D
244	1	RHX01A	PPG		MILESTONE	START RHR COMMON WORK	0	02JUN04 09:00	02JUN04 08:59	0							RHX01A START RHR COMMON WORK START RHR B LOOP WORK
245	1	ADMIN-82	PPG		ADMIN	Startup Readiness Meeting to Exit Hot Shutdown	4	02JUN04 13:00	02JUN04 18:59	0							ADMIN-82 Startup Readiness Meeting to Exit Hot Shutdown Startup Readiness Meeting
REACTOR ENGINEERING												PRE					
246	1	RESP-3.1A	PRE	77	RESP 3.1	COLD ROD FUNCTIONAL TESTING	3	01JUN04 08:00	01JUN04 10:59	0							RESP-3.1A COLD ROD FUNCTIONAL TESTING 0213863 PRIMARY SYSTEM TESTS

U1R28 WORKING SCHEDULE

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN					
											Mon 31			Tue 1			Wed 2		
											8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22						
RADIATION PROTECTION												RP							
247	1	OP9C-010B	RP		RMS	RESET PURGE SETPOINT FOR AT POWER	2	01JUN04 09:00	01JUN04 10:59	32				OP9C-010B	RESET PURGE SETPOINT FOR AT POWER				
248	1	RPJF-101L	RP		DEPOST CTM	POST CONTAINMENT HATCH FOR HEATUP >350	4	02JUN04 01:00	02JUN04 04:59	0				RPJF-101L	POST CONTAINMENT HATCH FOR HEATUP >350				
249	1	RPJF-101M	RP		DEPOST CTM	DEPOST INTERNAL AREA POSTINGS	4	02JUN04 05:00	02JUN04 08:59	0				RPJF-101M	DEPOST INTERNAL AREA POSTINGS				
250	1	RPJF-101O	RP		DEPOST CTM	POST LHRA AT CONTAINMENT HATCHES	1	02JUN04 09:00	02JUN04 09:59	0				RPJF-101O	POST LHRA AT CONTAINMENT HATCHES				
251	1	RPJF-101P	RP		DEPOST CTM	REMOVE LHRA POSTINGS IN CONTAINMENT	1	02JUN04 10:00	02JUN04 10:59	53				RPJF-101P	REMOVE LHRA POSTINGS IN CONTAINMENT				
LAUNDRY DECON - T. ENGLEMAN												RP1							
252	0	RPSH007	RP1		SHIELDING	INSTALL SHIELDING AROUND FRISK STATION NEAR P-9	16	01JUN04 07:00	02JUN04 14:59	105				RPSH007	INSTALL SHIELDING AROUND FRISK STATION NEAR P-9				
253	1	RPJF-101N	RP1		DEPOST CTM	REMOVE INTERNAL AREA SOPs, PC & TRASH BARRELS	4	02JUN04 05:00	02JUN04 08:59	0				RPJF-101N	REMOVE INTERNAL AREA SOPs, PC & TRASH BARRELS				
SITE DESIGN STRUCTURAL (CIVIL)												SDS							
254	0	SD307011MM	SDS	78	D-105	SD CIVIL SQUG INSP OF FINAL D-105 INSTALLATION	4	01JUN04 07:00	01JUN04 10:59	501				SD307011MM	SD CIVIL SQUG INSP OF FINAL D-105 INSTALLATION				
TURBINE GENERATOR GROUP												TGG							
255	0	TG0400112	TGG	77	SERVICE	SEN FLAMMABLE STORAGE LOCKER INSP	2	01JUN04 07:00	01JUN04 08:59	119				TG0400112	SEN FLAMMABLE STORAGE LOCKER INSP				
WORK CONTROL CENTER												WCC							
256	1	CL-2E	WCC		CL 2E	MODE 3 TO MODE 2 CHECKLIST	100	02MAY04 19:00A	04JUN04 15:59	0				CL-2E	MODE 3 TO MODE 2 CHECKLIST				
257	1	CL-2F	WCC		CL 2F	MODE 2 TO MODE 1 CHECKLIST	120	02MAY04 19:00A	05JUN04 11:59	0				CL-2F	MODE 2 TO MODE 1 CHECKLIST				
258	1	T-8933-R	WCC		TG-01-T	1 TU TG-01-T REV12-1	1	25MAY04 12:00A	31MAY04 12:59	26				T-8933-R	1 TU TG-01-T REV12-1				
259	1	CL-2C	WCC		CL 2C	MODE 5 TO MODE 4 CHECKLIST	37	26MAY04 19:00A	02JUN04 00:59	0				CL-2C	MODE 5 TO MODE 4 CHECKLIST				
260	1	CL-2D	WCC		CL 2D	MODE 4 TO MODE 3 CHECKLIST	54	26MAY04 19:00A	02JUN04 17:59	0				CL-2D	MODE 4 TO MODE 3 CHECKLIST				
261	1	RETEST08	WCC		RETESTS	WCC RUN S-8 REPORT FOR RCS >350 DEG F	0	31MAY04 12:00	31MAY04 11:59	53				RETEST08	WCC RUN S-8 REPORT FOR RCS >350 DEG F				
262	1	T-7365-H	WCC		Z-013	1 Z Z-13 INTEGRATED EMMM REV2-1	1	31MAY04 12:00	31MAY04 12:59	0				T-7365-H	1 Z Z-13 INTEGRATED EMMM REV2-1				

U1R28 WORKING SCHEDULE

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN			
											Mon 31	Tue 1	Wed 2	0, 2, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22	0, 2, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22	0, 2, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22	
											8, 10, 12, 14, 16, 18, 20, 22	0, 2, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22	0, 2, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22				
WORK CONTROL CENTER												WCC					
263	1	T-9276-R	WCC		P-28B	1 CS P-28B MM REV3-1	1	31MAY04 12:00	31MAY04 12:59	0	T-9276-R	1 CS P-28B MM REV3-1 1 CS P-28B MM REV3-10019276					
264	1	T-0699-R	WCC		VNPSE-3244	1 VNPSE VNPSE-3244/3245 OI-64	1	31MAY04 13:00	31MAY04 13:59	35	T-0699-R	1 VNPSE VNPSE-3244/3245 OI-64 OPS REV0-1 1 VNPSE VNPSE-3244/3245 OI-64 OPS REV0-10010699					
265	1	T-0700-R	WCC		VNPSE-3245	1 VNPSE VNPSE-3245 OI-64 OPS REV0-1	1	31MAY04 13:00	31MAY04 13:59	35	T-0700-R	1 VNPSE VNPSE-3245 OI-64 OPS REV0-1 1 VNPSE VNPSE-3245 OI-64 OPS REV0-10010700					
266	1	T-7364-R	WCC		Z-013	1 Z Z-13 INTEGRATED EM/MM REV1-1	1	31MAY04 13:00	31MAY04 13:59	35	T-7364-R	1 Z Z-13 INTEGRATED EM/MM REV1-1 1 Z Z-13 INTEGRATED EM/MM REV1-10017364					
267	1	T-9294-R	WCC		P-1A-M	1 RC P-1A-M BALANCE EM REV1-1	1	31MAY04 13:00	31MAY04 13:59	0	T-9294-R	1 RC P-1A-M BALANCE EM REV1-1 1 RC P-1A-M BALANCE EM REV1-10019294					
268	1	T-9788-R	WCC		E02	1 TU E02 BKR LEADS EM REV1-1	1	31MAY04 13:00	31MAY04 13:59	0	T-9788-R	1 TU E02 BKR LEADS EM REV1-1 1 TU E02 BKR LEADS EM REV1-10009788					
269	1	T-7587-H	WCC		TM 04-001	1 VNPSE TM 04-001 (3244) EM REV0-1	2	31MAY04 13:00	31MAY04 14:59	0	T-7587-H	1 VNPSE TM 04-001 (3244) EM REV0-1 1 VNPSE TM 04-001 (3244) EM REV0-10017587					
270	1	T-7589-H	WCC		VNPSE-3244	1 VNPSE TM 04-001 (3244) MMV REV0-1	2	31MAY04 13:00	31MAY04 14:59	0	T-7589-H	1 VNPSE TM 04-001 (3244) MMV REV0-1 1 VNPSE TM 04-001 (3244) MMV REV0-10017589					
271	1	T-0696-H	WCC		VNPSE-3212	1 VNPSE VNPSE-3212/3213 OI-64	1	31MAY04 15:00	31MAY04 15:59	0	T-0696-H	1 VNPSE VNPSE-3212/3213 OI-64 OPS REV0-1 0010696 1 VNPSE VNPSE-3212/3213 OI-64 OPS REV0-1					
272	1	T-0697-H	WCC		VNPSE-3213	1 VNPSE VNPSE-3213 OI-64 OPS REV0-1	1	31MAY04 15:00	31MAY04 15:59	0	T-0697-H	1 VNPSE VNPSE-3213 OI-64 OPS REV0-1 0010697 1 VNPSE VNPSE-3213 OI-64 OPS REV0-1					
273	1	T-8880-R	WCC		C-2	1 CONT C-2 MM REV2-1	1	31MAY04 15:00	31MAY04 15:59	31	T-8880-R	1 CONT C-2 MM REV2-1 0018880 1 CONT C-2 MM REV2-1					
274	2	T407307H	WCC		P-029-T	HANG TAG (2 AF P-29-T MM REV0-2)	1	31MAY04 15:00	31MAY04 15:59	0	T407307H	HANG TAG (2 AF P-29-T MM REV0-2)					
275	2	T407307R	WCC		P-029-T	REMOVE TAG (2 AF P-29-T MM REV0-2)	1	31MAY04 17:00	31MAY04 17:59	0	T407307R	REMOVE TAG (2 AF P-29-T MM REV0-2)					
276	1	T-0696-R	WCC		VNPSE-3212	1 VNPSE VNPSE-3212/3213 OI-64	1	31MAY04 20:00	31MAY04 20:59	28	T-0696-R	1 VNPSE VNPSE-3212/3213 OI-64 OPS REV0-1 0010696 1 VNPSE VNPSE-3212/3213 OI-64 OPS REV0-1					
277	1	T-0697-R	WCC		VNPSE-3213	1 VNPSE VNPSE-3213 OI-64 OPS REV0-1	1	31MAY04 20:00	31MAY04 20:59	28	T-0697-R	1 VNPSE VNPSE-3213 OI-64 OPS REV0-1 0010697 1 VNPSE VNPSE-3213 OI-64 OPS REV0-1					
278	1	T-7588-H	WCC		TM 04-001	1 VNPSE TM 04-001 (3212) MMV REV0-1	1	31MAY04 20:00	31MAY04 20:59	0	T-7588-H	1 VNPSE TM 04-001 (3212) MMV REV0-1 0017588 1 VNPSE TM 04-001 (3212) MMV REV0-1					
279	0	T301076H	WCC		F-235	HANG PERMIT (0 STP F-235 MM REV0-3)	1	31MAY04 20:00*	31MAY04 20:59	34	T301076H	HANG PERMIT (0 STP F-235 MM REV0-3)					
280	0	T302218H	WCC		F-235	HANG TAG (0 STP F-235 IC REV0-1)	1	31MAY04 20:00*	31MAY04 20:59	10	T302218H	HANG TAG (0 STP F-235 IC REV0-1)					
281	1	T-7586-H	WCC		TM 04-001	1 VNPSE TM 04-001 (3212) EM REV0-1	3	31MAY04 20:00	31MAY04 22:59	0	T-7586-H	1 VNPSE TM 04-001 (3212) EM REV0-1 0017586 1 VNPSE TM 04-001 (3212) EM REV0-1					

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN																	
											Mon 31			Tue 1						Wed 2											
											8	10	12,14,16,18,20,22	0	2	4	6	8	10	12,14,16,18,20,22	0	2	4	6	8	10	12,14,16				
WORK CONTROL CENTER												WCC																			
282	1	T-9279-R	WCC		W-43A	1 VNCF W-43A MM REV0-1	1	31MAY04 22:00	31MAY04 22:59	89				T-9279-R 1 VNCF W-43A MM REV0-1 0019279 1 VNCF W-43A MM REV0-1																	
283	1	T-7587-R	WCC		TM 04-001	1 VNPSE TM 04-001 (3244) EM REV0-1	2	01JUN04 01:00	01JUN04 02:59	22				T-7587-R 1 VNPSE TM 04-001 (3244) EM REV0-1 0017587 1 VNPSE TM 04-001 (3244) EM REV0-1																	
284	1	T-9221-R	WCC		Z-104A	1 SW Z-104A MM REV0-1	1	01JUN04 03:00	01JUN04 03:59	508				T-9221-R 1 SW Z-104A MM REV0-1 0019221 1 SW Z-104A MM REV0-1																	
285	2	T301196H	WCC		P-041	HANG TAG (2 AR P-41 MM REV0-1)	1	01JUN04 03:00*	01JUN04 03:59	2				T301196H HANG TAG (2 AR P-41 MM REV0-1)																	
286	2	T301196R	WCC		P-041	REMOVE TAG (2 AR P-41 MM REV0-1)	1	01JUN04 08:00	01JUN04 08:59	0				T301196R REMOVE TAG (2 AR P-41 MM REV0-1)																	
287	1	T-7586-R	WCC		TM 04-001	1 VNPSE TM 04-001 (3212) EM REV0-1	2	01JUN04 09:00	01JUN04 10:59	14				T-7586-R 1 VNPSE TM 04-001 (3212) EM REV0-1 0017586 1 VNPSE TM 04-001 (3212) EM REV0-1																	
288	1	OP4B-085	WCC		OP-4B	SECURE P-1B FOR PERFORMANCE OF	1	01JUN04 11:00	01JUN04 11:59	0				OP4B-085 SECURE P-1B FOR PERFORMANCE OF 6Z-A02 RMP REACTOR COOLANT PUMP OPERATION																	
289	1	T-7365-R	WCC		Z-013	1 Z Z-13 INTEGRATED EMM/REV2-1	1	01JUN04 12:00	01JUN04 12:59	12				T-7365-R 1 Z Z-13 INTEGRATED EMM/REV2-1 0017365 1 Z Z-13 INTEGRATED EMM/REV2-1																	
290	1	T-8689-R	WCC		102-1/TG-0	1 MRR 102-1/TG-01 CE REV3-1	1	01JUN04 14:00	01JUN04 14:59	0				T-8689-R 1 MRR 102-1/TG-01 CE REV3-1 0018689 1 MRR 102-1/TG-01 CE REV3-1																	
291	0	T201620H	WCC		K-002B	HANG TAG (0 IA K-2B MM REV0-1)	1	01JUN04 14:00*	01JUN04 14:59	3				T201620H HANG TAG (0 IA K-2B MM REV0-1)																	
292	0	T212184R	WCC		T-119A	REMOVE TAG (0 WT TM-02-037 REMOVAL CE)	1	01JUN04 15:00	01JUN04 15:59	496				T212184R REMOVE TAG (0 WT TM-02-037 REMOVAL CE REV0-1)																	
293	0	T302218R	WCC		F-235	REMOVE TAG (0 STP F-235 IC REV0-1)	1	01JUN04 15:00	01JUN04 15:59	496				T302218R REMOVE TAG (0 STP F-235 IC REV0-1)																	
294	1	T-7589-R	WCC		TM 04-001	1 VNPSE TM 04-001 (3244) MMV REV0-1	2	01JUN04 15:00	01JUN04 16:59	6				T-7589-R 1 VNPSE TM 04-001 (3244) MMV REV0-1 0017589 1 VNPSE TM 04-001 (3244) MMV REV0-1																	
295	1	T-7754-R	WCC		TG-01-G	1 TU TG-01-G APM REV0-1	1	01JUN04 17:00	01JUN04 17:59	0				T-7754-R 1 TU TG-01-G APM REV0-1 0017754 1 TU TG-01-G APM REV0-1																	
296	1	T-8169-R	WCC		TG-01-T	1 TU TG-01-T REV6.2-1	1	01JUN04 17:00	01JUN04 17:59	0				T-8169-R 1 TU TG-01-T REV6.2-1 0018169 1 TU TG-01-T REV6.2-1																	
297	1	OP4B-090	WCC		OP-4B	RE-START P-001B FOR HEATUP	1	01JUN04 18:00	01JUN04 18:59	0				OP4B-090 RE-START P-001B FOR HEATUP REACTOR COOLANT PUMP OPERATION																	
298	0	T301089H	WCC		HX-366	HANG PERMIT (0 HV HX-366 MM REV0-1)	1	01JUN04 20:00*	01JUN04 20:59	10				T301089H HANG PERMIT (0 HV HX-366 MM REV0-1)																	
299	0	T301090H	WCC		HX-367	HANG PERMIT (0 HV HX-367 MM REV0-1)	1	01JUN04 20:00*	01JUN04 20:59	34				T301090H HANG PERMIT (0 HV HX-367 MM REV0-1)																	
300	0	T301091H	WCC		HX-368	HANG PERMIT (0 HV HX-368 MM REV0-1)	1	01JUN04 20:00*	01JUN04 20:59	38				T301091H HANG PERMIT (0 HV HX-368 MM REV0-1)																	

#	U	ID	RESP	WO ST	EQID	DESCRIPTION	RD	ES	EF	MF	MAY			JUN			
											Mon 31	Tue 1	Wed 2	Mon 31	Tue 1	Wed 2	
WORK CONTROL CENTER												WCC					
301	0	T301092H	WCC		HX-369	HANG PERMIT (0 HV HX-369 MM REV0-1)	1	01JUN04 20:00*	01JUN04 20:59	58							T301092H HANG PERMIT (0 HV HX-369 MM REV0-1)
302	0	T301093H	WCC		HX-370	HANG PERMIT (0 HV HX-370 MM REV0-1)	1	01JUN04 20:00*	01JUN04 20:59	62							T301093H HANG PERMIT (0 HV HX-370 MM REV0-1)
303	1	T-7588-R	WCC		TM 04-001	1 VNPSE TM 04-001 (3212) MMV REV0-1	2	01JUN04 21:00	01JUN04 22:59	0							T-7588-R 1 VNPSE TM 04-001 (3212) MMV REV0-1
304	0	T-7624-H	WCC		IA-00229	0 IA K-2B FIN REV0-1 (IN 2004 FOLDER)	2	01JUN04 21:00	01JUN04 22:59	0							T-7624-H 0 IA K-2B FIN REV0-1 (IN 2004 FOLDER) 0017624
305	1	T-0693-R	WCC		OI-32B	1 HG OI-32B OPS REV0-1	1	01JUN04 23:00	01JUN04 23:59	0							T-0693-R 1 HG OI-32B OPS REV0-1 0010693
306	0	T301078H	WCC		F-237	HANG PERMIT (0 STP F-237 MM REV0-3)	1	02JUN04 00:00*	02JUN04 00:59	9							T301078H HANG PERMIT (0 STP F-237 MM REV0-3)
307	0	T201620R	WCC		K-002B	REMOVE TAG (0 IA K-2B MM REV0-1)	1	02JUN04 02:00	02JUN04 02:59	485							T201620R REMOVE TAG (0 IA K-2B MM REV0-1)
308	0	T307011R	WCC		D-105	REMOVE TAG (0 125V D-105 EM REV0-3)	2	02JUN04 03:00	02JUN04 04:59	0							T307011R REMOVE TAG (0 125V D-105 EM REV0-3)
309	1	T-6316-H	WCC		RH-700	1 RH RH-700 EM REV1-1	1	02JUN04 09:00	02JUN04 09:59	0							T-6316-H 1 RH RH-700 EM REV1-1 10016316
310	0	T301076R	WCC		F-235	REMOVE PERMIT (0 STP F-235 MM REV0-3)	1	02JUN04 10:00	02JUN04 10:59	477							T301076R REMOVE PERMIT (0 STP F-235 MM REV0-3)
311	0	T301089R	WCC		HX-368	REMOVE PERMIT (0 HV HX-368 MM REV0-1)	1	02JUN04 11:00	02JUN04 11:59	476							T301089R REMOVE PERMIT (0 HV HX-368 MM REV0-1)
312	1	T306095H	WCC		Z-027-1/2	HANG PERMIT (1 CW Z-27-1/2/3/4 MM REV0-1)	1	02JUN04 12:00*	02JUN04 12:59	5							T306095H HANG PERMIT (1 CW Z-27-1/2/3/4 MM REV0-1)
313	0	T301078R	WCC		F-237	REMOVE PERMIT (0 STP F-237 MM REV0-3)	1	02JUN04 13:00	02JUN04 13:59	474							T301078R REMOVE PERMIT (0 STP F-237 MM REV0-3)
314	1	T-0482-H	WCC		SI-852A	1 SI SI-852A EM REV0-1	2	02JUN04 15:00	02JUN04 16:59	0							T-0482-H 1 SI SI-852A EM REV0-1 10010482