

August 15, 2005

LICENSEE: Omaha Public Power District (OPPD)
FACILITY: Fort Calhoun Station, Unit 1
SUBJECT: SUMMARY OF JULY 14, 2005, CATEGORY 1 MEETING WITH OPPD TO DISCUSS THE FEASIBILITY OF FORT CALHOUN BEING A PILOT PLANT FOR THE RESOLUTION OF GENERIC LETTER 2004-02

On July 14, 2005, a public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of OPPD at NRC Headquarters, One White Flint North, 11555 Rockville Pike, Rockville, Maryland. The purpose of the meeting was to discuss the possibility of Fort Calhoun being a pilot plant for the NRC staff resolution of Generic Letter 2004-02 on the potential impact of debris blockage on pressurized-water reactor containment sumps.

OPPD presented an overview of its progress and approach in completing the required actions of Generic Letter 2004-02, along with its preliminary computational results and future plant sump modifications.

The NRC staff concluded that there were several areas of OPPD's evaluation that would be beneficial to review and evaluate. Therefore, the NRC staff accepted Fort Calhoun as a pilot plant and the NRC staff plans to conduct audits at the Fort Calhoun plant site, the New Jersey strainer testing facility, and the New Mexico fluid dynamics computational lab, which involves reviewing the following areas:

- Debris Generation
- Debris Characteristics
- Coating
- Transport
- Headloss
- Downstream Effects

The staff requested that a schedule for the audits be confirmed as soon as possible. The staff also requested the GE procedure for the strainer test.

A list of meeting attendees is attached. The presentation slides are available in the Agencywide Documents Access Management System under Accession No. ML051960023. A member of the public was in attendance. Public Meeting Feedback forms were not received.

/RA/
Gabriel Taylor, Engineer, Section 1
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-285

Attachment: List of Meeting Attendees
cc w/att: See next page

August 15, 2005

LICENSEE: Omaha Public Power District (OPPD)

FACILITY: Fort Calhoun Station, Unit 1

SUBJECT: SUMMARY OF JULY 14, 2005, CATEGORY 1 MEETING WITH OPPD TO DISCUSS THE FEASIBILITY OF FORT CALHOUN BEING A PILOT PLANT FOR THE RESOLUTION OF GENERIC LETTER 2004-02

On July 14, 2005, a public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of OPPD at NRC Headquarters, One White Flint North, 11555 Rockville Pike, Rockville, Maryland. The purpose of the meeting was to discuss the possibility of Fort Calhoun being a pilot plant for the NRC staff resolution of Generic Letter 2004-02 on the potential impact of debris blockage on pressurized-water reactor containment sumps.

OPPD presented an overview of its progress and approach in completing the required actions of Generic Letter 2004-02, along with its preliminary computational results and future plant sump modifications.

The NRC staff concluded that there were several areas of OPPD's evaluation that would be beneficial to review and evaluate. Therefore, the NRC staff accepted Fort Calhoun as a pilot plant and the NRC staff plans to conduct audits at the Fort Calhoun plant site, the New Jersey strainer testing facility, and the New Mexico fluid dynamics computational lab, which involves reviewing the following areas:

- Debris Generation
- Debris Characteristics
- Coating
- Transport
- Headloss
- Downstream Effects

The staff requested that a schedule for the audits be confirmed as soon as possible. The staff also requested the GE procedure for the strainer test.

A list of meeting attendees is attached. The presentation slides are available in the Agencywide Documents Access Management System under Accession No. ML051960023. A member of the public was in attendance. Public Meeting Feedback forms were not received.

/RA/
Gabriel Taylor, Engineer, Section 1
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-285 DISTRIBUTION: BKaras DCullison
PUBLIC RidsNrrDlpm (TMarsh) LWhitney

Attachment: List of Meeting Attendees PDIV-2 Reading RidsNrrDlpmLpdiv (HBerkow) DSolorio

cc w/att: See next page RidsNrrPMAWang RidsNrrDlpmLpdiv2 THafera
RidsOgcRp DCollins RCaruso
RidsAcrcAcnwMailCenter LLund JLehning
JDixon-Herrity, RIV RidsNrrLALFeizollahi HWagage
RidsRgn4MailCenter GTaylor TMensah
RArchitzel
MKowal

Meeting Notice: ML051750625 PKG: ML052230294 SLIDES: ML051960023
ACCESSION NO.: ML052080136 NRC-001

OFFICE	PDIV-1/GE	PDIV-2/LA	PDIV-2/(A)SC
NAME	GTaylor	LFeizollahi	DCollins
DATE	8/12/05	8/12/05	8/15/05

OFFICIAL RECORD COPY

MEETING WITH OMAHA PUBLIC POWER DISTRICT (OPPD)
LIST OF ATTENDEES

July 14, 2005

OPPD

T. Matthews
B. VanSant
M. Friedman

GE

B. Smith *
R. Hayes
S. Moen *

Sargent & Lundy

L. Garza
S. Raupp

Alion Science

J. Bostelman

INES

K. Sakamoto

NEI

J. Butler

LIS, Scientech

D. Rafegh

PUBLIC

S. Dolley

NRC

A. Wang
J. Lehning
L. Whitney
D. Collins *
D. Solorio
T. Hafera
H. Wagage
G. Taylor
L. Lund
B. Karas
D. Cullison
R. Architzel
M. Kowal
R. Caruso

* Denotes part-time attendance

Ft. Calhoun Station, Unit 1

cc:

Winston & Strawn
ATTN: James R. Curtiss, Esq.
1400 L Street, N.W.
Washington, DC 20005-3502

Chairman
Washington County Board of Supervisors
P.O. Box 466
Blair, NE 68008

Mr. John Hanna, Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 310
Fort Calhoun, NE 68023

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-4005

Ms. Sue Semerera, Section Administrator
Nebraska Health and Human Services
Systems
Division of Public Health Assurance
Consumer Services Section
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

Mr. David J. Bannister, Manager
Fort Calhoun Station
Omaha Public Power District
Fort Calhoun Station FC-1-1 Plant
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. John B. Herman
Manager - Nuclear Licensing
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. Daniel K. McGhee
Bureau of Radiological Health
Iowa Department of Public Health
Lucas State Office Building, 5th Floor
321 East 12th Street
Des Moines, IA 50319

Mr. R. T. Ridenoure
Vice President - Chief Nuclear Officer
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
Post Office Box 550
Fort Calhoun, Nebraska 68023-0550

June 2005