Appendix A

NRC NEPA Issues for License Renewal of Nuclear Power Plants

Oyster Creek Generating Station Environmental Report

- 1 AmerGen has prepared this environmental
- 2 report in accordance with the requirements
- 3 of U.S. Nuclear Regulatory Commission
- 4 (NRC) regulation 10 CFR 51.53. NRC 5 included in the regulation a list of National
- 6 Environmental Policy Act (NEPA) issues for
- 7 license renewal of nuclear power plants.

8 Table A-1 lists these 92 issues and 9 identifies the section in which AmerGen 10 addressed each applicable issue in this 11 environmental report. For organization and 12 clarity, AmerGen has assigned a number to 13 each issue and uses the issue numbers 14 throughout the environmental report.

Environmental Report Appendix A Tables

1

			Section of this	
leei	20	Catagony	Environmental	GEIS Cross Reference ^b
1331	Surface Water Ou	ality Hydrolo	nepon av' and Use (for a	(Section/Page)
1.	Impacts of refurbishment on surface water quality	1	NA	Issue applies to an activity, refurbishment, that OCGS has no plans to undertake.
2.	Impacts of refurbishment on surface water use	1	NA	Issue applies to an activity, refurbishment, that OCGS has no plans to undertake.
3.	Altered current patterns at intake and discharge structures	1	4 Introduction	4.2.1.2.1/4-5
4.	Altered salinity gradients	1	4 Introduction	4.2.1.2.2/4-4
5.	Altered thermal stratification of lakes	1	NA	Issue applies to a plant feature, discharge to a lake, that OCGS does not have.
6.	Temperature effects on sediment transport capacity	1	4 Introduction	4.2.1.2.3/4-8
7.	Scouring caused by discharged cooling water	1	4 Introduction	4.2.1.2.3/4-6
8.	Eutrophication	1	4 Introduction	4.2.1.2.3/4-9
9.	Discharge of chlorine or other biocides	1	4 Introduction	4.2.1.2.4/4-10
10.	Discharge of sanitary wastes and minor chemical spills	1	4 Introduction	4.2.1.2.4/4-10
11.	Discharge of other metals in waste water	1	4 Introduction	4.2.1.2.4/4-10
12.	Water use conflicts (plants with once-through cooling systems)	1	4 Introduction	4.2.1.3/4-13
13.	Water use conflicts (plants with cooling ponds or cooling towers using make-up water from a small river with low flow)	2	NA, and discussed in Section 4.1	Issue applies to a plant feature, cooling ponds or cooling towers, that OCGS does not have.
	Aqua	tic Ecology (for all plants)	
14.	Refurbishment impacts to aquatic resources	1	NA	Issue applies to an activity, refurbishment, that OCGS has no plans to undertake.
15.	Accumulation of contaminants in sediments or biota	1	4 Introduction	4.2.1.2.4/4-10
16.	Entrainment of phytoplankton and zooplankton	1	4 Introduction	4.2.2.1.1/4-15
17.	Cold shock	1	4 Introduction	4.2.2.1.5/4-18
18.	Thermal plume barrier to migrating fish	1	4 Introduction	4.2.2.1.6/4-19
19.	Distribution of aquatic organisms	1	4 Introduction	4.2.2.1.6/4-19

Page A-4

)

b

ไรรเ	10	Category	Section of this Environmental Report	GEIS Cross Reference ^b (Section/Page)
20.	Premature emergence of aquatic insects	1	4 Introduction	4.2.2.1.7/4-20
21.	Gas supersaturation (gas bubble disease)	1	4 Introduction	4.2.2.1.8/4-21
22.	Low dissolved oxygen in the discharge	1	4 Introduction	4.2.2.1.9/4-23
23.	Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	1	4 Introduction	4.2.2.1.10/4-24
24.	Stimulation of nuisance organisms (e.g., shipworms)	1	4 Introduction	4.2.2.1.11/4-25
	Aquatic Ecology (for plants with on	ce-through a	nd cooling pond	heat dissipation systems)
25.	Entrainment of fish and shellfish in early life stages for plants with once-through and cooling pond heat dissipation systems	2	4.2	4.2.2.1.2/4-16
26.	Impingement of fish and shellfish for plants with once-through and cooling pond heat dissipation systems	2	4.3	4.2.2.1.3/4-16
27.	Heat shock for plants with once- through and cooling pond heat dissipation systems	2	4.4	4.2.2.1.4/4-17
. 1 	Aquatic Ecology (for plants w	ith cooling-to	ower-based heat c	lissipation systems)
28.	Entrainment of fish and shellfish in early life stages for plants with cooling-tower-based heat dissipation systems	1	NA	Issue applies to a heat dissipation system, cooling towers, that OCGS does not have.
29.	Impingement of fish and shellfish for plants with cooling-tower-based heat dissipation systems	1	NA	Issue applies to a heat dissipation system, cooling towers, that OCGS does not have.
30.	Heat shock for plants with cooling- tower-based heat dissipation systems	1	NA	Issue applies to a heat dissipation system, cooling towers, that OCGS does not have.
	Grou	Indwater Use	and Quality	
31.	Impacts of refurbishment on groundwater use and quality	1	NA	Issue applies to an activity, refurbishment, that OCGS has no plans to undertake.
32.	Groundwater use conflicts (potable and service water; plants that use < 100 gpm)	1	4 Introduction	4.8.1.1/4-116 and 4.8.2.1/4- 119

Table A-1 OCGS Environmental Report Discussion of License Renewal NEPA Issues*

1

Environmental Report Appendix A Tables

Tab	Table A-1. OCGS Environmental Report Discussion of License Renewal NEPA Issues ^a (Continued) (Continued)					
Issi	ue	Category	Section of this Environmental Report	GEIS Cross Reference ^b (Section/Page)		
33.	Groundwater use conflicts (potable, service water, and dewatering; plants that use > 100 gpm)	2	NA, and discussed in Section 4.5	Issue applies to an activity, using 100 gpm or more of groundwater, that OCGS does not do.		
34.	Groundwater use conflicts (plants using cooling towers withdrawing make-up water from a small river)	2	NA, and discussed in Section 4.6	Issue applies to a plant feature, cooling towers, that OCGS does not have.		
35.	Groundwater use conflicts (Ranney wells)	2	NA, and discussed in Section 4.7	Issue applies to a plant feature, Ranney wells, that OCGS does not have.		
36.	Groundwater quality degradation (Ranney wells)	1	NA	Issue applies to a feature, Ranney wells, that OCGS does not have.		
37.	Groundwater quality degradation (saltwater intrusion)	1	4 Introduction	4.8.2/4-118		
38.	Groundwater quality degradation (cooling ponds in salt marshes)	1	NA	Issue applies to a feature, cooling ponds, that OCGS does not have.		
39.	Groundwater quality degradation (cooling ponds at inland sites)	2	NA, and discussed in Section 4.8	Issue applies to a feature, cooling ponds, that OCGS does not have.		
		Terrestrial Re	Sources			
40.	Refurbishment impacts to terrestrial resources	2	NA, and discussed in Section 4.9	Issue applies to an activity, refurbishment, that OCGS has no plans to undertake.		
41.	Cooling tower impacts on crops and ornamental vegetation	1	NA	Issue applies to a feature, cooling towers, that OCGS does not have.		
42.	Cooling tower impacts on native plants	1	NA	Issue applies to a feature, cooling towers, that OCGS does not have.		
43.	Bird collisions with cooling towers	1	NA	Issue applies to a feature, cooling towers, that OCGS does not have.		
44.	Cooling pond impacts on terrestrial resources	1	NA	Issue applies to a feature, cooling ponds, that OCGS does not have.		
45.	Power line right-of-way management (cutting and herbicide application)	1	4 Introduction	4.5.6.1/4-71		
46.	Bird collisions with power lines	1	4 Introduction	4.5.6.2/4-74		

بالكار ا

b

j

	(Continued)			
lssi	Je	Category	Section of this Environmental Report	GEIS Cross Reference ^b (Section/Page)
47.	Impacts of electromagnetic fields on flora and fauna (plants, agricultural crops, honeybees, wildlife, livestock)	1	4 Introduction	4.5.6.34-77
48.	Floodplains and wetlands on power line right-of-way	1	4 Introduction	4.5.7.7/4-81
	Threatened or	Endangered	Species (for all p	ants)
49.	Threatened or endangered species	2	4.10	4.1/4-1
[Air Qua	lity	anne anna an anna ann an ann an ann an ann an a
50.	Air quality during refurbishment (non-attainment and maintenance areas)	2	NA, and discussed in Section 4.11	Issue applies to an activity, refurbishment, that OCGS does not plan to undertake.
51.	Air quality effects of transmission lines	1	4 Introduction	4.5.2/4-62
	الم	Land U	Se	narnan ble å hennen, si alle i ble men en e
52.	Onsite land use	1	4 Introduction	3.2/3-1
53.	Power line right-of-way land use impacts	1	4 Introduction	4.5.3/4-62
		Human H	ealth	and a second
54.	Radiation exposures to the public during refurbishment	1	NA	Issue applies to an activity, refurbishment, that OCGS has no plans to undertake.
55.	Occupational radiation exposures during refurbishment	1	NA	Issue applies to an activity, refurbishment, that OCGS has no plans to undertake.
56.	Microbiological organisms (occupational health)	1	4 Introduction	4.3.6/4-48
57.	Microbiological organisms (public health) (plants using lakes or canals, or cooling towers or cooling ponds that discharge to a small river)	2	NA, and discussed in Section 4.12	Issue applies to plant features, cooling lakes, canals or towers, that OCGS does not have.
58.	Noise	1	4 Introduction	4.3.7/4-49
59.	Electromagnetic fields, acute effects	2	4.13	4.5.4.1/4-66
60.	Electromagnetic fields, chronic effects	NA	4 Introduction	
61.	Radiation exposures to public (license renewal term)	1 ·	4 Introduction	4.6.2/4-87
62.	Occupational radiation exposures (license renewal term)	1	4 Introduction	4.6.3/4-95

Environmental Report Appendix A Tables

Tab	Table A-1. OCGS Environmental Report Discussion of License Renewal NEPA Issues ^a (Continued)					
Issu	Je	Category	Section of this Environmental Report	GEIS Cross Reference ^b (Section/Page)		
	in the second	Socioecon	omics			
63.	Housing impacts	2	4.14	3.7.2/3-10 (refurbishment - not applicable to OCGS) 4.7.1/4-101 (renewable term)		
64.	Public services: public safety, social services, and tourism and recreation	1	4 Introduction	Refurbishment (not applicable to OCGS because issue applies to an activity that OCGS does not plan to undertake)		
				Renewal Term		
				4.7.3/4-104 (public safety)		
				4.7.3.3/4-106 (safety)		
				4.7.3.44-107 (social)		
				4.7.3.6/4-107 (tour, rec)		
65.	Public services: public utilities	2	4.15	3.7.4.5/3-19 (refurbishment - not applicable to OCGS) 4.7.3.5/4-107 (renewable term)		
66.	Public services: education (refurbishment)	2	NA, and discussed in Section 4.16	Issue applies to an activity, refurbishment, that OCGS does not plan to undertake.		
67.	Public services: education (license renewal term)	1	4 Introduction	4.7.3.1/4-106		
68.	Offsite land use (refurbishment)	2	NA, and discussed in Section 4.17.1	Issue applies to an activity, refurbishment, that OCGS does not plan to undertake.		
69.	Offsite land use (license renewal term)	2	4.17.2	4.7.4/4-107		
70.	Public services: transportation	2	4.18	3.7.4.2/3-17 (refurbishment - not applicable to OCGS) 4.7.3.2/4-106 (renewal term)		
71.	Historic and archaeological resources	2	4.19	3.7.7/3-23 (refurbishment - not applicable to OCGS) 4.7.7/4-114 (renewal term)		
72.	Aesthetic impacts (refurbishment)	1	NA	Issue applies to an activity, refurbishment, that OCGS has no plans to undertake.		
73.	Aesthetic impacts (license renewal term)	1	4 Introduction	4.7.6/4-111		
74.	Aesthetic impacts of transmission lines (license renewal term)	1	4 Introduction	4.5.8/4-83		

b

lssı	Je	Category	Section of this Environmental Report	GEIS Cross Reference ^b (Section/Page)
		Postulated A	ccidents	An ann an An Ann an
75.	Design basis accidents	1	4 Introduction	5.3.2/5-11 (design basis)
				5.5.1/5-114 (summary)
76.	Severe accidents	2	4.20	5.3.3/5-12 (probabilistic analysis)
				5.3.3.2/5-19 (air dose)
				5.3.3.3/5-49 (water)
				5.3.3.4/5-65 (groundwater)
				5.3.3.5/5-95 (economic)
				5.4/5-106 (mitigation)
				5.5.2/5-114 (summary)
	Uranium Fu	el Cycle and	Waste Manageme	energia and and a set the set of
77.	Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high- level waste)	1	4 Introduction	6.2/6-8
78.	Offsite radiological impacts (collective effects)	1	4 Introduction	Not in GEIS.
79.	Offsite radiological impacts (spent fuel and high-level waste disposal)	1	4 Introduction	Not in GEIS.
80.	Nonradiological impacts of the	1	4 Introduction	6.2.2.6/6-20 (land use)
	uranium fuel cycle			6.2.2.7/6-20 (water use)
				6.2.2.8/6-21 (fossil fuel)
				6.2.2.9/6-21 (chemical)
81.	Low-level waste storage and	1	4 Introduction	6.4.2/6-36 (low-level def)
	disposal			6.4.3/6-37 (low-level volume)
				6.4.4/6-48 (renewal effects)
82.	Mixed waste storage and disposal	1	4 Introduction	6.4.5/6-63
83.	Onsite spent fuel	1	4 Introduction	6.4.6/6-70
84.	Nonradiological waste	1	4 Introduction	6.5/6-86
85.	Transportation	1	4 Introduction	6.3/6-31, as revised by Addendum 1, August 1999.
	anne ann a chuid ann ann ann ann ann ann ann ann ann an	Decommiss	sioning	an a construction of all all all and a construction of a construction of a source of a construction of a source of
86.	Radiation doses (decommissioning)	1	4 Introduction	7.3.1/7-15
87.	Waste management	1	4 Introduction	7.3.2/7-19 (impacts)
	(decommissioning)			7.4/7-25 (conclusions)
88.	Air quality (decommissioning)	1	4 Introduction	7.3.3/7-21 (air)
				7.4/7-25 (conclusions)

Table A-1. OCGS Environmental Report Discussion of License Renewal NEPA Issues^a (Continued)

.

Environmental Report Appendix A Tables

Table A-1.		OCGS Environmental Report Discussion of License Renewal NEPA Issues ^a (Continued)					
Issu	16		Category	Section of this Environmental Report	GEIS Cross Reference ^b (Section/Page)		
89.	Water qu	ality (decommissioning)	1	4 Introduction	7.3.4/7-21 (water)		
					7.4/7-25 (conclusions)		
90.	Ecologica	ogical resources ommissioning)	1	4 Introduction	7.3.5/7-21 (ecological)		
	(decomm				7.4/7-25 (conclusions)		
91.	Socioeco	onomic impacts	1	4 Introduction	7.3.7/7-19 (socioeconomic)		
	(decomm	nissioning)			7.4/7-24 (conclusions)		
	an gesennen er fingerickeren er 1 militet i der soner er fingerickeren er fingerickeren er 1 militet i der soner er fingerickeren er fingerickeren er 1 militet i der soner er fingerickeren er fingerickeren er fingerickeren er 1 militet i der soner er fingerickeren er	al de la constante de la	Environmenta	I Justice			
92.	Environm	nental justice	NA	2.6.2			
a.	Source: 10	CFR 51, Subpart A, Appendi	x A, Table B-1.	(Issue numbers adde	ed to facilitate discussion.)		
b.	Source: Ge	eneric Environmental Impact S	Statement for Lic	ense Renewal of Nu	clear Plants (NUREG-1437).		

1

V

V

b

Appendix B NJPDES Permit

Oyster Creek Generating Station Environmental Report

This Appendix contains selected pages of Oyster Creek Generating Station's New Jersey Pollutant Discharge Elimination System permit, including the cover page, which authorizes the Plant to discharge wastewater to Oyster Creek, a part of the Barnegat Bay Estuarine system, and pages pertinent to the Chapter 4 discussions of entrainment, impingement, and heat shock.



Environmental Report Appendix B NPDES Permit

Part I-DSW Page 1 of 6

STATE OF NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION DIVISION OF WATER QUALITY

STANDARD CONDITIONS FOR ALL NJPDES/DSW PERMITS

The permittee shall comply with all the conditions set forth in this permit and all the applicable requirements relevant to the permittee's discharge(s) that can be found in the Federal Clean Water Act and the New Jersey Water Pollution Control Act (the State Act as amended), NJ.S.A. 58:10A-1 <u>state</u>. The permittee may be subject to penalties for any violations thereof.

The following conditions that are applicable to all NJPDES/DSW permits are incorporated by reference. The permittee is required to comply with the regulations which were in effect as of the effective date of the final permit.

Sec	tion A. GENERAL CONDITIONS	N.J.Å.C.
1.	Penalties for Violations	7:14-8.1 et seg.
2.	Consolidation of Permit Process	7:14A-1.4
3.	Incorporation by Reference	7:14A-1.10
4.	Duty to Comply	7:14A-2.5(a)
5.	Duty to Reapply	7:14A-2.1(g)5
6.	Continuation of Expired Permits	7:14A-2.3
7.	Duty to Mitigate	7:14A-2.1(f)
8.	Permit Actions	7:14A-2.5(a)8
9.	Duration of Permits	7:14A-2.7
10.	Effect of Permit other Laws	7:14A-2.10(a)(b) & (c)
11.	Inspection and Entry	7:14A-2.5(a)11
12.	Severability	7:14A-1.5
13.	Toxic Pollutants	7:14A-2.5(a)3
14.	Reopener Clause	7:14A-3.13(a)3
15.	Treatment Works Approval	7:14A-22
Sec	tion B. OPERATION AND MAINTENANC	F
1.	Proper Operation and Maintenance	7-144-7 5(*)7
2	Need to Halt or Reduce not a defense	7-112.7 5(a)5
3.	Bypass of Treatment Facilities	7.134.5 10
4.	Upset	7.144-3.10
5.	Power Failure	7-134-7 5(2)58-7
6.	Emergency Plans	7-134-3 17(6)
7.	Capacity Assurance Program	7:14A-22.16
Sec	tion C. MONITORING AND RECORDS	
1	Deservative Semalia	
	Representative Sampling	7:14A-2.5(a)12.1
<u>.</u> .	Monitoring Procedures	7:14A-2.5(a)12.ii
٥.	Retention of Records	7:14A-2.5(a)12.iii
4.	Monitoring Records	7:14A-2.5(a)12.iv
з.	Additional Voluntary Monitoring	7:14A-2.5(a)12.vi

 6. Averaging of Measurements
 7:14A-2.5(a)12.vii

 7. Required Additional Monitoring
 7:14A-2.5(a)12.vii

08 24 94

••••

Part I-DSW Page 3 of 6

Operation Restrictions

The operation of a waste treatment or disposal facility shall at no time create: (a) a direct discharge to the surface waters of the State, except as authorized by the Department and into the receiving water(s) at the specified location(s) as referenced in the Part III of this permit; (b) a persistent standing or ponded condition for water or waste on the permittee's property except as specifically authorized by this or another permit; or (c) any standing or ponded condition for water or maste on adjacent properties unless these activities are specifically included within this or another permit.

This permit does not authorize or approve any activities other than the discharge(s) as referenced above.

Monitoring and Reporting

A. Monitoring results shall be summarized and reported on the appropriate Discharge Monitoring Reports (DMRs) following the completed reporting period. If a discharge does not occur during a particular reporting period, the permittee should write "NODI" across the face of the DMR. Unless otherwise specified or directed, signed copies of these DMRs shall be submitted postmarked no later than the 25th day of the calendar month following the completed reporting period to the following address:

NJDEP Bureau of Permits Management CN 029 Trenton, New Jersey 08625-0029 Attn. Monitoring Reports

B. In addition, a duplicate signed copy of all other monitoring reports required from the permittee including the DMRs shall be submitted to the DRBC (only for dischargers to the Delaware River Basin), and the ISC (only for dischargers to the Interstate Sanitation Commission district), at the following addresses:

Delaware River Basin Commission P.O. Box 7360 West Trenton, New Jersey 08628 Atm: Executive Director Interstate Sanitation Commission 311 West 43rd Street New York, New York 10036 Attn: Director/Chief Engineer

Sampling Points

All samples shall be taken at the monitoring points specified in this permit and, unless otherwise specified, before the effluent joins or is diluted by any other wastestream, body of water or substance. Monitoring points shall not be changed without noification to and the approval of the Department.

Stormwater Only Discharges

Stormwater shall be sampled during the first precipitation event of the monitoring period which causes a discharge at the site during working hours, unless otherwise directed in the permit. Stormwater monitoring should not necessarily be conducted at 30-day intervals. Therefore, it is incorrect for the permittee to choose a sampling date which remains the same every month, and report "NODI" on the DMR if it does not rain on that particular day.

08 24 94

Part I-DSW Page 5 of 6

D. "NPDES Compliance Sampling Manual". U.S. Environmental Protection Agency. Office of Water Enforcement, Publication MCD-51, 1977, 140 pp. (Available from the General Services Administration (8FFS), Centralized Mailing Lists Services. Building 41. Denver Federal Center. Denver CO 80225.)

Oil and Grease Effluent Limitations

Oil & Grease and/or Petroleum Hydrocarbons samples shall be collected and analyzed in accordance with N.J.A.C. 7:14A-14.1 et sec.

Section G. ADDITIONAL DEFINITIONS

"Aliquot" means an individual sample of specified volume used to make up a total composite sample.

"Annual monitoring" means monitoring conducted at a minimum frequency of once every calendar year. beginning with the Effective Date of the Permit unless there is a different period specified in the permit.

"CoV100 mL" means the coliform colonies per 100 milliliters.

"Composite Sample" means a combination of individual (or continuously taken) samples (aliquots) of at least 100 milliliters, collected at periodic intervals over a specified time period. The composite can be either time proportional or flow proportional; either the time interval between each aliquot or the volume of each aliquot should be proportional to either the flow at the time of sampling or the total flow since the collection of the previous aliquot. Aliquots may be collected manually or automatically. For intermittent discharges of less than four (4) hours duration, aliquots shall be taken at intervals not to exceed 15-minutes. For intermittent discharges of four (4) hours or more duration, aliquots shall be taken at intervals not to exceed 30-minutes.

"Daily Monitoring" means monitoring conducted every day, including weekends and holidays.

"EDP" means Effective Date of the Permit.

"EDP.M" means Effective Date of the Permit Modification

"g/day" means grams per day

"kg/d or kg/day" means kilograms per day.

"Maximum Value" means the highest value measured during the monitoring period.

"mg/L" means milligrams per liter.

"Minimum Value" means the lowest value measured during the monitoring period.

"Monthly Monitoring" means monitoring conducted at a minimum of once every calendar month, beginning with the EDP unless there is a different period specified in the permit.

"Multiple Grab Composite" means a combination of individual samples (aliquots) collected at a specified frequency over a specified time period. Each aliquot must be collected in a glass vial with a septum cap and iced until delivered for analysis. An air space should remain in the vial. Each aliquot shall be analyzed individually. The recorded value will be the flow proportioned average of the individual analyses for the specific time period.

"Quarterly Monitoring" means monitoring conducted at a minimum frequency of once every three calendar months, beginning, with the EDP unless there is a different period specified in the permit.

08 24 94

Part II-B/C Page 1 of 2

ADDITIONAL STANDARD CONDITIONS FOR ALL NJPDES/DSW PERMITS FOR INDUSTRIAL DISCHARGES

1. Permit Conditions Relating to Treatment Works

A Treatment Works Approval (TWA) Permit is required prior to the construction, operation, or modification of a treatment works pursuant to NJ.A.C. 7:14A-22.1 et seq. and the amendments thereto. Applications for a TWA Permit shall be submitted to the following address:

New Jersey Department of Environmental Protection Division of Water Quality Bureau of Construction and Connection Permits CN-029, Trenton, New Jersey 08625-0029 Attn: Chief

The operation of the treatment works shall be under the supervision of a licensed operator with the appropriate operator's classification in accordance with the "Rules Governing the Examination and Licensing of Operators", N.J.A.C. 7:10-13.1 et seq., which became effective July 2, 1984. The licensed operator shall meet the requirements of the TWA Permit pursuant to the provisions of N.J.S.A. 58:11-64 and the amendments thereto.

2. Permit Conditions Relating to Industrial Residuals Management

Α.

Collected grit and screenings, scums, sand bed sands, slurries, and sludges, and all other solids from the treatment process shall be managed in such a manner as to prevent such materials form entering the ground and/or surface waters of the State except in accordance with the NJPDES permit. If for any reason such materials are placed in the water or on the lands where they may cause pollutants to enter the ground and/or surface waters of the State or for any other noncompliance which may endanger public health or the environment, the following information shall be reported to the Water and Hazardous Waste Enforcement Element and to the Bureau of Pretreatment and Residuals pursuant to the requirements as outlined under NJ.A.C. 7:14A-2.5(a)(14):

(i) Dates of occurrence;

(ii) A description of the non-complying discharge (nature and volume);

(iii) Cause of noncompliance;

(iv) Steps taken to reduce and eliminate the non-complying discharge; and

(v) Steps taken to prevent recurrence of the condition of noncompliance.

B. The permittee shall not be permitted to store sludge on-site beyond the capacity of the structural treatment and storage components of the treatment works nor shall the permittee be permitted to store residual on-site in any manner which is not in accordance with Solid Waste Management Rules, NJA.C. 7:26.

C. The permittee shall comply with the Sludge Quality Assurance Regulations, N.J.A.C. 7:14-4. Where quality information is required by these regulations, analyses must reflect the quality of the final sludge product which the permittee must remove.

Page 1 of 3	15 Pages 👘
Part III-B	/c .
NJ0005550	
Modified:	DEC 0 1 1996

() 1.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning EDP and lasting through EDP + five (5) years, the permittee is authorized to discharge main condenser non-contact cooling water from outfall serial number: DSN 001.

There shall be no discharge of floating solids or visible foam in other than trace amounts. There shall be no visible sheen. There shall be no discharge of Polychlorinated Biphenyl Compounds (PCBs).

The abbreviation "N/A" in the table below denotes "Not Applicable" while the 'abbreviation "NL" denotes "Not Limited" with both monitoring and reporting required.

Samples taken in compliance with the specified monitoring requirements shall be taken at the outfall of DSN 001 for thermal parameters, and in the main condenser discharge tunnel just east of the chlorine monitor shed prior to the outfall or at the outfall of DSN 001 for all other parameters, and reported monthly.

PARAMETER	DISCHARGE LIMITATIONS			MONITORING REQUIREMENTS		
	DAILY	MONTHLY	DAILY	······································	SAMPLE	
	MIN	¥VG	XAX	FREQUENCY [6]] TYPE	
Flow, MGD	N/A	NL.	NL	Continuous	Calculated	
Temperature-Intake °C(°F)	N/A	N/A	NL	Continuous	Grab	
<pre>Temperature-Effluent</pre>	N/A	NL	41.1(106)	Continuous	Grab	
Temperature-Effluent °C(°F) [2,3]	N/A	nl	43.3(110)	Continuous	Grab	
Temperature-Diff. °C(°F) [1]	N/A	NL	12.8(23)	Daily	Calculated	
Temperature-Diff. oC(op) [2,3]	N/A	NL	18.3(33)	Daily	Calculated	
Heat Addition MBTU/hr [1]	N/A	NL	5420	Daily	Calculated	
Heat Addition MBTU/hr [2,3]	N/A	NL	5700	Daily	Calculated	
Chlorine-Total Residual mg/l(kg/d) ^[4]	N/A	NL	0.2(41.7)	Daily	Grab	
TBCCW HX- Chlorine, Total Residual. mg/1[7]	N/A	NL	0.2	Daily	Grab	
pH, Intake S.U.	NL	N/A	NL	2/Week	Grab	
pH, Effluent S.U.	6.5[5]	N/A	8,5[5]	2/Week	Grab	
Intake Velocity, fps	NL	NL	2.2	See Part TV-B/C		
Acute Toxicity, LC50 * effluent	NL	N/A	N/A	Annually	See Part IV-B/C	

See footnotes on next page

()

:

Page 2 of 15 Pages Part III-B/C NJ0005550

1.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS continued

- Applies when four (4) circulating pumps are operating for condenser cooling.
 Applies during periods of condenser backwash or during intake component maintenance. The NJPDES Regulations require the permittee to maintain its plant in good working order and efficient operation. Preventive or corrective maintenance of any plant intake component (e.g. circulating water pumps and appurtenant equipment, traveling screens and appurtenant equipment, intake ports, etc.) may, therefore, be required. This maintenance could restrict velocity and/or which could have an effect on any one or a combination of the following: 1) maximum discharge temperature, 2) delta temperature or AT, and 3) heat addition.
- [3] Applies during an Emergency Need for Power which is defined as a situation in which the Pennsylvania-New Jersey-Maryland Interconnection has notified Jersey Central Power & Light Company (JCP4L) that it is unlikely to meet its load demand although the system has attempted to satisfy the load requirement by operating available generation. In the event of such a situation JCP4L System Operations would contact Oyster Creek Nuclear Generating Station to assist in meeting the load demand and only after the following measures have been initiated: 1) all maximum emergency generation has been ordered to run; 2) all controllable load management curtailment orders have been issued; 3) a voltage reduction of 5% has been ordered; and 4) voluntary customer load curtailment has been issued. Within eight (8) hours of an Emergency Need for Power being declared the permittee must notify the Department by telephone declaring that the Station has invoked the use of the alternate thermal limits of the Permit. The Station of an Emergency Need for Power: the time and date of the telephone notification to the Department, the time and date the Station actually invoked relief under this permit condition, and the time and date it terminated such relief.
- [4] Total Residual Chlorine may not be discharged from any single generating unit for more than two hours in one day. Note: There is only one unit.
 [5] The pH shall not be less than 6.5 Standard Units (S.U.) nor greater than 8.5
- The pH shall not be less than 6.5 Standard Units (S.U.) nor greater than 8.5 S.U.; or, during periods when the pH of the intake water is less than 6.5, the pH of the effluent shall not be less than that of the intake; or, during periods when the pH of the intake water is greater than 8.5, the pH shall not be greater than that of the intake.
- [6] Monitoring of these parameters is not required when there is no flow and/or heat load across the Station's main condensers.

÷۰

[7] Daily grab sample shall be taken for Total Residual Chlorine during periods of chlorination of the Turbine Building Closed Cooling Water Heat Exchanger.

. .

Page 3 of 15 Pages Part III-B/C NJ0005550

1. B. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning EDP and lasting through EDP + five (5) years, the permittee is authorized to discharge heat exchanger non-contact cooling water from outfall serial number: DSN 002.

There shall be no discharge of floating solids or visible foam in other than trace amounts. There shall be no visible sheen. There shall be no discharge of Polychlorinated Biphenyl Compounds (PCBs).

The abbreviation "N/A" in the table below denotes "Not Applicable" while the abbreviation "NL" denotes "Not Limited" with both monitoring and reporting required.

Samples taken in compliance with the specified monitoring requirements shall be taken from the common header located on the 23 foot elevation of the New Radwaste Heat Exchanger Room prior to the outfall of DSN 002, and reported monthly.

PARAMETER	DISCHAR	DISCHARGE LIMITATIONS			REQUIREMENTS
	DAILY MIN	MONTHLY AVG	DAILY	FREQUENCY	Sample Type
Flow, MGD	N/A	NL	NL	2/month	Calculated
Temperature-Intake °C(°F)	N/A	N/A	NL	2/month	Grab
Temperature-Effluent °C(°F)	N/A	NL	45(113)	2/month	Grab
Temperature-Diff. °C(°F)	N/A	NL	18.3(33)	2/month	Calculated
Heat Addition MBTU/hr	N/A	NL	790	2/month	Calculated
Chlorine-Total Residual	N/A	NL	0.2	2/month	Grab
pH, Intake S.U.	NL	N/A	NL	2/week	Grab
pH. Effluent S.V.	6.5[1]	N/A	8.5[1]	2/week	Grab
Acute Toxicity, LC50 % effluent	NL	N/A	N/A .	Quarterly	See Part IV-B/C
Chronic Toxicity, NOEC	NL.	N/A	N/A	Quarterly	See Part IV-B/C

[1] The pH shall not be less than 6.5 Standard Units (S.U.) nor greater than 8.5 S.U.; or, during periods when the pH of the intake water is less than 6.5, the pH of the effluent shall not be less than that of the intake; or, during periods when the pH of the intake water is greater than 8.5, the pH shall not be greater than that of the intake.

Page 4 of 15 Pages Part III-B/C NJ0005550

1.C. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning EDP and lasting through EDP + five (5) years, the permittee is authorized to discharge stormwater runoff, non-contact cooling water from reactor building and emergency service water heat exchangers, and discharge from the 1-5 sump from outfall serial number: DSN 004.

There shall be no discharge of floating solids or visible foam in other than trace amounts. There shall be no visible sheen. There shall be no discharge of Polychlorinated Biphenyl Compounds (PCBs).

The abbreviation "N/A" in the table below denotes "Not Applicable" while the abbreviation "NL" denotes "Not Limited" with both monitoring and reporting required.

Samples taken in compliance with the specified monitoring requirements shall be taken at the sample pipe located inside the fence near the terminus of the 30" header or at the outfall of DSN 004 (depending upon on-site conditions) and reported monthly. . •

PARAMETER	DISCHARGE LIMITATIONS			MONITORING REQUIREMENTS		
	DAILY	MONTHLY	DAILY		SAMPLE	
	min	λVG	MAX	FREQUENCY	TYPE	
Effluent Flow, MGD	N/A	NL	NL	Monthly	Calculated	
Heat Exchanger Flow, MGD	N/A	NL	NL '	Monthly	Calculated	
Net Flow, MGD [1]	N/A	NL ·	NL ·	Monthly	Calculated	
Temperature-Effluent °C(°F)	N/A	NL	37.2 (99)	Monthly	Grab	
Chlorine-Total Residual mg/1	N/A	NL	0.2	Monthly	Grab	
Influent TSS, mg/l (kg/d)	N/A	NL(NL)	NL(NL)	Monthly	Grab	
Effluent TSS, mg/l (kg/d)	N/A	NL(NL)	NL(NL)	Monthly	Grab	
Net TSS, mg/1 (kg/d) [1]	N/A	30 (NL)	100 (22.7)	Monthly	Calculated	
<pre>Influent Petr. Hydrocarbons mg/l (kg/d)</pre>	N/A	NL(NL)	NL(NL)	Monthly	Grab ·	
Effluent Petr. Hydrocarbons mg/l (kg/d)	N/A	NL (NL)	NL(NL)	Monthly	Grab	
Net Petroleum Hydrocarbons mg/l (kg/d) [1]	N/A	10(NL)	15(4.54)	Monthly	Calculated	
pH, Intake S.U.	NL	N/A	NL	Weekly	Grab	
pH, Effluent S.U.	6.0[2]	N/A	9.0[2]	Weekly	Grab	
TOC, mg/1	N/A	NL	50	Monthly	Grab	
Acute Toxicity, LC50 9 effluent	NL	N/A	N/A ·	Quarterly	See Part IV-B/C	
Chronic Toxicity, NOEC % effluent	NL	N/A .	N/A	Quarterly	See Part IV-B/C	

[1] Net Flow shall be used for the purposes of calculating <u>loading values only</u>:

Net Flow shall be used for the purposes of calculating <u>autually relate cally</u>. $Q_{net} = Q_{effluent} - Q_{heat}$ exchanger Concentration net values should be calculated as per the DMR Manual. The pH shall not be less than 6.0 Standard Units (S.U.) nor greater than 9.0 S.U.; or, during periods when the pH of the intake water is less than 6.0, the pH of the effluent shall not be less than that of the intake; or, during periods that the PH of the intake intake; or, during [2] period when the pH of the intake water is greater than 9.0, the pH shall not be greater than that of the intake.

Page 5 of 15 Pages Part III-B/C NJ0005550

1.D. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning EDP and lasting through EDP + five (5) years, the permittee is authorized to discharge dilution pump discharge water from outfall serial number: DSN 005.

There shall be no discharge of floating solids or visible foam in other than trace amounts. There shall be no visible sheen. There shall be no discharge of Polychlorinated Biphenyl Compounds (PCBs).

The abbreviation "N/A" in the table below denotes "Not Applicable" while the abbreviation "NL" denotes "Not Limited" with both monitoring and reporting required.

Samples taken (calculated) in compliance with the specified monitoring requirements shall be reported monthly.

PARAMETER	DISCHAR	GE LIMITAT	TIONS	MONITORING REQUIREMENTS				
	DAILY MIN	MONTELY AVG	DAILY MAX	FREQUENCY	Sample Type			
Flow, MGD	N/A	NL	NL	Continuous	Calculated			

The pH of the effluent shall not be less than 6.5 S.U. nor greater than 8.5 S.U.; or, during periods when the pH of the intake water is less than 6.5, the pH of the effluent shall not be less than that of the intake; or, during periods when the pH of the intake water is greater than 8.5, the pH shall not be greater than that of the intake. However, no monitoring or reporting is required.

Page 6 of 15 Pages Part III-B/C NJ0005550

1.E. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning EDP and lasting through EDP + five (5) years, the permittee is not authorized to discharge from DSN 006.

This discharge has ceased. There shall be no discharge from this outfall.

All limitations and conditions for this outfall have been deleted.

Page 7 of 15 Pages Part III-B/C NJ0005550

1.F. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning EDP and lasting through EDP + five (5) years, the permittee is authorized to discharge dilution pump seal water from the oil/water separator from outfall serial number: DSN 007.

There shall be no discharge of floating solids or visible foam in other than trace amounts. There shall be no visible sheen. There shall be no discharge of Polychlorinated Biphenyl Compounds (PCBs).

The abbreviation "N/A" in the table below denotes "Not Applicable" while the abbreviation "NL" denotes "Not Limited" with both monitoring and reporting required.

Samples taken in compliance with the specified monitoring requirements shall be taken at the north side of the dilution pump structure at the outfall of DSN 007, and reported monthly.

DISCHA	RGE LIMITA	TIONS	MONITORING REQUIREMENTS			
DAILY	MONTHLY	DAILY	FREQUENCY	SAMPLE		
MIN	AVG	MAX		TYPE		
N/A	NL	NL	Monthly	Calculated		
N/A	10	15	Monthly	Grab		
	DISCHA	DISCHARGE LIMITA	DISCHARGE LIMITATIONS	DISCHARGE LIMITATIONS		
	DAILY	DAILY MONTHLY	DAILY MONTHLY DAILY	DAILY MONTHLY DAILY		
	MIN	MIN AVG	MIN AVG MAX	MIN AVG MAX FREQUENCY		
	N/A	N/A NL	N/A NL NL	N/A NL NL Monthly		
	N/A	N/A 10	N/A 10 15	N/A 10 15 Monthly		

The pH of the effluent shall not be less than 6.0 S.U. nor greater than 9.0 S.U.; or, during periods when the pH of the intake water is less than 6.0, the pH of the effluent shall not be less than that of the intake; or, during periods when the pH of the intake water is greater than 9.0, the pH shall not be greater than that of the intake. However, no monitoring or reporting is required.

Page 8 of 15 Pages Part III-B/C NJ0005550

1.G. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning EDP and lasting through EDP + five (5) years, the permittee is authorized to discharge screen and strainer washwater discharge from outfall serial number: DSN 008.

There shall be no discharge of floating solids or visible foam in other than trace amounts. There shall be no visible sheen. There shall be no discharge of Polychlorinated Biphenyl Compounds (PCBs).

The abbreviation "N/A" in the table below denotes "Not Applicable" while the abbreviation "NL" denotes "Not Limited" with both monitoring and reporting required.

Samples taken in compliance with the specified monitoring requirements shall be taken at the outfall of DSN 008 and reported monthly.

PARAMETER	DISCH	RGE LIMITA	TIONS	MONITORING REQUIREMENTS				
·	DAILY MIN	MONTHLY AVG	DAILY MAX	FREQUENCY	SAMPLE Type			
Flow, MGD	N/A	NL	NL	Monthly	Calculated			

The pH of the effluent shall not be less than 6.5 S.U. nor greater than 8.5 S.U.; or, during periods when the pH of the intake water is less than 6.5, the pH of the effluent shall not be less than that of the intake; or, during periods when the pH of the intake water is greater than 8.5, the pH shall not be greater than that of the intake. However, no monitoring or reporting is required.

Page 9 of 15 Pages Part III-B/C NJ0005550

1.H. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning EDP and lasting through EDP + five (5) years, the permittee is authorized to discharge effluent from the fish sampling pool from outfall serial number: DSN 009.

There shall be no discharge of floating solids or visible foam in other than trace amounts. There shall be no visible sheen. There shall be no discharge of Polychlorinated Biphenyl Compounds (PCBs).

The abbreviation "N/A" in the table below denotes "Not Applicable" while the abbreviation "NL" denotes "Not Limited" with both monitoring and reporting required.

Samples taken in compliance with the specified monitoring requirements shall be taken at the outfall of DSN 009 and reported monthly.

PARAMETER	DISCH	RGE LIMITA	TIONS	MONITORING REQUIREMENTS			
	DAILY MIN	MONTHLY AVG	DAILY	FREQUENCY	Sample Type		
Flow, MGD	N/A	NL	NL	Monthly	Calculated		

The pH of the effluent shall not be less than 6.5 S.U. nor greater than 8.5 S.U.; or, during periods when the pH of the intake water is less than 6.5, the pH of the effluent shall not be less than that of the intake; or, during periods when the pH of the intake water is greater than 8.5, the pH shall not be greater than that of the intake. However, no monitoring or reporting is required.

Page 10 of 15 Pages Part III-B/C NJ0005550

.

1.I. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

. .

During the period beginning EDP and lasting through EDP + five (5) years, the permittee is not authorized to discharge from DSN 010.

•

.

. This discharge has ceased. There shall be no discharge from this outfall.

All limitations and conditions for this outfall have been deleted.

.

Page 11 of 15 Pages Part III-B/C NJ0005550

1. J. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning EDP and lasting through EDP + five (5) years, the permittee is authorized to discharge stormwater from the oil/water separator associated with the Combustion Turbine Facility, demineralizer water system drains, and other treated stormwater from outfall serial number: DSN 012 (former Forked River DSN 012).

There shall be no discharge of floating solids or visible foam in other than trace amounts. There shall be no visible sheen. There shall be no discharge of Polychlorinated Biphenyl Compounds (PCBs).

The abbreviation "N/A" in the table below denotes "Not Applicable" while the abbreviation "NL" denotes "Not Limited" with both monitoring and reporting required.

Samples shall be taken during the first precipitation event of the month which causes a discharge during working hours unless otherwise noted.

Samples taken in compliance with the specified monitoring requirements shall be taken at the outfall of DSN 012 and reported monthly.

PARAMETER	DISCH	RGE LIMITA	TIONS	MONITORING REQUIREMENTS			
	DAILY MIN	MONTELY AVG	DAILY MAX	FREQUENCY [1]	SAMPLE TYPE		
Flow, MGD	N/A	NL	NL	Monthly	Calculated		
pH, S.U.	6.0	N/A	9.0	Monthly	Grab		
COD, mg/l	N/A	NL	100	Monthly	Grab		
TSS, mg/l	N/A	NL	50	Monthly	Grab		
Petroleum Hydrocarbons, mg/l	N/A	NL	15	Monthly	Grab		

[1] Samples shall be taken during the first precipitation event of the month which . causes a discharge during working hours and which is preceded by a minimum dry period of 72 hours.

Page 12 of 15 Pages Part III-B/C NJ0005550

1.K. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning EDP and lasting through EDP + five (5) years, the permittee is authorized to discharge stormwater from outfall serial number: DSN 013 (former Forked River DSN 004).

÷. •.

There shall be no discharge of floating solids or visible foam in other than trace amounts. There shall be no visible sheen. There shall be no discharge of Polychlorinated Biphenyl Compounds (PCBs).

The abbreviation "N/A" in the table below denotes "Not Applicable" while the abbreviation "NL" denotes "Not Limited" with both monitoring and reporting required.

Samples shall be taken during the first precipitation event of the month which causes a discharge during working hours unless otherwise noted.

Samples taken in compliance with the specified monitoring requirements shall be, taken at the outfall of DSN 013 and reported monthly.

PARAMETER	DISCH	RGE LIMITA	TIONS	MONITORING REQUIREMENTS			
	DAILY MIN	MONTELY	DAILY MAX	FREQUENCY [1]	SAMPLE TYPE		
Flow, MGD	N/A	NL	NL	Monthly	Calculated		
pH, S.U.	6.0	N/A	9.0	Monthly	Grab		
COD, mg/l	N/A	NL	100	Monthly	Grab		
TSS, mg/l·	N/A	NL	50	Monthly	Grab		
Petroleum Hydrocarbons, mg/l	N/A	NL	15	Monthly	Grab		

[1] Samples shall be taken during the first precipitation event of the month which causes a discharge during working hours and which is preceded by a minimum dry period of 72 hours.

Page 13 of 15 Pages Part III-B/C NJ0005550 L MALI

1.L. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning EDP and lasting through EDP + five (5) years, the permittee is authorized to discharge stormwater from outfall serial number: DSN 014 (former Forked River DSN 007).

There shall be no discharge of floating solids or visible foam in other than trace amounts. There shall be no visible sheen. There shall be no discharge of Polychlorinated Biphenyl Compounds (PCBs).

The abbreviation "N/A" in the table below denotes "Not Applicable" while the abbreviation "NL" denotes "Not Limited" with both monitoring and reporting required.

Samples shall be taken during the first precipitation event of the month which causes a discharge during working hours unless otherwise noted.

Samples taken in compliance with the specified monitoring requirements shall be taken at the outfall of DSN 014 and reported monthly.

PARAMETER	DISCHA	RGE LIMITA	TIONS	MONITORING REQUIREMENTS			
	DAILY MIN	MONTHLY AVG	DAILY	FREQUENCY [1]	SAMPLE TYPE		
Flow, MGD	N/A	NL	NL	Monthly	Calculated		
pH, S.U.	6.0	N/A	9.0	Monthly	Grab		
COD, mg/l	N/A	NL	100	Monthly	Grab		
TSS, mg/l	N/A	NL	50	Monthly	Grab		
Petroleum Hydrocarbons, mg/l	N/A	NL	15	Monthly	Grab		

[1] Samples shall be taken during the first precipitation event of the month which causes a discharge during working hours and which is preceded by a minimum dry period of 72 hours.

Page 14 of 15 Pages Part III-B/C NJ0005550

2. TOXIC POLLUTANT REOPENER CLAUSE .

Pursuant to N.J.A.C. 7:14A-3.13(a) (3) (iv), the Department may modify or revoke and reissue any permit to incorporate limitations or requirements to control the discharge of toxic pollutants, including whole effluent, chronic and acute toxicity requirements, chemical specific limitations or toxicity reduction requirements, as applicable.

3. USE OF BIOCIDES OR OTHER COOLING WATER ADDITIVES

The permittee uses the following corrosion inhibitors, biocides, or other cooling water additives in its cooling water at the time of permit issuance:

DSN 001: Sodium hypochlorite is used in the main condenser and the Turbine Building Closed Cooling Water Heat Exchanger to control macroinvertebrate fouling.

DSN 002: Chlorine gas is used in the treatment of cooling water for both the new radwaste system heat exchangers and augmented off-gas heat exchanger cooling water.

DSN 004: Sodium hypochlorite is used in the Reactor Building Closed Cooling Water Heat Exchanger and the Emergency Service Water Heat Exchanger cooling water.

If the permittee decides to begin using or change any of these agents in the future, the permittee must notify the Department at least 180 days prior to use so that the permit may be reopened to incorporate any additional limitations deemed necessary.

4. MODIFICATION OF MONITORING REQUIREMENTS

The permittee may request a modification of their permit to decrease monitoring frequencies for limited parameters if site specific conditions indicate applicability of such a modification. The Department will consider reducing the monitoring frequency of a limited parameter provided that:

- ELGs applicable to the facility do not specify the required monitoring frequency;
- 2) the frequency reduction conditions are included in the public notice of the draft permit.
- 3) the permittee has shown consistent compliance with all permit conditions for the affected parameter(s) for:

Page 15 of 15 Pages Part III-B/C NJ0005550

- a minimum period of one (1) year for a a) monitoring frequency of weekly;
- a minimum period of two (2) years for a monitoring frequency of twice per month; a minimum period of three (3) years for a b)
- c) monitoring frequency of monthly;
- a minimum period of five (5) years for a d) monitoring frequency of quarterly; and a minimum period of four tests for Whole
- e) Effluent Toxicity (WET) limitations;
- 4) A monitoring frequency can be reduced as follows:
 - from weekly to monthly; a)
 - b) from twice monthly to monthly;
 - from monthly to quarterly; or C)
 - d) from quarterly to semi-annually or annually.
- 5) For WET limitations, monitoring frequencies can be reduced as follows:
 - a) a minimum of twice per year for major dischargers; and
 - b) a minimum of annually for minor dischargers.

Reduction of monitoring frequency is not automatic; the Department shall determine whether or not a reduction is warranted. The Discharge Monitoring Reports (DMRs) shall be reviewed to verify consistent compliance with permit limitations and conditions for the affected parameter(s). If the Department agrees to grant the request, the Department will perform a conditional change to the permit to change the monitoring frequency of the affected parameters.

The monitoring frequency for the affected parameters cannot be reduced below annual frequency, in accordance with N.J.A.C. 7:14A-3.13.

Page 1 of 12 Pages Part IV-B/C NJ0005550

ADDITIONAL REQUIREMENTS OF THIS PERMIT

1. TOXICITY TESTING REQUIREMENTS

The permittee shall conduct Acute and Chronic toxicity tests on its wastewater discharge DSN 001, DSN 002 and DSN 004 in accordance with the provisions in this section. Such testing will determine if appropriately selected effluent concentrations adversely affect the test species.

A. Acute Toxicity Testing Requirements

Acute toxicity tests shall be conducted using the Mysid (*Mysidopsis bahia*), 96 hr test. Any test that does not meet the specifications of N.J.A.C. 7:18-6, the laboratory certification regulations, must be repeated as soon as practicable within the monitoring period.

- B. Chronic Toxicity Testing Requirements
 - 1. Chronic toxicity testing shall consist of concurrent chronic toxicity tests, with two species on a split effluent sample. Chronic toxicity tests shall be conducted using the Sheepshead minnow (Cyprinodon variegatus), 7 day larval survival and growth test or Inland Silverside (Menidia beryllina), 7 day larval survival and growth test, and Mysid (Mysidopsis bahia) 7 day survival, growth and fecundity test. This chronic toxicity characterization study will be considered complete when four sets of acceptable concurrent tests, using split samples on the two species, have been completed and these data have been deemed sufficient to designate a more sensitive species for the discharge. If these data are deemed insufficient, testing shall · continue with two species until such designation is possible. If any test does not meet the specifications contained in the Department's "Interim Chronic Toxicity Testing Methodologies For Use In The NJPDES Permit Program" document, that set of concurrent split sample tests must be repeated as soon as practicable within the monitoring period. · .

Test results shall be expressed as both the NOEC (No Observable Effect Concentration), the LOEC (Lowest Observable Effect Concentration), and the IC25 for each test endpoint. Where a chronic toxicity testing methodology yields NOECs/IC25s from more than one test endpoint, the most sensitive endpoint will be used to determine permit compliance.

C. The monitoring frequency for acute/chronic toxicity shall be one test every permit quarter. The first test shall be conducted no later than EDP + 3 months.

2.

Page 2 of 12 Pages Part IV-B/C NJ0005550

D. Reporting Requirements

- 1. The information specified below shall be submitted, to the address in paragraph D.1.b., within EDP + two months. This information must also be resubmitted within two months of a change of contract laboratory.
 - a. A fully completed "Methodology Questionnaire for Acute Toxicity Tests," form and a completed "Methodology Questionnaire for Chronic Toxicity Tests," which includes an identification of the toxicity testing laboratory responsible for the testing. Copies of these forms are provided to certified laboratories, and may also be obtained by contacting the address below.
 - b. Acute and Chronic toxicity test results shall be reported on the "NJPDES Biomonitoring Report Form - Acute Bioassays," and the "NJPDES Biomonitoring Report Form - Chronic Toxicity Tests", copies of which are provided to certified laboratories. Copies of these report forms may also be obtained by contacting the address below. <u>TWO</u> COPIES of each completed report form shall be submitted within 60 days of test completion to:

Division of Water Quality, Bureau of Standard Permitting CN-029 Trenton, New Jersey 08625 Attention: Industrial Biomonitoring Program

c. The test results shall also be reported on the permittee's Discharge Monitoring Report (DMR) for the monitoring period during which the test was conducted.

2. EFFLUENT CHARACTERIZATION STUDY

An Effluent Characterization Study is required for the monitoring locations and pollutants listed below as these pollutants have the potential to be present due to the nature of the facility and/or materials used. Based on all available information, there is insufficient data to substantiate whether or not certain pollutants are present in the discharge and at what levels. The results of the Effluent Characterization Study will be used to make a determination on whether to impose numerical limitations on these pollutants.

A. Monitoring Locations, Pollutants, and Sample Types

The permittee shall sample outfall DSNs 001, 002, 004, and the 1-5 Sump prior to combining with other wastewaters discharged through DSN 004.

Page 3 of 12 Pages Part IV-B/C NJ0005550

DSN 001 shall be analyzed for the following parameters:

Total Organic Carbon (TOC)
Total Suspended Solids (TSS)
Petroleum Hydrocarbons
Beryllium ·
Cadmium
Chromium
Copper
Nickel
Silver
Zinc

.

÷

.

.

DSN 002 shall be analyzed for the following parameters:

Total Organic Carbon (TOC)
Total Suspended Solids (TSS)
Petroleum Hydrocarbons
Beryllium
Cadmium
Chromium
Copper
Nickel
Silver
Zinc
Di-N-Butyl Phthalate

DSN 004 shall be analyzed for the following parameters:

Beryllium	: ·		· ·	•				•	
Cadmium									
Chromium									
Copper					·				
Nickel									
Silver			•	·		•			
Zinc		:	•				'	•	
Di-N-Butyl Phthalat	e' ·			•					•
· · · · · ·	î .			•					

• ..

The 1-5 Sump shall be analyzed for the following parameters:

Total Organic Carbon (TOC)	
Total Suspended Solids (TSS)	
Petroleum Hydrocarbons	
pH	
Appendix I Metals and Cyanide;	

Page 4 of 12 Pages Part IV-B/C NJ0005550

Appendix I Base/Neutral Compounds; Appendix I Acid Compounds; Appendix I Volatile Compounds;

All samples shall be grab samples.

Monitoring for each location is required in accordance with N.J.A.C. 7:14A-3.14. All data collected from the Study shall be in accordance with <u>Part IV-B/C(2)(C)</u>, Recommended Quantitation Levels.

В.

Compliance Dates and Sampling Frequency

The Effluent Characterization Study shall be performed between EDP and EDP + 4 years. A total of 12 samples for each of the parameters listed above shall be collected over the Study time period. Ideally, samples should be collected on a quarterly basis. However, due to facility discharge variables, samples may be taken more or less frequently than quarterly, as long as a total of 12 samples are collected and the time period between samples is no less than 1 month and no greater than 6 months.

The permittee shall submit to the Department an Effluent Characterization Study Report summarizing the data collected by outfall/sampling point for each parameter. The permittee shall submit copies of all laboratory data sheets attached to the summary report. The final report shall be submitted within 180 days prior to permit expiration.

C. Recommended Quantitation Levels

The Department, in order to ensure useful data to characterize the permittee's wastewaters, has developed the Recommended Quantitation Levels (RQLs) in Appendix I of this Part. The Department has determined that the quantitation levels listed therein can be reliably achieved by most State certified laboratories for the listed pollutants using the appropriate procedures specified in 40 CFR 136.

Effluent Characterization data are considered adequate where the detection levels achieved are at least as sensitive as the RQLs in Appendix I. The quantitation levels listed in Appendix I are to be used by the permittee and its contract laboratory as a guideline of the quantitation levels the Department will accept without additional explanation and/or review. Less sensitive levels may be acceptable, but will require a detailed explanation on the part of the permittee and/or contract laboratory and a more detailed review on the part of the Department. Where no RQL is furnished (N/A), the RQL shall be five times the value achieved by the laboratory.

÷.

Page 5 of 12 Pages Part IV-B/C NJ0005550

If the permittee or laboratory believes or determines that the detection levels achieved for any pollutant or pollutants generally will not be as sensitive as those specified in Appendix I, a justification for a less sensitive detection level is required to be submitted to the Department. Pollutants that are detected but not quantified must be reported as such.

D. Deletion of Parameters from the Study

If a parameter is shown to be consistently less than the recommended quantitation level (<RQL and/or "not detectable" -see Part IV-B/C(2)(C)) utilizing an approved methodology and detection level, in a minimum of four consecutive analyses, the monitoring for that parameter may be discontinued from the Study. Additionally, for once-through cooling water only, a sample may count as non-detect towards discontinuance from the Effluent Characterization Study only if the parameter is detected in the influent and is either non-detect in the effluent or detected in the effluent at the same level as or less than the influent.

If a parameter is detected in one out of the first five sets of samples in the same order of magnitude as the RQL, and the permittee has reason to believe that the detection is "unwarranted" the permittee may submit a request in writing to the Department to request deletion of the parameter from the Study. However, this parameter should continue to be included in the Study until response is received from the Department.

For priority pollutant scans, if a single (or several) parameter(s) (except for pollutants of concern) is detected in one of the first four sets of samples of a particular scan, and the permittee has reason to believe that the detection(s) is "unwarranted", the scan should be continued as a part of the Study, and data for <u>all</u> parameters in the scan should continue to be submitted, even though other parameters were eligible for deletion from the Study. The permittee may submit a request for deletion of the entire scan from the Study, as above, but should continue to perform the scans until approval is received from the Department.

: 1

E. Correspondence

All submittals for the above studies shall be sent to:

··· •

Bureau of Standard Permitting Division of Water Quality CN-029 Trenton, NJ 08625-0029

Oyster Creek Generating Station License Renewal Application Page B-27

Page 6 of 12 Pages Part IV-B/C NJ0005550

3. DILUTION STUDY

- A. To enable the Department to determine the need for Water Quality-Based Effluent Limitations in conjunction with the Chronic Toxicity Characterization Study, the permittee is required to perform a Dilution Study for outfall DSNs 001, 002, and 004.
- B. The procedures for these studies must be in accordance with the Department's "Mixing Zone Implementation Policies for the Discharge of Toxic Substances Into Tidally Influenced Waters" (Part IV-B/C Appendix A).

A Dilution Study workplan shall be submitted within 180 days from the effective date of the permit EDP. The workplan must be approved by the Department prior to conducting the study.

- C. The permittee shall commence field work during the first designated "critical period" which occurs at least ninety (90) days after approval by the Department of the Dilution Study Work Plan(s). If a critical period exists during the 90 days after approval from the Department, the permittee is not precluded from commencing the Study during that period. The "critical periods" shall be defined in the Dilution Study Work Plan and is that period which produces the minimal dilution.
- D. The permittee shall submit to the Department a report of the results obtained from the Dilution Study within ninety (90) days of completion of the field work associated with the Dilution Study. The report shall be sent to the address in Section 2.E. above.

4. EFFLUENT TEMPERATURE EVALUATION STUDY

- A. Except as provided in Part IV-B/C (4)(B) below, the permittee shall conduct an Effluent Temperature Evaluation Study (ETES) as described in Part IV-B/C(4)(C) below if any maximum daily temperature readings at the Route 9 Bridge monitoring location exceed the temperature monitoring action level of 97°F. The ETES is intended to determine what caused the exceedances and to identify mitigation measures for meeting the monitoring action level for effluent water temperature within Oyster Creek at the Route 9 Bridge.
- B. When an exceedance occurs, the permittee shall:
 - Evaluate whether the exceedance of the temperature monitoring action level at the Route 9 Bridge monitoring location occurred solely as a result of any, or a combination of the following factors:
 - (a) unusually high influent temperature, i.e., any influent temperature in excess of 85°F,
Page 7 of 12 Pages Part IV-B/C NI0005550

- (b) Operation of the Dilution Pumps in accordance with Part IV-B/C(9),
- (c) Dilution Pump operation during the Dilution Pump Optimization Studies, or
- (d) Implementation of the alternate effluent limitations in accordance with Part III-B/C(1.A) of this permit

If the evaluation shows that any of the above factors caused the exceedance, the permittee need not conduct an ETES. However the permittee shall submit a report to the Department within ten (10) business days of the exceedance, which specifies the relationship of the exceedance to items(a) through (d) of Part IV-B/C(4)(B)(1) above. The report shall be submitted to the following address:

- Bureau of Standard Permitting Division of Water Quality CN-029
- Trenton, New Jersey 08625

When the temperature monitoring action level exceedance occurs and the cause cannot be attributed to the factors described in Part IV-B/C(4)(B)(1), then the permittee shall conduct an ETES in the following manner

- (1) The permittee shall evaluate the relationship of the following factors to the exceedance of the temperature monitoring action level of 97°F: Circulating Water Pump operation, Dilution Pump operation, plant power levels, heat rejection, effluent temperature at DSN 001, temperature at the Route 9 Bridge monitoring location, and the temperature differential across the main condenser for the date of the exceedance of the temperature monitoring action level as well as relevant periods prior to and following the exceedance.
- (2) A written report shall be prepared documenting the evaluation conducted in accordance with Part IV-B/C(4)(C)(1). The report shall include tabular and graphical presentation of daily maximum and average influent temperatures, effluent temperatures at DSN 001, Route 9 Bridge monitoring location temperatures, and the temperature differential across the main condenser. The report shall include an analysis and discussion of the cause of the exceedance and shall also include recommended mitigation measures.

С.

Page 8 of 12 Pages Part IV-B/C NJ0005550

- (3) If mitigation measures are identified that can be implemented while maintaining compliance with all other permit conditions, then the permittee is not required to obtain Department approval prior to implementation. Otherwise, Department approval will be required prior to implementation of mitigation measures or modification of the permit.
- (4) Two copies of all written submissions required above shall be sent to:

Bureau of Standard Permitting Division of Water Quality CN-029 Trenton, New Jersey 08625-0029

5. DILUTION PUMP OPTIMIZATION STUDIES

A. The permittee shall:

- (1) not later than EDP + six (6) months submit a Plan of Study to the Department for approval to identify the optimum operating schedule for the Station's dilution water system and corresponding temporal (i.e., months or other defined times) or other definite, reportable conditions (such as intake, discharge, and/or other temperatures); optimization shall be defined as minimization of the total loss of aquatic organisms due to impingement and entrainment at the Station at times when the risk of heat shock and/or cold shock fish kills is minimal;
- (2) not later than three (3) months after receipt of the Department's approval of the Plan of Study, implement the Plan of Study as approved by the Department and any conditions therein;
- (3) not later than twenty-one (21) months after the date of receipt of the Department's approval of the Plan of Study submit a Dilution Pump Optimization Study Report to the Department.

B. Reopener

The Department may modify or revoke and reissue this permit to incorporate limitations or conditions based on results of the Dilution Pump Optimization Study.

All correspondence and reports, in duplicate, shall be sent to:

Page 9 of 12 Pages Part IV-B/C NJ0005550

Bureau of Standard Permitting Division of Water Quality CN-029 Trenton, New Jersey 08625-0029

6. TEMPERATURE MONITORING AT ROUTE 9 BRIDGE (former Part II, Condition H)

The permittee shall continuously measure the temperature four (4) feet below the surface of Oyster Creek at the Route 9 Bridge.

7. FLOATING SOLIDS OR VISIBLE FOAM (former Part II, Condition B)

Except as specifically authorized in this permit, the permittee shall not discharge floating solids or visible foam, except such materials as are contained in the intake water. The causing of foam by agitation of the ambient water shall not be deemed a violation of this condition.

PLANT SHUTDOWN(S) (former Part II, Condition C)

·. ·

8.

- A. The permittee shall not schedule routine shutdowns during the months of December, January, February, and/or March.
- B. The permittee shall not schedule routine intake component (e.g. circulating water pumps and appurtenant equipment, traveling screens and appurtenant equipment, intake ports, etc.) maintenance which may cause violation of thermal limitations or intake velocity limitations during the months of June, July, August and/or September. The Department acknowledges that the NJPDES Regulations require the permittee to maintain its plant in good working order and efficient operation and, therefore, some intake component maintenance may be required.

9. DILUTION PUMP OPERATIONS (former Part II Condition D)

When the intake water temperature is at or above 60°F and the temperature as measured four (4) feet below the surface at the Route 9 Bridge over Oyster Creek is at or less than 87°F, no dilution pump operation is required.

- A. When the temperature in Oyster Creek exceeds 87°F, as measured four (4) feet below the surface at the Route 9 Bridge over Oyster Creek, one dilution pump will be put into operation. If, after one dilution pump has been in operation for at least two hours, the temperature measured at such point continues to exceed 87°F, a second dilution pump will be put into operation.
- B. When the intake water temperature is less than 60°F, two dilution pumps will be put into operation.

Page 10 of 12 Pages Part IV-B/C NJ0005550

- C. A third dilution pump shall be held in reserve at the Station and must be put into operation within 40 minutes after one of the other two dilution pumps becomes inoperable and the operation of two dilution pumps is required by Paragraphs A or B above.
- D. During periods of dilution pump and/or dilution pump component maintenance, a sufficient number of dilution pumps may not be available to meet the requirements of Paragraphs A, B, and C above. In that event, the Station may be operated for a period not to exceed 14 (fourteen) days in order to make necessary repairs, provided at least one dilution pump is available for operation. As soon as a second dilution pump is available for operation, it shall be placed into service as required under Paragraphs A, B, and C. When the Station has operated under this Paragraph for 14 days and continues to lack sufficient pumps to comply with Paragraphs A, B, and C, the Station shall become subject to Paragraph E instead of this Paragraph.
- E. If dilution pump operation is required under Paragraph A, B, and C and if onepump operation under Paragraph D continues for 14 (fourteen) days, remedial action will be taken within 24 hours to bring the plant into compliance with Paragraphs A, B, and C. If remedial action taken involves reduction of Station power output, power will be reduced as necessary to achieve the same effect as operating the proper number of dilution pumps as required by Paragraphs A, B, and C.
- F. Paragraphs 9.A. through 9.E. do not apply during Station shutdowns. Any dilution pump(s) will be operated, however, in a manner that will minimize the adverse impact of Station shutdown upon marine and estuarine life in Oyster Creek and Barnegat Bay.
- G. Paragraphs 9.A. through 9.E. do not apply in the event of a hazardous substance spill into the intake or discharge canals. In such cases, the dilution pumps will be operated in a manner which will minimize the environmental impact of the spill, while taking into consideration the need to minimize the possibility of thermal shock mortality of organisms residing in the discharge canal.

10. INTAKE VELOCITY (former Part II, Condition E)

A. The intake velocity shall not exceed 2.2 fps averaged over one minute at any point at the midplane of each port and the average of the average readings taken at 5 foot intervals from the top to the bottom of the water column of the individual port shall not exceed 1 fps during 6 port-6 screen operation. In the event that any screen must be removed from service due to intake component maintenance, then the 1 fps limitation shall apply as an average over the effective intake face.

Page 11 of 12 Pages Part IV-B/C NJ0005550

- B. When one circulating water pump is in operation, or when one circulating water pump is in operation in each half of the intake structure, or when there is no flow through the main condenser, the permittee is not required to measure intake velocity.
- The permittee shall report intake velocities monthly (on DMR for DSN 001) and any intake component maintenance actions taken during the month that requires a screen to be removed from service.

11. RATE OF TEMPERATURE CHANGE (former Part II, Conditions F & G)

The rate of temperature change shall not cause mortality of fish or shellfish.

12. TERMINATION OF SECTION 316(a) VARIANCE/PENALTIES

Notwithstanding any other provision of this permit, the Department specifically reserves the right to seek termination of the Section 316(a) variance granted in this permit or termination of this permit based on the permittee's noncompliance with any term or condition of this permit. Further, the Department specifically reserves the right to seek penalties pursuant to N.J.S.A. 58:10A-10 et seq. based on the permittee's noncompliance with any term or condition of this permit.

13. RENEWAL OF SECTION 316(a) VARIANCE

The Department proposes to grant a variance pursuant to Section 316(a). If the draft permit is finalized, the variance will automatically be terminated upon the expiration of the final NJPDES permit. Procedures for reissuance of a Section 316(a) variance are virtually unchanged from an initial Section 316(a) determination.

If upon renewal, the permittee wants the variance to be continued, the request for the variance along with a basis for its continuance must be submitted at the time of application for the renewal permit. In the event that the permittee wants the variance to be continued, the Department's Section 316(a) determination will include, but not be limited to a review of studies based on actual operating experience, a review of material submitted by the Permittee or others, to determine whether the nature of the aquatic population(s) associated with the Station have changed, whether the protection and propagation of the balanced, indigenous population has been continued to be assured, whether the best scientific methods to assess the effect of the permittee's cooling system have changed and whether the technical knowledge of stresses caused by cooling systems has changed.

14. DEPARTMENT NOTIFICATION OF EMERGENCY NEED FOR POWER

The permittee shall notify the Department within eight (8) hours after declaring an "Emergency Need for Power" which invokes the alternate limitations for heat, temperature and ΔT relief in the permit. Notification should be made to the Central Bureau of Water and Hazardous Waste

Environmental Report Appendix B NPDES Permit

Page 12 of 12 Pages Part IV-B/C NJ0005550

Enforcement during normal business hours and to the NJDEPE Hotline during non-business hours and weekends.

15. THREATENED/ENDANGERED SPECIES

The Permittee is required to comply with NRC Facility Operating License No. DPR-50-219, and all subsequent amendments that may be required by the National Marine Fisheries Service (NMFS) as approved by the NRC.

Page 72 of 84 Pages Fact Sheet/Basis · NJ0005550

Alternative Best Technologies Considered Under Section 316(b)

Under Section 316(b), the Department must determine whether the location, design, construction, and capacity of the intake structure(s) at the Station reflect the best technology available (BTA) for minimizing adverse environmental impact.

Decisions under Section 316(b) are made on a case-by-case basis which includes, among other things, evaluation of economic considerations. Best Technology Available is intended to mean "the best technology available commercially at an economically practicable cost" (from remarks of Don H. Clausen (a member of the House-Senate Conference Committee) during House debate on the 1972 Amendments. Library of Congress (Congressional Research Service, Environmental Policy Division), A Legislative History of the Water Pollution Control Act Amendments of 1972, (Two Volumes), January 1973, Serial No. 93-1, U.S.G.P.O. Stock No. 5270-01759, Washington, D.C. Page 264). Further, Section 316 is interpreted as not "requiring use of technology whose cost is wholly disproportionate to the environmental benefit to be gained." Administrator's Decision, In Re Public Service Company of New Hampshire, Case No. 76-7 (June 10, 1977) ("Seabrook Administrator's Decision"), 10 ERC 1261, and In the Matter of Carolina Power and Light Company (Brunswick Steam Electric Plant), NPDES Permit No. NC0007064 (November 7, 1977) at 31-32). Section 316(b) requires that an intake structure reflect BTA in order to minimize adverse environmental impact but, further, the Department notes that minimization of adverse environmental impact does not necessarily require that all losses of organisms due to Station operation be eliminated. In the matter of Boston Edison Electric Company (Pilgrim Nuclear Station NPDES Permit Nos. MA0003557 and MA0025135).

The Department evaluated available information on various technologies, including their technical feasibility, biological effectiveness, and associated costs. Versar found that the major intake impact to be minimized was entrainment losses to early life stages of aquatic organisms, particularly hard clams and sand shrimp. Versar also noted that impingement losses and fish kills were of some concern. The alternative technologies identified by Versar to have the greatest potential for application to reduce impingement and entrainment at the Station were:

1. Replacing the existing 3/8" mesh traveling screens with fine mesh screen panels.

and the second second

. . .

- 2. Traveling screens with conventional 3/8" mesh or fine mesh retrofitted in front of the dilution pumps and/or fine-mesh centerflow screens retrofitted in front of the dilution pumps.
- 3. Replacement of intakes with fine-mesh wedgewire screens.
- 4. Closed cycle cooling (cooling towers).

5. Optimization of dilution pump operations.

1989 Versar Report, pp. VII-6.7.

Page 73 of 84 Pages Fact Sheet/Basis NJ0005550

The first two alternatives would increase impingement loss while reducing entrainment. The net ecological benefit of these retrofits would depend on the degree to which the reduction in entrainment losses exceeds the gain in impingement losses. <u>1989 Versar Report, p. VII-6</u>. Versar looked primarily at the first three (physical barrier) alternatives as they could be applied without complete replacement of the intake structure so as to avoid the high cost of an entirely new intake structure. <u>1989 Versar Report, p. VII-22</u>. Versar was concerned with limited data on the engineering feasibility of some of these alternatives and was not able to recommend that the cost of these technologies could be appropriate in view of the limited benefits of these technologies. Versar found that none of the screening options reduces losses at the facility by even 50%. <u>1989 Versar Report, p. VII-22</u>.

Versar dismissed the wedgewire screen alternative because its costs far exceeded its benefits. <u>1989 Versar Report, p. VII-6</u>. Biofouling and detrital clogging would also be a concern in the application of wedgewire screens at the Station. The Department concurs with Versar's recommendations on the screening alternatives and determines that it is unable to demonstrate that they are available at a reasonable cost (not wholly disproportionate to environmental benefits).

Versar also considered the alternative of (recirculating) cooling towers which are a demonstrated, effective technology for reducing entrainment and impingement, as well as thermal discharge impacts. Cooling towers are the most expensive alternative but would reduce water withdrawal by more than 95 percent and provide the highest degree of protection of any single currently available technology as a reduction in impact would result from the withdrawal (flow) reduction. <u>1989 Versar Report, p. VII-7</u>. GPUN's estimated cost to install a natural draft cooling tower(s) is approximately \$70 million. (Mechanical draft cooling towers would be expected to have lower construction cost than natural draft cooling towers but a higher operating cost.) Cooling towers are expected to be more costly than the physical barrier alternatives and Versar did not recommend cooling towers be designated the best technology available due to concerns about economic cost. <u>1989 Versar Report, p. VII-7</u>. Additionally, there are ecological costs associated with cooling towers including visual impacts if natural draft cooling towers were used [natural draft towers are typically several hundred feet high and add considerable visual impact], noise from tower fans [from mechanical draft towers], and potential for local salt drift, fogging and icing.) <u>1989 Versar Report, p. VII-7</u>.

The Department concurs with Versar's recommendation and determines that it is not able, at this time, to demonstrate that (recirculating) cooling towers are available at a reasonable cost (not wholly disproportionate to environmental benefits), especially where, as here, the balanced indigenous population is protected by current operations. Versar concluded that "[c]ontinued operation of the Oyster Creek NGS at the estimated levels of losses to RIS populations, without modification to intake structures and/or operating practices, does not threaten the protection and propagation of balanced, indigenous populations." <u>1989 Versar Report, p. VIII-2</u>. As stated above, the Department concurs with this conclusion. Pursuant to Section 316(b), any cooling

Page 74 of 84 Pages Fact Sheet/Basis NJ0005550

water intake technology may be imposed by the Department despite a successful Section 316(a) demonstration, if the cost of the technology is not wholly disproportionate to the environmental benefit to be derived from the application of the technology. As discussed in the Decision of the General Counsel No. 63, July 29, 1977 at page 383, however, "[a]s a practical matter, it [is] more difficult for the [Department] to show, for example, that the imposition of a \$25 million technology under Section 316(b) is not "wholly disproportionate" to the magnitude of the adverse environmental impact if the discharger has shown under Section 316(a) that the overall impact of a less stringent thermal effluent limitation does not interfere with the protection and propagation of the balanced indigenous population."

Versar also looked into optimization of dilution pump operations as an alternative for reducing total plant impingement-entrainment losses. Optimization studies would compare the benefits of an altered thermal mortality rate (from the cooling provided by dilution pump flows) with the environmental cost of exposure by entrainment of a greater humber of organisms due to dilution pump flows. Versar found that the Section 316 Demonstration did not contain sufficient information to optimize dilution pump operations. Versar found that November through February (potential cold shock) and July and August (potential heat shock) are periods of high risk for fish kills, but that there was significant potential, based on the data in the 316 Demonstration, to reduce losses by reducing dilution pump flows.

Versar assumed that there would be no costs associated with reducing dilution pump flows. Operating costs to implement the Dilution Pump Optimization Studies are expected to be less than for the current operations. (Reduced flows will require less electricity for pump operations.)

120

Versar recommended that the Department require Dilution Pump Optimization Studies as the Best Technology Available for the Station to minimize the adverse impacts of the cooling water intake structure pursuant to Section 316(b). Such optimization studies were recommended to provide a sound, rational basis for operational schedule modifications which may reduce entrainment losses. Versar further recommended that prior to the collection of data for these optimization studies, operation of the dilution pumps should not be altered because of the risk of increasing total mortality associated with the facility. <u>1989 Versar Report. p. VII-23</u>.

The Department affirms and adopts Versar's recommendation that Dilution Pump Optimization Studies should be required at the Station. Therefore, the Department is proposing to require Dilution Pump Optimization Studies (see the section entitled "Dilution Pump Optimization Studies" of the Fact Sheet/Basis, and Part IV-B/C(5)). The permit will be modified if the studies provide information that dilution pump operations should be changed to reduce entrainment losses.

Based on the standard articulated in <u>In the Matter of Carolina Power and Light Company</u> (Brunswick Steam Electric Plant) NPDES Permit No. NC0007064 (November 7, 1977) at 31-32, the Department is persuaded that BTA as used in Section 316(b) is distinguishable from the

Page 75 of 84 Pages Fact Sheet/Basis NJ0005550

standard "best available technology (BAT)". The Department, however, provides the following analysis in the event that this is determined not to be the case.

Where USEPA has not promulgated an industry-wide technology-based standard, the Department must set BAT limitations on a case-by-case basis using its best professional judgment ("BPJ") consistent with the requirements of Section 304(b) of the CWA. Section 304(b) and the implementing regulations (40 CFR 125.3(c)(2)) require agencies including the Department to consider certain factors in making a BPJ BAT determination, including: the age of the equipment and facilities; the process employed; the engineering aspects of the application of various types of control techniques; process changes; the cost of achieving such effluent reductions; and non-water quality environmental impacts (including energy requirements).

Courts reviewing BAT limitations have found that effluent reduction benefits do not need to consider resultant ambient water quality improvements. Likewise, benefits do not need to be quantified in monetary terms. There is no structure as to how these must be considered and there is no specific weight to be given these factors in their consideration.

The administrative record provides detailed information on the age of equipment and facilities involved; the process employed; the engineering aspects of the application of various types of control techniques; process changes; the estimated cost of achieving such effluent reductions; and non-water quality environmental impacts (including energy requirements). Based on the analysis of this information, the Department is unable to demonstrate at this time that closed cycle cooling or physical barrier modification technologies are "available" for application at the Station to reduce impingement and entrainment at a reasonable cost (not wholly disproportionate to environmental benefits).

The existing cooling water system, in conjunction with Dilution Pump Optimization Studies (which the Department would be able to demonstrate to be available for application at the Station to reduce impingement and entrainment effects at a reasonable cost), would be designated as the BAT under Section 304(b) if that was found to be the standard applicable to a BTA determination under Section 316(b).

In sum, based on the above review of available technologies, the Department determines that the existing cooling water intake structure, in conjunction with Dilution Pump Optimization Studies, should be designated Best Technology Available under Section 316(b). Accordingly, pursuant to Section 316(b), the Department proposes to allow the Station to continue to operate with the present cooling water intake structures in conjunction with the conduct of the Dilution Pump Optimization Studies. A reopener clause has been included so that the permit can be revised upon review of the Dilution Pump Optimization Studies.

Appendix C

Special-Status Species Correspondence

Oyster Creek Generating Station Environmental Report

Table of Contents

Letter	<u>Page</u>
Gallagher (AmerGen) to Staples (U.S. Fish and Wildlife Service)	C-1
Day (U.S. Fish and Wildlife Service) to Gallagher (AmerGen)	C-4
Gallagher (AmerGen) to Niles (New Jersey Department of Environmental Protection)	C-11
Jenkins (New Jersey Department of Environmental Protection) to Gallagher (AmerGen)	C-54
Lord (New Jersey Department of Environmental Protection) to Mah[I]er (AmerGen)	C-55



An Exelon Company

AmerGen Energy Company, LLC www.exeloncoro.com 200 Exelon Way Kennelt Square, PA 19348

October 20, 2004 2130-04-20249

John Staples, Supervisory Fish & Wildlife Biologist U.S. Fish & Wildlife Service New Jersey Field Office 927 N. Main Street Heritage Square, Bldg. D Pleasantville, NJ 08232

Request for Information on Listed Species and Critical Habitats for the Oyster Creek Subject: Generating Station License Renewal Application

Dear Mr. Staples:

AmerGen Energy Company, LLC (AmerGen) is preparing an application to the U.S. Nuclear Regulatory Commission (NRC) to renew the operating license for Oyster Creek Generating Station (OCGS), which expires in April 2009. Renewing the license would extend operation of the plant through April 2029. AmerGen operates the plant and is the licensee. AmerGen acquired the plant from General Public Utilities in August of 2000.

AmerGen intends to submit an application for license renewal in the summer of 2005. As part of the license renewal process, the NRC requires license applicants to "assess the impact of the proposed action on threatened or endangered species in accordance with the Endangered Species Act" (10 CFR 51.53). As part of its review of the application, the NRC will consult with your office under Section 7 of the Endangered Species Act to determine if any listed species or critical habitat occurs in the project area. By contacting you in advance, we hope to identify any issues that need to be addressed or information required to expedite the NRC's consultation.

Oyster Creek Generating Station is in Ocean County, New Jersey, approximately 10 miles south of Toms River and approximately 35 miles north of Atlantic City (see Attachment 1, Figure 1). The plant lies approximately 2 miles inland from Barnegat Bay (see Attachment 1, Figure 1), which serves as its cooling water source and heat sink. One transmission line was constructed to connect OCGS to the regional transmission system. This transmission line (see Attachment 1, Figure 2) is now owned and maintained by FirstEnergy Corporation, which owns and operates a transmission system in Ohio, Pennsylvania, and New Jersey. Conectiv is planning to build a second transmission line from OCGS. However, because 10CFR51.53(c)(3)(ii)(H) requires an analysis of "lines that were constructed for the specific purpose of connecting the plant to the

1. N 17 y 16 1 17 1 1 1 1 2 1 1

Oyster Creek Generating Station License Renewal Application

.

U. S. Fish and Wildlife Service October 20, 2004 Page 2

transmission system," this line is not part of the scope of the proposed action, which is license renewal of OCGS. In addition, it is our understanding that Conectiv has complied with the requirements of the Endangered Species Act with regard to this line. Therefore, we are not requesting your office's assistance in identifying sensitive species or habitats that might be affected by this line.

The OCGS property (see Attachment 1, Figure 3) consists of the OCGS site, which lies west of Highway 9, and the former Finninger Farm, which lies east of Highway 9. The parcel of land west of Highway 9 includes the powerblock area, support facilities, roads, parking lots, and some undeveloped buffer areas. It totals approximately 150 acres. The parcel of land east of Highway 9, the former Finninger Farm, is largely undeveloped and is maintained as a natural area. It is comprised of approximately 650 acres of old fields, abandoned orchards, forests, wetlands, and marshlands. The two parcels of land total approximately 800 acres.

In response to a request from Amergen, the Natural Heritage Program of the New Jersey Department of Environmental Protection (NJDEP) recently searched its database for occurrences of rare, threatened, and endangered species on the OCGS property and within one-quarter mile of the site boundary. Based on the NJDEP responses (see Attachment 2), seven state-listed animals and three state-listed plants may occur in the vicinity of the site; however, no federally listed species occur on site or within one-quarter mile. One of the plants that NJDEP believes "may be on site" is the bog asphodel (*Narthecium americanum*), which is a candidate for federal listing.

Jersey Central Power & Light Company, which operated OCGS for several decades, built the single 230-kilovolt transmission line to connect the plant to the regional transmission system (see Figure 2). This line originates at a sub-station west of the plant's powerblock area, runs northwest for approximately 1.5 miles, crossing the Garden State Parkway, then turns north to run approximately 9.5 miles to the Manitou Substation at Toms River. For most of its length, the line parallels the Garden State Parkway. Most of the land crossed by the line is pine forest, but the line also crosses a number of streams (three branches of Forked River, Huckleberry Branch, Deep Hollow Branch, Cedar Creek, Factory Branch, and Jakes Branch) and associated wetlands, bogs, ponds, and agricultural areas. For approximately 1 mile of its length, the transmission line crosses Double Trouble State Park.

Although AmerGen has not surveyed the transmission corridor for rare plants and animals, control of woody vegetation in this corridor could provide habitat for species that depend on open conditions (grassland and bog-type habitats) that are maintained by regular mowing and selective application of approved herbicides. The recent NJDEP review of the project indicated that more than a dozen state-listed species and several significant natural communities could occur in the vicinity of the transmission corridor. In addition, NJDEP reported that one federally listed plant (the threatened Knleskern's beaked rush, *Rhynchospora knieskernii*) and one plant that is a candidate for federal listing (the aforementioned bog asphodel) "may be" in the vicinity of the OCGS-to-Manitou transmission line.

AmerGen is committed to the conservation of significant natural habitats and protected species, and believes that operation of OCGS and its transmission line since 1969 has had no adverse impact on any threatened or endangered species. AmerGen has no plans to alter current operations over the license renewal period. Any maintenance activities necessary to support

U. S. Fish and Wildlife Service October 20, 2004 Page 3

license renewal would be limited to previously disturbed areas. No expansion of existing facilities and no additional land disturbance is anticipated in support of license renewal. As a consequence, we believe that operation of the plant, including maintenance of the transmission line, over the license renewal period (an additional 20 years) would not adversely affect any threatened or endangered species.

We would appreciate your providing us with any information you may have about any state or Federally listed species or ecologically significant habitats that may occur on the 800-acre OCGS property or along the associated transmission corridor by December 1, 2004.

Please call Bill Maher at (610) 765-5939 If you have any questions or require any additional information.

Sincerely,

D. b. Helker /FOR

Michael P. Gallagher Director, Licensing & Regulatory Affairs

Attachment 1: Figure 1: 50-Mile Vicinity Map Figure 2: 6-Mile Vicinity Map Figure 3: Oyster Creek Generating Station Site Boundary Attachment 2: Letters from Herbert Lord (NJDEP) to William Mahler (AmerGen), "Oyster Creek Generating Station to Manitou Transmission Line" and "Oyster Creek Generating Station," both dated September 22, 2004.

cc: Karen Tucillo, NJ BNE File No. 04007



United States Department of the Interior

FISH AND WILDLIFE SERVICE



in Reply Refer to:

ES-04/618

New Jersey Field Office Ecological Services 927 North Main Street, Building D Pleasantville, New Jersey 08232 Tel: 609/646 9310 Fax: 609/646 0352 http://njfieldoffice.fws.gov

JAN 2 5 2005 MICHAELP, GALLAGHEN LICENSING SECTION

JAN 2 7 2005

REFER TO:

Dear Mr. Gallagher:

200 Exelon Way

Michael P. Gallagher, Director

AmerGen Energy Company, LLC Licensing and Regulatory Affairs

Kennett Square, Pennsylvania 19348

This responds to your October 20, 2004 letter to the U.S. Fish and Wildlife Service (Service) requesting information on federally listed species in the vicinity of the Oyster Creek Generating Station located in Ocean County, New Jersey. The Service understands that you are preparing an application to the U.S. Nuclear Regulatory Commission to renew the operating license, which expires in April 2009, for the Oyster Creek Generating Station.

AUTHORITY

This response is provided pursuant to the Endangered Species Act of 1973 (87 Stat. 884, as amended; 16 U.S.C. 1531 *et seq.*) (ESA) to ensure the protection of federally listed endangered and threatened species. These comments do not address all Service concerns for fish and wildlife resources and do not preclude separate review and comments by the Service pursuant to the Fish and Wildlife Coordination Act (48 Stat. 401, as amended; 16 U.S.C. 661 *et seq.*) if project implementation requires a Department of the Army permit pursuant to Section 10 of the Rivers and Harbors Appropriation Act (30 Stat. 1151, as amended; 33 U.S.C. 403 *et seq.*) and/or Section 404 of the Clean Water Act (33 U.S.C. 1341), or pursuant to the December 22, 1993 Memorandum of Agreement (MOA) among the U.S. Environmental Protection Agency, New Jersey Department of Environmental Protection (NJDEP), and the Service, if project implementation requires a permit from the NJDEP pursuant to the New Jersey Freshwater Wetlands Protection Act (N.J.S.A. 13:9B *et seq.*). The following remarks do not preclude comments on any forthcoming environmental documents pursuant to the National Environmental Policy Act of 1969 as amended (83 Stat. 852; 42 U.S.C. 4321 *et seq.*).

FEDERALLY LISTED SPECIES

There is a known occurrence of the federally listed (threatened) plant Knieskern's beaked-rush (*Rhynchospora knieskernii*) within 1.5 miles of the project site. Knieskern's beaked-rush occurs

in early successional wetland habitats, often on bog-iron substrate or mud deposits adjacent to slow-moving streams in the Pinelands region of New Jersey. This species is also found in mandisturbed wet areas including abandoned borrow pits, clay pits, ditches, rights-of-way, and unimproved roads. The species is intolerant of shade and competition, and is generally found on relatively bare substrate with sparse vegetation. Threats to Knieskern's beaked-rush include habitat loss from development, agriculture, hydrologic modification, and other wetland alterations; excessive disturbance from vehicle-use, trash dumping, and other activities; and natural vegetative succession of the open, sparsely-vegetated substrate preferred by this species. Additional information is enclosed regarding Knieskern's beaked-rush and its habitat.

There are two known occurrences of the federally listed (threatened) plant swamp pink (Helonias bullata) within 2.8 miles of the project site. Swamp pink is a perennial, shade-tolerant, obligate wetland plant found in forested freshwater wetlands, such as Atlantic white-cedar (Chamaecyparis thyoides) and red maple (Acer rubrum) swamps. The species usually occurs along small meandering streamlets, in headwater wetlands, or in spring seepage areas. Swamp pink habitat can have a variable canopy, and tends to have mucky substrates. Specific hydrologic requirements of swamp pink limit its occurrence to areas with lateral ground-water movement that are perennially saturated, but not inundated by floodwaters. The species also requires a water table at or near the surface, with only slight fluctuations in water levels throughout the year. Swamp pink often grows on hummocks formed by trees, shrubs, and sphagnum moss. The primary threats to swamp pink are the indirect effects of off-site activities and development, such as pollution and subtle changes in groundwater and surface water hydrology. Hydrologic changes include increased sedimentation from off-site construction; and increases in the frequency, duration, and volume of flooding, and subsequent erosion, caused by direct discharges to wetlands (such as stormwater outfalls) and by increased runoff from upstream development. Other threats to this species include direct destruction of habitat from wetland clearing, draining and filling; collection; and trampling. Additional information is enclosed regarding swamp pink and its habitat.

CANDIDATE SPECIES

There is a known occurrence of the federal candidate plant species, bog asphodel (*Narthecium americanum*), located within the Oyster Creek Generating Station site boundary and several additional locations within 1.3 miles of the project site. Bog asphodel is a perennial herb found in open bogs, wet savannahs, lowland oxbow meanders, iron ore streamlet seeps, and sunny borders of Atlantic white-cedar (*Chamaecyparis thyoides*) swamps. The species often forms clumps in mucky soil along small channels of cold seepage water. Bog asphodel favors areas influenced by slow-moving groundwater, and cannot tolerate heavy shade or extended periods of flooding or dessication. Threats to bog asphodel include long-term hydrologic change, habitat loss, and natural vegetation succession.

SERVICE COMMENTS AND RECOMMENDATIONS

Based upon a review of the information provided, the Service understands that there would be no expansion of the existing facilities, no additional land disturbance is anticipated in support of license renewal, and any maintenance activities necessary to support license renewal would be

2

limited to previously disturbed areas. Therefore, the Service concurs with your determination that operation of the plant, including maintenance of the transmission line, over the license renewal period would not adversely affect federally listed threatened and endangered species. No further consultation pursuant to Section 7 of the ESA is required by the Service. If additional information on federally listed species becomes available, or if project plans change, this determination may be reconsidered.

A review of the Service's National Wetlands Inventory maps indicates that wetlands occur within the project site. Many areas of New Jersey, including the project site, have not been thoroughly surveyed for endangered and threatened plant and animal species. Therefore, occurrences of Knieskern's beaked-rush and swamp pink, as well as several State-listed plants and animals, could be located within wetlands on or adjacent to the project site. Although the Service understands that these wetlands will not be affected by the license renewal, it is recommended (not required) that a qualified botanist conduct a survey within the project site to determine the absence or presence of rare plants, particularly Knieskern's beaked-rush and swamp pink. Please forward the results of any survey, whether showing presence or absence, to this office. Please include the survey method used and the qualifications of the surveyor.

Candidate species are under consideration by the Service for possible inclusion on the List of Endangered and Threatened Wildlife and Plants. Although these species receive no substantive or procedural protection under the Endangered Species Act, the Service encourages federal agencies and other planners to consider candidate species in project planning. If field surveys are conducted for Knieskern's beaked rush or swamp pink, the Service recommends the survey also include bog asphodel.

The Service appreciates your efforts to address federally listed species concerns early in the planning process. Lisa Arroyo of my staff is available at (609) 646-9310, extension 49, to provide further assistance if you have any questions concerning the above information or require further assistance regarding federally listed endangered or threatened species.

Sincerely,

Clifford G. Day Supervisor

3



Oyster Creek Generating Station License Renewal Application Page C-7

Swamp pink is a shade-tolerant plant that occurs in wetlands with varying canopy closure. Plant species Swamp pink is a snade-tolerant plant that occurs in weilands with varying catopy closure. Plant species associated with swamp pink include: Atlantic white codar (*Chamaesyparis thyoides*), red maple (*Acer rubrun*), pitch pine (*Pinus rigida*), American larch (*Larix lariciana*), black spruce (*Picea mariana*), red spruce (*Picea rubrun*), sweet pepperbush (*Clethra aluifolia*), sweetbay magnolia (*Magnolia virginiana*), sphagnum mosses (*Sphagnum*, spp.), cinnamon fern (*Osmunda cinnamomea*), skunk cabbage (*Symplocarpus foetidus*), and laurels (*Kalmia* spp.). Swamp pink often grows on hummocks formed by trees, shrubs, and sphagnum mosses, which indicates that these microtopographic conditions may be an important component of swamp pink habitat.

RANGE: Once found inhabiting weiland areas from New York to Georgia, swamp pink now occurs only along the coastal plain from New Jersey to Virginia and in small isolated bog areas in the Southern Appalachian Mountains. Containing more than 70 percent of the known sites. New Jersey represents the global stronghold for swamp pink. Plant celenics are found in Atlantic, Burlington, Canden, Cape May, Cumberland, Gloucester, Middlesex, Monmouth, Morris, Occar, and Salem Counties.

THREATS: Threats to swamp pink include: loss or degradation of habitat due to illegal filling of wetlands; sedimentation from off-site construction activities. Introduction of excess putrients or toxic chemicals (e.g., herbicides) into the warer, and, changes ht groundwater and surface water hydrology due to excavation, water withdrawal; and increased munoff from upstream development (causing flooding and eroston). Additionally, direct discharge from storm water outfalls can increase the frequency, duration, and wolume of flooding in swamp pink wetlands and adversely affect the species.

CONSERVATION AND PROTECTION: The Service's Swamp Pink Recovery Plan

and assistance.

SURVEY REQUIREMENTS: Although surveys can be conducted year round, the Service recommends conducting surveys from late fail to early toring when the foliage of other plant species is reduced, making the evergreen foliage of swamp pills easier to detect. Random transect autyeys are inappropriate since the species may be present in small wet pockets, which may be overlooked during the random transect method. All available suitable habitar within the project impact area should be surveyed, concentrating on forested werland areas as previously described, with suitable bydrology. The surveyor should tensus not only the werlands on the subject property. Our also upstream and downstream wetlands. Please do not collect specimens or send plants of plants to the Service for identification. Report the survey method useds the quantifications of the surveyor and the results of the survey (including size of area surveyed; hours searched; aerial, and/or ground photographs with index map, and wetland delineations) to

identifies permanent protection of at least 80 large populations. If you own property containing swamp pink or know of other landowners who would be interested in permanently protecting this species, please notify the Service for additional information



Oyster Creek Generating Station License Renewal Application



Knieskern's beaked-rush

DESCRIPTION: Knieskern's beaked-rush (Rhynchospora knieskernii) was listed as a threatened species on July 18, 1991, pursuant to the Endangered Species Act of 1973 (87 Stat. 884, as amended; 16 U.S.C. 1531 et seq.). Knieskern's beaked-rush belongs to the sedge family and is endemic to the Pinelands region of New Jersey. This grass-like plant was generally considered to be an annual species; however, it is currently suspected to be a shortlived perennial in locations where habitat conditions are stable, allowing uninterrupted growth year after year. Knieskern's beaked-rush grows from 1.5 to 60 centimeters high (0.6 to 24 inches), has slender culms (stems) branching from the base, and short, narrowly linear leaves. Small spikelets (flower clusters) are numerous and occur at distant intervals along the entire length of the culm. The achene (fruit) is obovate, narrow at the base, 1.1 to 1.3 millimeters long (0.04 to 0.05 inches), and equal in length to the six downwardlybarbed or rarely, upwardly-barbed attached bristles. Fruiting typically occurs from July to September (U.S. Fish and Wildlife Service, 1993).

HABITAT: Knieskern's beaked-rush is an obligate hydrophyte (wetland plant) that occurs in groundwaterinfluenced, constantly fluctuating, successional habitats. An early successional species and colonizer, Knieskern's beaked-rush is intolerant of competition, especially from woody species. It is found on naturally occurring early successional habitats and disturbed areas such as burns, bog-iron deposits, gravel and clay pits, road cuts, mowed roadsides, utility and railroad rights-of-way, cleared home sites, eroded areas, cleared edges of Atlantic white-cedar swamps, wheel ruts, and muddy swales (Gordon, 1993; U.S. Fish and Wildlife Service, 1993; Radis, 1995). In the past, fire may have played an important role in creating and maintaining suitable habitat for Knieskern's beaked-rush. Occurrence records indicate that this plant is found in wet open areas within fire-dependent open pitch-pine forests. Periodic disturbance, either natural or human-induced, which maintains a damp-to-wet site in an early ecological successional stage, may be necessary for the successful colonization, establishment, recruitment, and maintenance of this species.





Achene (fruit) with six barbed bristles

Human-disturbed sites exhibit some of the same characteristics as bog-iron sites, including a high water table, temporary inundation, and open, early-successional habitat with relatively bare substrate. Plant species associated with Knieskern's beaked-rush include warty panic-grass (Panicum vertucosum), poverty-grass (Aristida longispica), and spatulate-leaved sundew (Drosera intermedia) (Gordon, 1993).

THREATS: Originally, the primary threat to the species was the loss of wetlands to urban and agricultural development. However, current State and federal wetland protection laws have reduced the loss of wetlands over time. Presently, vegetative succession is a major factor threatening Knieskern's beaked-rush. Human-induced threats to the species include alteration of wetland hydrology, off-road vehicle activity, trash dumping, and possibly roadside grading (U.S. Fish and Wildlife Service, 1993). Gordon (1993) found that fire can be both beneficial and detrimental to the species depending on the timing, duration, and intensity of the burn.

SURVEY REQUIREMENTS: The Service requests that a qualified biologist conduct a comprehensive search for Knieskern's beaked-rush in any potentially suitable early successional wetlands or disturbed wet areas that may be impacted by project activities. Surveys should be conducted from July to September. Random transect surveys are inappropriate since the species may be present in small wet pockets, which may be overlooked by this survey method. Please report in writing the survey method used, the qualifications of the surveyor, and the results of the survey to:

> U.S. Fish and Wildlife Service New Jersey Field Office 927 North Main Street, Building D-1 Pleasantville, New Jersey 08232 Telephone: 609/646-9310 Facsimile: 609/646-0352



Cluster of spikelets

LITERATURE CITED

Gordon, T. 1993. Monitoring and Survey of Rhynchospora knieskemil in New Jersey - 1992. New Jersey Office of Natural Lands Management, Trenton, New Jersey. 9 pp.

Radis, R. 1995. Monitoring and survey research on Rhynchospora knieskemil Carey in New Jersey. 16 pp.





•	AmerGen
AmerCen Energy Company, LLC www.exeloncorp.com 200 Exelon Way Kennett Square, PA 19348	An Exelon Company
December 3, 2004	
2130-04-20320	· ·
Mr. Larry Niles Chief, Endangered and Non-Game Species Program Division of Fish & Wildlife New Jersey Dept. of Environmental Protection 501 East State Street. Floor 3	
P.O. Box 400 Trenton, NJ 08625-0400	
Dear Mr. Niles:	
AmerGen Energy Company, LLC (AmerGen) is preparing a Regulatory Commission (NRC) to renew the operating licer Station (OCGS), which expires in April 2009. Renewing the the facility through April 2029. AmerGen, a wholly-owned s operates the plant and is the licensee. AmerGen intends to submit this application for license rene the license renewal process, the NRC requires license appl proposed action on threatened or endangered species in ac Species Act" (10 CFR 51.53). The NRC will consult with the under Section 7 of the Endangered Species Act and may al identification of important species and habitats in the project the application process, we hope to identify any issues that your office may need to expedite the NRC consultation.	an application to the U.S. Nuclear has for Oyster Creek Generating e license would extend operation of subsidiary of Exelon Corporation, wal in late-summer 2005. As part of licants to "assess the impact of the coordance with the Endangered e U.S. Fish and Wildlife Service iso seek your assistance in the t area. By contacting you early in need to be addressed or information
In response to a request from AmerGen, the New Jersey Na searched its database for occurrences of rare, threatened, a OCGS property and within one-quarter mile of the site boun the Natural Heritage Program response (see Attachment 2), three state-listed plants may occur in the vicinity of the site; occur on site or within one-quarter mile. One of the plants t "may be on site" is the bog asphodel (<i>Narthecium american</i> listing.	atural Heritage Program recently and endangered species on the idary (see Attachment 1). Based on , seven state-listed animals and however, no federally listed species hat the Heritage Program believes um), which is a candidate for federal
Jersey Central Power & Light Company, which operated OC single 230-kilovolt transmission line to connect the plant to t (see Attachment 1). This line originates at a sub-station we runs northwest for approximately 1.5 mile, crossing the Gard	CGS for several decades, built a he regional transmission system st of the plant's powerblock area, den State Parkway, then turns north

Endangered and Non-Game Species Program December 3, 2004 Page 2

to run approximately 9.5 miles to the Manitou Substation at Toms River. The recent Heritage Program review of the project indicated that more than a dozen state-listed species and several significant natural communities could occur in the vicinity of the transmission corridor. In addition, the Heritage Program reported that one federally listed plant (the threatened Knieskern's beaked rush, *Rhynchospora knieskerni*) and one plant that is a candidate for federal listing (the aforementioned bog asphodel) "may be" in the vicinity of the OCGS-to-Manitou transmission line.

AmerGen is committed to the conservation of significant natural habitats and protected species, and believes that operation of OCGS and its transmission line since 1969 has had no adverse impact on any threatened or endangered species. AmerGen has no plans to alter current operations over the license renewal period. Any maintenance activities necessary to support license renewal would be limited to previously disturbed areas. No expansion of existing facilities is planned, and no additional land disturbance is anticipated in support of license renewal. As a consequence, we believe that operation of the plant, including operation and maintenance of the transmission line, over the license renewal period (an additional 20 years) would not adversely affect any threatened or endangered species.

We would appreciate your sending us a letter by January 7, 2005, detailing any additional information you have on state- or federally-listed species that may be affected by OCGS operations during the license renewal term or confirming AmerGen's conclusion that operation of OCGS over the license renewal term would have no adverse impact on any listed species. This will enable us to meet our application preparation schedule. AmerGen will include a copy of this letter and your response in the license renewal application that we submit to the NRC.

Please call Bill Maher at (610) 765-5939, if you have any questions or require any additional information to review the proposed action.

Sincerely,

D. G. Heller IFon

Michael P. Gallagher Director, Licensing & Regulatory Affairs AmerGen Energy Company, LLC

Attachments: 1) 6-Mile Vicinity Map

- Letters from Herbert Lord (NJDEP) to William Mahler (AmerGen), "Oyster Creek Generating Station to Manitou Transmission Line" and "Oyster Creek Generating Station," both dated September 22, 2004
- cc: Karen Tuccillo, NJ DEP BNE Dave Golden, NJ DEP DFW Dave Jenkins, NJ DEP DFW File No. 04007

101





_

ATTACHMENT 2

Letters from Herbert Lord (NJDEP) to William Mahler (AmerGen)

•

Oyster Creek Generating Station License Renewal Application



State of New Jersey

James E. McGreevey Governor Department of Environmental Protection Division of Parks and Forestry Office of Natural Lands Management Natural Heritage Program P.O. Box 404 Trenton, NJ 08625-0404 Tenton, NJ 08625-0404 Tenton, NJ 08625-0404 Tenton, Su 0864-1339 Fax, #609-984-1427

September 22, 2004

William Mahler Amergen Energy Company, LLC 200 Exclon Way Kennett Square, PA 19348

Re: Oyster Creek Generating Station to Manitou Substation Transmission Line

Dear Mr. Mahler:

Thank you for your data request regarding rare species information for the above referenced project site in Berkeley Township, Lacey Township and South Toms River Borough, Ocean County.

Searches of the Natural Heritage Database and the Landscape Project (Version 2) are based on a representation of the boundaries of your project site in our Geographic Information System (GIS). We make every effort to accurately transfer your project bounds from the topographic map(s) submitted with the Request for Data into our Geographic Information System. We do not typically verify that your project bounds are accurate, or check them against other sources.

We have checked the Natural Heritage Database for occurrences of rare plant species or natural communities. The Natural Heritage Data Base has records for occurrences of Juncus caesariensis and Calamovilfa brevipilis that may be on the site and for pitch pine-shrub oak barrens (pb4/5), pine-oak-shrub oak woodland (pow), pitch pine lowlands (undifferentiated), Rhynchospora knieskernii, Schizaea pusilla, Narthecium americanum and Muhlenbergia torreyana that may be in the immediate vicinity of the site. The attached lists provide more information about these occurrences. Because some species are sensitive to disturbance or sought by collectors, this information is provided to you on the condition that no specific locational data are released to the general public. This is not intended to preclude your submission of this information to regulatory agencies from which you are seeking permits.

We have also checked the Natural Heritage Database and the Landscape Project habitat mapping for occurrences of any rare wildlife species or wildlife habitat on the referenced site. Please see Table 1 for species list and conservation status.

New Jersey is an Equal Opportunity Employer Recycled Paper Bradley M. Campbell Commissioner

Common Name	Scientific Name	Federal Status	State Status	Grank	Srank
American rubyspot	Hetaerina americana			G5	S3
barred owl	Strix varia		тл	G5	S3B
bar-winged skimmer	Libellula axilena			· G5	S2BS3B,SZN
black skimmer foraging area	Rynchops niger		Ε.	G5	\$1B
black-crowned night-heron foraging habitat	Nycticorax nycticorax		T/S ·	G5	\$38,\$4N
black-throated green warbier	Dendroica virens		Soedal Concern	G5	\$3B
carpenter frog	Rana virgatipes	·	Special Concern	. G5	· S4
cerulean warbler	Dendroica cerulea		Special Concern	G4 .	\$3B
colonial waterbird foraging habitat	• •				
Cooper's hawk	Accipiter cooperli		T/T	G5	S38,S4N
com snake	Elaphe g. guttata		E	G5T5	\$1
datted skipper	Hesperia attalus siossonae		Special Concern	G3G4T3	* - ···\$2\$3
eastern box turtle	Terrapene carolina		Special Concern	G5 -	\$5B
eastern kingsnake	Lampropettis g. getula		U	G5T5	S3
Fowler's toad	Buto woodhousil fowlari		Special Concern	G5	S4
golden-winged skimmer	Libellula auripennis			G5	S1S2
Martha's pennant	Celithemis martha			G4	\$3\$4
northern parula	Parula americana		Special Concern	G5	S3B
northern pine snake	Pituophis m. melanoleucus		T	G4T4	53
pine barrens treefrog	Hyte andersonil		Т	G4 .	S3
red-headed woodpecker	Melanerpes erythrocephalus		. T/T	G5	S2B, S2N
spotted turtle	Clemmys guttata		Special Concern	G5	S4
tern species foraging habitat				•	
timber rattlesnake	Crotaius h. horridus	·	E	G4T4	S2
veery	. Cetherus fuscescens		Special Concern	G5 ·	\$3B
wood turtie	Clemmys insculpta		· T	G4	· S3

We have also checked the Natural Heritage Database and the Landscape Project habitat mapping for occurrences of any rare wildlife species or wildlife habitat within 1/4 mile of the referenced site. Please see Table 2 for species list and conservation status. This table excludes any species listed in Table 1.

Table 2 (additional spe	ecies within 1/4 mile of reference	ed site).		::	
Common Name	Scientific Name	Federal Status	State Status	Grank '	Srank
a satyr	Neonympha areolata septentrionalis			G4T3T4	83
•					

Also attached is a list of rare species and natural communities that have been documented from Ocean County. If suitable habitat is present at the project site, these species have potential to be present.

Status and rank codes used in the tables and lists are defined in the attached EXPLANATION OF CODES USED IN NATURAL HERITAGE REPORTS.

The Natural Heritage Program reviews its data periodically to identify priority sites for natural diversity in the State. Included as priority sites are some of the State's best habitats for rare and endangered species and natural communities. Four of these sites are located within or near the areas you have outlined. Please refer to the enclosed Natural Heritage Priority Site Maps for the locations and boundaries of these sites. On the back of each Priority Site Map is a report describing the significance of the site. You may find the site biodiversity significance rating to be useful if you need to prioritize among the sites in your environmental assessment.

If you have questions concerning the wildlife tecords or wildlife species mentioned in this response, we recommend that you visit the interactive I-Map-NJ website at the following URL, http://www.state.nj.us/dep/gis/imapnj/imapnj.htm or contact the Division of Fish and Wildlife, Endangered and Nongame Species Program.

PLEASE SEE THE ATTACHED 'CAUTIONS AND RESTRICTIONS ON NHP DATA'.

..

Thank you for consulting the Natural Heritage Program. The attached invoice details the payment due for processing this data request. Feel free to contact us again regarding any future data requests.

Sincerely,

Herbert a. Lord

Herbert A. Lord Data Request Specialist

cc: Robert J. Cartica Lawrence Niles NHP File No. 04-3907472

¢

21 SEP 2004

1

POSSIBLY ON PROJECT SITE BASED ON SEARCH OF NATURAL HERITAGE DATABASE RARE PLANT SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN

THE NEW JERSEY NATURAL HERITAGE DATABASE

-			•			•	••		
NAME	CONHON NUME	FEDERAL STATUS	STATE STATUS	REGIONAL STATUS	grank	FRANK	DATE OBSERVE	D IDENT.	LOCATION
••• Vascular plants CAIAMOVILFA PREVIPILIS	PINE BARREN REEDGRASS	•	· · ·	LP	G	54	1985-09-29	¥ .	N. OP HIDDLE BRANCH FORKED River, Just W. of Garden State Parkyay.
JUNCUS CATSARIENSIS	NEW JERSKY RUSH		E.	LP .	ca	52	1985-09-29	¥ 	N. OF HIDDLE BRANCH FORKED RIVER, JUST W. OF GARDEN STATE FARKWAY.

2 Records Processed

.

Environmental Report
Appendix C Special-Status Species Correspondence

1 21 SEP 2004

IMMEDIATE VICINITY OF PROJECT SITE BASED ON SEARCH OF NATURAL HERITAGE DATABASE RARE FLANT SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE

NAME .	COMMON NAME	FEDERAL	STATE STATUS	REGIONAL GRANK STAIVS	SRANK	DATE ÖBSERVED	IDENT.	LOCATION '
*** Ecosystems								
FINUS RIGIDA SATURATED WOODTAND ALLIANCE	PITCE PINE LOWLANDS (UNDIFFERENTIATED)		۰,	C3	53 .	2003-01-25	¥	SEVERAL PATCHES S OF JAKES BRANCH, N OF FINENALD RESNICK GROVE ROAD, EAST OF THE JCPL Pomerline, and N of the Garden State Parkway.
CINUS RIGIDA-(P. ECHINATA'-QUERCUS SPP./QUERCUS (MARILANDICA, ILICIFOLIA) *OCOLAND	PINE-OAK-SHRUB OAK HXXDLAND (PON)			G3	53	2003-01-25	¥	TWELVE SCATTERED PATCHES LOCATED SOUTH OF JAKES BRANCH, MOSTLY NORTH OF PINEWALD-KESWICK GROVE ROAD, MOSTLY EAST OF THE JCPL FOMERLINE, AND WEST OF THE CARDEN STATE FARMAY.
PINUS RIGIDA/QUERCUS (MARILANDICA, LICIFOLIA)/PYXIDANTHERA BARBULATA MOODLAND	PITCH PINE-SHRUB OAK BARRENS (PB4/5)			G2	Ş 2	2002-10-15	Y	TWO MAIN PATCHES ARE LOCATED SOUTH OF JAKES BRANCH, NORTH OF PINEWALD RESWICK GROVE ROAD, EAST OF JCPL POWERLINE,

.

N OF THE GARDEN D PATCHES JAKES BRANCH, GROVE ROAD, THE JCPL NEST OF THE REWAY. ARE LOCATED BRANCH, NORTH HICK GROVE CPL POWERLINE, AND WEST OF THE GARDEN STATE PARKHAY. PATCHES ARE LOCATED 0.5 TD 2.3 MILES NORTH OF THE DOUBLE TROUBLE STATE PARK ENTRANCE, PARTLY WITHIN JAKES BRANCH COUNTY PARK IN BEACHWOOD BORD, AND PARTLY WITHIN DOUBLE TROUBLE STATE FARK AND PRIVATE LANDS IN BERKELEY TWP.

Environmental Report Appendix C Special-Status Species Correspondence

Oyster Creek Generating Station License Renewal Application

2 21 SEP 2004

IMMEDIATE VICINITY OF PROJECT SITE BASED ON SEARCH OF NATURAL HERITACE DATABASE RARE FLANT SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE

							-		
NAME	CONHON NAME	FEDERAL STATUS	STATE STATE	REGION STATUS	IAL GRANK	SRANK	DATE OBSERVE	D IDENT.	LOCATION
• •	•.				•			•	
*** Vascular plants	·. · ·.								
WURLENBERGIA TORREYANA	PINE BARREN EMOKR CRASS		٠	LP	G3	S3	1985-09-29	¥	N. OF HIDDL
		•	•						RIVER, 0.25
· · · · ·	• •				-				STATE PARKWA
NARTHECIUM AMERICANUM	BOG ASPHODEL	с	R	LP .	C2	82	1995-09-04	Y	CA. 0.1 HTL
	•	•						• •	STATE PARKWA
•			•			•	• • •		BRANCH AND B
						÷ .		•	FORKED RIVER
									SOUTHWEST OF
•		•					•		OF RT. 9 AND
HYNCHOSPORA KNIESKERNII	KNIESKERN'S BEAKED-RUSH	LT	B	LP	G 2	52	1994-09-03	Y	N. OF MIDDLE
·.		·		•					RIVER, JUST
:		· •			·			·	. PARKWAY. APP
•	•						•		HILES SOUTH
,									OF GSP.
CHIZAPA PUSILLA	CURLY GRASS FERN			LP	G3	8 3	1907-07-25	¥	LANK INLET A
CHIZAEA PUSILLA	CURLY GRASS FERN		•	LP	G3	\$3	1915-07-10	Y ·	CEDAR SWAMP

Records, Processed

BRANCH FORKED MI. W. OF GARDEN ÀY. 28 EAST OF GARDEN AY BETWEEN MIDDLE SOUTH BRANCE OF R, CA. 2 HILES THE INTERSECTION LACEY RD. BRANCH FORKED W. OF GARDEN STATE PROXIMATELY 2.0 OF INTERCHANUE 74 AT DOUBLE TROUBLE. ALONG SOUTH BRANCH OF FORKED RIVER SW OF FORKED

.

Appendix C

Environmental Report Special-Status Species Correspondence

RIVER. .

Frequently Asked Questions About Natural Heritage Priority Sites

What are Natural Heritage Priority Sites? Through its Natural Heritage Database, the Office of Natural Lands Management (ONLM) identifies critically important areas to conserve New Jersey's biological diversity. The database provides detailed, up-to-date information on rare species and natural communities to planners, developers, and conservation agencies for use in resource management, environmental impact assessment, and both public and private land protection efforts.

Using the database, ONLM has identified Natural Heritage Priority Sites that represent some of the best remaining habitat for rare species and exemplary natural communities in the state. These areas should be considered to be top priorities for the preservation of biological diversity in New Jersey. If these sites become degraded or destroyed, we may lose some of the unique components of our natural heritage.

ONLM has identified 410 priority sites over the course of more than 10 years. We have received assistance from many partner individuals and agencies over this time. The Nature Conservancy and the DEP Endangered and Nongame Species Program have provided key information or assisted with the delineation of a number of the sites.

How are Natural Heritage Priority Site maps used in conservation of biological diversity? Natural Heritage Priority Site maps are used by individuals and agencies concerned with the protection and management of land. The maps have been used by municipalities preparing natural resource inventories; public and private conservation organizations preparing open space acquisition goals; land developers and consultants identifying environmentally sensitive lands; and public and private landowners developing land management plans.

Natural Heritage Priority Sites contain some of the best and most viable occurrences of endangered and threatened species and natural communities, but they do not cover all known habitat for endangered and threatened species in New Jersey. If information is needed on whether or not endangered or threatened species have been documented from a particular piece of land, a Natural Heritage Database search can be requested by contacting the Office of Natural Lands Management at the address below.

What do the boundaries of the sites contain? The boundaries of each Natural Heritage Priority Site are drawn to encompass critical habitat for the rare species or natural communities. Often the boundaries extend to include additional buffer lands that should be managed to protect the habitat. A justification for the boundary is provided for each site. The term "primary bounds" is sometimes used to refer to boundaries enclosing critical habitat. The term "secondary bounds" is sometimes used to refer to boundaries enclosing additional buffer. In maps where both primary and secondary boundaries are described, only the outermost boundary is provided in the mapping.

What is the background map that the sites are drawn upon?

The sites are portrayed on background maps produced from a digital copy of the U.S. Geological Survey 7.5 minute topographic maps. The background maps contain topographic lines as well as streams, lakes, roads, towns and place names. These background maps do not always reflect recent changes in land development. Some may be more than 20 years old. Some sites appear to be shifted in position against this topo map. This shift is due to the fact that most sites have been digitized against a background of rectified aerial photography, and some of the digitized USGS topo maps do not align with this photography.

What do "public lands" depict on the maps? The "public lands" shaded on these maps are stateowned open space lands that have been digitized as a GIS coverage by the state Green Acres Program. This information is provided to show patterns of State land ownership in the vicinity of the Priority Site. The public lands are areas such as State Parks and Forests, Wildlife Management Areas, and Natural Lands Trust preserves. They do not currently include lands owned by other state agencies, federal, county or municipal governments or nonprofit conservation organizations. This GIS coverage is constantly being updated, and therefore future editions of the maps will likely contain additional public lands that are not currently mapped as such.

What is the biodiversity significance rank and how is it used? Each site is ranked according to its significance for biological diversity using a scale developed by The Nature Conservancy and the network of Natural Heritage Programs. The ranks can be used to distinguish between sites that are of global significance for conservation of biological diversity vs. those that are of state significance. The scale ranges from B1 to B5 with sites ranked B1-B3 generally being of global significance. The specific definitions for each rank are as follows:

B1 - Outstanding significance, generally the "last of the least" in the world, such as the only known occurrence of any element (species or natural community), the best or an excellent occurrence of an element ranked critically imperiled globally, or a concentration (4+) of good or excellent occurrences of elements that are imperiled or critically imperiled globally. The site should be viable and defensible for the elements or ecological processes contained.

B2 - Very high significance, such as the most outstanding occurrence of any natural community. Also includes areas containing other occurrences of elements that are critically imperiled globally, a good or excellent occurrence of an element that is imperiled globally, an excellent occurrence of an element that is rare globally, or a concentration (4+) of good occurrences of globally rare elements or viable occurrences of globally imperiled elements.

B3 - High significance, such as any other viable occurrence of an element that is globally imperiled, a good occurrence of a globally rare element, an excellent occurrence of any natural community, or a concentration (4+) of good or excellent occurrences of elements that are critically imperiled in the State.

B4 - Moderate significance, such as a viable occurrence of a globally rare element, a good occurrence of any natural community, a good or excellent occurrence or only viable state occurrence of an element that is critically imperiled in the State, an excellent occurrence of an element that is imperiled in the State, or a concentration (4+) of good occurrences of elements that are imperiled in the State or excellent occurrences of

elements that are rare in the State.

B5 - Of general biodiversity interest.

How can I obtain Natural Heritage Priority Site maps for an area of interest to me? Natural Heritage Priority Site hard copy maps can be obtained by submitting a written request accompanied by a check or money order made payable to the Office of Natural Lands Management at the following address:

Office of Natural Lands Management P.O. Box 404 Trenton, NJ 08625-0404 Phone: 609-984-1339; Fax: 609-984-1427

Individual 8.5" X 11" maps are available at the

1 - 10 site maps & reports:	\$1.50/site
11 - 20 site maps & reports:	\$1.00/site ·
> 20 sites:	\$0.50/site

Digital GIS Coverage of Natural Heritage Priority Sites A digital version of the AreView GIS file of Natural Heritage Priority Sites is also available. The zipped version of the file is approximately 1 MB in size. The 2001 version of Natural Heritage Priority Sites will be emailed upon request. The 1999 version of the digital files can be obtained on the internet at the following address: http://www.state.nj.us/dep/gis/ -Click on "GIS Data Downloads" and then "Select a data layer" and then "Natural Heritage Priority Sites". There is no charge for emailing or downloading the GIS data.

How often are the maps updated? The Natural Heritage Priority Site information is constantly being updated in the Natural Heritage Database. A new edition of the maps will be made . available after significant revisions or additions to the Database.

April 9, 2002



ND Department of Environmental Protection Division of Parks and Forestry Natural Lands Management

Oyster Creek Generating Station License Renewal Application Page C-23


Natural Heritage Priority Site Crossley RR Corridor Macrosite

Locational Information

Quad Name: Keswick Grove ; Toms River

County: Ocean

Municipality Berkeley Twp ; Manchester Twp ; Lacey Twp ; Beachwood Boro ; South Toms River Boro

Description of Site

A large patch of contiguous pine/oak woods with predominantly Lakehurst soils.

Boundary Justification

Bounds drawn to include large contiguous patch of pine/oak uplands that is habitat to endangered and threatened animal species.

Biodiversity Rank B4

Excellent site for State Endangered and Threatened animal species.

July, 2001 Natural Lande Management











Oyster Creek Generating Station License Renewal Application

Natural Heritage Priority Site Forked River Mountain Macrosite

Locational Information

Quad Name: Brookville; Forked River; Woodmansie; Keswick Grove; Whiting, County: Ocean

Municipality Lacey Twp; Ocean Twp; Manchester Twp; Barnegat Twp

Description of Site

A few small occurrences of dwarf pine plains (<150 acres) associated with up to 1000+ acres of transitional pine plains, and several small occurrences of hydric pine plains. Most of the plains are in the vicinity of Forked River Mountain, near the center of a large fireshed of over 30,000 acres. Within the fireshed are extensive occurrences of pitch pine-scrub oak barrens, other pine barrens and pine-oak forests, pitch pine lowlands, red maple-black gum palustrine forest, and atlantic white cedar palustrine forest.

Boundary Justification

Fireshed limits where most plant community-maintaining wildfires would originate and be contained within, using convenient man-made and natural firebreaks and distribution of flammable pine barren plant communities for management purposes.

Biodiversity Rank B2

The site contains a globally imperiled pine plains natural community.

Oyster Creek Generating Station License Renewal Application

Natural Lands Managemen

Page C-27

July, 2001

S.USNJHP1*236

Site Code:



Ocean County



Natural Heritage Priority Site Middle Branch Forked River

Locational Information Quad Name: Forked River County: Ocean

Municipality Lacey Twp

Description of Site

Open wetlands adjacent to pine barren stream through Atantic white cedar swamp.

Boundary Justification

Boundaries include wetland habitat for rare plant species plus undeveloped uplands in the drainage basin east of the Garden State Parkway. With additional field work, bounds may be expanded upstream west of the Parkway.

Biodiversity Rank B2

Several globally rare and State listed plant species.





Natural Heritage Priority Site Pits and Pond

Locational Information

Quad Name:Forked RiverCounty:OceanMunicipalityLacey Twp

Description of Site

Two borrow pits (heavily used by ORV's) under and adjacent to mowed pipeline right-of-way through pitch pine lowland forest.

Boundary Justification

Uses existing sand roads to north, west, and south to enclose the adjacent wetlands and uplands draining towards the rare plants, with the Garden State Parkway forming the eastern boundary.

Biodiversity Rank B2

The site contains four globally rare plant species, two of which are state endangered, and one of which is also federally threatened.



July, 2001 Site Code: S.USNJHP1*440

Oyster Creek Generating Station License Renewal Application i

Environmental Report Appendix C Special-Status Species Correspondence

James E. McGreevey Governor



Department of Environmental Protection Division of Parks and Forestry Office of Natural Lands Wanagement Natural Heritage Program P.O. Box 404 Trenton, NJ 08625-0404 Tel: #609-984-1339 Fax, #609-984-1427

September 22, 2004

William Mahler Amergen Energy Company, LLC 200 Exclon Way Kennett Square, PA 19348

Re: Oyster Creek Generating Station

Dear Mr. Mahler:

Thank you for your data request regarding rare species information for the above referenced project site in Lacey Township, Ocean County.

Searches of the Natural Heritage Database and the Landscape Project (Version 2) are based on a representation of the houndaries of your project site in our Geographic Information System (GIS). We make every effort to accurately transfer your project bounds from the topographic map(s) submitted with the Request for Data into our Geographic Information System. We do not typically verify that your project bounds are accurate, or check them against other sources.

We have checked the Natural Heritage Database and the Landscape Project habitat mapping for occurrences of any rare wildlife species or wildlife habitat on the referenced site. Please see Table 1 for species list and conservation status.

Common Name	Scientific Name	Federal Status	Slate Status	Grank	Srank
barred owl	Strix varia		T/T	G5	S38
black skimmer foraging area	Rynchops niger		E	G5	S1B
black-crowned night-heron foraging habitat	Nycticorax nycticorax		T/S	G5	\$38,54N
colonial waterbird foraging habitat					
Cooper's hawk	Accipiter cooperil		Т/Т	G5	\$38,\$4N
dolted skipper	Hesporia attalus slossonas		Special Concern	G3G4T3	S2S3
eastem box turtle	Terrapene carolina	•	Special Concern	G5	S5B
Fowler's toad	Buto woodhousil fowler		Special Concern	G5	S4
northern pine snake	Pituophis m. melanoleucus		т	G4T4	S3
pine barrens treefrog	Hyla andersonil		T	G4	S3
tern species foraging habitat					
wood turtle	Clemmys insculpta	1	т	G4	S3

Table 1 (on referenced site).

We have also checked the Natural Heritage Database and the Landscape Project habitat mapping for occurrences of any rare wildlife species or wildlife habitat within 1/4 mile of the referenced site. Please see Table 2 for species list and conservation status. This table excludes any species listed in Table 1.

Table 2 (additional species within 1/4 mile of referenced site).

Common Name	Scientific Name	Federal Status	State Status	Grank	Srank
spotled turile	Clemmys guttata		Special Concern	G5	S4

We have also checked the Natural Heritage Database for occurrences of rare plant species or natural communities. The Natural Heritage Data Base has records for occurrences of Narthecium americanum that may be on the site, and for Pycnanthemum setosum that may be on or in the immediate vicinity of the site, and for Eupatorium resinosum, Pycnanthemum setosum, Juncus caesariensis and Schizaea pusilla that may be in the immediate vicinity of the site. The

New Jersey is an Equal Opportunity Employee Recycled Paper Bradley M. Campbell Commissioner attached lists provide more information about these occurrences. Because some species are sensitive to disturbance or sought by collectors, this information is provided to you on the condition that no specific locational data are released to the general public. This is not intended to preclude your submission of this information to regulatory agencies from which you are seeking permits.

Also attached is a list of rare species and natural communities that have been documented from Ocean County. If suitable habitat is present at the project site, these species have potential to be present.

Status and rank codes used in the tables and lists are defined in the attached EXPLANATION OF CODES USED IN NATURAL HERITAGE REPORTS.

The Natural Heritage Program reviews its data periodically to identify priority sites for natural diversity in the State. Included as priority sites are some of the State's best habitats for rare and endangered species and natural communities. One of these sites is located within or near the areas you have outlined. Please refer to the enclosed Natural Heritage Priority Site Map for the location and boundary of this site. On the back of each Priority Site Map is a report describing the significance of the site.

If you have questions concerning the wildlife records or wildlife species mentioned in this response, we recommend that you visit the interactive I-Map-NJ website at the following URL, http://www.state.nj.us/dep/gis/imapnj/imapnj.htm or contact the Division of Fish and Wildlife, Endangered and Nongame Species Program.

PLEASE SEE THE ATTACHED 'CAUTIONS AND RESTRICTIONS ON NHP DATA'.

Thank you for consulting the Natural Heritage Program. The attached invoice details the payment due for processing this data request. Feel free to contact us again regarding any future data requests.

Sincerely,

Herbert a. Lord

Herbert A. Lord Data Request Specialist

cc: Robert J. Cartica Lawrence Niles NHP File No. 04-3907472

CAUTIONS AND RESTRICTIONS ON NATURAL HERITAGE DATA

The quantity and quality of data collected by the Natural Heritage Program is dependent on the research and observations of many individuals and organizations. Not all of this information is the result of comprehensive or site-specific field surveys. Some natural areas in New Jersey have never been thoroughly surveyed. As a result, new locations for plant and animal species are continuously added to the database. Since data acquisition is a dynamic, ongoing process, the Natural Heritage Program cannot provide a definitive statement on the presence, absence, or condition of biological elements in any part of New Jersey. Information supplied by the Natural Heritage Program summarizes existing data known to the program at the time of the request regarding the biological elements or locations in question. They should never be regarded as final statements on the elements or areas being considered, nor should they be substituted for on-site surveys required for environmental assessments. The attached data is provided as one source of information to assist others in the preservation of natural diversity.

. This office cannot provide a letter of interpretation or a statement addressing the classification of wetlands as defined by the Freshwater Wetlands Act. Requests for such determination should be sent to the DEP Land Use Regulation Program, P.O. Box 401, Trenton, NJ 08625-0401.

The Landscape Project was developed by the Division of Fish & Wildlife, Endangered and Nongame Species Program to map critical habitat for rare animal species. Some of the rare species data in the Landscape Project is in the Natural Heritage Database, while other records were obtained from other sources. Natural Heritage Database response letters will list all species (if any) found during a search of the Landscape Project. However, any reports that are included with the response letter will only reference specific records if they are in the Natural Heritage Database. This office. cannot answer any inquiries about the Landscape Project. All questions should be directed to the DEP Division of Fish and Wildlife, Endangered and Nongame Species Program, P.O. Box 400, Trenton, NJ 08625-0400.

This cautions and restrictions notice must be included whenever information provided by the Natural Heritage Database is published.

nental Prot of Parks and Forestry latural Lands Management ÷

21 SEP 2004

1

.

POSSIBLY ON PROJECT SITE BASED ON SEARCH OF NATURAL HERITAGE DATABASE RARE PLANT SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE

NIME	COMMON NAME	FEDERAL STATUS	STATE STATUS	REGION	AL CRANK	SRANK	DATE OBSERVI	E IDENT.	LOCATION
*** Vascular plants NARTHECTUM AMERICANUM	BOG ASPRODEL	. c	E	LP	G2	\$2	1991-05-22	Y	CA. 1 MILE EAST-MORTHEAST OF OYSTER CREEK POWER PLANT AND SOUTH OF THE SOUTH BRANCE OF POREED BIVES. APPROXIMATELY 1
• .	• •								1/2 NTLES SOUTH OF THE INTERSECTION OF ROUTE 9 AND LACEY ROAD.
1 Records Processed									·
• • • • •		•							

.

		CN OR 1	N INDEDIAT	L VICINITY OF FROJ	TECT SITE	_		
	649	BASED O	AND MATTIN	AL COMMENTIES DEE	CONTRRASI			
		THE NE	W JERSEY N	ATURAL HERITAGE DA	TABASE			
NAME	COMMON NAME	FELERAL	STATE	REGIONAL GRANK	SRANK	DATE OBSERVED	IDENT.	LOCATION
		STATUS	STATUS	STATUS				
*** Vascular plants								
PYCNANTHFMUM SETOSIM	anned mountain nint			637	53	1993-77-7?	¥	SOUTH OF ORLANDO DRI NORTH OF OYSTER CREE TWP.
1 kecords Processed								

Page.C-36

ĺ

i

Environmental Report Appendix C Special-Status Species Correspondence Oyster Creek Generating Station License Renewal Application

1 21 SEP 2004

NEME

~

Page C-37

COMMON NAME FEDERAL STATE STATUS STATUS *** Vascular plants EUPATORIUM RESINCEUM PINE BARREN DONESET R JUNCUS CAESARIENSIS NEW JERSEY RUSH E LP ANNED HOUNTATH MINT

037 53 PYCNANTHEMUM SETOSUM FYCNANTHEMIM SETOSIM AWNED MOUNTAIN MINT G37 93 G37 63 PYCNANTHEMUN SETOSUM . SCHIZAEA PUSILLA CURLY GRASS FERN 83 LP G3 6 Records Processed

Q3 82 LP .

• . .

REGIONAL GRANK SRANK DATE OBSERVED IDENT. LOCATION STATUS

G2

\$2

INMEDIATE VICINITY OF PROJECT SITE . BASED ON SEARCH OF NATURAL HERITAGE DATABASE RARE PLANT SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE

> NORTH OF BAY PAREWAY. IN RECOVERING CRANBERRY BOG ON SOUTH BANK OF OYSTER CREEK. 1922-09-77 ï۳ OYSTER CREEK ALCING TUCKERTON ER, NW (OF) WARETOWN. 1993-77-77 Y WEST OF CABLE ROAD AND RAST OF DOCK ROAD AND & SMALL 1993-77-77 Y SANDS HARBOR FOINT, PARKWAY. 1993-77-77 Y OYSTER CREEK. 1915-07-10 Y

.

۲

1993-08-77

EMBANEMENT OF OYSTER CREEK. NORTHERNMOST TIP, NORTH OF BAY EAST SIDE OF ROUTE 9, JUST NORTH OF BAY PARKWAY, SOUTH OF BY OYSTER CREEK NW ALONZ TUCKERTON RR FROM WARETOWN.

EAST SIDE OF ROUTE 9 JUST

Frequently Asked Questions About Natural Heritage Priority Sites

What are Natural Heritage Priority Sites? Through its Natural Heritage Database, the Office of Natural Lands Management (ONLM) identifies critically important areas to conserve New Jersey's biological diversity. The database provides detailed, up-to-date information on rare species and natural communities to planners, developers, and conservation agencies for use in resource management, environmental impact assessment, and both public and private land protection efforts.

Using the database, ONLM has identified Natural Heritage Priority Sites that represent some of the best remaining habitat for rare species and exemplary natural communities in the state. These areas should be considered to be top priorities for the preservation of biological diversity in New Jersey. If these sites become degraded or destroyed, we may lose some of the unique components of our natural heritage.

ONLM has identified 410 priority sites over the course of more than 10 years. We have received assistance from many partner individuals and agencies over this time. The Nature Conservancy and the DEP Endangered and Nongame Species Program have provided key information or assisted with the delineation of a number of the sites.

How are Natural Heritage Priority Site maps used in conservation of biological diversity? Natural Heritage Priority Site maps are used by individuals and agencies concerned with the protection and management of land. The mapshave been used by municipalities preparing natural resource inventories; public and private conservation organizations preparing open space acquisition goals; land developers and consultants identifying environmentally sensitive lands; and public and private landowners developing land management plans.

Natural Heritage Priority Sites contain some of the best and most viable occurrences of endangered and threatened species and natural communities, but they do not cover all known habitat for endangered and threatened species in New Jersey. If information is needed on whether or not endangered or threatened species have been documented from a particular piece of land, a Natural Heritage Database search can be requested by contacting the Office of Natural Lands Management at the address below.

What do the boundaries of the sites contain? The boundaries of each Natural Heritage Priority Site are drawn to encompass critical habitat for the rare species or natural communities. Often the boundaries extend to include additional buffer lands that should be managed to protect the habitat. A justification for the boundary is provided for each site. The term "primary bounds" is sometimes used to refer to boundaries enclosing critical habitat. The term "secondary bounds" is sometimes used to refer to boundaries enclosing additional buffer. In maps where both primary and secondary boundaries are described, only the outermost boundary is provided in the mapping.

What is the background map that the sites are drawn upon?

The sites are portrayed on background maps produced from a digital copy of the U.S. Geological Survey 7.5 minute topographic maps. The background maps contain topographic lines as well as streams, lakes, roads, towns and place names. These background maps do not always reflect recent changes in land development. Some may be more than 20 years old. Some sites appear to be shifted in position against this topo map. This shift is due to the fact that most sites have been digitized against a background of rectified aerial photography, and some of the digitized USGS topo maps do not align with this photography.

What do "public lands" depict on the maps? The "public lands" shaded on these maps are stateowned open space lands that have been digitized as a GIS coverage by the state Green Acres Program. This information is provided to show patterns of State land ownership in the vicinity of the Priority Site. The public lands are areas such as State Parks and Forests, Wildlife Management Areas, and Natural Lands Trust preserves. They do not currently include lands owned by other state agencies, federal, county or municipal governments

Page.C-38

or nonprofit conservation organizations. This GIS coverage is constantly being updated, and therefore future editions of the maps will likely contain additional public lands that are not currently mapped as such.

What is the biodiversity significance rank and how is it used? Each site is ranked according to its significance for biological diversity using a scale developed by The Nature Conservancy and the network of Natural Heritage Programs. The ranks can be used to distinguish between sites that are of global significance for conservation of biological diversity vs. those that are of state significance. The scale ranges from B1 to B5 with sites ranked B1-B3 generally being of global significance. The specific definitions for each rank are as follows:

B1 - Outstanding significance, generally the "last of the least" in the world, such as the only known occurrence of any element (species or natural community), the best or an excellent occurrence of an element ranked critically imperiled globally, or a concentration (4+) of good or excellent occurrences of elements that are imperiled or critically imperiled globally. The site should be viable and defensible for the elements or ecological processes contained.

B2 - Very high significance, such as the most outstanding occurrence of any natural community. Also includes areas containing other occurrences of elements that are critically imperiled globally, a good or excellent occurrence of an element that is imperiled globally, an excellent occurrence of an element that is rare globally, or a concentration (4+) of good occurrences of globally rare elements or viable occurrences of globally imperiled elements.

B3 - High significance, such as any other viable occurrence of an element that is globally imperiled, a good occurrence of a globally rare element, an excellent occurrence of any natural community, or a concentration (4+) of good or excellent occurrences of elements that are critically imperiled in the State.

B4 - Moderate significance, such as a viable occurrence of a globally rare element, a good occurrence of any natural community, a good or excellent occurrence or only viable state occurrence of an element that is critically imperiled in the State, an excellent occurrence of an element that is imperiled in the State, or a concentration (4+) of good occurrences of elements that are imperiled in the State or excellent occurrences of

elements that are rare in the State.

B5 - Of general biodiversity interest.

How can I obtain Natural Heritage Priority Site maps for an area of interest to me? Natural Heritage Priority Site hard copy maps can be obtained by submitting a written request accompanied by a check or money order made payable to the Office of Natural Lands Management at the following address:

Office of Natural Lands Management P.O. Box 404 Trenton, NJ 08625-0404 Phone: 609-984-1339; Fax: 609-984-1427

Individual 8.5" X 11" maps are available at the

following rate:		•	
1 - 10 site maps & repor	ts:	. •	\$1.50/site
11 - 20 site maps & repo	rts:		\$1.00/site
> 20 sites:	۰.	•	\$0.50/site

Digital GIS Coverage of Natural Heritage Priority Sites

A digital version of the AreView GIS file of Natural Heritage Priority Sites is also available. The zipped version of the file is approximately 1 MB in size. The 2001 version of Natural Heritage Priority Sites will be emailed upon request. The 1999 version of the digital files can be obtained on the internet at the following address: http://www.state.nj.us/dep/gis/ -Click on "GIS Data Downloads" and then "Select a data layer" and then "Natural Heritage Priority Sites". There is no charge for emailing or downloading the GIS data.

How often are the maps updated? The Natural Heritage Priority Site information is constantly being updated in the Natural Heritage Database. A new edition of the maps will be made available after significant revisions or additions to the Database.

April 9, 2002



NI Department of Environmental Protection Division of Parks and Forestry Natural Lands Management

Oyster Creek Generating Station License Renewal Application



Natural Heritage Priority Site Middle Branch Forked River

Locational Information

Quad Name:Forked RiverCounty:OceanMunicipalityLacey Twp

Description of Site

Open wetlands adjacent to pine barren stream through Atantic white cedar swamp.

Boundary Justification

Boundaries include wetland habitat for rare plant species plus undeveloped uplands in the drainage basin east of the Garden State Parkway. With additional field work, bounds may be expanded upstream west of the Parkway.

Biodiversity Rank B2

Several globally rare and State listed plant species.

Natural Lands Management

July, 2001 Sile Code: S.USNJIP 1*365

Oyster Creek Generating Station License Renewal Application

Environmental Report Appendix C Special-Status Species Correspondence

EXPLANATIONS OF CODES USED IN NATURAL HERITAGE REPORTS

FEDERAL STATUS CODES

The following U.S. Fish and Wildlife Service categories and their definitions of endangered and threatened plants and animals have been modified from the U.S. Fish and Wildlife Service (F.R. Vol. 50 No. 188; Vol. 61, No. 40; F.R. 50 CFR Part 17). Federal Status codes reported for species follow the most recent listing.

- LE Taxa formally listed as endangered. LT Taxa formally listed as threatened.
- PE Taxa already proposed to be formally listed as endangered.
 - PT Taxa already proposed to be formally listed as threatened.
 - C Taxa for which the Service currently has on file sufficient information on biological vulnerability and threat(s) to support proposals to list them as endangered or threatened species.
 - S/A Similarity of appearance species.

STATE STATUS CODES

Two animal lists provide state status codes after the Endangered and Nongame Species Conservation Act of 1973 (NSSA 23:2A-13 et, seq.): the list of endangered species (N.J.A.C. 7:25-4.13) and the list defining status of indigenous, nongame wildlife species of New Jersey (N.J.A.C. 7:25-4.17(a)). The status of animal species is determined by the Nongame and Endangered Species Program (ENSP). The state status codes and definitions provided reflect the most recent lists that were revised in the New Jersey Register, Monday, June 3, 1991.

- Declining species a species which has exhibited a continued decline in population numbers over the years. D Endangered species-an endangered species is one whose prospects for survival within the state are in immediate danger due to one or F many factors - a loss of habitat, over exploitation, predation, competition, disease. An endangered species requires immediate assistance or extinction will probably follow. Extirpated species-a species that formerly occurred in New Jersey, but is not now known to exist within the state. ΕX Introduced species-a species not native to New Jersey that could not have established itself here without the assistance of man. Т ... increasing species-a species whose population has exhibited a significant increase, beyond the normal range of its life cycle, over a long INC term period. 2 т Threatened species-a species that may become endangered if conditions surrounding the species begin to or continue to deteriorate. Peripheral species-a species whose occurrence in New Jersey is at the extreme edge of its present natural range.
 - S Stable species-a species whose population is not undergoing any long-term increase/decrease within its natural cycle.

U . Undetermined species-a species about which there is not enough information available to determine the status.

Status for animals separated by a slash() indicate a duel status. First status refers to the state breeding population, and the second status refers to the migratory or winter population.

•			•	•		•		
• .	•.	•	•					
	-		•				•	
			.•		•		•	
		• •					•	
		• •	••					Page 2
		• • •	• • • •					•
•		• •	•		. •.		• •	
lant taxa listed as	endangered are from I	New Jersey's official En	dangered Plant Specie	s List NJ.S.A. 13	18-15.151 et sei	1		
· •	•				•	•		
• ·					•			
	Native New Jersey Di	lant species whose surv	vival in the State of Ita	tion is in Jeopard	Ŷ			
	••.	•		•		•••		
ECIONAL STATUS	CODES FOR PLANTS							
•			• .• . :			•		
				• .				•.•
	Indicates taxa listed	i by the Pinelands Com	mission as endangere	d or threatened v	vithin their legal	jurisdiction. No	t all species (urrently
	tracked by the Pinel	ands Commission are t	racked by the Natural	Heritage Program	n. A complete il	st of endangere	d and threater	ned
• • •	Pineland species is i	included in the New Jer	sey Pinelands Compre	hensive Manager	nent Plan.	• .		•
	• :			•	•		. •.	
				• . •			• •	
PLANATION OF C	LOBAL AND STATE EL	EMENT RANKS		• •	•	• ·		
•••	• • •				,		· · ·	
e Nature Conser	vancy has developed a	ranking system for use	e in identifying eleme	nts frare species	and natural com	munities) of nati	ural diversity	mast
- d d - deb								
udangered with ex	Minction. Each elemen	nt is ranked according t	to its global, national,	and state (or sui	national in othe	r countries) rari	cy. Inese ran	ks are used
o prioritize conser	vation work so that th	e most endangered ele	ments receive attenti	on first. Definitio	ins for element r	anks are after Ți	he Nature Cor	servancy
982: Chapter 4, 4	6.1-1 through 4.4.1.3-	-3).						
			• . •	·' ·		•		
	• •	• • •			• • •			•
LOBAL ELEMENT F	ANKS	•		· ·.	1	•		•
• • • •		•	• • •			•	•	• .
CI	Critically Imperiled	globally because of ext	treme rarity (5 or fewe	r occurrences or	very few remaini	ing Individuals o	r acres) or be	cause of
	some factor(s) mak	ing it expectativasiners		. •	•	••		
•	source sector (s) men			.•	•.		3.0	
•		• •		۰.	•	· · ·		
. C2	imperiled globally b	ecause of rarity (6 to 2	to occurrences or few	remaining Individ	duals or acres) o	r because of sor	ne factor(s) m	sking it .
	very vulnerable to e	extinction throughout it	is rance.				· •	
						•	•	
		•					•	
C3	Either very rare and	focal throughout its ra	inge or found locally (even abundantly	at some of its lo	cations) in a res	tricted range	(e.g., a
	single western state	e, à physiographic regi	on in the East) or beca	use of other fact	ors making it vul	nerable to extin	ction through	out It's
· ·	'range: with the nun	nber of occurrences in i	the range of 21 to 10	n '				
						•		•
	•			• •	•	• .	•	
G4 ·	Apparently secure g	globally; although it ma	iy be quite rare in par	ts of its range, es	pecially at the p	eriphery.	•	
			÷	•	. •	•		
·	Demonstrably serve	re globally: although #	may be quite rare in	parts of ite ranne	especially at the	e nerioherv	•••	•
	Server and a second	i				· · · · · · · · · · · · · · · · ·		
		•		•				
CH	Of historical occurr	rence throughout its rai	nge I.e., formerly part	of the establishe	d blota, with the	expectation the	it It may be re	discovered.
		• • •	•	· .		•		
си.	Possibly to part the	na-wide but statue un	certaia: mare informa	tion needed	· ·			•
CU.	Possibly in peril far	ige-wide but status un	· · ·	tion fireded.	· •	•	•	
•		•		, • •		· •.	· •	
cx	Believed to be extir	nct throughout range (e	r.g., passenger pigeor) with virtually n	o likelihood that	It will be redisci	overed.	
•		•	•					
. a	factor has a to	·	· · •		•		•	•
G	opecies has not yet	DEEL LUKED.	•		•			•
 .		•			•			
TATE ELEMENT RA	ANKS	•	•	•				
	-	•			• •			

S1 Critically imperiled in New Jersey because of extreme rarity (5 or fewer occurrences or very few remaining individuals or acres). Elements so ranked are often restricted to very specialized conditions or habitats and/or restricted to an extremely small geographical area of the state. Also included are elements which were formerly more abundant, but because of habitat destruction or some other critical factor of its biology, they have been demonstrably reduced in abundance. In essence, these are elements for which, even with intensive searching, sizable additional occurrences are unlikely to be discovered.

. .

•

.

•

.

.

Oyster Creek Generating Station License Renewal Application

.

Page C-43

Environmental Report Appendix C Special-Status Species Correspondence

	· · · ·	Pege 3
,	Immeried in New Jersey because of ratio (6 to 20 occurrences). Historically many of these elements may have been n	nore frequent but
•	inspersed in new jersely because of handy to to 20 occurrencess, misconcers in any or these crements in many interested and the second and the se	ald additional
	are now known nom very lew extant occurrences, primarily because or nabilat destruction. Drigent starching may y	
	occurrences,	Ę.
L .	Rare in state with 21 to 100 occurrences (plant species in this category have only 21 to 50 occurrences). Includes ele	ements which are
	widely distributed in the state but with small populations/acreage or elements with restricted distribution, but locally	y abundant. Not yet
	Imperied in state but may soon be if current trends continue. Searching often yields additional occurrences.	
•		
,	Annasanthi secure in state with many occurrences	
•	Apparentiy secure in state, with many occurrences.	•
5	Demonstrably secure in state and essentially ineradicable under present conditions.	•
•		
ι	Accidental in state, including species (usually birds or butterflies) recorded once or twice or only at very great interva	ls, hundreds or even
	thousands of miles outside their usual range; a few of these species may even have bred on the one or two occasions	they were recorded
	examples include European strave or western birds on the East Coast and vice-vesta	•
	exemples module complete strays of weatern birds on the cast coast and site-verse.	
_	and the second	
E	Elements that are clearly exotic in New Jersey including those taxa not native to North America (introduced taxa) or t	axa deliberately of
	accidentally introduced into the State from other parts of North America (adventive taxa). Taxa ranked SE are not a co	onservation priority
	(viable introduced occurrences of G1 or G2 elements may be exceptions).	
		:/.
н	Elements of historical occurrence in New Jersey. Despite some searching of historical occurrences and/or potential h	abitat, no extart
· .	occurrences are known. Since not all of the historical occurrences have been field surveyed, and unsearched notenti-	al habitat remains.
	bista deally waked taxes are careford and provide a vesation and campion a concentration of outine of antipued field work	·r.
	historickny ranked taxa are considered possibly extant, and remain a conservation priority for continued field work.	
	Claurens han antenstatus annus la timu lassan hut an assurement have been terrested	
r	Liement has potential to occur in New Jersey, but no occurrences have been reported.	
R	Elements reported from New Jersey, but without persuasive documentation which would provide a basis for either ac	cepting or rejecting
	the report. In some instances documentation may exist, but as of yet, its source or location has not been determine	d.
	· .	• .
RF	Elements erroneously reported from New Jersey, but this error persists in the literature.	
	· · · · · · · · · · · · · · · · · · ·	
	Channess to the state to be to possible up the descent of some succession. Also healeded are received of spreatein taxonom	sical standing. More
υ.	plements believed to be in perit but the degree of farity uncertain, wiso included are take take of uncertain taxonom	incar standing. more
	Information is needed to resolve rank.	
	·	
X	Elements that have been determined or are presumed to be extirpated from New Jersey. All historical occurrences h	ave been searched
	and a reasonable search of potential habitat has been completed. Extirpated taxa are not a current conservation pri	ority.
	·	
	Flaments presumed avelenated from New Jarcey, but pative populations collected from the wild exist in cultivation.	
	Demens presentes excepted nominew jersey, but raine populations concered nominal entry in campoon	
	n an	
Z	Not of practical conservation concern in New Jersey, because there are no definable occurrences, although the taxon	i is native and
	appears regularly in the state. An SZ rank will generally be used for long distance migrants whose occurrences durin	ng their migrations
	are too irregular (in terms of repeated visitation to the same locations), transitory, and dispersed to be reliably ident	lified, mapped and
	protected. In other words, the migrant regularly passes through the state, but enduring, mappable element occurre	nces cannot be
	defined.	
		•
	Yuntashiy oka CY parts annihas on a nan-braadhan nanyiysia- 188 to ata asas. faravamula kirda an mlanasian da C	7 rank mail in a faire
	rypically, the 52 tank applies to a non-preesing population (N) in the state - for example, birds on migration. An 5	A TANK MAY IN A TOW
	Instances also apply to a breeding population (B), for example certain lepidoptera which regularly die out every year	with no significant
	return migration.	
	•	

Abhough the 52 rash typically applies to migrants, it should not be used indicationately. Just because a species is on migration does not mean it necesses an 52 will only apply when the migrants excur in an irregular, transitory and dispersed marker. Refers to the benching opplication of the element in the state. The Benest make containing a "T indicate that the infrageding turon is being marked differently than the hill species. For example Sockyr publicity of an another dispersed marker, and the state. The Benest make containing a "T indicate that the infrageding turon is being marked differently than the hill species. For example Sockyr publicity or a dispersed or uncertainty as a "T indicate that the infrageding turon is being marked differently than the hill species. For example Sockyr publicity or a dispersed or uncertainty as a "T indicate base that the infrageding turon is being marked differently than the hill species. For example Sockyr publicity or a dispersed or uncertainty as a "T indicate base to the species is globally secure but the global and the sock as not base dispersed to marke dispersed to the species or uncertainty as a "D in policy and the sack hill be trans in date species that the uncertainty as a species of the species or community has been checked by a mitable indicate of a indicate be dispersed or a species or community has been checked by a mitable indication of the species or a community mark be called and be indicative of significant habitat. The deminication has not been verified and be indicative of significant habitat. The the maximum ty mark be confusing of dispersed. The transmitty mark be confusing of dispersed. The transmitty mark be confusing of dispersed. The transmitty mark be confusing of dispersed. The transmitter is a species o		
Although the 52 rank typically applies to migranis, it should not be used inductioninestyl. Just because a species is on migration does not mean it receives an 52 rank. 52 will only upply when the migrates occur in an irregular, transitory and dispersed manner. Refers to the breading population of the element in the state. Refers to the non-breading population of the element in the state. Refers to the non-breading population of the element in the state. Refers to the non-breading population of the element in the state. Refers to the non-breading population of the element in the state. Refers to the non-breading population of the element in the state. Refers to the non-breading population of the element in the state. Refers to the non-breading population of the element in the state. Refers to the non-breading population of the element in the state. Refers to the non-breading population of the element in the state. Refers to the non-breading population of the element in the state. Refers to the non-breading population of the state in inflaged to a state a plotably secure but the global rathy of the var. Annatotic has not been determined, in they far place the state is plotably secure but the global rathy of the var. Annatotic has not been determined, in the place to a full predet, while deters treat it at the subspectific ferst. Refers to the nonst likely tank is assigned and a question mark added (e.g., C27). A range is indicated by combining two rasks (e.g., C1C2, S1S3). Refers to whether the klentification of the species or community has been checked by a ratable individual and is indicative of significant babitat. Refers to the the has not been verified and is indicative of significant babitat. Refers to the hot has not been verified but there is no reason to believe it is not indicative of significant habitat. Refers to the first has been verified but there is no reason to believe it is not indicative of significant habitat. Refers to the formatic the babitat is determined if the tecord is i	•	
Although the 32 mark typically upplies to migrants, it should not be uned indiscriminately. Just because a packas is on migration does not mean it receives as 52 mile. 52 will only apply when the migrants occur in an inregular, transform and disparsed mannee. Refers to the bon-breeding population of the element in the state. Refers to the non-breeding population of the element in the state. Bernant ranks containing a TT indicate that the infraspecific tusion is being ranked differently thin the full species. For example 5xx/byr Adviction will be not determined, is the vicing it ranked hindicates that the global ranky of the sor. Anomorichies has not been determined, is the vicing it ranked hindicates that the taxion is of questionable, or uncertain tuxonomical standing, e.g., some authors region K as a full species, while entry track it as the subspecific locel. The express uncertainty, the most likely rank it is stalpend and a question mark added (e.g., C22). A range is indicated by comforming two ranks (e.g., CICC, 5133). THECHTON CODIES e codes refer to whether the identification of the species or community has been checked by a milable individual and is indicated or significant habitat. There is no been to be not been specied or community has been checked by a milable individual and is indicated or significant habitat. There is no to be not been specied or is indicative of significant habitat. HANK is determined if the record is indicative of significant habitat. There is no to be a determined of the indicative of significant habitat. Ciccle is not been been writhed but there is no reason to believe it is not indicative of significant habitat. New new here is not been determined in the species or community may be confusing or disputed. New new here is not be a confusing or disputed.		
Although the SZ rack typically applies to subpants, it should not be used industriminately. Just because a species is on migration does not mean it receives an SZ rack. S2 will only apply when the migrates occur in an important transmy, and dispersed manner. Refers to the non-breeding population of the element in the state. Dement note containing a TT industes but the inference in the state. Elements containing a TT industes but the inference in the state. Elements containing a TT industes but the inference is planking secure but the global rachy of the var. Anomechab base not been determined, in New Johny in maning the full secure is planking secure but the global rachy of the var. Anomechab base not been determined, in New Johny in Strake Matters that the table state but the state is a base of a questionable, or uncertain taxonomical standing, e.g., atome authors regired it as a Alt species, while other track it as the subpactific level. T Betweets documented from a single location. To express uncertainty, the most likely rack is assigned and a question mark added (e.g., CZR). A range is indicated by combining two rasks (e.g., CIC2, SISS). TRIPICATION COODS e Godet refer to whether the Maintfication of the species or community has been checked by a ratiable individual and is indicate of significant babitat. T Identification has been writted and is indicative of significant babitat. T User is not been been writted and is indicative of significant babitat. T User is not been been indired are determined if the record is indicative of significant babitat. T Community may be containing or dispute.		
Although the 32 rank typically applies to migrants, it should not be used indiscriminately. Just because a species is on migration does not make it receives an 52 rank. 52 will only upply when the migrants occur is an irregular, transmey and dispersed manner. Refers to the brenchmeeting population of the element in the state. Refers to the non-breeding population of the element in the state. Exement ranks containing a TT indicate that the infragredic turon is being naked differently this in the full species. For siample 50-obyer extentions, is non-breeding population of the element in the state. Exement containing a TT indicate that the infragredic turon is being naked differently this in the full species. For siample 50-obyer extention, down determined, is how prime the work by a maked historie. Beneads containing a TT indicate that the infragredic turon is being naked differently this in the full species. For siample 50-obyer extended were and the migration of its rank haddets that the taxon is of questionable, or uncertain taxonomical standing, e.e., down earlier or inform a single location. C. Elements containing a TT indicate that the infragredic turo is the the subspecific level. The segress uncertaining, the most likely rank is a subgred and a question mark added (e.g., C27). A range is indicate by combining two nakes (e.g., C162, 5153). THEATION CODES e codes refers which in the Meentification of the species or community has been checked by a rubble individual and is indicative of significant habitat. The demutification has not been verified but there is no reason to believe B is not indicative of significant habitat. HAMK Identification has not been verified but there is no reason to believe B is not indicative of significant habitat. Ether it has not been determined If the neared is indicative of significant habitat or the identification of the species or community may be contain or of the prace. HAMK Identification has not been set determined If the neared is indicative of s		
Although the SZ rask typically applies to migrants, it should not be used inductiminately. Just because a species is on migration does not mean it receives an SZ rask. SZ will only apply when the migrants occur it as irregular, transitory and dispersed memore. I Refers to the bon-breeding population of the element in the state. T Ensert next containing a TT indicate that the infragotic scone is being maked differently this the full species. For example Subdyr <i>Advertig var. Abnoticita</i> is nanked '5577 SH' meaning the full species is globally secure but the global ratify of the var. <i>Annoticita</i> has not been determined, it is anaked '5577 SH' meaning the full species is globally secure but the global ratify of the var. <i>Annoticita</i> has not been determined, it is plot and the global ratify of the var. <i>Annoticita</i> has not been determined, it is anaked the stated in the state of the global ratify of the var. <i>Annoticita</i> has not been determined, it is anaked high secure but the global ratify of the var. <i>Annoticita</i> has not been determined, it is anaked high scient whether the global ratify of the var. <i>Annoticita</i> has a full species, while enter trat it at the tobapecific level. 1 Elements containing a 'T in the global portion of its rank kindicates that the taxon is of questionable, or uncertain taxonomical standing, e.g., some authors repaired it as a full species, while enter trast it at the tabapecific level. 1 Elements containing a 'T indicate global portion of its rank kindicate and a distribution trast it as the state and the determined of the species or community may be constant to an a distribution. 1 Elements containing a the species or community has been checked by a reliable individual and is indicative of significant habitat. <td>•</td> <td>Page 4</td>	•	Page 4
 Although the 52 rask typically applies to migranian, it should not be used indiscriminately. Just because a species is on migranian does not mean it receives an 52 rank. 52 mill only apply when the migranis occur in an inregular, transitory and dispersed manner. Refers to the non-breading population of the element in the state. Befers to the non-breading population of the element in the state. Construction of the element in the state. Befers to the non-breading population of the element in the state. Construction of the element in the state. Befers to the non-breading population of the element in the state. Construction of the element of the state of significant habitat. To express uncertainty, the most likely rank is a state of a community has been checked by a reliable individual and is indicative of significant habitat. Identification has been verified and is indicative of significant habitat. Bubber if has not been determined if the record is indicative of significant habitat. Bubber if has not been determined if the record is indicative of significant habitat. Bubber if has not been determined if the	· · · ·	
Although the 24 rask typically application of prantit, it should not be used indiscriminatory, but because a species is an imparison does not mean it receives an 32 rank. 52 millionly apply when the migratus occur in an inregular, transitory and dispersed manner. It Refers to the bon-breading population of the element in the state. T Evenent make containings a TT indicate that the infrance of the practice trans is being particularly than the full speciet. For example <i>Socilysy padiatority</i> was. Anomotifying a TT indicate that the infrance of the practice is globally secure but the global parket of the var. Anomotifying has non-breading population of the rank holicates that the taxins is of questionable, or uncertain taxonomical standing, e.g., some authors' regired it as a full speciet, while others track the tube packet level. I Elements containing a 'T' infra globall portion of its rank indicates that the taxins is of questionable, or uncertain taxonomical standing, e.g., some authors' regired it as a full speciet, while others track it as the taxins is of questionable, or uncertain taxonomical standing, e.g., some authors' regired it as a full speciet, or community has been checked by a reliable individual and is indicative of significant habitar. The express uncertaining, the most likely rank is assigned and a question mark added (e.g., C22). A range is indicated by combining two ranks (e.g., CIC2, SISS). THIFCATION CODIS e codest refer to whether the kleinification of the species or community has been checked by a reliable individual and is indicative of significant habitar. Y Identification has not been verified and is indicative of significant habitar. or the indication of the spec		
 Not mean it meeters an 52 rank. 52 will only apply when the migrants occur in an inegular, transitory and dispersed marner. Refers to the breeding population of the element in the state. Refers to the non-breeding population of the element in the state. Element ranks containing a TI indicate that the infrapacific tuson is being ranked differently than the full species. For example Surphyr publicity of the var. Associative is an interval to be an determined; in New Joing the var. Associative has not been determined; in New Joing Var 1 and for the var. Associative has not been determined; in New Joing Var 1 and for the var. Associative has not been determined; in New Joing Var 1 and its rank indicates that the taxin is of questionable, or uncertain taxonomical standing, e.g., some authors regular it as a full species, while other to text tax it to be subspecific level. Elements containing a 'Q' in the global portion of its rank indicates that the taxin is of questionable, or uncertain taxonomical standing, e.g., some authors regular it as a full species, while other to text is to be subspecific level. Elements documented from a single location. To express encertainty, the most likely mark is assigned and a question mark added (e.g., C27). A range is indicated by combining two ranks (e.g., C172, S13). TIRICATION CODIS e codes refer to whether the klentification of the species or community has been checked by a reliable individual and is indicative of significant habitat. ELANK Identification has been verified and is indicative of significant habitat, or is indicative of significant habitat. To be it is a bein determined if the record is indicative of significant habitat, or its demarkation of the species or community may be confusing or disputed. 	. Alti	rough the SZ rank typically applies to migrants, it should not be used indiscriminately. Just because a species is on migration does
 Refers to the breeding population of the element in the state. Refers to the non-breeding population of the element in the state. Element ranks containing a T indicate that the infrapecific taxon is being ranked differently than the hill species. For example Steedysy polarity ear. Non-other barshed barshed is the infrapecific taxon is being escares but the global arty of the var. Account of the element of the species is globally secure but the global arty of the var. Account of the species is globally secure but the global arty of the var. Account of the species is globally secure but the global arty of the var. Account of the species is globally secure but the global arty of the var. Account of the species is globally secure but the global arty of the var. Account of the species is globally secure but the global arty of the var. Account is a forget of the var. Account of the species is globally secure but the global arty of the var. Account is a species of globally secure but the species of globally secure but the species of polarity of the var. Account is a forget based of the var. Account is a forget based of the species of the species of the var. Account is a forget based of the species of the var. Account is a forget based of the var. Account is a species of the var. Account is a forget based of the var. Account is a species of the var. Account is an other way for a species of the var. Account is an other way for a species of the var. Account is an other way for a species of the var. Account is an other way for a species of the var. Account is an other way for a species of the var.	not	mean it receives an SZ rank. SZ will only apply when the migrants occur in an irregular, transitory and dispersed manner.
 Refers to the non-breeding population of the element in the state. Refers to the non-breeding population of the element in the state. Element ranks containing a "T indicate that the infraspecific taxon is being ranked differently than the full species. For example <i>Steepyr pulation put</i>. <i>Anomenickul</i> is marked "CSTD SH" meaning the full species is globally secure but the global rarky of the var. <i>Anomenickul</i> is an kinkd "CSTD SH" meaning the full species is globally secure but the global rarky of the var. <i>Anomenickul</i> is an kinkd "CSTD SH" meaning the full species is globally secure but the global rarky of the var. <i>Anomenickul</i> is an one of the species of the var. <i>Anomenickul</i> is an subspecific level. Elements containing a "Q" (in the global portion of its rank indicates that the taxon is of questionable, or uncertain taxonomical standing, e.g., some authors regist it as a full pipeles, while others treat it at the tubspecific level. Elements documented from a single location. To express uncartainty, the most likely rank is assigned and a question mark added (e.g., G27). A range is indicated by combining two ranks (e.g., G162, S153). TIFICATION CODES e Codest refer to whether the klenntfication of the species or community has been checked by a reliable individual and is indicative of significant habitat. Y Identification has not been verified and is indicative of significant habitat. T Ether it has not been verified and is indicative of significant habitat. 7 Ether it has no been determined if the record is indicative of significant habitat. 7 Ether it has no been determined if the record is indicative of significant habitat. 7 Ether it has no been determined if the record is indicative of significant habitat. 7 Ether it has no been determined if the record is indicative of significant habitat. 	. •	
 Refers to the non-breeding population of the element in the state. Element ranks containing a "T indicate that the infraspecific tuson is being ranked differently than the full species. For example <i>Specifyst pulation vue. Anneoticide</i> is ranked for the ver. Anneoticide has not been determined. In New Jersey the variety is ranked historic. Elements containing a "C" in the global portion of its rank indicates that the taxion is of questionable, or uncertain taxonomical standing, e.g., some authors regard it as a full species, while others treat it at the subspectific feed. Elements documented from a single location. To express uncertaining, the most likely rank is assigned and a question mark added (e.g., G27). A range is indicated by combining two ranks (e.g., CIE2, SIS3). TIRICATION CODES e Godes refer to whether the Mentification of the species or community has been checked by a ruleable individual and is indicative of significant habitat. I demultication has been verified and is indicative of significant habitat. BLANK I demultication a two been verified but there is no reason to believe it is not indicative of significant habitat. Either <i>K</i> has not been verified but there is no reason to believe it is not indicative of significant habitat. Either <i>K</i> has not been verified but there is no reason to believe it is not indicative of significant habitat. 	B Ref	ers to the breeding population of the element in the state.
N Refers to the non-breeding population of the alement in the state. T Element ranks containing a "T indicate that the infraspecific taxon is being ranked differently than the full species. For example Suckyr polatotity vir, Anometricke has not been determined, in here prices that "STST" meaning the full species is globally secure but the global rarky of the vir, Anometricke has not been determined. In here prices up the variety is ranked histoc. Q Elements containing a "Q" in the global polation of its rank indicates that the subspectific fevel. 1 Elements containing a "Q" in the global polation. To express uncertainty, the most likely rank is a signed and a question mark added (e.g., C27). A range is indicated by combining two ranks (e.g., G1C2, S13). TO express uncertainty, the most likely rank is a signed and a question mark added (e.g., C27). A range is indicated by combining two ranks (e.g., G1C2, S13). TIFICATION CODIS e coder refer to whether the identification of the species or community has been checked by a reliable individual and is indicative of significant habitat. Y Identification has not been verified and is indicative of significant habitat. Y Identification has not been verified but there is no reason to believe it is not indicative of significant habitat. T ELEMENT Identification has not been verified but there is no reason to believe it is not indicative of significant habitat. T ELEMENT has not been verified but there is no reason to believe	•	
 T Element ranks containing a "T indicate that the infraspecific taxon is being ranked differently than the full species. For example Society pullicity var. Annotricide is another than a structure that and the species is globally secure but the global ranky of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the rank of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of the var. Annotricide is another and the global parties of disputed. Y Identification has not been verified and is indicative of significant habitat. Y Identification has not been verified but there is no reason to believe it is not indicate of significant habitat. Y Ether it has not been verified but there is no reason to believe it is not indicate of significant habitat. Y Ether it has not been verified but there is no reason to believe it is not indicate of significant habitat. Y Ether it has no	'N Ref	ers to the non-breeding population of the element in the state,
 T Dement must contining a "T indicate that the infraspecific taxons is being ranked differently thin the full species. For example Sockyr publishifty examinate the full species is globally secure but the global ranky of the var. Anomotifich as an other determined; is here if examined the varies of a must be indicated by a containing a "Q" (in the global portion of its rank indicates that the taxon is of questionable, or uncertain taxonomical standing, e.g., some authors' regard it is a shift species, while others treat it at the subspecific level. Q Elements containing a "Q" (in the global portion of its rank indicates that the taxon is of questionable, or uncertain taxonomical standing, e.g., some authors' regard it is a shift species, while others treat it at the subspecific level. I Elements documented from a single location. To express uncertainty, the most likely rank is a stigned and a question mark added (e.g., CZ). A range is indicated by combining two ranks (e.g., GIG2, SIS3). TIFICATION CODES e codes refer to whether the klenification of the species or community has been checked by a reliable individual and is indicative of significant habitar. Y Identification has been verified and is indicative of significant habitar. BLANK Identification has not been wrified but there is no reason to believe it is not indicative of significant habitar. BUANK Identification as not been wrified but there is no reason to believe it is not indicative of significant habitar. BUANK Identification as not been wrified but there is no reason to believe it is not indicative of significant habitar. BUANK Identification of the species or community may be confusing or disputed. 	· ·	3
 <i>polasticity var.</i> AdmostricAs is ranked "CST? SH" meaning the full species is plobally secure but the plobal rarity of the var. AdmostricAs has not been determined; is New jerrer the variety is ranked historic. Q Elements containing a "Q" (rule global portion of its rank holicates that the taxion is of questionable, or uncertain taxonomical standing, e.g., some authors regird it as a full species, while others treat it at the subspecific level. 1 Elements documented from a single location. To express uncertainty, the most likely rank is assigned and a question mark added (e.g., CZ?). A range is indicated by combining two ranks (e.g., CIC2, SIS3). TIFICATION CODES e codes refer to whether the klentification of the species or community has been checked by a reliable individual and is indicative of significant habitat. BLANK Identification has been verified and is indicative of significant habitat. BLANK Identification has not been verified but there is no reason to believe it is not indicative of significant habitat. Priver is has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 	T Ele	ment ranks containing a "T" indicate that the infraspecific taxon is being ranked differently than the full species. For example Scochys
not been determined; in New Jersey the variety is ranked historic. Q Elements containing a "Q" in the global portion of its rank indicates that the taxon is of questionable, or uncertain taxonomical standing, e.g., some authors regard it as a full species, while others treat it at the subspecific level. I Elements documented from a single location. To express succentainty, the most likely rank is assigned and a question mark added (e.g., C27). A range is indicated by combining two ranks (e.g., C1C2, S1S3). TIFICATION CODES e codes refer to whether the klentification of the species or community has been checked by a reliable individual and is indicate of significant habitat. Y Identification has been verified but three is no reason to believe it is not indicative of significant habitat. BLANK Identification has not been verified but three is no reason to believe it is not indicative of significant habitat. T Ether it has not been determined if the record is indicate of significant habitat or the Identification of the species or community may be confusing or disputed.	pa	ustris var. homotriche is ranked "GST7 SH" meaning the full species is globally secure but the global ranky of the var. homotriche has
 Elements containing a "Q" (in the global portion of its rank indicates that the subspecific level. Elements documented from a single location. To express uncertainity, the most likely rank is assigned and a question mark added (e.g., C27). A range is indicated by combining two ranks (e.g., C162, S153). TIFICATION CODES c codes refer to whether the klentification of the species or community has been checked by a reliable individual and is indicative of significant habitat. Y identification has been verified and is indicative of significant habitat. BLANK identification has been verified but there is no reason to believe it is not indicative of significant habitat. Either K has not been querified but there is no reason to believe it is not indicative of significant habitat. Either K has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 	noi	been determined: in New Jersey the variety is ranked historic.
Q Elements containing a "Q" in the global portion of its rank indicates that the taxion is of questionable, or uncertain taxonomical standing, e.g., some authors regard it as a full species, while others treat it at the subspecific level. 1 Elements documented from a single location. To express uncertainty, the most likely rank is assigned and a question mark added (e.g., C27). A range is indicated by combining two ranks (e.g., C1G2, S1S3). TIPICATION CODES e Codes refer to whether the identification of the species or community has been checked by a reliable individual and is indicative of significant habitat. Y Identification has been verified and is indicative of significant habitat. BLANK Identification has not been verified but there is no reason to believe it is not indicative of significant habitat. 7 Ethern it has not been verified but there is no reason to believe it is not indicative of significant habitat. 7 Ethern it has not been verified but there is no reason to believe it is not indicative of significant habitat. 8 Ether it has not been of determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed.	• • •	
e.g., some authors' regird it as a full species, while others treat it at the subspecific level. I Elements documented from a single location. To express uncertainty, the most likely rank is assigned and a question mark added (e.g., C27). A range is indicated by combining two ranks (e.g., CIG2, S153). TIRICATION CODES e codes refer to whether the identification of the species or community has been checked by a reliable individual and is indicative of significant habitat. Y identification has not been verified and is indicative of significant habitat. BLANK identification has not been verified and is indicative of significant habitat. 7 Either it has not been verified and is indicative of significant habitat. 7 Either it has not been verified and is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 8 Community may be confusing or disputed.	O Ele	ments containing a "O" in the global portion of its rank indicates that the taxon is of questionable, or uncertain taxonomical standing
I Elements documented from a single location. To express uncertainty, the most likely rank is assigned and a question mark added (e.g., C27). A range is indicated by combining two ranks (e.g., C1C2, S1S3). TIFICATION CODES e codes refer to whether the kientification of the species or community has been checked by a reliable individual and is indicative of significant habitat. Y identification has been verified and is indicative of significant habitat. BLANK identification has not been verified and the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed.		some authors' resident that a full species while others that the subcondition of a least
I Elements documented from a single location. To express uncertainty, the most likely rank is assigned and a question mark added (e.g., G27). A range is indicated by combining two ranks (e.g., G1G2, 5153). TIFICATION CODES e codes refer to whether the klentification of the species or community has been checked by a reliable individual and is indicative of significant habitat. Y identification has not been verified but there is no reason to believe it is not indicative of significant habitat. BLANK identification has not been verified but there is no reason to believe it is not indicative of significant habitat. 7 Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. Next species the species of the species or community may be confusing or disputed. Next species the species of the species	y	
 Contract discusses uncertainty, the most likely rank is assigned and a question mark added (e.g., C27). A range is indicated by combining two ranks (e.g., CIC2, S1S3). TIFICATION CODES e codes refer to whether the identification of the species or community has been checked by a reliable individual and is indicative of significant habitat. Y Identification has been verified and is indicative of significant habitat. BLANK Identification has not been verified but there is no reason to believe it is not indicative of significant habitat. ? Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 	1 Ela	mants documented from a single location
 To express uncertainty, the most likely rank is assigned and a question mark added (e.g., C27). A range is indicated by combining two ranks (e.g., G1G2, S1S3). TIFICATION CODES e codes refer to whether the identification of the species or community has been checked by a reliable individual and is indicative of significant habitat. Y Identification has been verified and is indicative of significant habitat. BLANK Identification has not been verified but there is no reason to believe it is not indicative of significant habitat. 7 Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 	Ere	
CIC2, 5153). TIRICATION CODES e codes refer to whether the klentification of the species or community has been checked by a reliable individual and is indicative of significant habitar. Y identification has been verified and is indicative of significant habitat. BLANK identification has not been verified and is indicative of significant habitat. 7 Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed.	. To every	vertilate the most likely such is eveloped and a question mark added in a 1970. A much is indicated by a militan and a such is a
 Crock as a start TIFICATION CODES e Codes refer to whether the kientification of the species or community has been checked by a reliable individual and is indicative of significant habitat. Y identification has not been verified and is indicative of significant habitat. BLANK identification has not been verified but there is no reason to believe it is not indicative of significant habitat. 7 Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 	CICS PRESS W	wernenny, we more neer renk is essigned and a question mark added (e.g., 627). A range is indicated by combining two ranks (e.g.,
TIFICATION CODES e codes refer to whether the Identification of the species or community has been checked by a reliable individual and is indicative of significant habitar. Y identification has been verified and is indicative of significant habitat. BLANK identification has not been verified but there is no reason to believe it is not indicative of significant habitat. P Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. Beautification has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. Beautification has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. Beautification has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. Beautification has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. Beautification has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. Beautification has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. Beautification has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. Beautification has not been determined if the record is indicative of significant habitat or the identification of the species or community is a species of the species	. 6162, 3133).	
e codes refer to whether the klentification of the species or community has been checked by a reliable individual and is indicative of significant habitar. Y identification has been verified and is indicative of significant habitat. BLANK identification has not been verified but there is no reason to believe it is not indicative of significant habitat. ? Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed.		
e codes refer to whether the Identification of the species or community has been checked by a reliable individual and is indicative of significant habitat. Y Identification has not been verified but there is no reason to believe it is not indicative of significant habitat. BLANK Identification has not been verified but there is no reason to believe it is not indicative of significant habitat. T Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. T Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. T Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. T Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. T Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. T Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. T Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. T Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. T Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. T Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community is indicat	TIFICATION CODES	
e codes refer to whether the Identification of the species or community has been checked by a reliable individual and is indicative of significant habitat. Y Identification has been verified and is indicative of significant habitat. BLANK Identification has not been verified but there is no reason to believe it is not indicative of significant habitat. 7 Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 8 and the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 8 and the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 8 and the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 8 and the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 8 and the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 8 and the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 8 and the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 8 and the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 8 and the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 8 and the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 8 and the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed or community may be confusing or community may be c		
 Y Identification has been verified and is indicative of significant habitat. BLANK Identification has not been verified but three is no reason to believe it is not indicative of significant habitat. 7 Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. 	se codes refer to wh	ether the identification of the species or community has been checked by a reliable individual and is indicative of significant habitar.
Y identification has been verified and is indicative of significant habitat. BLANK identification has not been verified but there is no reason to believe it is not indicative of significant habitat. 7 Ether it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed.		
BLANK Identification has not been verified but there is no reason to believe it is not indicative of significant habitat. 7 Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. Record Sector 100 (Sector 100 (S	Y - ,	identification has been verified and is indicative of significant habitat.
BLANK Identification has not been verified but there is no reason to believe it is not indicative of significant habitat. ? Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. Provide the species of	· . ·	
7 Either it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. Busine Business	BLANK	identification has not been verified but there is no reason to believe it is not indicative of significant habitat.
Pitter it has not been determined if the record is indicative of significant habitat or the identification of the species or community may be confusing or disputed. Record Business	• • .	
community may be confusing or disputed.	້	Either it has not been determined if the record is indicative of significant habitat or the identification of the species or
		- community may be confusing or disputed.
	•	
	• •	Resert Business test
	••	
	•	
	•	
	•••	
	•••	
		· · · · · · · · · · · · · · · · · · ·
	•	

.

۰.

OCEAN COUNTY RARE SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE

	NAME	COMMON NAME	FEDERAL	STATE	REGIONAL	GRANK	SRANK
			STATUS	STATUS	STATUS		
	•		•				
*** Vertebrates				- 1-			
	ACCIPITER COOPERII	COOPER'S HAWK		T/T		G5	538,54N
	AMBYSTCHA TIGRINUM TIGRINUM	EASTERN TIGER SALAMANDER		E		G5T5	52
	AMMODRAMUS SAVANNARUM	GRASSHOPPER SPARROW		T/S		G\$	S2B
	ARDEA HERODIAS	GREAT BLUE HERON		` 5/S		G5	S2B, S4N
	BARTRAMIA LONGICAUEA	UPLAND SANDPIPER.	•	3		GS	\$1B
	BOTAURUS LENTIGINOSUS	AMERICAN BITTERN		5/S		G4	S2B
	BUTED LINEATUS	RED-SHOULDERED HANK		E/T .		G5	S1B, S2N
	CALIDRIS CANUTUS	KED KNOT .		T		GS	SIN
	CHARADRIUS MELODUS	PIPING PLOVER	LT	ε,		G3	S1B
	CIRCUS CYANEUS	NORTHERN HARRIER		E/U		G5	\$18, \$3N
	CISTOTHORUS PLATENSIS	SEDGE WREN		E		GS	SIB
	CLEMYS INSCULPTA	WOOD TURTLE		T		Gł	S 3
	CLEMMYS MUHLENBERGII	BOG TURTLE	LT	E		G3	52
	CROTALUS HORRIDUS HORRIDUS	TIMBER RATTLESNAKE		E		G4T4	S2
	EGRETTA CAERULEA	LITTLE BLUE RERON		s/s		GS	\$2B
	EGRETTA THULA	SNOWY ECKET		s/s		GS	S38, 34N
	EGRETTA TRICOLOR	TRICOLORED HERON		INC/S		G5 -	S18
	ELAPHE GUTTATA CUTTATA	CORN SNAKB		E		GSTS	S1
	KUMECES FASCIATUS	FIVE-LINED SKINK		. U		G5	\$3
	FALCE PERECRINUS	PERSONAL FALCON		B		G4	\$18,57N
	HALLASKINS LEUCKEPHALUS	BALD FACLE	LT	E		GI	\$18,62N
	INTA ANTERIONI I	PINE BARBENS TREEFRON		5		G4	53
		COPE'S CRAY TREEFEOG		Е ⁻		65	52
	TYODAY THE FULLS	TENER DITTION		- n/s		65	518
	TAUBRICAUS EXTERS	TENEL FINE CALL		0,0			63
	LAMPROPELTIS GETULA GETULA	EASTERN KING SMARE		50		0313	33 828
	LATERALIAS JAMAICENSIS	PLACE RAID		<u>.</u>			340
	LYNX RUFUS	BCBCAT		5	-	65	10
	MELANERPES ERYTHROCEPHALUS	RED-HEADEN WOUDPECKER		T/T		GS .	\$28,52N
	NYCTANASSA VIOLACEA .	YELLON - CROWNED NIGHT - HERON		T/T		G5	52B

÷

.

.

Oyster Creek Generating Station License Renewal Application

ĺ

- (

.

(

·
NAMI

*** Ecosystems

COASTAL DUNE SHRUBLAND COASTAL DUNE WOODLAND MARINE INTERTIDAL GRAVEL/SAND BEACH COMMUNITY PINE PLAINS

. .

PINUS RIGIDA-CALAHOVILPA BREVIPILIS SAVANNA . .

. • *** Invertebrates . ACRONICTA ALBARUFA AESHNA CLEPSYDRA ACROTIS BUCHHOLZI AMBLYSCIRTES VIALIS

OCEAN COUNTY RARE SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN

THE NEW JERSEY NATURAL HERITAGE DATABASE

· · · · · · · ·	.•			•
COMMON NAME	FEDERAL	STATE	REGIONAL	GRANK
· . ·	STATUS	STATUS	STATUS	
BLACK-CROWNED NIGHT-HERON	•	T/S		05
OSPREY		T/T		G 5
NORTHERN PINE SHAKE		T		G4T4
GLOSSY IBIS		D/S	• '	G 5
PIED-BILLED GREBE		¥/5 [.]	•	C5
VESPER SPARROW		E .	•	G5
BLACK SKIPPER	•	E		GS .
LEAST TERN		E		G4 [†] †
ROSEATE TERN .	LŻ	E		G4T3
COMMON TERM	· ·	D/8		G5
GULL-BILLED TERN		8.		Q5
BARRED ONL	· .	T/T		G5
BOUTHERN BOG LEMMING	• • •	U		05 .
COASTAL DUNE SHRUBLAND			. •	G4
COASTAL DUNE WOODLAND				(2)(3)

COASTAL DUNE WOODLAND					
MARINE INTERTIDAL GRAVEL/SAND					
BEACH CONFUNITY		•			
DWARP PITCH PINE-BLACKJACK OAK				•	
PINE PLAINS			•		
PITCH PINE-PINELANDS REEDGRASS	•	·			•
BAVANNA					
•••	•		•		

BARRENS DAGGERMOTH MOTTLED DARNER BUCHROLZ'S DART ROADSIDE SKIPPER

CRANK \$38,84N \$2B

83 838, \$4N sis, 83M \$18,\$2N \$1B \$1B SHO \$3B \$1B

\$3B 82 827 81

÷

0203

œ

61

C1

G3G4

G4

G2

05

SU 81 **'**£1 SU 8253 \$2

5253

Appendix C Environmental Report Special-Status Species Correspondence

.

.

OCEAN COUNTY RARE SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE

.

.

.

				-			
•	KUML .	CLAMON NAME	FEDERAL STATUS	STATE Status	REGIONAL STATUS	GRANK	SKANK
	APHARETRA DENTATA	A HOCIUID MITH				G4	S2S3
	ATRYICHE ARODOS ARODOS	AROGOS SKIPPER		ĸ		G3G4T1T2	51
	BOLORIA SELLNE MYRINA	A SILVER-BORDERED FRITILIARY		т		GST5	52
	CALLUPIRYS HENRICI	HENRY'S ELPIN				GS	5354
	CALLOPHRYS HESSELI	HESSEL'S HAIRSTREAK	-			G3G4	5354
	CALLOFHRYS IRUS	FROSTED ELFIN		Ŧ		G3	5253
	CALLGERRYS POLIOS	HOARY MLFIN				G5	83
	CALLEPISTRIA GRANITOSA	GRANITOSA FERN MOTH				G4G5	\$253
	CATUCALA HERODIAS GERHARDI	HERODIAS OR GERHARD'S				G1T3	23
	CATOCALA JAIR SSP 2					G4T4	\$3
	CELITHEMIS MARTHA	MARTHA'S PLANANT		•		64	5184
	CICINUMIA DORSALIS DOREALIS	NORTHEASTERN BEACH TIGER	LT	E		GATZ	S1
		BEETLE		-			
	CICINDELA PAINUELA	A TIGER DEETLE				G3T2T3	5253
	CONSENTANEA						
•	CRAMBUS DAECKELLUS	DASCKE'S PYRALID MOTH	•			G1G3	5153
	DATANA RANASCEPS	A HAND-MAID MOTH				G3G4	\$354
	ENALLAGMA PICTUM	SCARLET BLUET				G3	53
	ENALLACMA RECURVATUM	PINE HARRENS BLUET				63	53
	ERYNNIS PERSIUS PERSIUS	A PERSIUS DUSKY WING	•			G512T3	SH
	EUPHYES BIMACULA	THO-SPOTTED SKIPPER				G4	53
	FARONIA RUBRIPEINIS	PINK SIREAK				G3G4	S3
	GLENA PLUMOSARIA					G4	SU
	GRAMMIA PLACENTIA	PLACENTIA TIGER MOTH				Gé	8153
	HESPERIA ATTALUS SLOSSONAS	DOTTED SKIPPER				G3G4T3	\$253
-	HETAERINA AMERICANA	AMERICAN KUBYSPOT				GS	\$3
	HETEROCAMPA VARIA	A NOTUDUNTID HOTH				0364	\$3
	HYPOMECIS BUCHHOLZARIA	BUCHNOLZ'S GRAY				G3G4	\$3
	ITAME SP 1	A SFANWURM				G3	\$3

.

Environmental Report Appendix C Special-Status Species Correspondence

•

		, oc	EAN COUNTY			•	•
		RARE SPECIES AND NATURAL	COMMUNITIES PRE	SENTLY RECORDS	ED IN		
		THE NEW JERSEY	NATURAL HERITAGE	DATABASE			
					· ·		
•		•					
	173.100						
		COMPON NAME	FEDERAL	STATE	REGIONAL	CRANK	SR
• •	-	• *	STATUS	STATUS .	STATUS		
	LIBELLULA AUTRIPENNIS	GOLDEN-WINGED SKIMMER		•			
	LIBELLULA ATTLENA	BAR-WINGED SEIMMER	3		•	45	01
•			-			03	84
	LITHOPHANE LEMMERI	LEMMER'S PINION MOTH	•		•		· #
•	MACROCHILO SP 1	A NOCTUTO MOTH				0304	82
	MEROLONCHE DOLLI	DOLL'S MEROLONCHE				03	51
	METARRANTHIS PILOBARIA	COASTAL BOG METARRANTHIS	•			- 0304	. 81
	METARRANTHIS SP 1	A GEOMETRID MOTH	•			0304	331
•	NEONYMPHA AREYLATA	1 CLTYD	•			03	32
•	SEPTENTRIONALIS			· ·		GATITA	33
	NICROPHORTIS AMERICANUS	WERTIN BURYTUN STONE		-		'	
• • •	PONTIA PROTODICE	ADDATED DOLLAR	140	в		0263	SH
	PTICHOIR BISTOLGATA			T		Gé	51
		VELON PORT PRODUCTS			•	G3	\$15
	PICHIE CD 2	ILLOW ELGED PHOARCTIA	• .		•	G304	81
	SPHILTHICS PREVIATE					010	51
•	SPARTINI PRACE CANTERAD	CAREA-LINED ANGLE POTH	•	•		G4 .	SU
	THE CO I	CORTER'S NOCTOID NOTH				0203	. 82
		FINE BARKENS ZALE				0304	\$3
•			•			03G4	S3 .
	LANCIOGRAFIAR INCRALIS			•		C4	SH
*** Other types		. •			•		
••	BALD RAGLE WINTERING SITE	BALD PATE NUMERING STOP					
۰.	COASTAL HERON ROOKERY	COASTAL REPOR BOOKERY					87
	MIGRATORY SHOPPHIED	NIGENTORY PUOPPOIED	•			GU	53
	CONCENTRATION SITE		•			. G?	\$7
	· · ·	CONCENTION SITE	•			· · .	
*** Vascular plants							
,				•	•	•	
•	ADVICTOR ALGORITS VAR	SHORT-AWN HEADOW FOXTALL				G5T?	52
						•	
	•				•	• •	
						•	
				•			

UNK 152 28538,62

> 83 64 R٦

.

OCEAN COUNTY RARE SPECIES AND NAIUKAL COMMUNITIES FRESENTLY RECURDED IN THE NEW JERSEY NATURAL HERITAGE LATABASE

.

.

.

NAME	COMMON NAME	FEDERAL	STATE	REGIONAL	GRANK	SRANK
		STATUS	STATUS	STATUS		
AMAKANTHUS PUMILUS	SEABEACH AMARANTH	LT	E		G2	51
ANIANTHIUM MUSCITOXICUM	FLY POISON				G4G5	\$2
ARETHUSA BULBOSA	LRAGON HOUTH				G4	S2
ARISTIDA DICHOTOMA VAR	CURTISS TIREE AWN GRASS				GST5	52
CURTISSII						
ARISTOLOCHIA SERPENTARIA	VIRGINIA SNAKEROOT				G4	S 3
ARTEMISIA CAMPESTRIS SSP	BEACH HORMHOOD				GST5	S2
CAUDATA						
ASCLEPIAS LANCEOLATA	SMOOTH ORANGE MILKWEED				GS	52
ASCLEPIAS RUBRA	RED MILKWEED			LP	GIGS	52
ASTER RADULA	LOW ROUCH ASTER		8		GS	51
BUCHNERA AMERICANA	BLUEREARTS	•			G\$?	5X
CACALIA ATRIPLICIPOLIA	PALE INDIAN PLANTAIN		E		G4G5	S1
CALAMOVILFA BREVIPILIS	PINE BARREN REEDCHASS			LP	G4	51
CARDAMINE LONGII	LONI'S BITTERCRESS	•	K		GJ	क्ष
CAREX BARRATTII	BARRATT'S SEDGE			LP	G4	54
CAREX MITCHELLIANA	MITCHELL'S SEDGE				G3G4	52
LAREX PALLESCENS	PALE SEDGE				G5	52
CAREX WILLDENOWII VAR	WILLDENOW'S SEDGE				GSTS	\$2
WILLDENOWII				•		
CIRSIUM VIRGINIANUM	VIRGINIA THISTLE		£		G3	51
CLITCRIA MARIANA	BUTTERFLY - PEA	•	5.		G 5	51
COREMA CONRADIT	BROOM CROWBERRY		5	LP	G4	51
COREOPSIS ROSEA	ROSE-COLOR COREOPSIS		- ·	LP	63	52
CROTON WILLDENOWII	ELLIPTICAL RUSHPOIL			LP	GS	62
DESHODIUM PAUCIFLORUM	FEW-FLOWER TICK-TREFOIL		B		65	51
ELEOCHARIS HALOPHILA	SALT-MARSH SPIKE-RUSH				64	52
ELEOCHARIS TORTILIS	TWISTED SPIKE-RUSH		B .		65	51
LALOCALITION PARKERI	FARKER'S PIPEWORT		-		61	\$2
ERIOPHORUM TENELLUM	ROUGH COTTON-GRASS					

Environmental Report Appendix C Special-Status Species Correspondence

ı.

(

.

.

27 JUN 2002

.

6

OCEAN COUNTY RARE SPECIES AND NATURAL COMMUNITIES FRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE .

.

•.

			•		•		
NAME	COMMON NAME	FEDERAL	STATE .	REGIONAL		SPANY	
• •		STATUS	STATUS	STATUS		,	
ERYNJILM AQUATICUM VAR	MARSH RATTLESNAKE-MASTER		-				
AQUATICUN		•				63	
EUPATORIUM RESINOSUM	PINE BARREN BONESET		E	I.P	G 3		
FIMERISTYLIS CAROLINIANA	CAROLINA FINDRY		_		C.	62	
FRAXINUS PROFUNDA	pumprin Ash		£ .	•	64 · ·		·
FUIRENA SQUARROSA	RAIRY UNBRELLA-SEDGE		-		GAGE	e) '	
GALACTIA VOLUBILIS	DOWNY MILK-PEA		F		65	67 ·	
GENTIANA AUTOMNALIS	PINE BARREN GENTIAN	•	-	T.P	60	63	
GLAUI HARITIMA	SRA-MILEWORT		2		65 CK		•
CHAPBALIUN HELLERI	SMALL EVERLASTING	•	E		6465732	64.1 CU ' '	
HELONIAS BULLATA	SHAMP-PINK	LT	- R	t.P	a ·	57 61	
HONCKENYA PEPLOIDES VAR	SEABEACH SANDWORT	•			0574	63 E1	
ROBUSTA							•
HOTTONIA INFLATA	FEATHERPOIL			•	Ga	6 1	
HOUSTONIA LONGIPOLIA	LONG-LEAF STREET BLUET .		•		GACS .	54	
JEFFERSONIA DIPHYLIA	TWINLEAP	•	<u>г</u> .		CS.	81 ·	
JUNCUS CAESARIENSIS	NEW JERSEY RUSH	•	. <u>B</u>	LP	62	51 57	
JUNCUS GREENET	GREENE'S RUSH			·	 G5	57	
JUNCUS TORRETT	TORREY'S RUSH		8		05	81	
LINOSELLA SUNVLATA	ANL-LEAP MIDWORT		8	•	GACS	e1	
LINUM INTERCURSUM	SANDPLAIN FLAX		5		04	61 61	•
LISTERA AUSTRALIS	SOUTHERN TWAYBLADE			t.P		**	•
LOBELIA CANBYI	CANBY'S LOBELIA			LP .	GA	83	
LUDWIGIA BREVIDES	TUCKER'Ş ISLAND	•		•	G4G5 .	8T.1	
•	PRIMROSE-WILLOW	•				04.1	
LUZULA ACUMINATA	HAIRY WOOD-RUSH		¥		057475	\$7	
MELANTHIUM VIRGINICUM	VIRGINIA BUNCHFLOWER		B		05	e1	
MUHLENBERGIA TORREYANA	PINE BARREN SMOKE GRASS		-	Z.P	 01	83	
MYRIOPHYLLIM TENELLIM	SLENDER WATER-MILFOIL		. B.	-		e1 '	
MIRIOPHYLIAM VERTICILLATUN	MHORLED WATER-MILFOIL	•	- R		05 05	era .	
			-		0.5	on .	

Appendix C Environmental Report Special-Status Species Correspondence

7. 27 JUN 2002

· .

NAME

OCEAN COUNTY RARE SPECIES AND NATURAL CONMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE

• •	•	•					
NAME	CONMON NAME	FEDERAL	. STATE	REGIONAL	GRANK	SRANT	
	•	STATUS	STATUS	STATUS		•	· · .
NARTHECIUM AMERICANUM	BOG ASPHODEL	с	E	L.P	G2 ·	\$2	•
MYMPHOIDES CORDATA	FLOATINGHEART			LP	G5	53	
OENOTHERA HUNI FUSA	SEA-BEACH EVENING-PRIMROSE		B		G5 .	62	
ONOSHODIUN VIRGINIANUN	VIRGINIA FALSE-GRONWELL .		E		G4	S1	
PASPALLH DISSECTUR	MUDBANK CROWN GRASS				G47	62 ·	
PHORADENDRON LEUCARPON	AMERICAN MISTLETOS	•	•	LP	GS ·	52	
PITYOPSIS FALCATA	SICKLE-LEAP COLDEN-ASTER			19	0304	5]	
PLANTAGO MARITIMA VAR	SEASIDE PLANTAIN				GSTS	62	
JUNCOIDES				•			
PLANTAGO PUSILLA	DHARP PLANTAIN		B	•	cs	SH	
POLYCONAN GLAUCUM	SEA-BEACH KNOTWEED		5		G3	S1	
PRENAMTHES AUTUMNALIS	PINE BARREN RATTLESNARE-ROOT	•		LP	G4G5		
PRUNUS ANGUSTIFOLIA	CHICKASAN PLUN		Б		GST4TS	S2	
PUCCINELLIA FASCICULATA	SALTMARSH ALKALI GRASS				GIGS	82 .	
PYCNANTHEMM SETOSUM	ANNED HOUSTAIN-NINT				G37	83	
RAMINCULUS CYNHALARIA	SEASIDE BUTTERCUP		E		G5	SH .	
RHODODENDRON ATLANTICUM	UNARY AZALEA	· · .	2		G4G5	S1	
RHYNCHOSPORA CEPHALANTHA	LARGE-HEAD BRAKED-RUSH			LP	Q5	S 3	
RHYNCHOSPORA GLOBULARIS	COARSE GRASS-LIKE BEAKED-RUSH	•	B	•	Ģ\$7	61	
· RHYNCHOSPORA' ININDATA	SLENDER HORNED-BUSH			цэ.	G3G4	62	
RHYNCHOSPORA KNIESKERNII	INIESKERN'S BEAKED-RUSH	LT .	2	LP .	G1	S1 .	•
RHYINCHOSPORA NICROCEPHALA	SMALL-HEAD BEAKED-RUSH	•	8	· .	GST5	S1	•
RHYNCHOSPORA MITENS	SHORT-BEAKED BALD-RUSH		•		642 .	\$2	
RHYNCHOSPORA PALLIDA	PALE BEAKED-RUSH				G3	63	
RUBUS RECURVICAULIS	BLANCHARD'S DENBERRY		•		G47	\$1.1	
RUMEX HASTATULUS	. ENGELMANN'S SORREL	. •		•	Ģ5	64	
SABATIA CAMPANULATA	SLENDER MARSH-PINK				GS .	\$3	
SABATIA DODECANDRA VAR	LARGE MARSH-PINK				G57T4T5	62	• •
DODECANDRA	•	:		•			
SCHIZAEA PUSILLA	CURLY GRASS FERN	•		LP	G3	£3 · ·	

Environmental Report Appendix C Special-Status Species Correspondence

Oyster Creek Generating Station License Renewal Application

. 27 JUN 2002

D
Ъв
e
- 2
ដ

•	•	•	•	• •		•
				.•	• •	
	NAME	COMMON NAME	PIDERAL	STATE	RECIONAL	GRAM
			STATUS	STATUS	STATUS	
		•	· ·			
	SCHWALBER AMERICANA	CHAFPSEED	LE	R	LP	62
	SCIRPUS LONGII	LONG'S WOOLGRASS		E	LP ·	Ġ2
	SCIRPUS MARITIMUS	SALTMARSH PULKUSH		Ξ.		. 85
	SCLERIA MINOR	SLENDER NUT-RUSH		:	LP.	G4
	SOLIDADO STRICTA	WAND-LIKE GOLDENROD			LP	GS
	SOLIDAGO TARDA	LATE COLDENROD				6470
•	SPIRANTHES TACINIATA	LACE-LIP LADIES'-TRESSES		E	•	04G5
	SPIRANTHES ODORATA	FRAGRANT LADIES - TRESSES			•	. az
	STYLISMA PICKERINGII VAR	PICKERING'S MORNING-GLORY		· B	LP	G4721
· •	PICKERINGII	•	· · ·			
	TIPULARIA DISCOLOR	CRANEPLY ORCHID				G4G5
: ·	TRIDENS FLAVUS VAR CHAPMANII	CHATMAN'S REDTOP	. · ·	E		0577
	TRIGLOCHIN MARITIMA	SEASIDE ARROW-GRASS		B.	•	CS.
	UTRICULARIA BIPLORA	THO-FLOWER BLADDEPHORT	· ·	. .		CS.
	UTRICULARIA MINOR	LESSER, BLADDERNORT	•	E		65
•	UTRICULARIA PUNPUREA	PURPLE BLADDFRWORT	•	· · ·	I.P	05
	UVULARIA PUBERULA VAR NITIDA	PINE BARREN BELLWORT		T		05717
•	. VERBENA CIMPLEY	NARROW-LEAF VERVAIN		E		65
	XYRIS FINERIATA	FRINGED YELLOW-SYED-GRASS		E		65
•	ZIGADENUS LEIMANTINIDES	DEATH-CAMUS				640
• .	•	• • • • •	•			
Records Processe	đ	• •	_			
		. •	•	•	• •	•

٠t

81 81 \$1 . ۰.

. .

Appendix C Environmental Report Special-Status Species Correspondence

SRANK

51 **S**2 SĦ 84 83 53 \$1 **S**2 **\$1** .

ន់3 5Ħ \$1 \$1 **S1** 83. 82

OCEAN COUNTY RARE SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE .

Richard J. Codey Acting Governor State of New Jersey Department of Environmental Protection

Division of Fish, and Wildlife Martin J. McHugh, Director P.O. Box 400 Trenton, NJ 08625-0400 tel. 609-292-2965, fax 609-984-1414 Visit our Division Website: njfishandwildlife.com

January 18, 2005

AmerGen Energy Company, LLC 200 Exelon Way Kennett Square, PA 19348

Dear Mr Gallagher:

I am responding at Larry Nile's request to your letter of 12/3/2003 to Dr. Niles regarding renewal of AmerGen's operating license for the Oyster Creek Generating Station. Specifically your letter requested additional information regarding Threatened and Endangered species potentially affected by the operation of OCGS. You letter included a copy of response from the New Jersey Natural Heritage Program that provides a thorough accounting of Endangered and Threatened species found in the project area. At this time we have no additional information to add to that provided by NHP. Our agency is responsible for managing and monitoring of Endangered and Threatened wildlife species only, so I cannot comment with regard to any additional information that may exist pertaining to listed plant species. If you require any additional information with regard to Endangered and Threatened wildlife, please do no hesitate to contact me directly.

Sincerely.

C. David Jenkińs, Jr. / Principal Zoologist Endangered and Nongame Species Program

cc. Larry Niles, Chief, ENSP

New Jersey is an Equal Opportunity Employes Recycled Paper MICHAEL P. GALLAGHEH LICENSING SECTION

JAN 2 7 2005

REFER TO:

Bradley M. Campbell Commissioner



James E. McGreevey Governor Department of Environmental Protection Division of Parks and Forestry Office of Natural Lands Management Natural Heritage Program P.O. Box 404 Trenton, NJ 08625-0404 Tenton, NJ 08625-0404 Tel. #609-884-1333 Fax. #809-984-1427 September 22, 2004 Bradley M. Campbell Commissioner

William Mahler Amergen Energy Company, LLC 200 Exelon Way

Kennett Square, PA 19348

Re: Oyster Creek Generating Station to Manitou Substation Transmission Line

Dear Mr. Mahler:

Thank you for your data request regarding rare species information for the above referenced project site in Berkeley Township, Lacey Township and South Toms River Borough, Ocean County.

Searches of the Natural Heritage Database and the Landscape Project (Version 2) are based on a representation of the boundaries of your project site in our Geographic Information System (GIS). We make every effort to accurately transfer your project bounds from the topographic map(s) submitted with the Request for Data into our Geographic Information System. We do not typically verify that your project bounds are accurate, or check them against other sources.

We have checked the Natural Heritage Database for occurrences of rare plant species or natural communities. The Natural Heritage Data Base has records for occurrences of *Juncus caesariensis* and *Calamovilfa brevipilis* that may be on the site and for pitch pine-shrub oak barrens (pb4/5), pine-oak-shrub oak woodland (pow), pitch pine lowlands (undifferentiated), *Rhynchospora knieskernii, Schizaea pusilla, Narthecium americanum and Muhlenbergia torreyana* that may be in the immediate vicinity of the site. The attached lists provide more information about these occurrences. Because some species are sensitive to disturbance or sought by collectors, this information is provided to you on the condition that no specific locational data are released to the general public. This is not intended to preclude your submission of this information to regulatory agencies from which you are seeking permits.

We have also checked the Natural Heritage Database and the Landscape Project habitat mapping for occurrences of any rare wildlife species or wildlife habitat on the referenced site. Please see Table 1 for species list and conservation status.

New Jersey is an Equal Opportunity Employer Recycled Paper

Oyster Creek Generating Station License Renewal Application Page C-55

Environmental Report Appendix C Special-Status Species Correspondence

Common Name	Scientific Name	Federal Status	State Status	Grank	Srank
American rubyspot	Hetaerina americana			G5	53
barred owl	Strix varia		Τ/T	G5	S3B
bar-winged skimmer	Libellula axilena			G5	S2BS3B.SZN
black skimmer foraging area	Rynchops niger	· · ·	E	G5	S1B
black-crowned night-heron - foraging habitat	Nycticorax nycticorax		T/S	G5	S3B.S4N
black-throated green warbler	Dendroica virens		Special Concern	G5	\$3B
carpenter frog	Rana virgatipes	· ·	Special Concern	G5	S4
cerulean warbler	Dendroica cerulea		Special Concern	G4 .	S3B
colonial waterbird foraging habitat	· · ·				· .
Cooper's hawk	Accipiter cooperil		т/т	G5	S3B.S4N.
com snake	Elaphe g. guttata		E	G5T5	51
dotted skipper	Hesperia attalus slossonae		Special Concern	G3G4T3	
eastern box turtle	Terrapene carcilna		Special Concern	G5.	S5B
eastern kingsnake	Lampropeltis g. getula		U	G5T5	\$3
Fowler's toad	Bufo woodhousil fowlerf		Special Concern	G5	S4
golden-winged skimmer	Libellula sunpennis			G5	\$1\$2
Martha's pennant	Celithemis martha			1 G4	\$3\$4
northern parula	Parula americana		Special Concern	G5	S3B
northem pine snake	Pituophis m. melancieucus	•	Т	· G4T4	S3
pine barrens treefrog	Hyla andersonii	•	Т	G4	S3
red-headed woodpecker	Melanerpes erythrocephatus		тл	G5	S2B,S2N
spotted turtle	Clemmys guttate		Special Concern	G5	S4
tern species foraging habitat			•	•	
timber rattlesnake	Crotalus h. horridus		·E	G4T4	S2
veery	Catharus fuscescens		Special Concern	G5	S3B
wood turtle	Clemmys Insculpta		T	G4	S3

We have also checked the Natural Heritage Database and the Landscape Project habint mapping for occurrences of any rare wildlife species or wildlife habitat within 1/4 mile of the referenced site. Please see Table 2 for species list and conservation status. This table excludes any species listed in Table 1.

Table 2 (additional spec	ies within 1/4 mile of reference	d site).			
Common Name	Scientific Name	Federal Status	State Status	Grank	Srank
a salyr	Neonympha areolata septentrionalis			G4T3T4	S3

Also attached is a list of rare species and natural communities that have been documented from Ocean County. If suitable habitat is present at the project site, these species have potential to be present.

Status and rank codes used in the tables and lists are defined in the attached EXPLANATION OF CODES USED IN NATURAL HERITAGE REPORTS.

The Natural Heritage Program reviews its data periodically to identify priority sites for natural diversity in the State. Included as priority sites are some of the State's best habitats for rare and endangered species and natural communities. Four of these sites are located within or near the areas you have outlined. Please refer to the enclosed Natural Heritage Priority Site Maps for the locations and boundaries of these sites. On the back of each Priority Site Map is a report describing the significance of the site. You may find the site biodiversity significance rating to be useful if you need to prioritize among the sites in your environmental assessment.

If you have questions concerning the wildlife records or wildlife species mentioned in this response, we recommend that you visit the interactive I-Map-NJ website at the following URL, http://www.state.nj.us/dep/gis/imapnj/imapnj.htm or contact the Division of Fish and Wildlife, Endangered and Nongame Species Program.

PLEASE SEE THE ATTACHED 'CAUTIONS AND RESTRICTIONS ON NHP DATA'.

...

Thank you for consulting the Natural Heritage Program. The attached invoice details the payment due for processing this data request. Feel free to contact us again regarding any future data requests.

Sincerely,

Herbert a. Lord

Herbert A. Lord Data Request Specialist

. .

cc: Robert J. Cartica Lawrence Niles NHP File No. 04-3907472

Oyster Creek Generating Station License Renewal Application Page C-57

Oyster Creek Generating Station License Renewal Application

.

Page.C-58

1 21 SEP 2004

NAME

*** Vascular plants CALAMOVILES BREVIEILIS

JUNCUS CAESARIENSIS

2 Records Processed

CONHON NAME

PINE BARREN REEDGRACS

NEW JERSEY RUSH

FEDERAL

STATUS

STATE

STATUS

POSSIBLY ON PROJECT SITE BASED ON SEARCH OF NATURAL HERITAGE DATABASE RARE PLANT SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE ۰.

REGIONAL GRAFK

Gé

a2

STATUS

LP

LP

÷.

Environmental Report Appendix C Special-Status Species Correspondence

۰.

1985-09-29

1985-09-29

DATE OBSERVED IDENT.

Y

Y

GRANK

.

54

52

PARKWAY.

N. OF MIDDLE BRANCH FORKED RIVER, JUST W. OF GARDEN STATE

N. OF MIDDLE BRANCH FORKED

RIVER, JUST W. OF GARDEN STATE

LOCATION

PARKWAY.

1 21 SEP 2004

SARPULATA WOODLAND

INMEDIATE VICINITY OP PROJECT SITE Pased on Search op Natural Heritaje Database Pare plant species and Natural commutites presently recorded in The New Jersey Natural Heritaje Database

							•	•	•
name	COMMON NAME	FEDERAL STATUS	STATE Status	regional Status	GRANK	SRANK	DATE OBSERVE	D IDENT.	LOCATION
*** Ecosystems									
PINUS RIGIDA SATURATED	PITCH PINE LOWLANDS	•			G3 ·	83 ·	2003-01-25	Y	SEVERAL
WOODLAND ALLIANCE	(UNDIFFERENTIATED)					·	•		BRANCH, I
									GROVE RO
			ı	•			•		POWERLIN
			•						STATE PAI
PINUS RIGIDA- (P.	PINE-OAK-SHRUB OAK WOODLAND				G3	់ទា	2003-01-25	Y	TWELVE ST
ECHINATA) - QUERCUS SPP. / QUERCUS	(POW) ·		•	•					LOCATED S
(MARILANDICA, ILICIPOLIA)	•							•	MOSTLY N
400DLAND		•	•••••						· PINEWALD
•									MOSTLY E
•		•					. •		POWERLIN
				•			•		GARDEN ST
21NUS RIGIDA/QUERCUS	PITCH PINE-SHRUB OAK BARRENS				Q2	S2	2002-10-15	Y	THO MAIN
(MARILANDICA,	(PB4/5)		•				· · .		SOUTH OF
LICIPOLIA) / PYRIDANTHERA	· .					•			OF FINEW

L PATCHES S OF JAKES , N OF PINEWALD-KESWICK ROAD, EAST OF THE JCPL INE, AND W OF THE GARDEN PARKWAY. SCATTERED PATCHES D SOUTH OF JAKES BRANCH, NORTH OF . . LD-KESWICK GROVE ROAD, EAST OF THE JCPL INE, AND WEST OF THE STATE PARKWAY. IN PATCHES ARE LOCATED OF JAKES BRANCH, NORTH OF PINEWALD-RESWICK GROVE ROAD, EAST OF JCFL FOWERLINE, AND WEST OF THE GARDEN STATE PARIMAY. PATCHES ARE LOCATED 0.5 TO 2.3 MILES NORTH OF THE DOUBLE TROUBLE STATE PARK ENTRANCE, PARTLY WITHIN JAKES BRANCH COUNTY PARK IN BEACHNOOD BORD, AND PARTLY WITHIN DOUBLE TROUBLE STATE PARK AND PRIVATE LANDS IN

BERKELEY TWP.

2 . 21 SEP 2004

INMEDIATE VICINITY OF PROJECT SITE BASED ON SEARCH OF NATURAL HERITAGE DATABASE RARE FLANT SPECIES AND NATURAL COMMUNITIES PRESSNILY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE

.

.

	•								
dake .	CONTION NAME	Federal Status	STATE STATUS	regional Status	GRANK .	6RANK	DATE ONSERVED	IDENT.	LOCATION
*** Vascular plants		• •			•				
WHLENBERGIA TORREYANA	PINE BARREN SMOKE GRASS			LP	G3	S 3	1985-09-29	Y	N. OF HIDDL
		•	•						RIVER, 0.25
	•								STATE PAREW
NARTHECTUM AMERICANOM	BOG ASPHODEL	c	E .	LP	G2	62	1995-09-04	Y	CA. 0.1 HIL
		•						• .	STATE PARKW
	·.								BRANCH AND A
									FORKED RIVES
								•	SOUTHWEST OF
			· •						OF RT. 9 AND
UIVNCHOSPORA KNIESKERNII .	' KNIESKERN'S BEAKED-RUSH	LT	B	LP	G2	52	1994-09-03	r	N. OF MIDDLE
		•	•••	•					RIVER, JUST
	_	• •					•		. PARKWAY. APP
	· · ·	•							MILES SOUTH
	· .								OF GSP.
CHIZAEA PUSILLA	CURLY GRASS FERN			LP	G3	83	1907-07-25	Y	LAKĘ INLET A
CHIZAER PUSILLA	CURLY CRASS FERN			LP	G3	83	1915-07-10	¥	CEDAR SHAMP
		•							OF DORTOD BI

Records, Processed

B BRANCE FORKED MI. W. OF GARDEN IAY. RE EAST OF GARDEN AY BETWEEN MIDDLE SOUTH BRANCH OP R, CA. 2 NILES F THE INTERSECTION D LACEY RD. E BRANCH FORKED W. OF GARDEN STATE PROXIMATELY 2.0 OF INTERCHANGE 74 . AT DOUBLE TROUBLE. ALONG SOUTH BRANCH

Environmental Report Appendix C Special-Status Species Correspondence

OF FORKED RIVER SW OF FORKED RIVER.

.
About Natural Heritage Priority Sites **Frequently Asked Questions** ..

٠. • natural communities to planners, developers, and critically important areas to conserve New Jersey's biological diversity. The database provides detailed, up-to-date information on rare species and What are Natural Heritage Priority Sites? Through its Natural Heritage Database, the Office of Natural Lands Management (ONLM) identifies management, environmental impact assessment, and both public and private land protection efforts. conservation agencies for use in resource

Using the database, ONLM has identified Natural Heritage Priority Sites that represent some of the best remaining habitat for rare species and exemplary natural communities ١, ••• components of our natural heritage. the preservation of biological diversity in New Jersey. If these sites become degraded or destroyed, we may lose some of the unique exemplary natural communities in the state. These areas should be considered to be top priorities for •••

ONLM has identified 410 priority sites over the course of more than 10 years. We have received assistance from many partner individuals and agencies over this time. The Nature Conservancy and the DEP Endangered and Nongame Species . Program have provided key information or assisted with the delineation of a number of the sites.
Horv are Natural Heritage Priority Site maps used in conservation of biological diversity? Natural Heritage Priority Site maps are used by individuals and agencies concerned with the protection and management of land. The maps have been used by municipalities preparing natural resource inventories; public and private

conservation organizations preparing open space . acquisition goals; land developers and consultants identifying environmentally sensitive lands; and public and private landowners developing land

7

management plans.

best and most viable occurrences of endangered . Natural Heritage Priority Sites contain some of the

and threatened species and natural communities,

but they do not cover all known habitat for. ... endangered and threatened species in New Jersey... If information is needed on whether or not

endangered or threatened species have been documented from a particular piece of land, a Natural Heritage Database search can be requested by contacting the Office of Natural Lands Management at the address Latural Lands Management at the address below. · .-

 sometimes used to refer to boundaries enclosing additional buffer. In maps where both primary and secondary boundaries are described, only the outermost boundary is provided in the mapping. boundaries extend to include additional buffer lands that should be managed to protect the habitat. A justification for the boundary is provided for each site. The term "primary bounds" is sometimes used to refer to boundaries enclosing critical habitat. The term "secondary bounds" is What do the boundaries of the sites contain? The boundaries of each Natural Heritage Priority Site are drawn to encompass critical habitat for the rare species of natural communities. Often the boundaries extend to include additional buffer

What is the background map that the sites are drawn upon?

as streams, lakes, roads, towns and place names. are drawn upon? The sites are portrayed on background maps produced from a digital copy of the U.S. Geological Survey 7.5 minute topographic maps. The background maps contain topographic lines as well against a background of rectified aerial photography, and some of the digitized USGS topo maps do not align with this photography. These background maps do not always reflect recent changes in land development. Some may be more than 20 years old. Some sites appear to be shifted in position against this topo map. This shift is due to the fact that most sites have been digitized :

a GIS coverage by the state Green Acres Program. This information is provided to show patterns of State land ownership in the vicinity of the Priority Site. The public lands are areas such as State Parks and Forests, Wildlife Management Areas, and Natural Lands Trust preserves. They do not currently include lands owned by other state agencies, federal, county or municipal governments What do "public lands" depict on the maps? The "public lands" shaded on these maps are state-owned open space lands that have been digitized as

License Renewal Application **Oyster Creek Generating Station** or nonprofit conservation organizations. This GIS coverage is constantly being updated, and therefore future editions of the maps will likely contain additional public lands that are not currently mapped as such.

What is the biodiversity significance rank and how is it used?

Each site is ranked according to its significance for biological diversity using a scale developed by The Nature Conservancy and the network of Natural

Heritage Programs. The ranks can be used to distinguish between sites that are of global significance for conservation of biological diversity vs. those that are of state significance. The scale ranges from B1 to B5 with sites ranked B1-B3 generally being of global significance and sites ranked B4-B5 being of state significance. The specific definitions for each rank are as follows;

B1 - Outstanding significance, generally the "last of the least" in the world, such as the only known occurrence of any element (species or natural community), the best or an excellent occurrence of an element ranked critically imperiled globally, or a concentration (4+) of good or excellent occurrences of elements that are imperiled or critically imperiled globally. The site should be viable and defensible for the elements or ecological processes contained.

B2 - Very high significance, such as the most outstanding occurrence of any natural community. Also includes areas containing other occurrences of elements that are critically imperiled globally, a good or excellent occurrence of an element that is imperiled globally, an excellent occurrence of an element that is rare globally, or a concentration (4+) of good occurrences of globally rare elements or viable occurrences of globally imperiled elements.

B3 - High significance, such as any other viable occurrence of an element that is globally imperiled, a good occurrence of a globally rare element, an excellent occurrence of any natural community, or a concentration (4+) of good or excellent occurrences of elements that are critically imperiled in the State.

B4 - Moderate significance, such as a viable occurrence of a globally rare element, a good occurrence of any natural community, a good or excellent occurrence or only viable state occurrence of an element that is critically imperiled in the State, an excellent occurrence of an element that is imperiled in the State, or a concentration (4+) of good occurrences of elements that are imperiled in the State or excellent occurrences of elements that are rare in the State.

B5 - Of general biodiversity interest.

How can I obtain Natural Heritage Priority Site maps for an area of interest to me? Natural Heritage Priority Site hard copy maps can be obtained by submitting a written request accompanied by a check or money order made payable to the Office of Natural Lands Management at the following address:

Office of Natural Lands Management P.O. Box 404 Trenton, NJ 08625-0404 Phone: 609-984-1339; Fax: 609-984-1427

Individual 8.5" X 11" maps are available at the following rate:

1 - 10 site maps & reports:	\$1.50/site
11 - 20 site maps & reports:	\$1.00/site
> 20 sites:	\$0.50/site

Digital GIS Coverage of Natural Heritage Priority Sites

A digital version of the AreView GIS file of Natural Heritage Priority Sites is also available. The zipped version of the file is approximately I MB in size. The 2001 version of Natural Heritage Priority Sites will be emailed upon request. The 1999 version of the digital files can be obtained on the internet at the following address: http://www.state.nj.us/dep/gis/ -Click on "GIS Data Downloads" and then "Select a data layer" and then "Natural Heritage Priority Sites". There is no charge for emailing or downloading the GIS data.

How often are the maps updated? The Natural Heritage Priority Site information is constantly being updated in the Natural Heritage Database. A new edition of the maps will be made a available after significant revisions or additions to the Database.

April 9, 2002

NJ Department of Environmental Protection Division of Parks and Forestry Vatural Lands Management

Oyster Creek Generating Station License Renewal Application



Oyster Creek Generating Station License Renewal Application Page C-63

Environmental Report Appendix C Special-Status Species Correspondence

Natural Heritage Priority Site **Crossley RR Corridor Macrosite**

Locational Information

Quad Name: Keswick Grove ; Toms River County: Ocean

Municipality Berkeley Twp ; Manchester Twp ; Lacey Twp ; Beachwood Boro ; South Toms River Boro

.

Description of Site

A large patch of contiguous pine/oak woods with predominantly Lakehurst soils. .

Boundary Justification

Natural Lands Management

Bounds drawn to include large contiguous patch of pine/oak uplands that is habitat to endangered and . threatened animal species.

Biodiversity Rank B4

Excellent site for State Endangered and Threatened animal species.

July, 2001 S.USNJHP1*60



Oyster Creek Generating Station License Renewal Application Page C-65

Natural Heritage Priority Site Forked River Mountain Macrosite

Locational Information

Quad Name: Brookville; Forked River; Woodmansie; Keswick Grove; Whiting County: Ocean

Municipality Lacey Twp; Ocean Twp; Manchester Twp; Barnegat Twp

Description of Site

A few small occurrences of dwarf pine plains (<150 acres) associated with up to 1000+ acres of transitional pine plains, and several small occurrences of hydric pine plains. Most of the plains are in the vicinity of Forked River Mountain, near the center of a large fireshed of over 30,000 acres. Within the fireshed are extensive occurrences of pitch pine-scrub oak barrens, other pine barrens and pine-oak forests, pitch pine lowlands, red maple-black gum palustrine forest, and atlantic white cedar palustrine forest.

Boundary Justification

Fireshed limits where most plant community-maintaining wildfires would originate and be contained within, using convenient man-made and natural firebreaks and distribution of flammable pine barren plant

communities for management purposes.

Biodiversity Rank B2

The site contains a globally imperiled pine plains natural community.



July, 2001

She Code: S.USNJIP1+236



Oyster Creek Generating Station License Renewal Application Environmental Report Appendix C Special-Status Species Correspondence

Natural Heritage Priority Site Middle Branch Forked River

Locational Information

Quad Name: Forked River

County: Ocean

Municipality Lacey Twp

Description of Site

Open wetlands adjacent to pine barren stream through Atantic white cedar swamp.

Boundary Justification

Boundaries include wetland habitat for rare plant species plus undeveloped uplands in the drainage basin east of the Garden State Parkway. With additional field work, bounds may be expanded upstream west of the Parkway.

Blodiversity Rank B2

Several globally rare and State listed plant species.

Disposed of Bortsmann Principal Disposed for the Affrence of Natural Lands Management

July, 2001 Stee Code: S.USNJHP1*365



,

Natural Heritage Priority Site Pits and Pond

Locational Information

Quad Name:Forked RiverCounty:OceanMunicipalityLacey Twp

Description of Site

Two borrow pits (heavily used by ORV's) under and adjacent to mowed pipeline right-of-way through pitch pine lowland forest.

Boundary Justification

Uses existing sand roads to north, west, and south to enclose the adjacent wetlands and uplands draining towards the rare plants, with the Garden State Parkway forming the eastern boundary.

Biodiversity Rank B2

The site contains four globally rare plant species, two of which are state endangered, and one of which is also federally threatened.

Matural Lands Management

July, 2001 Site Code: S.USNJHP1*440 1

Environmental Report Appendix C Special-Status Species Correspondence

James E. McGreevey Governor



Department of Environmental Protection Division of Parks and Forestry Office of Natural Lends Management Natural Heritage Program P.O. Box 404 Trenton, NJ 06625-0404 Tel: #609-984-1339 Fax, #609-984-1427

September 22, 2004

Bradley M. Campbell Commissioner

William Mahler Amergen Energy Company, LLC 200 Exelon Way

Kennett Square, PA 19348

Re: Oyster Creek Generating Station

Dear Mr. Mahler:

Thank you for your data request regarding rare species information for the above referenced project site in Lacey Township, Ocean County.

Searches of the Natural Heritage Database and the Landscape Project (Version 2) are based on a representation of the boundaries of your project site in our Geographic Information System (GIS). We make every effort to accurately transfer your project bounds from the topographic map(s) submitted with the Request for Data into our Geographic Information System. We do not typically verify that your project bounds are accurate, or check them against other sources.

We have checked the Natural Heritage Database and the Landscape Project habitat mapping for occurrences of any rare wildlife species or wildlife habitat on the referenced site. Please see Table 1 for species list and conservation status.

Table 1 (on referenced site).				••	•
Common Name	Scientific Name	Federal Status	State Status	Grank	Srank
barred owl	Strix varia		ТЛ	G5	S3B
black skimmer foraging area	Rynchops niger		ε	G5	S1B
black-crowned night-heron foraging habitat	Nycticorax nycticorax		T/S	G5	\$38,\$4N
colonial waterbird foraging habitat					
Cooper's hawk	Accipiter cooperti		тл	G5	S3B,S4N
dotted skipper	Hesperie attalus slossonae		Special Concern	G3G4T3	S2S3
eastern box turtle	Terrapene carolina	· ·	Special Concern	G5	S5B
Fowler's toad	Buto woodhousll fowlerf		Special Concern	G5	S4
northem pine snake	Pituophis m. melanoleucus		Т	G4T4	S3
pine barrens treefrog	Hyla endersonli		Т	G4	S3
tern species foraging habitat					[
wood turtle	Clemmys insculpta	1	т	G4	S3

We have also checked the Natural Heritage Database and the Landscape Project habitat mapping for occurrences of any rare wildlife species or wildlife habitat within 1/4 mile of the referenced site. Please see Table 2 for species list and conservation status. This table excludes any species listed in Table 1.

Table 2 (additional species within 1/4 mile of referenced site).

Common Name	Scientific Name	Federal Status	State Status	Grank	Srank
spotted turtle	Clemmys guttata		Special Concern	G5	S4

We have also checked the Natural Heritage Database for occurrences of rare plant species or natural communities. The Natural Heritage Data Base has records for occurrences of Narthecium americanum that may be on the site, and for Pycnanthemum setosum that may be on or in the immediate vicinity of the site, and for Eupatorium resinosum, Pycnanthemum setosum, Juncus caesariensis and Schizaea pusilla that may be in the immediate vicinity of the site. The

> New Jersey is an Equal Opportunity Employer Recycled Paper

attached lists provide more information about these occurrences. Because some species are sensitive to disturbance or sought by collectors, this information is provided to you on the condition that no specific locational data are released to the general public. This is not intended to preclude your submission of this information to regulatory agencies from which you are seeking permits.

Also attached is a list of rare species and natural communities that have been documented from Ocean County. If suitable habitat is present at the project site, these species have potential to be present.

Status and rank codes used in the tables and lists are defined in the attached EXPLANATION OF CODES USED IN NATURAL HERITAGE REPORTS.

The Natural Heritage Program reviews its data periodically to identify priority sites for natural diversity in the State. Included as priority sites are some of the State's best habitats for rare and endangered species and natural communities. One of these sites is located within or near the areas you have outlined. Please refer to the enclosed Natural Heritage Priority Site Map for the location and boundary of this site. On the back of each Priority Site Map is a report describing the significance of the site.

If you have questions concerning the wildlife records or wildlife species mentioned in this response, we recommend that you visit the interactive I-Map-NJ website at the following URL, http://www.state.nj.us/dep/gis/imapnj/imapnj.htm or contact the Division of Fish and Wildlife, Endangered and Nongame Species Program.

PLEASE SEE THE ATTACHED 'CAUTIONS AND RESTRICTIONS ON NHP DATA'.

Thank you for consulting the Natural Heritage Program. The attached invoice details the payment due for processing this data request. Feel free to contact us again regarding any future data requests.

Sincerely,

Herbert a.Lord

Herbert A. Lord Data Request Specialist

cc: Robert J. Cartica Lawrence Niles NHP File No. 04-3907472

CAUTIONS AND RESTRICTIONS ON NATURAL HERITAGE DATA

The quantity and quality of data collected by the Natural Heritage Program is dependent on the research and observations of many individuals and organizations. Not all of this information is the result of comprehensive or site-specific field surveys. Some natural areas in New Jersey have never been thoroughly surveyed. As a result, new locations for plant and animal species are continuously added to the database. Since data acquisition is a dynamic, ongoing process, the Natural Heritage Program cannot provide a <u>definitive</u> statement on the presence, absence, or condition of biological elements in any part of New Jersey. Information supplied by the Natural Heritage Program summarizes existing data known to the program at the time of the request regarding the biological elements on the elements or areas being considered, nor should hever be regarded as final statements on the elemental assessments. The attached data is provided as one source of information to assist others in the preservation of natural diversity.

This office cannot provide a letter of interpretation or a statement addressing the classification of wetlands as defined by the Freshwater Wetlands Act. Requests for such determination should be sent to the DEP Land Use Regulation Program, P.O. Box 401, Trenton, NJ 08625-0401.

The Landscape Project was developed by the Division of Fish & Wildlife, Endangered and Nongame Species Program to map critical habitat for rare animal species. Some of the rare species data in the Landscape Project is in the Natural Heritage Database, while other records were obtained from other sources. Natural Heritage Database response letters will list <u>all</u> species (if any) found during a search of the Landscape Project. However, any reports that are included with the response letter will only reference specific records if they are in the Natural Heritage Database. This office cannot answer any inquiries about the Landscape Project. All questions should be directed to the DEP Division of Fish and Wildlife, Endangered and Nongame Species Program, P.O. Box 400, Trenton, NJ 08625-0400.

This cautions and restrictions notice must be included whenever information provided by the Natural Heritage Database is published.

of Parks and Roy

Vatural Lands Management

Oyster Creek Generating Station License Renewal Application

...

21 SEP 2004

1

POSSIBLY ON PROJECT SITE BASED ON SEARCH OF NATURAL HERITAGE DATABASE RARE PLANT SPECIES AND NATURAL COMPLUITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL MERITAGE DATABASE

NAME	COMMON NAME	PEDERAL STATUS	state Status	REGIONAL STATUS	GRANK	SRANK	DATE OBSERVE	DIDENT.	LOCATION
*** Vascilar plants NARTHECIUM AMERICANUM	EOG ASVHODEL	. c	E	LP .	G2	52	1991-05-22	Y	CA. 1 MILE EAST-NORT OYSTER CREEK POWER P SOUTH OF THE SOUTH B PORKED RIVER. APPROX 1/2 MILES SOUTH OF TH INTERSECTION OF POUT LACEY POAD.
1 Records Processed									

.

HEAST OP LANT AND RANCH OF IMATELY 1 HE CE 9 AND

Environmental Report Appendix C Special-Status Species Correspondence

Oyster Creek Generating Station License Renewal Application

.

1 21 SEP 2001

CN OR IN IMMEDIATE VICINITY OF PROJECT SITE BASED ON SEARCH OF NATURAL HERITAGE DATABASE RARE PLANT SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE

NAME		COMMON NAME	FECERAL STATUS	STATE STATUS	REGIONAL GRANK STATUS	BRANK	DATE OBSERVED IDENT	. LOCATION
*** Vascular pla	int s							
PYCNANTHEMIM SET	OSUM	AWNED MOUNTAIN-MINT			G37	\$3	1993-77-77 ¥	SOUTH OF ORLANDO DRIVE AND

.

1 Records Processed

•

NORTH OF OYSTER CREEK, LACEY TNP.

.

·

.

.

1 21 SEP 2004

INMEDIATE VICINITY OF PROJECT SITE BASED ON SEARCH OF NATURAL HERITAGE DATABASE RARE PLANT SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE CATABASE

NAME	COMMON NAME	FEDERAL STATUS	state Status	REGIONAL STATUS	CRANK	SRANK	DATE CESERVE	D IDENT.	LOCATION
*** Vascular plants Eupatorium resinosum	PINE BARREN BONESET		E	lp	G3	52	1993-08-77	¥.	EAST SIDE OF ROUTE 9 JUST MORTH OF BAY PARKNAY. IN RECOVERING CRANBERRY BOG ON
JUNCUS CAESARIENSIS	NEW JERSEY RUSH		E	LP	G2	52	1922-09-77	¥	SOUTH BANK OF OYSTER CREEK. OYSTER CREEK ALONG TUCKERTON
PYCHANTHERUM SETOSUM	ANNED HOUNTAIN HINT				GJ7	\$3	1993-77-77	Y	NEST OF CABLE ROAD AND EAST OF DOCK ROAD AND A SMALL
PYCHANTHERIM SETOSUM	ANNED NORMAIN-KINT				G37	53	1993-77-77	Y	ENGANKMENT OF OYSTER CREEK. SANDS HARBOR POINT, NORTHERNMOST TIP, MORTH OF BAY
PYCNANTHERUM SETOSUM	ANNED MOUNTAIN-MINT				637	63	1993-77-77	¥	PARKWAY. EAST SIDE OF ROUTE 9, JUST NORTH OF BAY PARKWAY, SOUTH OF
SCHIZAFA PUSILLA	CURLY GRASS FERN			LP	63	63	1915-07-10	¥	OYSTER CREEK. BY OYSTER CREEK NW ALONG TUCKERTON ER FROM MARETOWN.

& Records Processed

.

. ·

•

Frequently Asked Questions About Natural Heritage Priority Sites

What are Natural Heritage Priority Sites? Through its Natural Heritage Database, the Office of Natural Lands Management (ONLM) identifies critically important areas to conserve New Jersey's biological diversity. The database provides detailed, up-to-date information on rare species and natural communities to planners, developers, and conservation agencies for use in resource management, environmental impact assessment, and both public and private land protection efforts.

Using the database, ONLM has identified Natural Heritage Priority Sites that represent some of the best remaining habitat for rare species and exemplary natural communities in the state. These areas should be considered to be top priorities for the preservation of biological diversity in New. Jersey. If these sites become degraded or destroyed, we may lose some of the unique components of our natural heritage.

ONLM has identified 410 priority sites over the course of more than 10 years. We have received assistance from many partner individuals and agencies over this time. The Nature Conservancy and the DEP Endangered and Nongame Species Program have provided key information or assisted with the delineation of a number of the sites.

How are Natural Heritage Priority Site maps used in conservation of biological diversity? Natural Heritage Priority Site maps are used by individuals and agencies concerned with the protection and management of land. The maps have been used by municipalities preparing natural resource inventories; public and private conservation organizations preparing open space acquisition goals; land developers and consultants identifying environmentally sensitive lands; and public and private landowners developing land management plans.

Natural Heritage Priority Sites contain some of the best and most viable occurrences of endangered and threatened species and natural communities, but they do not cover all known habitat for : endangered and threatened species in New Jersey. If information is needed on whether or not endangered or threatened species have been documented from a particular piece of land, a Natural Heritage Database search can be requested by contacting the Office of Natural Lands Management at the address below.

What do the boundaries of the sites contain? The boundaries of each Natural Heritage Priority Site are drawn to encompass critical habitat for the rare species or natural communities. Often the boundaries extend to include additional buffer lands that should be managed to protect the habitat. A justification for the boundary is provided for each site. The term "primary bounds" is sometimes used to refer to boundaries enclosing critical habitat. The term "secondary bounds" is sometimes used to refer to boundaries enclosing additional buffer. In maps where both primary and secondary boundaries are described, only the outermost boundary is provided in the mapping.

What is the background map that the sites are drawn upon? The sites are portrayed on background maps produced from a digital copy of the U.S. Geological Survey 7.5 minute topographic maps. The background maps contain topographic lines as well as streams, lakes, roads, towns and place names. These background maps do not always reflect recent changes in land development. Some may be more than 20 years old. Some sites appear to be shifted in position against this topo map. This shift is due to the fact that most sites have been digitized

against a background of rectified aerial photography, and some of the digitized USGS topo maps do not align with this photography.

What do "public lands" depict on the maps? The "public lands" shaded on these maps are stateowned open space lands that have been digitized as a GIS coverage by the state Green Acres Program. This information is provided to show patterns of State land ownership in the vicinity of the Priority Site. The public lands are areas such as State Parks and Forests, Wildlife Management Areas, and Natural Lands Trust preserves. They do not currently include lands owned by other state agencies, federal, county or municipal governments or nonprofit conservation organizations. This GIS coverage is constantly being updated, and therefore future editions of the maps will likely contain additional public lands that are not currently mapped as such.

What is the biodiversity significance rank and how is it used?

Each site is ranked according to its significance for biological diversity using a scale developed by The Nature Conservancy and the network of Natural Heritage Programs. The ranks can be used to

distinguish between sites that are of global significance for conservation of biological diversity vs. those that are of state significance. The scale ranges from B1 to B5 with sites ranked B1-B3 generally being of global significance and sites ranked B4-B5 being of state significance. The specific definitions for each rank are as follows:

B1 - Outstanding significance, generally the "last of the least" in the world, such as the only known occurrence of any element (species or natural community), the best or an excellent occurrence of an element ranked critically imperiled globally, or a concentration (4+) of good or excellent occurrences of elements that are imperiled or critically imperiled globally. The site should be viable and defensible for the elements or ecological processes contained.

B2 - Very high significance, such as the most outstanding occurrence of any natural community. Also includes areas containing other occurrences of elements that are critically imperiled globally, a good or excellent occurrence of an element that is imperiled globally, an excellent occurrence of an element that is rare globally, or a concentration (4+) of good occurrences of globally rare elements or viable occurrences of globally imperiled elements.

B3 - High significance, such as any other viable occurrence of an element that is globally imperiled, a good occurrence of a globally rare element, an excellent occurrence of any natural community, or a concentration (4+) of good or excellent occurrences of elements that are critically imperiled in the State.

B4 - Moderate significance, such as a viable occurrence of a globally rare element, a good occurrence of any natural community, a good or excellent occurrence or only viable state occurrence of an element that is critically imperiled in the State, an excellent occurrence of an element that is imperiled in the State, or a concentration (4+) of good occurrences of elements that are imperiled in the State or excellent occurrences of

elements that are rare in the State.

B5 - Of general biodiversity interest,

How can I obtain Natural Heritage Priority Site maps for an area of interest to me? Natural Heritage Priority Site hard copy maps can be obtained by submitting a written request accompanied by a check or money order made payable to the Office of Natural Lands Management at the following address:

Office of Natural Lands Management P.O. Box 404 Trenton, NJ 08625-0404 Phone: 609-984-1339; Fax: 609-984-1427

Individual 8.5" X 11" maps are available at the following rate:

1 - 10 site maps & report	s:	\$1.50/site
11 - 20 site maps & report	rts:	\$1.00/site
> 20 sites:		\$0.50/site

Digital GIS Coverage of Natural Heritage Priority Sites

A digital version of the ArcView GIS file of Natural Heritage Priority Sites is also available. The zipped version of the file is approximately 1 MB in size. The 2001 version of Natural Heritage Priority Sites will be emailed upon request. The 1999 version of the digital files can be obtained on the internet at the following address: http://www.state.nj.us/dep/gis/ -Click on "GIS Data Downloads" and then "Select a data layer" and then "Natural Heritage Priority Sites". There is no charge for emailing or downloading the GIS data.

How often are the maps updated? The Natural Heritage Priority Site information is constantly being updated in the Natural Heritage Database. A new edition of the maps will be made available after significant revisions or additions to the Database.

April 9, 2002

NJ Department of Environmental Pr

Division of Parks and Forestry Vatural Lands Management

> **Oyster Creek Generating Station** License Renewal Application



Oyster Creek Generating Station License Renewal Application Page C-79

Natural Heritage Priority Site Middle Branch Forked River

Locational Information

Quad Name:	Forked River	
County:	Ocean	·
Municipality	Lacey Twp	

Description of Site

Open wetlands adjacent to pine barren stream through Atantic white cedar swamp.

Boundary Justification

Boundaries include wetland habitat for rare plant species plus undeveloped uplands in the drainage basin east of the Garden State Parkway. With additional field work, bounds may be expanded upstream west of the Parkway.

Biodiversity Rank B2

Several globally rare and State listed plant species.

No Description of Internation Definition of Junior and Foundary Natural Lands Management

Vatural Lands Management July, 2001 Sile Code: SUSNJHP1*365

Page.C-80

Oyster Creek Generating Station License Renewal Application EXPLANATIONS OF CODES USED IN NATURAL HERITAGE REPORTS

FEDERAL STATUS CODES

The following U.S. Fish and Wildlife Service categories and their definitions of endangered and threatened plants and animals have been modified from the U.S. Fish and Wildlife Service (F.R. Vol. 53 No. 188; Vol. 61, No. 40; F.R. 53 CFR Part 17). Federal Status codes reported for species follow the most recent listing.

LE Taxa formally listed as endangered. LT Taxa formally listed as threatened.

PE Taxa already proposed to be formally listed as endangered.
PT Taxa already proposed to be formally listed as threatened.

C Taxa for which the Service currently has on file sufficient information on biological vulnerability and threat(s) to support proposals to list them as endangered or threatened species.

S/A Similarity of appearance species.

STATE STATUS CODES . .

E

Two animal lists provide state status codes after the Endangered and Nongame Species Conservation Act of 1973 (NSSA 23:2A-13 et. seq.): the list of endangered species (NJA.C. 7:25-4.13) and the list defining status of indigenous, nongame wildlife species of New Jersey (NJA.C. 7:25-4.17(a)). The status of animal species is determined by the Nongame and Endangered Species Program (ENSP). The state status codes and definitions provided reflect the most recent lists that were revised in the New Jersey Register, Monday, June 3, 1991.

D . Declining species a species which has exhibited a continued decline in population numbers over the years.

Endangered species-an endangered species is one whose prospects for survival within the state are in immediate danger due to one or many factors — a loss of habitat, over exploitation, predation, competition, disease. An endangered species requires immediate assistance or extinction will probably follow.

EX Extirpated species - a species that formerly occurred in New Jersey, but is not now known to exist within the state.

I Introduced species-a species not native to New Jersey that could not have established itself here without the assistance of man.

incensing species-a species whose population has exhibited a significant increase, beyond the normal range of its life cycle, over a long term period.

P Peripheral species-a species whose occurrence in New Jersey is at the extreme edge of its present natural range.

Stable species a species whose population is not undergoing any long-term increase/decrease within its natural cycle.
 Undetermined species a species about which there is not enough information available to determine the status.

U ... Undetermined species-a species about which there is not enough information available to determine the status.

Status for animals separated by a slash() indicate a duel status. First status refers to the state breeding population, and the second status refers to the migratory or winter population.

	· ·	•	
• •	•		
. • •			
			Pana 7
		•	
		•	• •
nt taxa listed as	endangered are from New Jersey's official Endangered Plant Species List NJ.S.A. 1318-15.	151 et seq.	•••
•		•	· ·
E.	Native New Jersey plant species whose survival in the State or nation is in Jeopardy,		F
•	· · · · · · · · ·	•	
CIONAL STATUS	CODES FOR PLANTS		· •
LP.	Indicates taxa listed by the Pinelands Commission as endangered or threatened within 1	their legal jurisdiction. N	ot all species currently
•	tracked by the Pinelands Commission are tracked by the Natural Heritage Program. A c	omplete list of endangere	d and threatened
• •	Pineland species is included in the New Jersey Pinelands Comprehensive Management P	tan.	• • •
		• •	•
PLANATION OF C	CLOBAL AND STATE ELEMENT RANKS		
e Nature Conser	rvancy has developed a ranking system for use in identifying elements (rare species and na	itural communities) of nat	ural diversity most
dangered with e	extinction. Each element is ranked according to its global, national, and state (or subnation	nal in other countries) rar	ity. These ranks are used
prioritize conse	rvation work so that the most endangered elements receive attention first. Definitions for	element ranks are after T	he Nature Conservancy
982: Chapter 4,	4.1-1 through 4.4.1.3-3).		
			•
OBAL ELEMENT	RANKS		• •.•
•		· .	4 .
CI	Critically Imperiled globally because of extreme rarity (5 or fewer occurrences or very f	w remaining individuals	or acres) or because of
	some factor(s) making it especially vulnerable to extinction.		
•		•	у.
_ C2 _	imperiled globally because of rarity (6 to 20 occurrences or few remaining individuals o	or acres) or because of so	me factor(s) making it
•	very vulnerable to extinction throughout its range.		
-			• •
C3	Either very rare and local throughout its range or found locally leven abundantly at sort	he of its locations) in a re-	stricted range (e.g., a
	single western state, à physiographic region in the East) or because of other factors ma	king it vulnerable to extl	nction throughout it's
•	range; with the number of occurrences in the range of 21 to 100.	• •	
•			•
• · · G4 •	Apparently secure globally; although it may be quite rare in parts of its range, especial	ly at the periphery.	•
• .• •	·	•	
· CS	Demonstrably secure globally; although it may be quite rare in parts of its range, espec	cially at the periphery.	
СН	Of historical occurrence throughout its range i.e., formerly part of the established blot	a, with the expectation th	at it may be rediscovered.
		•	
CU	Possibly in peril range-wide but status uncertain; more information needed.	•	• . •
•		•	•
a	Believed to be extinct throughout range (e.g., passenger pigeon) with virtually no likeli	hood that it will be redisc	overed.
•			•
Γ C 7	Species has not yet been ranked.		•
 .	· ·		
TATE ELEMENT R	ianks ·		
		· · ·	
	• •		
S1	Critically imperiled in New Jersey because of extreme rarity (5 or fewer occurrences or	very few remaining indivi	duals or acres). Elements

so ranked are often restricted to very specialized conditions or habitats and/or restricted to an extremely small geographical area of the state. Also included are elements which were formerly more abundant, but because of habitat destruction or some other critical factor of its biology, they have been demonstrably reduced in abundance. In essence, these are elements for which, even with intensive searching, sizable additional occurrences are unlikely to be discovered.

	•	
	• • •	
		Page 3
•		
• •	52	Imperiled in New Jersey because of rarity (6 to 20 occurrences). Historically many of these elements may have been more frequent but
	•	are now known from very few extant occurrences, primarily because of habitat destruction. Diligent searching may yield additional
	•	occurrences.
•	53	Rare in state with 21 to 100 occurrences (plant species in this category have only 21 to 50 occurrences), includes elements which are .
	•	widely distributed in the state but with small populations/acreage or elements with restricted distribution, but locally abundant. Not yet
•	•	Imperiled in state but may soon be if current trends continue. Searching often yields additional occurrences.
	.	
•	S4 - 1	Apparently secure in state, with many occurrences.
•		Darbaneershie encure in seasa and accordiable incruitionals we doe success and there
	· ·	Bennonski aby secure in state and essentially merganizatie present conditions.
	SA .	Accidental in state, including species (usually birds or butterfiles) recorded once or twice or only at very great intervals, hundreds or even
		thousands of miles outside their usual range; a few of these species may even have bred on the one or two occasions they were recorded;
		examples include European strays or western birds on the East Coast and vice-versa.
•		
	· 3E	Elements that are clearly exolic in New Jersey including those taxa not native to North America (introduced taxa) or taxa deliberately or
• •	• •	(viable introduced into the state from other parts of North America (advenue taxa), taxa tanked so are not a conservation priority
·	SH ·	Elements of historical occurrence in New Jersey. Despite some searching of historical occurrences and/or potential habitat, so extant
	·	occurrences are known. Since not all of the historical occurrences have been field surveyed, and unsearched potential habitat remains,
		historically ranked taxa are considered possibly extant, and remain a conservation priority for continued field work.
	ćo	Clament has notabilite accurt in New Jarray, but as accurate have been denoted
	<u>.</u>	
•	SR	Elements reported from New Jersey, but without persuasive documentation which would provide a basis for either accepting or rejecting
	٠	the report. In some instances documentation may exist, but as of yet, its source or location has not been determined.
	SRF	Elements erroneously reported from New Jersey, but this error persists in the literature.
	!</th <th>Flaments believed to be in partil but the degree of cariny uncertain. Also included are rate taxa of uncertain taxonomical standing. More</th>	Flaments believed to be in partil but the degree of cariny uncertain. Also included are rate taxa of uncertain taxonomical standing. More
		Information is needed to resolve rank.
	•	
	sx	Elements that have been determined or are presumed to be extirpated from New Jersey. All historical occurrences have been searched
•		and a reasonable search of potential habitat has been completed. Extirpated taxa are not a current conservation priority.
	EYC.	Elements may used evelopeed from New Jacoby has not a population antiacted from the wild evict in subjustion
	340	cientens presumed extirpated nom new jersey, but native populations conected nom the wild exist in contracton.
	•sz	Not of practical conservation concern in New Jersey, because there are no definable occurrences, although the taxon is native and
		appears regularly in the state. An SZ rank will generally be used for long distance migrants whose occurrences during their migrations
•		are too irregular (in terms of repeated visitation to the same locations), transitory, and dispersed to be reliably identified, mapped and
		protected. In other words, the migrant regularly passes through the state, but enduring, mappable element occurrences cannot be
	• •	Gefined.
		Typically, the SZ rank applies to a non-breeding population (N) in the state - for example, birds on migration. An SZ rank may in a few
		Instances also apply to a breeding population (8), for example certain lepidoptera which regularly die out every year with no significant
		return migration.
•		
		\cdot

.

 \bigcirc

Environmental Report Appendix C Special-Status Species Correspondence

				_					:	·			• .
				•		•		•					•
		•						•				•	
	·				••	•							
					•				•			Page	•
•••	•			•		•							
	Although	the SZ rank ty	pically app	olles to migra	ants, it show	uld not be use	d indiscrimi	nately, just	because a s	pecies is on	migratio	n does .	
	not mean	It receives an	SZ rank, S	SZ will only a	pply when	the migrants i	occur in an ir	regular, tra	insitory and	dispersed m	anner.		
	•						•		•		Ż		
8 .	Refers to t	the breeding	population	of the elem	ent in the si	tate		• .			• •		
· .	• •			ation of the		, 	• .			•••			
n		ing non-pree	aing popul	•	element In				•		. •		
τ.	Element r	anks containi	ng a "T" ind	dicate that th	ne infraspec	ific taxon is t	eing ranked	differently	than the full	species. Fo	or examp	le Stachys	
	palustris	at. homotric	<i>ha</i> is ranke	4 "CST7 SH"	meaning th	e full species	is globally se	cure but th	he global rar	ty of the va	r, homet	richa has	
	not been	determined; I	in New Jers	ey the variety	y is ranked	historic.				•			
	•. •		•		• •			<u>.</u> .					•
Q.	Elements	containing a '	"Q" in the g	lobal portio	n of its rani	k Indicates the	it the taxon I	is of questl	onable, or u	certain tax	onomical	standing,	
	e.g., some	authors reg	ard It as a f	iuli species,	while other	s treat it at th	e subspecific	level.					
.1	Elemente	documented	from a sleef	ale location	• •			•		•			•
					•	• •	•						
. То ехр	ess uncertair	nty, the most	likely rank	is assigned	and a quest	tion mark add	led (e.g., G2?,). A range	is Indicated	by combinin	ng two rai	nks (e.g.,	
G1 G2, S	5153).	-			·•	•		•	•				
. •	•		•				•	· ·	:	- *		•	
TIFICATION C	ODES				·		•	••	·				
												•	
	•	•		•.	•	•		• •					
e codes refer	to whether t	he Identificat	lon of the s	•. species or co	- mmunity h	as been check	ed by a relia	ble individu	at and is inc	icative of si	gnificant	habitat.	
ie codes refer Y -	to whether t	he identificati	ion of the s 	species of co	- mmunhy hi - I is indicath	as been check	ted by a relial nt habitat.	ble individu	at and is inc	icative of si	gnificant	habitat,	
ie codes refer Y	to whether t	he Identificati	ion of the s n has been	species or co verified and	mmunity h	as been check /e of significa	ted by a relial nt habitat.	ble individu	ial and is inc	icative of si	gnificant	habitat,	
se codes refer Y BLANK	to whether t	he identificatio Identificatio	ion of the s In has been In has not t	pecies or co verified and	mmunity h Is indicath but there i	as been check /e of significa: s no reason to	ed by a reliai nt habitat. 9 believe it is	ble individu :	iat and is inc	icative of si cant habita	gnHicant	habitat,	
e codes refer Y BLANK	to whether t	he Identificatio Identificatio Identificatio	ion of the s n has been n has not b	pecies or co verified and	ommunity h I is indicath but there i	as been check ve of significa s no reason to	ed by a relial nt habitat. a believe it is	ble individu	ial and is inc	icative of si cant habita	gnHlcant L	habitat.	
e codes refer Y BLANK 7	to whether t	he Identificati Identificatio Identificatio Either It has	ion of the s in has been in has not b i not been c	pecies or co verified and peen verified determined i	ommunity h Is indicath but there is f the record	as been check ve of significa s no reason to l is indicative	ted by a relial nt habitat. a believe it is of significant	ble individu : not indicat ; habitat or	ral and is inc live of signifi the identific	icative of si cant habita ation of the	gnificant t. species d	habitat,	
e codes refer Y BLANK 7	to whether t	he identificatio Identificatio Identificatio Ether it has community	ion of the s n has been n has not b not been o may be cor	pecies or co verified and peen verified determined i nfusing or di	mmunity h Is indicath but there is f the record sputed,	as been check ve of significa s no reason to I is indicative	ted by a relial nt habitat. b believe it is of significant	ble individu not indicat : habitat or	tal and is inc tive of signifi the identific	icative of si cant habita ation of the	gnificant t. species o	habitat.	
e codes refer Y BLANK 7	to whether t	he identification Identification Identification Either it has community	ion of the s in has been in has not b not been d may be cor	pecies of co verified and peen verified determined i nfusing or di	binmunity h Is indicath but there is f the record sputed.	as been check ve of significa s no reason to i is indicative	ted by a reliai nt habitat. a believe it is of significant	ble individu not indicat habitat or	tal and is inc the of signific the identific	icative of si cant habita ation of the	gnificant L specles (habitat, or	
e codes refer Y BLANK 7	to whether t	he identificatio Identificatio Identificatio Ether it has community	ion of the s n has been n has not b not been o may be cor	species or co sverified and seen verified determined i nfusing or di	mmunity h: I is indicath but there i f the record sputed,	as been check ve of significa s no reason to l is indicative	ted by a reliai nt habitat. a believe it is of significant	ble Individu not Indicat habitat or	nat and is inc the of signific the identific	icative of si cant habita ation of the	gnificant t. species d	habitat, or	
e codes refer Y BLANK 7	to whether t	he identificati Identificatio Identificatio Either it has community	ion of the s n has been n has not b not been o may be cor	species or co verified and seen verified fetermined i nfusing or di	mmunity hi I is indicath but there is f the record sputed,	as been check re of significa s no reason to I is indicative	ted by a relial nt habitat. a believe it is of significant	ble individu not Indicat	ial and is inc ive of signifi the identific	icative of si cant habita ation of the	gnHicant t	habitat, or	
e codes refer Y BLANK 7	to whether t	he identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not b not been c may be cor	species or co sverified and seen verified determined i fusing or di	mmunity hi i is indicath but there is f the record sputed.	as been check re of significa s no reason to I is indicative	ed by a reliai nt habitat. 9 believe it is of significant	ble individu not indicat	tal and is inc live of signifi the identific Round Secure	icative of si cant habita ation of the	gnificant t. species d	habitat, or	
e codes refer Y BLANK 7	to whether t	he Identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not t not been c may be cor	species or co sverified and seen verified determined i fusing or di	mmunity h: Is indicath but there i: f the record sputed.	as been check re of significa s no reason to	ed by a reliai nt habitat. 9 believe it is of significant	ble individu	tal and is inc live of signifi the identific Round Basers	icative of si cant habita ation of the	gnificant t. species d	habitat. or	
e codes refer Y BLANK 7	to whether t	he identificatio Identificatio Identificatio Ether it has community	ion of the s n has been n has not t not been c may be cor	species or co species and speen verified determined i fusing or di	mmunity h is indicath but there i f the record sputed.	as been check re of significa s no reason to	ed by a reliai nt habitat. 9 believe it is of significant	ble individu	tal and is inc live of signifi the identific	icative of si cant habita ation of the	gnHicant t.	habitat, or	
e codes refer Y BLANK 7	to whether t	he identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not b not been c may be cor	species or co species and speen verified determined i afusing or di	mmunity h is indicath but there is f the record sputed.	as been check re of significa s no reason to	ed by a reliai nt habitat. 9 believe it is of significant	ble individu	ial and is inc ive of signifi the identific	icative of si cant habita ation of the	gnHicant t.	habitat, or	
e codes refer Y BLANK 7	to whether t	he identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not b not been c may be cor	species or co species and speen verified determined i fusing or di	mmunity hi Is indicath but there is f the record sputed.	as been check re of significa s no reason to	ed by a reliai nt habitat. 9 believe it is	ble individu	ial and is inc ive of signifi the identific	icative of si cant habita ation of the	gnificant t.	habitat, or	· · · · · · · · · · · · · · · · · · ·
e codes refer Y BLANK 7	to whether t	he identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not b not been o may be cor	species or co verified and seen verified determined I fusing or di	mmunity hi Is indicath but there is f the record sputed.	as been check re of significa s no reason to i is indicative	ed by a reliai nt habitat. 9 believe it is of significant	ble individu	ial and is inc ive of signifi the identific	icative of si cant habita ation of the	gnificant t.	habitat, or	
e codes refer Y BLANK 7	to whether t	he identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not b not been o may be cor	species or co verified and seen verified fetermined i fusing or di	mmunity hi I is indicath but there is f the record sputed.	as been check re of significa s no reason to i is indicative	ed by a reliai nt habitat. 9 believe it is of significant	ble individu	ial and is inc ive of signifi the identific	icative of si cant habita ation of the	gnificant t.	habitat, or	
e codes refer Y BLANK 7	to whether t	he identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not b not been may be cor	species or co verified and seen verified fetermined i fusing or di	mmunity hi I is indicath but there is f the record sputed.	as been check re of significa s no reason to i is indicative	ed by a reliai nt habitat. 9 believe it is of significant	ble individu	ial and is inc ive of signifi the identific	icative of si cant habita ation of the	gnificant t.	habitat, or	
se codes refer Y BLANK 7	to whether t	he identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not t not been may be cor	species or co verified and seen verified determined i nfusing or di	mmunity hi I is indicath but there is f the record sputed.	as been check re of significa s no reason to i is indicative	ed by a reliai nt habitat. 9 believe it is of significant	ble individu	ial and is inc ive of signifi the identific	icative of si cant habita ation of the	gnificant t.	habitat, or	
se codes refer Y BLANK 7	to whether t	he identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not t not been o may be cor	species or co verified and seen verified determined i nfusing or di	mmunity hi I is indicath but there is f the record sputed.	as been check re of significa s no reason to I is indicative	ed by a reliai nt habitat. 9 believe it is of significant	ble individu	ial and is inc ive of signifi the identific	icative of si cant habita ation of the	gnificant t.	habitat, or	
se codes refer Y BLANK 7	to whether t	he identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not t not been may be cor	species or co sverified and seen verified determined i nfusing or di	mmunity hi I is indicath but there is f the record sputed.	as been check re of significa s no reason to I is indicative	ed by a reliai nt habitat. 9 believe it is of significant	ble individu	ial and is inc ive of signifi the identific	icative of si cant habita ation of the	gnificant t.	habitat, or	
se codes refer Y BLANK 7	to whether t	he Identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not t not been o may be cor	species or co verified and seen verified determined i nfusing or di	mmunity hi I is indicath but there is f the record sputed.	as been check re of significa s no reason to I is indicative	ed by a reliai nt habitat. 9 believe it is of significant	ble individu	ial and is inc ive of signifi the identific	icative of si cant habita ation of the	gnificant t.	habitat, or	
se codes refer Y BLANK 7	to whether t	he Identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not t not been o may be cor	species or co verified and seen verified determined i nfusing or di	mmunity hi	as been check re of significa: s no reason to	ed by a reliai nt habitat. 9 believe it is of significant	ble individu not indicat habitat or	ial and is inc ive of signifi the identific	icative of si cant habita ation of the	gnificant t.	habitat,	
e codes refer Y BLANK 7	to whether t	he Identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not t not been o may be cor	species or co verified and seen verified determined i nfusing or di	mmunity h is indicath but there is f the record sputed.	as been check re of significa: s no reason to	ed by a reliai nt habitat. 9 believe it is of significant	ble individu	ial and is inc ive of signifi the identific	icative of si cant habita ation of the	gnificant t.	habitat,	
se codes refer Y BLANK 7	to whether t	he Identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not t not been o may be cor	species or co verified and seen verified determined i nfusing or di	mmunity h is indicath but there is f the record sputed.	as been check re of significa: s no reason to	ed by a reliai nt habitat. 9 believe it is of significant	ble individu	ial and is inc ive of signifi the identific	Icative of si cant habita ation of the	gnificant t.	habitat,	
se codes refer Y BLANK 7	to whether t	he Identificatio Identificatio Identificatio Either it has community	ion of the s n has been n has not t not been o may be cor	species or co sverified and seen verified determined i nfusing or di	mmunity h is indicath but there is f the record sputed.	as been check re of significa: s no reason to	ed by a reliai nt habitat. 9 believe it is of significant	ble individu	ial and is inc ive of signifi the identific	Icative of si cant habita ation of the	gnificant t. species (habitat,	

1 27 JUN 2002

. .

. . ۰.

OCEAN COUNTY RARE SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE

•	1014E	Common Name	yederal Status	 STATE STATUS 	regional Status	CRANK	SRANK	
*** Vertebrates			•	· . ·	•			
•	ACCIPITER COOPERII	COOPER'S HAWK		T/T		C15 ·	838, 54N	
•	AMBYSTOMA TIGRINUM TIGRINUM	EASTERN TIGER SALAMANDER		В		GSTS	82	
	AMMODRAMUS SAVANNARUM	GRASSHOPPER SPARROW		T/8	•	GS	82B	
	ARDEA HERODIAS	GREAT BLUE HERON	• . • .	8/8		GS	82B, 84N	•
· · .	BARTRANIA LONGICAUDA	UPLAND SANDPIPER		8		GS	81B ·	
·	BOTAURUS LENTIGINOSUS	AMERICAN BITTERN		E/S	• •	64	\$2B	
•	BUTEO LINEATUS	RED-SHOULDERED HANK		5/T .	. •	G5	\$18.82N	
• •	CALIDRIS CANUTUS	RED KNOT		T		05	63 N	
	CHARADRIUS MELODUS	PIPING PLOVER	LT		•	G3	518	
	CIRCUS CYANEUS	NORTHERN HARRIER		E/U		05	81B.53N	
	CISTOTHORUS PLATENSIS	SEDCE WREN	-	I	•	as'	· 818	
	CLEMMYS INSCULPTA	WOOD TURTLE		T		G4	63 ·	
۰.	CLIMMYS MUNISVBERGII	BOG TURTLE	LT	E		C3	52	
	CROTALUS HORRIDUS HORRIDUS	TIMBER RATTLESNAKE		- E		GATA	57	
· • •	EGRETTA CAERULEA	LITTLE BLUE RERON		5/S		C5	528	
•	ECRETTA THULA	SNOWY EGRET		8/8		G 5	838. S4N	
	ECRETTA TRICOLOR	TRICOLORED HERON		INC/S		G5 ·	838	
•	ELAPHE GUTTATA GUTTATA	CORN ENGLISE		E	• •	GSTS	81	
•	EUMECES FASCIATUS	FIVE-LINED SKINK	•	U		GS	61	
	FALCO PERECRIMUS	PERECRINE FALCON		E		G4	51B.87W	. ·
	HALIAETTUS LEUCOCEPHALUS	BALD ENGLE	LT	в.		G4 .	S18.52N	
•	HYLA ANDERSON'I I	PINE BARRENS TREEFROS	·	E		G4	· 83	
	HYLA CHRYSOSCELIS	COPE'S GRAY TREEFROG		8.		05	87	
	IKOBRYCHUS EXILIS	LEAST BITTERN		D/8		35	61R	
	LAMPROPELTIS GETULA GETULA	EASTERN KING SNAKE		sc		0575	91	
•	LATERALLUS JAMAICENSIS	BLACK RAIL		T/T		C4	\$7B	
•	LYNK RUFUS	BOBCAT				05		
•	MELANERPES ERYTHROCEPHALIES	RED-HEADED WOODPECKPR		7/7	•	03 68		
•	NYCTANASSA VIOLACEA	* YELLOW- CROWNED HT CHE- HERCH		*/*			048,84M	

Appendix C Special-Status Species Correspondence

۰.

Page C-85

• •

Page.C-86

2 27 JUN 2002

OCLAN COUNTY RARE SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE

.

	NUME	COMMON NAME	FEDERAL	STATE	REGIONAL	GRANK	SRAN
		• • •	STATUS	STATUS	STATUS		
	SYCTICORAX HICTICORAX	BLACK-CROWNED NIGHT-HERON		T/S		GS	83B,
• •	FANDION HALIAETUS	OSPREY	· :	T/T		G5 ·	S2B
	PITUOPHIS MELANOLEUCUS	NORTHERN PINE SNAKE		т		64T4	63
	MELANOLEUCUS	• .		•		•	
	PLEGADIS PALCINELLUS	CLOSSY IBIS		D/S		G5	S39.
	PODILYNOUS PODICEPS	PIED-BILLED CREES		E/8 .		05	S18.
	POOPCETES GRAMINEUS	VESPER SPARROW		ε.		05	S18.
	RYNCHOPS NIGHT	BLACK SKIMMER		x		GS	818
	STERNA ANTILLARUM	LEAST TERN		B		G4	518
	STERNA DOUCALLII DOUCALLII	ROSEATE TERM .	LE	2		G4T3	SHB
	STERNA HIRUNDO	CONTINUE TERM	•	D/S		GS	838
	STERNA NILOTICA	GULL-BILLED TERN		s		G5	S18
	STRIX VARIA	BARRED ONL		T/T		GS	\$39
	SYNAPTOMYS COOPERI	SOUTHERN BOG LEMMING	· ·	υ		GS	. 52
			•		•		
. FCORARCOUR						•	
	CUASTAL DUNE SHRUBLAND	COASTAL DUNE SHRUBLAND	••		. •	G4	527
•	COASTAL DONE WOODLAND	COASTAL DUNE WOODLAND	•			0203	51
•	MARINE INTERTIDAL GRAVEL/SAND	MARINE INTERTIDAL GRAVEL/SAND				GU	ទប
• •	BEACH COMMUNITY	BEACH COMMUNITY .	• .				
	PINE PLAINS	DWARP PITCH PINE-BLACKDACK OAK	• •			G1 .	81
-	· ·	PINE PLAINS					
	PINUS RIGIDA-CALAMOVILFA	PITCH PINE-PINELANDS RESDORASS	- ·		•	G1	\$1
	BREVIFILIS SAVANNA	5AVAIQIA .					
Invertebrates			·				
	ACRONICIA ALBARUFA	BARRENS DAGGERMOTH					
	AESHNA CLEPSYDRA	NOTTLED DARNER				01	50
	AGROTIS BUCHHOLZI	BICHHOL& S DART				-	8433
	AMBLYSCIRTES VIALIS	ROADSIDE SEIRDER				ω <u>ν</u> , .	52
						U 2	578]
	• •						

, 62M 3 4 4

· · ·

SU 8253 52 5263

••

4

٠.

.

.

•

.

<i>*</i>		•				
			:		•	
NAME	COMMON NAME	FEDERAL STATUS	STATE STATUS	RECIONAL STATUS	GRANK	SRANK
•						
APHARETRA DENTATA	A NOCTULD HOTH				G4	8253
ATRYTONE AROOOS AROOOS	AROGOS SEIPPER		. x		G3G4T1T2	S1
BOLORIA SELENE MYRINA	A SILVER-BORDERED FRITILLARY		T	•	G5T5-	52
CALLOPHRYS HENRICI	HENRY'S ELFIN				GS	\$154
CALLOPHRYS RESSELT	HESSEL'S HAIRSTREAK	• •	•		G3G4	\$354
CALLOPHRYS IRUS	FROSTED ELFIN	•	т	• .	G3	8783
CALLOFTRYS POLIOS	HOARY ELFIN				GS .	83
CALLOPISTRIA GRANITOSA	GRANITOSA PERN MOTH	•		•	G4G5	8253
CATOCALA HERODIAS GERHARDI	HERODIAS OR GERHARD'S				G3Ť3	83
	UNDERWING	•	•			
CATOCALA JAIR SSP 2					G4T4	83
CELITHENIS MARTHA	. MARTHA'S PENNANT		• •		Gi	8384
CICINDELA DOREALIS DOREALIS	NORTHEASTERN BEACH TIGER	LT .	E		G412 .	S1
	BEETLE		•			
CICINDELA PATRUELA	A TIGER BEETLR				G3T2T3	£253
CONSENTANEA		•.	•			
CRAHBUS DARCKELLUS	DAECKE'S FYRALID MOTH				G1G3	\$153
DATANA RANASCEPS	A HAND-HAID MOTH	•			G3G4	5354
ENALLAGHA PICTUM	SCARLET BLUET		•		G3	S 3
ENALLACHA RECURVATUM	PINE BARRENS BLUET		:		G 3	83
ERYNNIS PERSIUS PERSIUS	A PERSIUS DOSKY WING				G51213	SH
EUPHYES BIMACULA	TNO-SPOTTED SEIPPER				04	83
FARONTA RUBRITEDNIS	PINK STREAK	•	•		G3G4	53 .
· GLENA PLUMOSARIA					G4 ·	5U
GRAMMIA PLACENTIA	PLACENTIA TIGER HOTH	•		:	G4 ·	\$1\$3
HESPERIA ATTALUS SLOSSONAE	DOTTED SRIPPER		••		G3G4T3	\$253
HETAERINA AMERICANA	AMERICAN RUBYSPOT				GS .	83
HETEROCAMPA VARIA	A NOTODONTID NOTU	•		•	G3G4	83
HYPOMECTS BUCHHOLZARIA	BUCHHOLZ'S GRAY				6364	53
ITAME SP 1	A SPANNORM	•	•		G3	· 53
	NAME APHARETRA DENTATA ATRITIONE ARODOS ARODOS BOLORIA SELENE MIEINA CALLOPIENIS HENRICI CALLOPIENIS HENRICI CALLOPIENIS HENRICI CALLOPIENIS HENRICI CALLOPIENIS FRISSELI CALLOPIENIS FOLIOS CALLOPIENIS FOLIOS CALLOPIENIS FOLIOS CALLOPIENIS FOLIOS CALCOLA JAIR SSP 2 CELITHENIS MARTHA CICINDELA DOREALIS DOREALIS CICINDELA DOREALIS DOREALIS CICINDELA DOREALIS DOREALIS CICINDELA DARCTELLUS DATAMA RAMARCEPS ENALLACHA FLOTUM EMILLACHA FLOTUM EMILLACHA FLOTUM EMILLACHA FLOTUM ENALLACHA FLOTUM HESPERIA ATTALUS ELOSSONAE HETAERINA MERICANA HITEROCAMPA VARIA HITEROCAMPA VARIA	NAME CHAMON NAME APPARETRA. DENTATA A NOCTULD MOTH ATRITONIC ARGOOS ARGOOS ARGOOS ARGOOS EXIPPER BOLORIA SELENE MIRIDA A SILVER-BORDERED FRITILLARY CALLOPHRYS HENRICI EENRY'S ELFIN CALLOPHRYS HENRICI EENRY'S ELFIN CALLOPHRYS HENRICI EENRY'S ELFIN CALLOPHRYS POLIOS ROMOS ROMITOSA FERN MOTH CALOCALA HENOIAS GERHARDI EERODIAS OR GERHARD'S UNDERWIND CATOCALA HENOIAS GERHARDI EERODIAS OR GERHARD'S UNDERWIND CATOCALA HENOIAS GERHARDI EERODIAS OR GERHARD'S CATOCALA HENOIAS GERHARDI EERODIAS OR GERHARD'S UNDERWIND CATOCALA HENOIAS GERHARDI EERODIAS OR GERHARD'S CATOCALA HENOIAS GERHARDI ERODIAS OR GERHARD'S CATOCALA HENOIAS GERHARDI ERODIAS OR GERHARD'S CATOCALA HENOIAS SORTE BARDI EARCH EARTH EARTH EARTH EARTH EARTH EARTH FINAL A HAND-HAID MOTH ENALLACHA FUNNESENTS A PERSIUS A PERSIUS COSET WING EUPHYES BIHACULA THO SINCES PINK STREAK GEAM HENOIAS RIDS FRUSTIS A PERSIUS TOA SINPER FARONTA RUBRIFICANA ANERICAN RUBSISOT ANERICAN RUBRIFICANA ANTOONTID MOTI HENOICAN AREA HENOICANA ANTOONTID MOTI HENOICAN AREA HENOICANA ANTOONTID MOTI HITPOMECIS BUCHENCLARTA BUCHALA ANTOONTID MOTI HITPOMECIS BUCHENCLARTA BUCHALA ANTOONTID MOTI	NAME COMMON NAME FEDERAL STATUS APPARETRA. DENTATA A NOCTULD MOTE ATETTONE AROOOS AROOOS AROOOS AROOOS SELEPTER BOLORIA SELENE MYEINA A SILVER-BORDERED FRITILLARY CALLOPHRYS HENRICI EENRY'S ELFIN CALLOPHRYS HENRICI EENRY'S ELFIN CALLOPHRYS HENRICI EENRY'S ELFIN CALLOPHRYS PESSELI MESSELI'S MAIRSTREAK CALLOPHRYS POLIOS BENNITOSA GRANITOSA FENN MOTH CATOCALA HEROOIAS GERHARDI HEEODIAS OR GERHARD'S UNDERWINO CATOCALA HEROFINSA MATHA'S PENNAMT CATOCALA HEROFINS DORSALIS MORTHEASTERN BEACH TIGER LT DEFILE CICINDELA DOREALIS DORSALIS MORTHEASTERN BEACH TIGER LT DEFILE CICINDELA DARCHELA A TIGER BEETLR CONSENTANEA CRAMBUS DARCHELUUS A PARTON FINT BAITHASTERN BEACH TIGER CATOCALA PARTOLELA A TIGER BEETLR CONSENTANEA CRAMBUS DARCHELUUS A PARTON FINT BAITHASTERN BEACH TIGER CATOCALA TROCESS DARCHELUUS PARTONES DARCHELUUS DARCHELUUS A PARTONE A PARTUS CONSENTANEA CRAMBUS DARCHELUUS A PARTUS CONSENTANEA CRAMBUS DARCHELUUS A PARTUS CONSENTANEA CRAMBUS PERSIOS A PARTUS PERSIOS CONSENTANEA CRAMBUS PERSIOS A PARTUS PERSIOS CONSENTANEA CRAMBUS PERSIOS A PARTUS PERSIOS CONSENTANEA CILACAMA PUTTA PINTE BANGENS BUJET EXTINIS PERSIOS A PARTUS PERSIOS CIEVA PLACENTIA TWO-SPOTTED SKIPPER FARONA RUBRIFEDNIS PINT STREAK CIEVA PLACENTIA HESPERIA ATALOS ELOSSONAE COTTED SKIPPER HETAERICANEA PLACENTIA A NOTOCONTIL MUTI HENDELCANA A ANDOLONIU MUTI HENDELCANA A MARICCAN EUSISPOT HETEROCAMPA VARIA A MOTOCONTIL MUTI HENDELCANA A MARICCANE SUSSISPOT HETEROCAMPA VARIA A MOTOCONTIL MUTI	NAME COMMON NAME FEDERAL STATE STATUS STATUS APELARETRA. DENTATA A NOCTUID MOTH ATÉRITCHE ARGODS ARGODS ARGODS BRIPPER BOLORIA SELENE MIRINA A SILVER-BORDERED FRITILLARY E CALLOMERYS HEISTEL HENRY'S ELFIN CALLOMERYS HEISTEL HESSELI HESSEL'S HAIRSTREAK CALLOMERYS HEISTEL HESSELI HESSEL'S HAIRSTREAK CALLOMERYS HEISTEN FROSTEL HERSELS HAIRSTREAK CALLOMERYS FRUST CALLOMERYS FRUST CALLOMERYS FRUST CALLOMERYS FRUST CALLOMERYS FRUST CALLOMERYS BOLOS HOARY ELFIN CALLOMERYS FRUST CALLOMERYS BOLOS HOARY ELFIN CALLOMERYS BOLOS HERMON CATOCALA HERODIAS GEREBARDI HERODIAS GEREBARDI CATOCALA HERODIAS GEREBARDI HERODIAS GEREBARDI CATOCALA HERODIAS GEREBARDI HERODIAS GEREBARDI CATOCALA MERCOIAS GEREBARDI HERODIAS GEREBARDI HERODIAS DASCHES FIRA CICINDELA DORBALIS DORBALIS DORBALIS DORBALIS DORBALIS DASCHES FIRANDE CALOGUEA DASCHESLUPS CALOGUEA DASCHESLUPS DASCHES FIRANDE CALOGUEA DASCHESLUPS CALOGUEA DASCHESLUPS DASCHES FIRANDE CALOGUEA DASCHESLUPS DASCHESTER CALOGUEA DASCHESLUPS DASCHESTER CALOGUEA DASCHESLUPS DASCHESTER CALOGUEA DASCHESLUPS DASCHESTER CALOGUEA DASCHESLUPS DASCHESTER CALOGUEA DASCHESLUPS DASCHESTER CALOGUEA DASCHESLUPS DASCHESTER CALOGUEA DASCHESLUPS DASCHESTER CALOGUEA DASCHESLUPS DASCH	NAME COMMON NAME FEDERAL STATE RECIONAL STATUS STATE RECIONAL STATUS STATE RECIONAL STATUS STATUS APHARETRA. DENTATA A NOCTULD MOTH ATÉRTIONE ARCOOS ARCOOS ARCOOS ARCOOS SEIPPER NOLORIA SELENE MIRINA A SILVER-BORDERED FRITILLARY T CALLOPHRYS MERSELT MESSEL'S MARSTREAK CALLOPHRYS MERSELT MESSEL'S MAIRSTREAK CALLOPHRYS MERSEL CALLOPHRYS MERSEL CALLOPHRYS MERSEL CALLOPHRYS MERSEL CALLOPHRYS MERSEL DESCRIPTING CALOPIST FOLIOS MARY SLFIM CALLOPHRYS MERSEL CALLOPHRYS MERSEL CALLOPHRYS MERSEL CALLOPHRYS MERSEL DESCRIPTING CALOPIST FOLIOS MARY SLFIM CALLOPHRYS MERSEL DESCRIPTING CALLOPHRYS MERSEL CALLOPHRYS MERSEL DESCRIPTING CALLOPHRYS MERSEL CALLOPHRYS MERSEL DESCRIPTING CALLOPHRYS MERSEL CALLOPHRYS MERSEL CALLOPHRYS MERSEL CALLOPHRYS MERSEL DESCRIPTING CALLOPHRYS MERSEL CALLOPHRYS MERSEL DESCRIPTING CALLOPHRYS MERSEL CALLOPHRYS MERSEL DESCRIPTING CALLOPHRYS MERSEL CALLOPHRYS MERSEL DESCRIPTING CALLOPHRYS MERSEL DESCRIPTING CALLOPHRYS MERSEL DESCRIPTING CALLOPHRYS MERSEL CALLOPHRYS MERSEL DESCRIPTING CALLOPHRYS MERSEL DESCRIPTING CALLOPHRYS MERSEL DESCRIPTING DATAMA RANARCEPPS A HAND-MAID MOTH DATAMA RANARCEPPS A HAND-MAID MOTH DATAMA RANARCEPPS A HAND-MAID MOTH DATAMA RANARCEPPS A HAND-MAID MOTH DATAMA RANARCEPPS A HAND-MAID MOTH BUHLING MERSEL DESCRIPTION A MERSICAL DESCRIPTION A MERSEL DESCRIPTION A MERSEL DESCRIP	NAME COMMON NAME PEDERAL STATE REJORAL GANK STATES STATE REJORAL GANK STATES STATE STATES STATE STATUS STATE STATE STATUS STATE STATE STATUS STATE STATUS STATE STATUS STATE STATUS STATE STATUS AMULARIA A MOCTULID MOTE ATTITUME AGOODS AMOODS AMOODS SETEPHER ATTITUME AGOODS AMOODS SETEPHER ATTITUME AGOODS AMOODS SETEPHER ATTITUME STATUS STATE STATE CALLOPHERTS REMAINED STATES STATE CALLOPHERTS REMAINED STATES STATE STATUS STATE STATUS AMULARIA STATE STATE CALLOPHERTS REMAINED STATES STATE STATUS AMULARIA STEMBLET STATUS AMULARIA MERCHANDI MOSTED STATES STATE CALLOPHERTS REMAINED STATES CALLOPHERTS STATES ST

.

.

.

OCEAN COUNTY

RARE SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN

.

• •

•

.

.

.

•

.

• . •

.

Environmental Report Appendix C Special-Status Species Correspondence

· ..

.

.

Page.C-88

27 JUN 2002

4

OCEAN COUNTY RARE SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSET NATURAL HERITAGE DATABASE

				•				
	•							
	NAME .	COMMON NAME.	FECERAL	STATE	REGIONAL	GRANK	SEANK	
		•	STATUS	STATUS	STATUS			•
	LINE III A AIRIDENNIS	COLDEN-MINCED SKINNER					\$192	
	LIBUTINA AVILENA	BAR-WINGED STIMLE	1				S28518.62	-
• .			-				N .	
	LITHOPHANE LEMERI	LEMMER'S PINION MOTH	•			G3G4 -	52 ·	
•	MACROCHILO SP 1	A NOCTUID NOTH				G3	£3	
	MEROLONCHS DOLLI	DOLL'S NEROLONCHE				G3G4	8163	•
	METARRANTHIS PILOSARIA	COASTAL BOG METARRANTHIS	•			G3G4	SJ64	
	METARRANTHIG SP 1	A GEOMETRID MOTH	•		•	G3	\$2	
	NEONYMPHA AREOLATA	A SATYR		•		GATITA	\$3	
•	SEPTENTRIONALIS				•			
•	MICHOPHORUS AMERICANUS	AMERICAN BURYING BEETLE	LE	E	· ·	G2G3	5.H	
•	PONTIA PROTODICE	CHECKERED WHITE		τ.		G4	S1	
	PTICHODIS BISTRIGATA	SOUTHERN PTICHODIS				G3	S153 -	
	FYGARCTIA ABDOMINALIS	YELLOW EDGED PYGARCTIA	•			G3G4	SH .	
	RICHIA SP 2	•				610	81 .	
• .	SEMIOTHIEA EREMIATA	THEFE-LINED ANGLE HOTH				G4	su	
	SPARTINIPHAGA CARTERAE	CARTER'S NOCTULD MOTH				G2G3	52	
	ZALE SP 1	PINE BARRENS SALE				G3G4	53	:
	ZANCLOGNATHA SP 1					G3G4	53	
•	2ANCLOGNATES THERALIS	•				G4	en .	
				·	• .			
*** Other types		•						
	BALD FAGLE WINTERING SITE	BALD EAGLE NINTERING SITE	•			G7	67 <u>.</u>	
•	COASTAL HERON ROOKERY	COASTAL HERON ROOKERY				ou 🦾	\$3	
	NICRATORY SHOREBIRD	MIGRATORY SHOREBIRD				- G7	87	
	CONCENTRATION SITE	CONCENTRATION SITE						
	ALOPECURUS AEQUALIS VAR	SHORT-ANN MEADOW-FOITALL		•		9577	S2 .	

• •

5 27 JUN 2002 .

OCEAN COUNTY RARE SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSET NATURAL HERITAGE DATABASE

NAME	CONTRON NAME	PEDERAL STATUS	state Status -	STATUS	GRANK	SRANK
AMARANTHUS PUNILUS	SEABLACH AMARANTH	LT	X.		G2	51
ANIANTHIUN MUSCITOXICUN	FLY POISON	· · .			G4C5 ·	\$ 2
ARETRUSA BULBOSA	DRAGON HOUTH				G4 ·	82
ARISTIDA DICHOTOHA VAR	CURTISS' THREE-ANN GRASS	· •			G5T5	\$2
CURTISSII	: . :		•			
ARISTOLOCHIA SERPENTARIA	VIRGINIA SNAKEROOT	•			Gá	83
ARTEMISIA CAMPESTRIS SSP	BEACH NORMHOOD	1			GSTS	S2
CAUDATA	· .				•	
ASCLEPTAS LANCEOLATA	SHOOTH ORANGE MILKWEED				GS	52
ASCLEPIAS RUBRA	. RED HILKWEED		·	LP	G405	53
ASTER RADULA	LOW ROUGH ASTER		E		G\$	51
BUCHNERA AMERICANA	BLUEHEARTS	•		· .	G57 .	SI
CACALIA ATRIPLICIPOLIA	PALE INDIAN PLANTAIN		¥.		G4Q5	S1
CALAMOVILFA BREVIPILIS	PINE BARREN REEDGRASS	. •	•	· LP	G4 ·	54
CARDANINE LONGII	LONG'S BITTERCRESS	•	B		C3 '	. SH
CAREY BARRATTII	BARRATT'S SEDGE		•	LP	G4	84
CAREX MITCHELLIANA	MITCHELL'S SEDGE				G3G4	52
CAREX PALLESCENS	PALE SEDCE	. •			G5'	£2
CAREX WILLDENOWII VAR	WILLDENOW'S SEDGE	•	•		CST5	52
WILLDENOWII	·			•		
CIRSIUM VIRGINIAMUM	VIRGINIA THISTLE		E		a 3	51
CLITORIA MARIANA	- PUTTERFLY-PEA	• .	Ξ.	•	G5	S1
COREMA CONRADII	BROOM CROWBERRY	•	E	LP	G4	\$1
COREOPSIS ROSEA	ROSE-COLOR COREOPSIS			LP '	C3	. 82
CROTON WILLDENOWII	ELLIPTICAL RUSHPOIL			. LP	GS .	52
DESHODIUM PAUCIFLORUN	FEW-FLOWER TICK-TREFOIL	•	B .		GS	S1
ELEOCHARIS HALOPHILA	SALT-MARSH SPIKE-RUSH		•		G4	82
ELEOCHARIS TORTILIS	TWISTED SPIKE-RUSH	,	· 2 ·	-	ġs.	S1
ERIOCAULON PARKERI	PARKER'S PIPEWORT			•	G3	52
ERIOPHORUM TENELLUM	ROUGH COTTON-CRASS	•••	E		05	81

.

÷

Page.C-90

6 27 JUN 2002

JUN 2002

OCEAN COUNTY RARE SPECIES AND RATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE

.

. .

			•		•	
NAME	CONNENT NAME	FEDERAL	STATE	REGIONAL	. GRANK	SRANK .
• • •		STATUS	STATUS	STATUS		
ERYNGIUM AQUATICUM VAR AQUATICUM	MARSH BATTLESNAKE-MASTER .	•			G1T1	S 3 ·
EUPATORIUN RESINOSUM	PINE BARREN BONESET	•	B	LP .	63	\$ 2
FINDRISTYLIS CAROLINIANA	CAROLINA FINERY				G4 .	62
FRAXINUS PROFUNDA	PUMPRIN ASH	· .	E		G4 · · ·	51
FUTRENA SQUARROSA	HAIRY UNBRELLA-SEDGE				G4G5	\$3
CALACTIA VOLUBILIS	DOWNY MILK-PEA	•	3		QS	ян
GENTIANA AUTOMALIS	PINE BARREN GENTIAN	•		LP	GJ	83
GLAUE HARITIMA	SEA-MILKNORT		B .		cs	6X.1
INAPHALIUM HELLERI	SMALL EVERLASTING	•	E		G4G5T37	SM .
HELONIAS BULLATA	SNAMP-PINK	LT	E	LP	ω.	51
HONCKENYA PEPLOIDES VAR	SEABEACH SANDWORT		•	•	QST4	\$2
ROBUSTA .						•
HOTTONIA INFLATA	FEATHERFOIL		E		04	S1
HOUSTONIA LONGIPOLIA	LONG-LEAF SUMMER BLUET .		•		GeCS	sh
JEFFERSONIA DIPHYLLA	THINLEAF		E ·	• •	. C2	S1 '
JUNCUS CAESARIENSIS	NEW JERSEY RUSH		· E	LP .	G2	52
JUNCUS GREENET	CREENE'S RUSH			•	G5	52
JUNCUS TORREYI	TORREY'S RUSH		E		C5	61
LINOSELLA SUBULATA	ANL-LEAF MUDWORT		. 5	•	G4GS	\$1
LINUM INTERCURSUN	SANDPLAIN FLAX		. 5		G4	S1
LISTERA AUSTRALIS	SOUTHERN THAYBLADE		-	LP .	G4	<u>92</u>
LOBELIA CANBYI	CANBY'S LOBELIA			LP	G4 .	\$ 3
LUDWIGIA BREVIPES	TUCKER'S ISLAND				G4G5 .	SX.1
	PRIMROSE-WILLOW	•		•		
LUZULA ACUMINATA	HAIRY HOOD-RUSH		<u>R</u>		G57475	82
ELANTHIUM VIRGINICUM	VIRGINIA BUNCHFLOWER		E		65	\$1
RHLENBERGIA TORREYANA	PINE BARREN SMOKE GRASS	•		LP	G 3	53
ATTOPHYLLIM TENELLIM	SLENDER WATER-MILFOIL		E .	•	G5	51
WRIOPHYLLIN VERTICILLATIN	MHORLED MATER-MILFOIL	·	2		GS	SH ·

Oyster Creek Generating Station License Renewal Application Environmental Report Appendix C Special-Status Species Correspondence

2

. •

7 27 JUN 2002

OCEAN COUNTY RARE SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN

•		

COMMON NAME

BOG ASPHODEL

FLOATINGHEART

SEA-BEACH EVENING-PRIMROSE

VIRGINIA FALSE-GRONWELL

SICKLE-LEAF GOLDEN-ASTER

PINE BARREN RATTLESNAKE-ROOT

HUDBANK CROWN GRASS

AMERICAN MISTLETOE

SEASIDE PLANTAIN

DWARF PLANTAIN

CHICKASAN PLUM

DWARF AZALEA

SEA-BEACH KNOTWEED

SALTHARSH ALKALI CRAES

LARGE-HEAD BEAKED-RUSH

SLENDER HORNED-RUSH

INIESKERN'S BEAKED-RUSH

SMALL-HEAD BEAKED-RUSH

SHORT-BEAKED BALD-RUSH

BLANCHARD'S DEWBERRY

ENGELMANN'S SORREL

SLENDER MARSH-PINK

LARGE MARSH-PINK

CURLY GRASS PERN

· PALE BEAKED-RUSH

COARSE GRASS-LIKE BEAKED-BUSH

ANNED MOUNTAIN-MINT

SEASIDE BUTTERCUP

. . •

NAME

NARTHECIUM AMERICANUM , NYMPHOIDES CORDATA CENOTHERA HUMIFUSA ONOSHODION VIRGINIANUN PASPALUM DISSECTUM PHORADENDRON LEUCARPUN PITYOPSIS FALCATA PLANTAGO MARITIMA VAR JUNCOIDES PLANTAGO PUSILLA POLYGONUN GLADCIN PRENANTHES AUTUNNALIS PRUNUS ANGUSTIFOLIA PUCCINELLIA PASCICULATA PYCNANTHENM SETOSUM

RAMINCULUS CIMBALARIA RHODODENDRON ATLANTICUM RHYNCHOSPORA CEPHALANTHA RHYNCHOSPORA GLOBULARIS "RHYNCHOSPORA' INUNDATA RHYNCHOSPORA KNIESKERNII RHYNCHOSPORA MICROCEPHALA RHYNCHOSPORA NITENS RHYNCHOSPORA PALLIDA RUBUS RECURVICAULIS RUMEN HASTATULUS

SABATIA CAMPANULATA SABATIA DODECANDRA VAR DODECANDRA SCHIZAEA PUSILLA

THE NEW JERSEY NATURAL HERITAGE DATABASE

STATUS

LT

FEDERAL STATE REGIONAL GRANK SRANK . STATUS STATUS ip **G**2 **S**2 LP G5 **S**3 \$2 G5 **51** G4 52 G47 G5 52 LP LP G3G4 \$3 G5**T5** 52 CS . 6Ħ G3 **S1** G4G5 S2 1.P GST4TS 82 asas 82 **G3?** 83 GS БH X CIGS 51 LP GS \$3 G57 81 G3G4 Ś2 LP Gl 81 GST5 51 G42 -52 63 G3 \$1.1 G4? GS 5Ħ GS S3

1.9

G57T4T5 · 82 63 C3

Page.C-92

8 27 JUN 2002

OCEAN COUNTY BARE SPECIES AND NATURAL COMMUNITIES PRESENTLY RECORDED IN THE NEW JERSEY NATURAL HERITAGE DATABASE

.

۰.

	NAME	COMMON MAKE	FIDERAL	STATE	REGIONAL	GRANK	SRANK
			STATUS	STATUS	STATUS		
•	SCHWALBER AMERICANA	CHAFFSEED	LE	E	LP '	C1	81
	SCIRPUS LONGII	LONG'S WOOLGRASS		E	LP	G2 .	S2
	SCIRPUS MARITIMUS	SALTMARSH BULRUSH		x		. 05	SH
	SCLERIA MINOR	SLENDER MUT-RUSH	-		LP.	G4	54
	SOLIDADO STRICTA	WAND-LIKE GOLDENROD			1.P	G5	5 3
	SOLIDAGO TARDA	LATE GOLDENROD				G47Q	\$3 [']
•	SPIRANTHES LACINIATA	LACE-LIP LADIES'-TRESSES		8		G405	S1
	SPIRANTHES ODORATA	FRAGRANT LADIES - TRESSES			• •	GS	£2 ·
	STYLISMA PICKERINJII VAR	. PICKERING'S MORNING-GLORY		B	LP	G4T2T3	51 .
•	PICKERINGII		· ·				
	TIPULARIA DISCOLOR	CRANEPLY ORCHID				G4G5 :	53
	TRIDENS FLAVUS VAR CHAPMANII	CHAIMAN'S REDTOP		E		GST?	511
	TRIGLOCHIN MARITIMA	SEASIDE ARROW-GRASS		E		GS	51
	UTRICULARIA BIFLORA	THO-PLOWER BLADDERNORT		E		GS	51 .
	UTRICULARIA MINOR	LESSER. BLADDERWORT		5		GS	61
	UTRICULARIA PURPUREA	PURPLE BLADDERHORT			LP	G5	83 '
	UVULARIA PUBERULA VAR NITIDA	PINE BARREN BELLMORT		E		Q5737	82 ·
	. VERBENA SIMPLEX	NARROW-LEAP VERVAIN		B	·	GS	51
	XYRIS FIMBRIATA	FRINGED YELLOW-EYED-GRASS		E		GS	S 1
•	ZIGADEMUS LEIMANTHOIDES	DEATH-CANUS		B		GLO	S1

201 Records Processed

Oyster Creek Generating Station License Renewal Application Environmental Report Appendix C Special-Status Species Correspondence

Appendix D

State Historic Preservation Officer Correspondence

Oyster Creek Generating Station Environmental Report

Table of Contents

Letter	<u>Page</u>
Gallagher (AmerGen) to Guzzo (State Historic Preservation Officer)	D-1
Guzzo (State Historic Preservation Officer) to Gallagher (AmerGen)	D-5

Ć

October 7, 2004 2130-04-20228

AmerCen Energy Company, LLC

200 Exelon Way Kennett Square, PA 19348

Dorothy Guzzo, State Historic Preservation Officer Historic Preservation Office P.O. Box 404 Trenton, NJ 08625-0404

ww.exeloncorp.con

Attn: Deborah Fimbel

Dear Ms. Guzzo:

AmerGen Energy Company, LLC (AmerGen) is preparing an application to the U.S. Nuclear Regulatory Commission (NRC) to renew the operating license for Oyster Creek Generating Station (OCGS), which expires in April 2009. As part of the license renewal process, the NRC requires license applicants to "assess whether any historic or archaeological properties will be affected by the proposed project." The NRC may also request a consultation with your office at a later date under Section 106 of the National Historic Preservation Act of 1966, as amended (16 USC 470), and Federal Advisory Council on Historic Preservation regulations (36 CFR 800). By contacting you early in the application process, we hope to identify any issues that need to be addressed or any information your office may need to expedite the NRC consultation.

OCGS has operated since 1969. OCGS is located near the Atlantic Ocean within the State of New Jersey (see attached map). The site, approximately 800 acres, is in Lacey and Ocean Townships in Ocean County, New Jersey, about two miles inland from the shore of Barnegat Bay and about seven miles west-northwest of Barnegat Light. The site is approximately nine miles south of Toms River, New Jersey, about fifty miles east of Philadelphia, Pennsylvania, and about sixty miles south of Newark, New Jersey.

In the context of the National Historic Preservation Act, the Director, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission has determined that the Area of Potential Effect for a license renewal action is the area at the power plant site and its immediate environs which may be impacted by post-license renewal land disturbing activities or projected refurbishment activities, specifically related to license renewal, regardless of ownership or control of the land of interest.

AmerGen does not expect OCGS operation through the license renewal term (an additional 20 years) to adversely affect cultural or historic resources at the plant or its immediate environs because AmerGen has no plans to alter current operations for license renewal. No expansion of existing facilities is planned and no structural modifications have been identified for the purpose of supporting license renewal. Maintenance activities necessary to support license renewal would be restricted to previously disturbed areas. No additional land disturbance is anticipated in support of license renewal.

An Exelon Company

State Historic Preservation Officer October 7, 2004 Page 2

Using the National Register Information System on-line database, we have compiled a list of sites on the National Register of Historic Places within a six-mile radius. The Barnegat Light Public School, Barnegat Lighthouse, Double Trouble Historic District, Falkinburg Farmstead, and Manahawkin Baptist Church all fall within a 6-mile radius of the OGCS. We will provide this information to the NRC to aid in its evaluation of the license application.

We would appreciate your sending us a letter by November 12, 2004, detailing any concerns you may have about historic or archaeological properties in the area of OCGS or confirming AmerGen's conclusion that operation of OCGS over the license renewal term would have no effect on any historic or archaeological properties in New Jersey. This will enable us to meet our application preparation schedule. AmerGen will include a copy of this letter and your response in the license renewal application that we submit to the NRC.

Please call Bill Maher at (610) 765-5939, if you have any questions or require any additional information to review the proposed action.

Sincerely,

Michael P. Gallagher Director, Licensing & Regulatory Affairs

Attachment: 6 mile Vicinity Map

cc: Karen Tuccillo, NJ BNE File No. 04007


•

Oyster Creek Generating Station License Renewal Application

Page D-3





An Exelon Company

AmerGen Energy Company, LLC 200 Exelon Way Kennett Square, PA 19348

> RECEIVED OCT 1 3 2004 HISTORIC PRESERVATION OFFICE 04-2563-204-1001

October 7, 2004 2130-04-20228

Dorothy Guzzo, State Historic Preservation Officer Historic Preservation Office P.O. Box 404 Trenton, NJ 08625-0404

www.exclencorp.com

Attn: Deborah Fimbel

Dear Ms. Guzzo:

AmerGen Energy Company, LLC (AmerGen) is preparing an application to the U.S. Nuclear Regulatory Commission (NRC) to renew the operating license for Oyster Creek Generating Station (OCGS), which expires in April 2009. As part of the license renewal process, the NRC requires license applicants to "assess whether any historic or archaeological properties will be affected by the proposed project." The NRC may also request a consultation with your office at a later date under Section 106 of the National Historic Preservation Act of 1966, as amended (16 USC 470), and Federal Advisory Council on Historic Preservation regulations (36 CFR 800). By contacting you early in the application process, we hope to identify any issues that need to be addressed or any information your office may need to expedite the NRC consultation.

OCGS has operated since 1969. OCGS is located near the Atlantic Ocean within the State of New Jersey (see attached map). The site, approximately 800 acres, is in Lacey and Ocean Townships in Ocean County, New Jersey, about two miles inland from the shore of Barnegat Bay and about seven miles west-northwest of Barnegat Light. The site is approximately nine miles south of Toms River, New Jersey, about fifty miles east of Philadelphia, Pennsylvania, and about sixty miles south of Newark, New Jersey.

In the context of the National Historic Preservation Act, the Director, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission has determined that the Area of Potential Effect for a license renewal action is the area at the power plant site and its immediate environs which may be impacted by post-license renewal land disturbing activities or projected refurbishment activities, specifically related to license renewal, regardless of ownership or control of the land of interest.

AmerGen does not expect OCGS operation through the license renewal term (an additional 20 years) to adversely affect cultural or historic resources at the plant or its immediate environs because AmerGen has no plans to alter current operations for license renewal. No expansion of existing facilities is planned and no structural modifications have been identified for the purpose of supporting license renewal. Maintenance activities necessary to support license renewal would be restricted to previously disturbed areas. No additional land disturbance is anticipated in support of license renewal.

Page D-5

Environmental Report Appendix D State Historic Preservation Officer Correspondence

State Historic Preservation Officer October 7, 2004 Page 2

.

Using the National Register Information System on-line database, we have compiled a list of sites on the National Register of Historic Places within a six-mile radius. The Barnegat Light Public School, Barnegat Lighthouse, Double Trouble Historic District, Falkinburg Farmstead, and Manahawkin Baptist Church all fall within a 6-mile radius of the OGCS. We will provide this information to the NRC to aid in its evaluation of the license application.

We would appreciate your sending us a letter by November 12, 2004, detailing any concerns you may have about historic or archaeological properties in the area of OCGS or confirming AmerGen's conclusion that operation of OCGS over the license renewal term would have no effect on any historic or archaeological properties in New Jersey. This will enable us to meet our application preparation schedule. AmerGen will include a copy of this letter and your response in the license renewal application that we submit to the NRC.

Please call Bill Maher at (610) 765-5939, if you have any questions or require any additional information to review the proposed action.

Sincerely,

.....

Michael P. Gallagher Director, Licensing & Regulatory Affairs

Attachment: 6 mile Vicinity Map

cc: Karen Tuccillo, NJ BNE File No. 04007

I conc proper effects no fur additic impler	ur with yo ties affect s. Conseq her Sectio onal resour nentation	ur finding the ed within the uently, pursu in 106 consul rccs are disco pursuant to 3	t there are a project's a lant to 36 C tation is req wered durin 6 CFR 800.	no histori rea of po FR 800. uired un ng projec .13.	io tential 4(d)(1), less t
Deput	Doro y State His	Hy P. Guzzo storic Preserv	vation Offic	- <u>10</u>	

ATTACHMENT 6-Mile Vicinity Map í

110



Appendix E Coastal Zone Consistency Certification

-

Oyster Creek Generating Station Environmental Report

AmerGen Energy Company, LLC 200 Exelon Way Kennett Square, PA 13348 January 20, 2005 Mr. Andy Heyl Land Use Regulation Program Bureau of Coastal Management NJ Department of Environmental Protection 501 East State Street Trenton, NJ 08625-0439 Subject: Federal Consistency Certification For Federal Permit And License Applicants Oyster Creek Generating Station License Renewal Application

Mr. Heyl:

AmerGen Energy Company, LLC (AmerGen) is requesting concurrence with the enclosed Federal Consistency Certification for Federal Permit and License Applicants. The certification presents AmerGen's position that continued operation of the Oyster Creek Generating Station (OCGS) in Lacey Township, NJ would be in compliance with the current New Jersey Coastal Management Program.

1. **. . . .** .

As part of the application process to the U. S. Nuclear Regulatory Commission (NRC) requesting renewal of the OCGS operating license, AmerGen performed a review for consistency with the New Jersey Coastal Management Program. In conjunction with the application submittal, AmerGen must certify to the NRC and the State of New Jersey that OCGS operations and activities are in compliance with the Coastal Zone Management Act.

Per NRC regulations for license renewal (10 CFR 54), AmerGen is in the process of preparing an environmental report as Appendix E of the license renewal application. The Environmental Report will include a description of the proposed action and the affected environment, and an analysis of environmental consequences of the proposed action and mitigating actions. Also to be included in the Environmental Report is a complete list of licenses, permits, and other approvals from Federal, State, and local authorities for current OCGS operations. A summary of this information is provided in the enclosed consistency certification.

Federal Consistency Certification January 20, 2005 Page 2

After your office reviews the Consistency Certification, AmerGen requests a letter concurring with the enclosed Federal Consistency Certification for Federal Permit and License Applicants. AmerGen will include a copy of this letter and your response in the license renewal application that we submit to the NRC.

Please call Bill Maher at (610) 765-5939 if you have any questions or require any additional information to review the attached certification.

Sincerely,

Kith R. Jury

Keith R. Jury Director – Licensing and Regulatory Affairs AmerGen Energy Company, LLC

Enclosure 1: Federal Consistency Certification for Federal Permit and License Applicants

cc: Karen Tuccillo, NJ BNE Peter Tam, Senior Project Manager, NRR File No. XXXX

Page 1 of 33

FEDERAL CONSISTENCY CERTIFICATION FOR FEDERAL PERMIT AND LICENSE APPLICANTS'

This is the AmerGen Energy Company, LLC (AmerGen) certification to the U. S. Nuclear Regulatory Commission (NRC) and the State of New Jersey that renewal of the Oyster Creek Generating Station (OCGS) operating license would be consistent with enforceable policies of the federally approved state coastal zone management program. The certification describes background requirements, the proposed action (i.e., license renewal), anticipated environmental Impacts, New Jersey enforceable coastal resource protection policies and OCGS's compliance status, and summary findings.

CONSISTENCY CERTIFICATION

1 . .

17.7

1 1

AmerGen will certify to the NRC that renewal of the OCGS operating license will be consistent with the federally approved New Jersey coastal management program. AmerGen expects OCGS operations during the license renewal term to be a continuation of current operations as described below, with no station structural or operational modifications related to license renewal that would change effects on New Jersey's coastal zone.

1 54

NECESSARY DATA AND INFORMATION

Statutory Background

The federal Coastal Zone Management Act (16 USC 1451 et seq.) imposes requirements on the applicant for a federal license to conduct an activity that could affect a state's coastal zone. The Act requires an applicant to certify to the licensing agency that the proposed action would be consistent with the state's federally approved coastal zone management program. The Act also requires the applicant to provide to the state a copy of the certification statement and requires the state, at the earliest practicable time, to notify the federal agency and the applicant whether the state concurs with, or objects to, the consistency certification [16 USC 1456(c)(3)(A)].

The National Oceanic and Atmospheric Administration (NOAA) has promulgated implementing regulations that indicate that the certification requirement is applicable to renewal of federal licenses for activities not previously reviewed by the state [15 CFR 930.51(b)(1)]. NOAA approved the New Jersey coastal management program in 1980 (Ref. 2).

In New Jersey, the approved program is the Coastal Management Program. The Coastal Management Program comprises a network of offices within the New Jersey Department of Environmental Protection that serve distinct functions yet share responsibility for the coast of New Jersey. The Coastal Management program implements three major state laws: the Waterfront Development Law, the Wetlands Act of 1970, and the Coastal Area Facility Review Act (CAFRA). The Hackensack Meadowlands Reclamation and Development Act, and the Freshwater Wetlands Protection Act are additional authorities for Federal Consistency Review. Enforceable policies are contained in the Coastal Zone Management rules (New Jersey Administrative Code [NJAC] 7:7E), the Coastal Permit Program rules (NJAC 7:7) and the the second of

1 This certification is patterned after the example certification included as Appendix E of the NRC Office of Nuclear Reactor Regulation's "Procedural Guidance for Preparing Environmental Assessments and Considering Environmental Issues* (LIC-203, 6-21-01).

· . .

· • •

...*

e . •

Page 2 of 33

Freshwater Wetlands Protection rules (NJAC 7:7A) (Ref. 3). The licensing of OCGS in 1969 by the NRC, pre-dated the state program approval.

Proposed Action

The NRC operating license for OCGS will expire in 2009. NRC regulations provide for license renewal, and AmerGen is applying for renewal of the license to 2029.

OCGS is an electric generating station located within the New Jersey coastal zone, in Lacey Township, Ocean County, between the South Branch of the Forked River and Oyster Creek, two miles inland of Barnegat Bay. The plant withdraws water from Barnegat Bay via the South Branch of the Forked River, and a manmade intake canal for non-contact cooling, and returns the heated discharge to Barnegat Bay via a discharge canal and Oyster Creek. Approximately 60 percent of the area within a 50-mile radius of OCGS is the water of the Atlantic Ocean. Attachments 2 and 3 of this enclosure are OCGS 50- and 6-mile vicinity maps, respectively.

OCGS is a boiling water reactor with an expected total output of 1,930 MW thermal and an expected electric output of 640 MW. The intake structure has four circulating water pumps within two bays. The four pumps provide a continuous supply (maximum of 460,000 gallons per minute [gpm]) of condenser cooling water. After moving through the condensers (and service water systems) water is discharged into a discharge canal and thence to Oyster Creek, which flows into Barnegat Bay. In addition to the four circulating water pumps (and four service water pumps with a total maximum pump capacity of 16,000 gpm) in the same intake structure, three dilution pumps pull water from the intake canal directly into the discharge canal to ameliorate the elevated temperatures in the discharge canal during part of the year. Maximum total capacity of the three dilution pumps is 780,000 gpm. Maximum flow with all circulation and dilution pumps working would be 1.25 million gpm; however, the NJPDES permit allows only two dilution pumps to operate simultaneously.

The OCGS workforce consists of approximately 470 AmerGen employees and 150 long-term contract employees. More than 80 percent reside in Ocean County. The OCGS reactor is on a 24-month refueling cycle. During refueling outages, site employment increases by approximately 1,300 workers for temporary (approximately 20 days) duty. AmerGen has no plans to add additional employees as a result of license renewal.

AmerGen has not identified any refurbishment activities necessary to allow operation for an additional 20 years, and have identified no significant environmental impacts from programs and activities for managing the effects of aging. As such, renewal would result in a continuation of environmental impacts currently regulated by the state. Table E-1 lists State and Federal licenses, permits, and other environmental authorization for current OCGS operations and Table E-2 identifies compliance activities associated specifically with NRC license renewal.

One transmission line was built to connect OCGS to the regional electric grid. The corridor runs approximately 11 miles, from OCGS to the Manitou substation near Toms River, and encompasses about 320 acres (Attachment 1). Conectiv is proposing to construct a new transmission line from the Oyster Creek substation south to Egg Harbor, but that proposal is not within the scope of this certification. The proposed action, renewing the license of OCGS for an additional 20 years, would not require additional transmission lines, nor is AmerGen anticipating that this action would change any corridor maintenance practices.

Environmental Impacts

NRC has prepared a generic environmental impact statement (GEIS; Ref. 4) on impacts that nuclear power plant operations could have on the environment and has codified its findings (10 CFR 51, Subpart A, Appendix B, Table B-1). The regulation identified 92 potential environmental issues, 69 of which the NRC identified as having small impacts and termed "Category 1 issues." NRC defines "small" as:

Small - For the issue, environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource. For the purpose of assessing radiological impacts, the Commission has concluded that those impacts that do not exceed permissible levels in the Commission's regulations are considered small as the term is used in this table (10 CFR 51, Subpart A, Appendix B, Table B-1)

The NRC regulation and the GEIS discuss the following types of Category 1 environmental ne ne en grechen Le four de Le Reig issues:

. .

- Surface water quality, hydrology, and use
 - Aquatic ecology
- Groundwater use and quality
- **Terrestrial resources**
- Air quality

í

- Land use
- Human health
- Postulated accidents
- Socioeconomics
- Uranium fuel cycle and waste management

1

Decommissioning

In its decision-making for plant-specific license renewal applications, absent new and significant information to the contrary, NRC relies on its codified findings, as amplified by supporting information in the GEIS, for assessment of environmental impacts from Category 1 issues [10 CFR 51.9(c)(4)]. For plants such as OCGS that are located in coastal areas, many of these issues involve impacts to the coastal zone. AmerGen will adopt by reference the NRC findings and GEIS analyses for all 58 applicable Category 1 issues. The remaining Category 1 issues do not apply to OCGS because either they are associated with design or operational features the OCGS does not have (e.g., cooling ponds), or to an activity (i.e., refurbishment) that OCGS does not intend to undertake.

· . · . . .

Page 4 of 33

The NRC regulation identified 21 issues as "Category 2," for which license renewal applicants must submit additional site-specific information.² Of these, 11 apply to OCGS, and, like the Category 1 issues, could involve impacts to the coastal zone. The applicable issues and AmerGen's impact conclusions are listed below.

· Entrainment of fish and shellfish in early life stages - This issue addresses mortality of organisms small enough to pass through the plant's circulating cooling water system. AmerGen monitored the fishery in Barnegat Bay from the early 1970s through the mid 1980s to identify impacts of OCGS on the fishery. Species collected included resident species, warm water migrants and cold water migrants. The patterns of species composition and relative abundance appeared stable. More recently, in response to the Barnegat Bay Study Act, other groups have studied the Bay, including its fish community. Results indicate that the water quality of the Bay, which had been in decline, is recovering and now supports a healthy fish population. One measure of the significance of environmental impacts is the degree to which they meet environmental protection legal standards. The New Jersey Department of Environmental Protection regulates OCGS entrainment and impingement, under its authority to issue the OGCS NJPDES discharge permit. To the best of Amergen's knowledge, OCGS is in compliance with its NJPDES permit. AmerGen concludes that the impacts of entrainment during current operations are small and it has no plans that would change this conclusion for the period of extended operation.

Pursuant to Section 316(b) of the Clean Water ct, the U.S. Environmental Protection Agency has recently revised cooling water intake structure requirements for facilities such as OGCS. New Jersey will have to incorporate these revisions into its discharge permit program and the State and AmerGen will have to evaluate whether OCGS modifications would be necessary to comply with the new requirements. This evaluation could effectively re-define what would be an acceptable OGCS entrainment or impingement impact. If this happens, however, AmerGen observes that any modifications made to meet the new 316(b) requirements would only reduce, not increase, current OCGS impacts and that the post-modification result would still be small impacts.

- Impingement of fish and shellfish This issue addresses mortality of organisms large enough to be caught by intake screens before passing through the plant's circulating cooling water system. OCGS has a fish return system consisting of Ristroph traveling screens at the intake pumps and a flume that delivers fish to the head of the discharge canal. This system reduces the number of fish impinged and impingement mortality. AmerGen concludes that impacts of impingement during current operations are small and it has no plans that would change this conclusion for the period of extended operation. See the paragraph above for discussion of 316(b).
- <u>Heat shock</u> This issue addresses mortality of aquatic organisms by exposure to heated plant effluent. Cooling water flow rates and heat rejection rates are limited by provisions of NJPDES permit number NJ0005550. OCGS employs three dilution pumps to move water from the Intake canal to the head of the discharge canal under certain temperature

² 10 CFR 51, Subpart A, Appendix B, Table B-1 also identifies 2 issues as "NA" for which NRC could not come to a conclusion regarding categorization. AmerGen believes that these issues, chronic effects of electromagnetic fields and environmental justice, do not affect the "coastal zone" as that phrase is defined by the Coastal Zone Management Act [16 USC 1453(1)].

Page 5 of 33

- conditions, as part of the NJPDES permit. AmerGen concludes that the impacts of heat shock during current operations are small and it has no plans that would change this conclusion for the license renewal term.
- <u>Threatened or endangered species</u> This issue addresses effects that OCGS operations could have on species that are listed under federal law as threatened or endangered. In analyzing this issue, AmerGen has also considered species that are protected under New Jersey law (Table E-3).

Based on a review of the Natural Heritage Database and Landscape Project records, the following state-listed animal species occur in the vicinity of the OCGS site: barred owl (*Strix varia*), Cooper's hawk (*Accipter cooperii*), Northern pine snake (*Pituophis m. melanoleucus*), pine barrens treefrog (*Hyla andersoni*), and wood turtle (*Clemmys insculpta*). The Natural Heritage Database and Landscape Project also indicated that foraging habitat for the black skimmer (*Rhynchops niger*) and the black-crowned night heron (*Nycticorax nycticorax*) were within ¼ mile of the site. A survey of the undeveloped part of the site west of Rt. 9 done in support of security upgrades determined that none of the state-protected species were on site.

Although prior to 1992, no special-status marine species were observed or captured in the OCGS cooling canals, between June 1992 and July 1994, 9 sea turtles were impinged on the OCGS intake trash rack. An increase in the number of sea turtles observed in Barnegat Bay and in the number of sea turtles impinged at OCGS corresponded to the U.S. Army Corps of Engineers' deepening of Barnegat Inlet. It also followed the implementation in 1987 (full implementation in 1989) of federal regulations requiring U.S. shrimp trawlers to use Turtle Exclusion Devices that substantially reduced fishing-related mortality of sea turtles in south Atlantic and Gulf coastal waters.

In November 1993, the Nuclear Regulatory Commission (NRC) requested a formal consultation with the National Marine Fisheries Service (NMFS) regarding possible impacts of OCGS on listed sea turtles, and followed with a Biological Assessment in January 1995. In 2000 NRC submitted an updated Biological Assessment. In both instances, NMFS determined that OCGS may adversely affect three species of federally-protected sea turtle: endangered Kemp's ridley, endangered green, and threatened loggerhead. Each Biological Opinion further concluded that OCGS would not likely jeopardize the species' existences. Currently OCGS has an Incidental Take annual allowance of 5 loggerhead (no more than 2 lethal), 4 Kemp's Ridley (no more than 3 lethal), and 2 green (no more than one lethal) sea turtles. The Biological Opinion included Reasonable and Prudent Measures that must be implemented at OCGS to minimize impacts to sea turtles as well as a list of Terms and Conditions that implement the Reasonable and Prudent Measures. These nondiscretionary Terms and Conditions include requirements for regular inspections of the intake trash racks in summer and fall; requirements for capturing, handling, resuscitating, and treating injured sea turtles; requirements for recording and reporting sightings and strandings; requirements for necropsies of dead turtles; and reporting requirements, including an annual report to NMFS on incidental takes. In 2004 OCGS exceeded its incidental take allowance for Kemp's ridley turtles.

As a result of this, NRC requested re-initiation of Endangered Species Act Section 7 consultation with NMFS. This consultation is on-going.

No other federally- or state-listed threatened or endangered species is known to occur, with the exception of the consultation noted above, at OCGS or along the OCGS-to-Manitou transmission corridor.

AmerGen is corresponding with cognizant federal and state agencies. With the exception of the consultation noted above, no federal or state agencies have identified any area of concern. AmerGen concludes that OCGS impacts to these protected species are small during current operations and has no plans that would change this conclusion for the license renewal term.

- <u>Electromagnetic fields, acute effects (electric shock)</u> This issue addresses the potential for shock from induced currents, similar to static electricity effects, in the vicinity of transmission lines. Because this human-health issue does not directly or indirectly affect natural resources of concern within the Coastal Zone Management Act definition of "coastal zone" [16 USC 1453(1)], AmerGen concludes that the issue is not subject to the certification requirement.
- Housing This issue addresses impacts that additional AmerGen employees required to support license renewal and the additional resulting indirect jobs could have on local housing availability. NRC concluded, and AmerGen concurs, that impacts would be small for plants located in high population areas that do not have growth control measures which limit housing development. Using the NRC definitions and categorization methodology, OCGS is located in a high population area without restrictive growth controls. AmerGen expects no additional employees would be required to support license renewal. AmerGen concludes that impacts during the OCGS license renewal term would be small.
- <u>Public services; public utilities</u> This issue addresses impacts that adding license renewal workers could have on public utilities, particularly public water supply. AmerGen has analyzed the availability of public water supplies in the area and has found no limitations that would suggest that additional OCGS workers would cause impacts. AmerGen expects no additional employees to support license renewal. Therefore, AmerGen has concluded that impacts during the OCGS license renewal term would be small.
- Offsite land use This issue addresses impacts that local government spending of plant
 property tax dollars can have on land use patterns. OCGS property taxes comprised 4
 percent of Lacey Township's total tax revenues in 2003. AmerGen projects that OCGS
 taxes will remain relatively constant during the license renewal term. AmerGen
 concludes that impacts during the OCGS license renewal term would be small and not
 warrant mitigation.
- <u>Public services; transportation</u> This issue addresses impacts that adding license renewal workers could have on local traffic patterns. AmerGen expects no additional employees would be required to support license renewal. Therefore, AmerGen has concluded that impacts during the OCGS license renewal term would be small.

· ·

 <u>Historic and archaeological resources</u> – This issue addresses impacts that license renewal activities could have on resources of historic or archaeological significance. Several archaeological or historic sites have been identified within 6 miles of OCGS; however, AmerGen is not aware of any adverse or detrimental impacts to these sites from current operations and AmerGen has no plans for license renewal activities that would disturb these resources. AmerGen correspondence with the State Historic Preservation Officer Identified no Issues of concern.

· · · ·

 <u>Severe Accidents</u> – This issue addresses the impact of severe accidents and the probability-weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to ground water, and societal and economic impacts. The NRC has already determined the impacts from severe accidents to be of small significance for all plants.

State Program

The New Jersey Coastal Management Program is administered by the Land Use Regulation Program within the Department of Environment Protection. The Department maintains a website that describes the program in general terms (Ref. 3). The New Jersey Coastal Management Statutes (Ref. 5) contain guidelines for preservation and management of the coastal area that are set forth in policy statements, standards, and management objectives. Attachment 1 lists these objectives and discusses for each the applicability to OCGS.

Findings:

- NRC has determined that the impacts of certain license renewal environmental issues (i.e., Category 1 issues) are small. AmerGen will adopt by reference NRC findings for these issues as they are applicable to OCGS.
- For all other license renewal issues (i.e., Category 2 and "NA" issues), except endangered species, that are applicable to OCGS, AmerGen has determined that the environmental impacts are small.
- NRC and NMFS are engaged in an Endangered Species Act Section 7 consultation regarding three protected sea turtle species. Outcome of this consultation will include recommendations, which will be reviewed by AmerGen.
- 4. To the best of AmerGen's knowledge, OCGS and its transmission corridor are in compliance with all New Jersey's licensing and permitting requirements and are in compliance with its state-issued licenses and permits.
- 5. AmerGen's license renewal and continued operation of OCGS would be consistent with the enforceable policies of the New Jersey coastal zone management program.

Page 8 of 33

STATE NOTIFICATION

By this certification that OCGS license renewal is consistent with New Jersey's coastal zone management program, New Jersey is notified that it has six months from receipt of this letter and accompanying information in which to concur with or object to AmerGen's certification (15 CFR 930.51). However, pursuant to 15 CFR 930.51(b)(1), if New Jersey has not issued a decision within three months following the commencement of state agency review, it shall notify the contact listed below of the status of the matter and the basis for further delay. New Jersey's concurrence, objection, or notification of review status shall be sent to:

Andrew Kugler Chief of Environmental Section Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission One White Flint 11555 Rockville Pike Rockville, MD 20555 (301) 415-2828 Keith Juny Director, Licensing and Regulatory Affairs Exelon Corporation 200 Exelon Way Kennett Square, PA 19348 (630) 657-2831

RE	FERE	NCES						(, <i>1,</i> , ; ,	• •	•	•	
1.	NRR Asse Com	Office ssment missior	Instruc ts and n, Office	tion No. Consider of Nuclea	LIC-203, ring Env r Reactor	"Proced ironmen Regulat	ural G tal Iss ion, Ju	uidanc sues." une 21	e for U. , 2001	Prepari S. Nu	ng Envi Iclear F	ronment legulator
2.	State Mana at htt	and igemer p://www	Territor 1t Progra w.ocrm.r	y Coastal am. Natior nos.noaa.	I Manag nal Ocear gov/czm/c	ement Fic and A czmsiteli	Program trnosp st.html	n Sun heric A . Acces	nmarie Idminis ssed Ju	s, Nev stration uly 19, 2	v Jersey Availat 2004.	/ Coast ble on lin
3.	New Avail	Jersey able at	Departr http://w	ment of Er ww.nj.gov	nvironmei /dep/cmp	ntal Prote	ection. sed Jul	2004. ly 19, 2	Coast 2004.	al Man	agement	Program
4.	Gene Nucle http:/	eric En ear Re www.r	vironme egulator nrc.gov/i	intal Impa y Commi reading-m	ct staten ission, N Vdoc-coll	nent for IUREG-1 ections/r	Licens 437, juregs/	se Rer May 'staff/si	newal 1996. 1437.	of Nuc Avai Acces	lear Plai lable oi sed 12-2	nts, U. 1 n line 1 3-03.
5.	New	Jersey	Admini	strative Co	de, Title	7, Chap	er 7E,	Coast	al Zone	Мапа	gement i	ules.
		•			``. .``'				•	•	•	
	· · ·	•	T			· · ·	•••	-	· · ·			
•	•		•	•					· ·	· · · ·	6 ·	
	•		· ·			•		•1	(. •	•	
	• •		•	•					•	.		
		,		•		• •	• •				,	
:	•	•	•		· : '	•						
											•	
									.•	•, •	•	
		- - .					۲ ۲	 '	•		:	
• * 7	Г., - Л.		. ·				115. 115	 •	•			
	-				/	1					•••	
							•					

Page 10 of 33

Figure E-1, 50-Mile Vicinity Map





Oyster Creek Generating Station License Renewal Application

Page E-15



1

.

Page 13 of 33

.

.

Agency	Authority	Requirement	Number	issue or Expiration Date	Activity Covered
<u>.</u>	F	ederal Requirements to	License Renewal	····	· ·
U. S. Nuclear Regulatory Commission	Atomic Energy Act (42 USC 2011, et seq.), 10 CFR 50.10	License to operate	DPR-16	issued: 4/9/1969 Expires: 4/9/2009	Operation of OCG
U.S. Department of Transportation	49 USC 5108	Registration	052804700004MO	Issued: 5/28/04 Expires: 6/30/07	Hazardous materials shipments
National Marine Fisheries Service	Endangered Species Act of 1973 (16 USC 1531-1544)	incidental Take Permit - Sea Turtles	To be determined	•• • • •	Possession and disposition of impinged or stranded sea turtle
Vew Jersey Department of Environment Protection	Clean Water Act (33 USC 1251 et seq.), NJ Statutes Annotated (N.J.S.A.) Water Pollution Control Act 58:10A et seq. and N. J. Administrative Code (N.J.A.C.)7:14A et seq.	New Jersey Potlutant Discharge Elimination System Permit – surface water	NJ0005550	Issued: 10/21/94; Expires: 11/30/99	Wastewater (Industrial surface water, thermal surface water and stormwater runoff) discharges to Oyster Creek, Forked River, and South Branch of Forked River
New Jersey Department of Environment Protection	Clean Water Act (33 USC 1251 et seq.), N.J.S.A. 58:10A et seq. and N.J.A.C. 7:14A et seq.	New Jersey Pollutant Discharge Elimination System Permit – ground water	NJ0101966	Issued: 2/20/04 Expires: 2/20/09	Wastewater (percolation lagoon, underground injection, dredge spoils) to groundwater

•

Page 14 of 33

Адепсу	Authority	Requirement	Number	issue or Expiration Date	Activity Covered
New Jersey Department of Environment Protection	Coastal Area Facility Review Act (N.J.S. A. 13:19-1 et seq.), Waterfront Development Act (N.J.S.A. 12:5-3), and Wetlands Act of 1970 (N.J.S.A. 13:9A-1 et seq.)	Certification			Compliance with Coastal Zone management rules, Freshwater Wetlands protection rules, and Coastal Permit Program rules
New Jersey Department of Environment Protection	Water Supply Management Act, N.J.S.A. 58: 1A et seq.	Water Use Registration	11108W	Issued: 7/25/01 Expires: not applicable	Registers two wells with collective diversions of less than 100,000 gallons per day
New Jersey Department of Environmental Protection	N.J.A.C. 7:7A	Freshwater Wetlands Statewide General Permit	1500-02-0004.1	Issued: 6/4/02 Expires: 6/4/07	Remove vegetation from fire pond
New Jersey Department of Environmental Protection	Chapter 251, Soil Erosion and Sediment Control Act, P.L. 195	Certificate	SCD 1302	Issued: 10/31/01 Expires: 4/3/05	Soil Erosion Control and Sediment Control plan for upland dredge disposal site
New Jersey Department of Environmental Protection	Clean Air Act (42 USC 7401 et seq); Air Pollution Control Act (1954), N.J.S.A. 26:2C- 9.2	Certificate to operate	PCP970001	Issued: 9/8/97 Expires: 9/8/07	Air emission for DL-42 boiler and DL-68 boller

Environmental Report Appendix E Coastal Zone Consistency Certification

Oyster Creek Generating Station License Renewal Application

·

.

Land Use Regulation January XXX, 2005,	Prograu Enclosu	m, re	NJ 1	l Dep	partr	nen	t Of	Enviro	nme	ental Pro	lection
	•	•		÷		ŝţ	·				

Page 15 of 33

Agency	Authority	Requirement	Number	issue or Expiration Date	Activity Covered
New Jersey Department of Environmental Protection	Clean Air Act (42 USC 7401 et seq); Air Pollution Control Act (1954), N.J.S.A. 26:2C- 9.2	Certificate to operate	PCP970002	Issued: 10/9/02 Expires: 10/9/07	Emergency Fire Diesel 1-2
New Jersey Department of Environmental Protection	Clean Air Act (42 USC 7401 et seq); Air Pollution Control Act (1954), N.J.S.A. 26:2C- 9.2	Certificate to operate	PCP970003	lssued: 11/14/97 Expires: 11/14/07	#1 boiler
New Jersey Department of Environmental Protection	Clean Air Act (42 USC 7401 et seq); Air Pollution Control Act (1954), N.J.S.A. 26:2C- 9.2	Certificate to operate	PCP970005	Issued: 1/8/03 Expires: 1/8/08	Forked River Emergency Fire Diesel
New Jersey Department of Environmental - Protection	Clean Air Act (42 USC 7401 ef seq); Air Pollution Control Act (1954), N.J.S.A. 26:2C- 9.2	Certificate to operate	PCP970006	Issued: 10/31/02 Expires: 10/29/07	Dirty Oil Lube Tank
New Jersey Department of Environmental Protection	Clean Air Act (42 USC 7401 et seq); Air Pollution Control Act (1954), N.J.S.A. 26:2C- 9.2	Certificate to operate	PCP960005	Issued: 3/23/04 Expires: 3/23/09	Main Fuel Tank
New Jersey Department of Environmental Protection	Clean Air Act (42 USC 7401 et seq); Air Pollution Control Act (1954), N.J.S.A. 26:2C- 9.2	Certificate to operate	PCP960006	issued: 7/10/04 Expires: 7/10/09	Emergency Generator 1

Page 16 of 33

Agency	Authority	Requirement	Number	Issue or Expiration Date	Activity Covered
New Jersey Department of Environmental Protection	Ckean Air Act (42 USC 7401 et seq); Air Pollution Control Act (1954), N.J.S.A. 26:2C- 9.2	Certificate to operate	PCP960007	Issued: 7/10/04 Expires: 7/10/09	Emergency Diesel Generator 2
Now Jersey Department of Environmental Protection	Clean Air Act (42 USC 7401 et seq); Air Pollution Control Act (1954), N.J.S.A. 26:2C- 9.2	Certificate to operate	PCP960008	Issued: 6/26/96 Expires: 6/26/06	Grit Blaster
New Jersey Department of Environmental Protection	Clean Air Act (42 USC 7401 et seq); Air Pollution Control Act (1954), N.J.S.A. 26:2C- 9.2	Certificate to operate	PCP020001	lssued: 7/29/02 Expires: 7/28/07	Emergency Fire Diesel 1-1
New Jersey Department of Environmental Protection	N.J.A.C. 7:14B	Certificate to operate	GEN000001	lssued: 7/19/00 Expires: 7/18/05	Emergency Generator C2
New Jersey Department of Environmental Protection	Clean Water Act (33 USC 1251 et seq.); Clean Air Act (42 USC 7401 et seq.); Resource Conservation and Recovery Act (42 USC 6901 et seq.); Water Pollution Control Act, N.J.S.A. 48:10A et seq.; Industrial Site Recovery Act, N.J.S.A. 26:2C-1 et seq. and N.J.A.C. 7:14B	Registration	UST 000002	lssued: 8/24/04 Expires: 8/24/09	Underground storage tank – emergency spill tank

Page 17 of 33

Agency	Authority	Requirement	Number	Issue or Expiration Date	Activity Covered
New Jersey Department of Environmental Protection	Industrial Site Recovery Act, N.J.S.A. 26:2C-1 et.seq. and N.J.A.C. 7:27-8	Operating Certificate	CN 099746	Issued: 10/16/00 Expires: 10/16/05	Above-ground Gasoline Storage Tank
New Jersey Department of Environmental Protection	N.J.A.C. 7:18 et seq.	Laboratory Certification	15304	Issued: 6/30/04 Expires: 6/30/05	State certified laboratory to perform listed analyses
New Jersey Department of Transportation	Fish and Game, Wild Birds and Animals	License	H-205	Issued: 2/2004 Expires: 1/2005	Oyster Creek Helistop
New Jersey Department of Environmental Protection	Clean Air Act (42 USC 7401 et seq); Air Pollution Control Act (1954), N.J.S.A. 26:2C- 9.2	Certificate to Operate	PCP960004	Issued: 2/13/01 Expires: 2/13/06	EDG Fuel Oil Storage Tank
South Carolina Department of Health and Environmental Control – Division of Waste Management	South Carolina Radioactive Waste Transportation and Disposal Act (Act No. 429)	South Carolina Radioactive Waste Transport Permit	0043-29-05-X	12/31/05	Transportation of radioactive waste into the State of South Carolina
Commonwealth of Virginia Department of Environmental Protection	Virginia Department of Emergency Management Title 44, Code of Virginia, Chapter 3.3, Section 44-146.3	Virginia Registration to Transport Hazardous Radioactive Materials	AO-S-063006	Issued: 5/27/2004 Expires: 6/30/2006	Transport of hazardous radioactive materials
•		· -			

Environmental Report Appendix E Coastal Zone Consistency Certification

.

Page 18 of 33

Agency	Authority	Requirement	Number	Issue or Expiration Date	Activity Covered
State of Tennessee Department of Environment and Conservation Division of Radiological Health	Tennessee Department of Environment and Conservation Rule 1200-2-10.32	Tennessee Radioactive Waste License-for-Delivery	T-NJ001-L05	12/31/05	Transportation of radioactive waste into the State of Tennessee
New Jersey Department of Environmental Protection	40 CFR 266 Subpart N N.J.A.C. 7:26G	Conditional Exemption			Storage and treatment of low- level mixed waste
Ocean County Utilities Authority		Agreement	Not applicable	Not applicable	OCGS provides continuous radiation monitorin of discharges of OCGS wastewater to publicly-owned treatment facility

.

Page E-22

Table E-2. Environment	al Authorizations for (OCGS License Re	newal*
Agency	Authority	- Requirement -	Remarks
U.S. Nuclear Regulatory	Atomic Energy Act	License renewal	Environmental Report
Commission	(42 USC 2011		submitted in support of
	et seq.)		license renewal application
U.S. Fish and Wildlife	Endangered	Consultation	Requires federal agency
Service	Species Act		Issuing a license to consult
	Section 7 (16 USC		with the U.S. Fish and Wildlif
	1536)	•••	Service
New Jersey Department	Clean Water Act	Certification	State issuance of NJPDES
of Environmental	Section 401	. <u>6</u> .1	permit (Section 9.1.5)
Protection	(33 USC 1341)		constitutes 401 certification
New Jersey Coastal	Coastal Zone	Certification	Requires applicant to prove
Management Program	Management Act	· ·	certification to federal agency
	(16 USC 1452 et	· ·	issuing the license that
	seq.)		license renewal would be
		. .	consistent with the rederally
			Management program
			Based on its review of the
	· · · · ·	· ·	proposed activity, the State
		N2 1	must concur with or object to
	· ?		the applicant's certification
New Jersey Office of	National Historic	Certification	Requires federal agency
Historic Preservation	Preservation Act		Issuing a license to consider
	Section 106		cultural impacts and consult
2	(16 USC 4701)		with State Historic
		•	Preservation Unicer (SHPU)
			license renewal will not affect
			any sites listed or eligible for
	1		listing
No renewal-related require	ments identified for local of	or other agencies.	
	1. 1.1	. ,	•
		· .	• • • •
		<u>.</u>	
	ı	. •	÷ • •
		•	
			· · _ · · ·
	· • • · ·	• • * * *.	
			· . ·

Page 20 of 33

Scientific Name	Common Name	Federal Status*	State Status
Mammals			
Lynx rufus	Bobcat	. •	E
Birds			
Accipiter cooperli	Cooper's hawk	-	т
Ammodramus savannarum	Grasshopper sparrow	•	т
Bartramia longicauda	Upland sandpiper	-	E
Botaurus lentiginosus	American bittern	•	E
Calidris canutus	Red knot	•	т
Charadrius melodus	Piping plover	т	E
Circus cyaneus	Northern harrier	•	E
Cistothorus platensis	Sedge wren	-	E
Faico peregrinus	Peregrine falcon	-	E
Hallaeetus leucocephalus	Bald eagle	т	E
Lateralius jamaicensis	Black rall	-	т
Melanerpes erythrocephalus	Red-headed woodpecker	-	. T
Nyctanassa violacea	Yellow-crowned night-heron	-	т
Nycticorax nycticorax	Black-crowned night-heron	-	т
Pandion haliaetus	Osprey	•	Т
Podilymbus podiceps	Pled-billed grebe	-	E
Pooecetes gramineus	Vesper sparrow	-	E
Rynchops niger	Black skimmer	-	E
Sterna antillarum	Least tern	•	E
Sterna dougallii dougallii	Roseate tem	E	E
Strix varia	Barred owl	•	т
Reptiles			
Ambystoma tigrinum tigrinum	Eastern tiger salamander	-	E
Clemmys insculpta	Wood turtle	-	т
Clemmys muhlenbergil	Bog turtle	Т	Ť
Crotalus horridus horridus	Timber rattlesnake		E
Elaphe guttata guttata	Corn snake	-	E
Hyla andersoni	Pine barrens treefrog	•	E
Hyla chrysosceli s	Cope's gray treefrog	•	E
Pituophis melanoleucus	Northern pine snake	٠	т
Invertebrates			
Cicindela dorsalis dorsalis	Northeastern beach tiger beetle	т	Ē
Nicrophorus americanus	American burying beetle	E	E

	Page	21	of	33

Scientific Name	Common Name	Federal Status*	State Status
Plants			
Amaranthus pumilus	Seabeach amaranth	т	E
Aster radula	Low rough aster	•	E
Cacalla atriplicifolia	Pale Indian plantain		È
Cardamine Iongli	Long's bittercress	-	Е
Cirsium virginianum	Virginia thistle	-	E
Clitoria mariana	Butterfly-pea	•	Е
Corema conradil	Broom crowberry	•	Е
Desmodium paucillorum	Few-flower tick-trefoll	-	E
Eleocharis tortilis	Twisted spike-rush	-	. E
Eriophorum tenellum	Rough cotton-grass	• • •	E
Eupatorium resinosum	Pine Barren boneset	• •	. E
Fraxinus profunda	Pumpkin ash	- 1	E
Galactia volubilis	Downy milk-pea	•	Ē
Glaux maritima	Sea-milkwort	-	· E
Gnachalium helieri	Small everlasting	-	E
Helonias bullata	Swamp-pink	т	E
Hottonia inflata	Featherfoil	-	E
Jeffersonia diphvlla	Twinleaf	•	E
Juncus caesariensis	New Jersey rush	•	Е
Juncus torrevi	Torrey's rush	•	Е
Limosella subulata	Awl-leaf mudwort	-	Е
Linum Intercursum	Sandplain flax	-	Е
Luzula acuminate	Hairy wood-rush	•	Е
Melanthium virginicum	Virginia bunchflower	-	E
Myriophyllum tenellum	Slender water-milfoil	•	E
Myriophyllum verticillatum	Whorled water-milfoil	• ·	E
Narthecium americanum	Bog asphodel	С	Ε
Oenothera humifusa	Sea-beach evening-primrose	•	E
Onosmodium virginianum	Virginia false-gromwell	-	E
Plantago pusilla	Dwarf plantain	-	Ε
Polygonum glaucum	Sea-beach knotweed	•	Е
Prunus angustifolia	Chickasaw plum	-	Е
Ranunculus cymbalaria	Seaside buttercup	•	Е
Rhododendron atlanticum	Dwarf azalea	-	E
Rhynchospora globularis	Coarse grass-like beaked-rush	• •	E '
Rhvnchospora knieskemii	Knieskem's beaked-rush	т	Е

Oyster Creek Generating Station License Renewal Application

.

Page 22 of 33

 Table E-3.
 Endangered and Threatened Species that Could Occur at or Near OCGS or Along Associated OCGS-Manitou Transmission Line (Continued).

Scientific Name	Common Name	Federal Status*	State Status*
Rhynchospora mlcrocephala	Small-head beaked-rush	•	E
Schwalbea americana	Chaffseed	Ē	E
Scirpus longil	Long's woolgrass	-	E
Scirpus maritimus	Saltmarsh bulrush	-	E
Spiranthes laciniata	Lace-lip ladles'-tresses	-	E
Stylisma pickeringil var	Pickering's morning glory	-	E
Tridens flavus var chapmanli	Chapman's redtop	•	E
Triglochin maritima	Seaside arrow-grass	-	E
Utricularia biflora	Two-flower bladderwort	-	E
Utricularia minor	Lesser bladderwort	•.	E
Uvularia puberula var nitida	Pine Barren bellwort	-	E
Verbena simplex	Narrow-leaf vervaln	•	E
Xyris fimbriata	Fringed yellow-eyed-grass	-	E
Zigadenus leimanthides	Death-camus		E

a. E = Endangered; T = Threatened; C = Candidate; - = Not listed.

Source: NJDEP NHP 2001.

. . .

ATTACHMENT 1

NEW JERSEY COASTAL ZONE MANAGEMENT RULES

and the first states

APPLICABILITY

The New Jersey Department of Environmental Protection (NJDEP) maintains a website that describes the state coastal management program (Ref. E-1) and provides a discussion of Federal consistency certification and links to the New Jersey's Federal Consistency Guidance Document and New Jersey's Approved Federal Consistency Listing (Ref. E-2). The consistency discussion and the guidance document indicate that the enforceable policies of the New Jersey coastal management program are contained in the following state rules:

- Coastal Zone Management Rules (NJAC³ 7:7E)
- Coastal Permit Program Rules (NJAC 7:7)
- Freshwater Wetlands Protection Act Rules (NJAC 7:7A)

The Federal Consistency listing includes "[p]ermits and licenses required for the construction and operation of nuclear facilities under the Atomic Energy Act of 1954, Sections 6, 7, 8, and 10." While the listing does not expressly include license renewal, AmerGen has prepared this certification as if it did. The following paragraphs present AmerGen's conclusions with regard to the applicability of the New Jersey enforceable coastal management policies to U. S. Nuclear Regulatory Commission renewal of the Oyster Creek Generating Station (OCGS) operating license.

<u>Coastal Zone Management Rules (NJAC 7:7E, as amended 2/13/03)</u> – The New Jersey Land Use Regulation Program administers these rules under the authority of the state Coastal Area Facility Review Act (CAFRA) and other laws. The Program website (Ref. E-3) provides additional detail about its coastal programs and includes a link to a CAFRA zone map for a preliminary assessment of geographic coverage of the Act (Ref. E-4). The map indicates that the eastern one half of Ocean County is with the coastal area. OCGS is located within that portion of Ocean County, in Lacey Township. The rules at section 7:7E-1.2(a)1 indicates that the chapter (i.e., 7E) is applicable to consistency determinations. AmerGen has concluded that the location of the OCGS is within the CAFRA geographic coverage and that these rules, as they implement CAFRA, apply to the OCGS certification.

<u>Coastal Permit Program Rules (NJAC 7:7, as amended 2/13/03)</u> – These are the rules by which NJDEP implements its requirements for permits for construction within the coastal area; draining, dredging, excavation, or deposition of material, and erection of any structure in any coastal wetlands; and filling or dredging, or construction in certain upland areas adjacent to tidal waterways. Because AmerGen is not performing these activities as a result of license renewal, has no plans to perform such activities as a result of license renewal, and is not seeking a coastal permit for such activities, AmerGen has concluded that these rules are not applicable to its federal consistency certification.

3 NJAC = New Jersey Administrative Code

Page 24 of 33

<u>Freshwater Wetlands Protection Act Rules (NJAC 7:7A, effective 10/20/03)</u> – These are the rules by which DEP regulates construction in, or other disturbance of, freshwater wetlands. AmerGen has concluded that these rules do not apply to the OCGS certification because AmerGen Is not performing such a regulated activity and has no plans to perform such a regulated activity as a result of license renewal.

The following sections address specific provisions of the New Jersey Coastal Zone Management Rules and AmerGen's basis for its conclusions regarding applicability and consistency. Subchapter 1 of the rules deals with general information (e.g., purpose, jurisdiction, definitions) and Subchapter 2 is reserved, so the discussion begins with Subchapter 3,

POLICY ANALYSIS

Subchapter 3 – Special Areas

Rule Section 7:7E-3.1 groups Subchapter 3 requirements by the following categories of Special Areas:

- Special Water Areas, NJAC 7:7E-3.2 through 3.15
- Special Water's Edge Areas, NJAC 7:7E-3.16 through 3.32
- Special Land Areas, NJAC 7:7E-3.33 through 3.35
- Coastwide Special Areas, NJAC 7:7E-3.36 through 3.49

The following paragraphs address each category.

Special Water Areas, NJAC 7:7E-3.2 through 3.15

OCGS is located on approximately 800 acres in Lacey Township, Ocean County, New Jersey. The OCGS property lies between the South Branch of Forked River to the north, and Oyster Creek to the south. The plant withdraws and discharges water from Barnegat Bay via the South Branch of Forked River and Oyster Creek, respectively. OCGS operations have the potential to affect Special Water Areas of Barnegat Bay, the South Branch of Forked River, and Oyster Creek. The state regulates these effects through the OCGS New Jersey Environmental Pollutant Discharge Elimination System (NJPDES) permit. AmerGen is in compliance with its NJPDES permit and has no plans that would change these effects as a result of license renewal.

7:7E-3.2 Shellfish habitat

Hardshell clam (*Mercenaria mercenaria*) populations in Barnegat Bay declined in the 1960s and 1970s and do not appear to be recovering. However, because Barnegat Bay has a history of natural shellfish production, it is considered a shellfish habitat for the purposes of this document.

AmerGen will construct no docks, piers or mooring in Barnegat Bay. AmerGen will not dredge in Barnegat Bay, and if dredging the existing intake and discharge canals is necessary, the spoils will be disposed at a properly-permitted upland site. OCGS is in compliance with the rules protecting shellfish habitat.

: .:

Land Use Regulation Program, NJ Department Of Environmental Protection January XXX, 2005, Enclosure 1 Page 25 of 33

7:7E-3.3 Surf clam areas

OCGS operations and license renewal involve no development in coastal waters; therefore, these requirements are not relevant.

· · · 1

Prime fishing areas 7:7E-3.4

· · · · ·

. /

1.11.27

•

10 11 21

Oyster Creek, from Route 9 to Barnegat Bay, is a popular recreational fishing area as is the Bay itself. AmerGen will not mine sand or gravel from the creek and is not proposing additional development; therefore, OCGS is in compliance with the rules protecting prime fishing areas.

Finfish migratory pathways 7:7E-3.5

Finfish seasonally migrate up and down Barnegat Bay. OCGS has no physical barriers that impede fish migrations in Barnegat Bay. The thermal plume entering the Bay from Oyster Creek has temperatures a few degrees Fahrenheit above the ambient temperature of the Bay, and does not interfere with any fish migrations. These conditions will remain throughout the license renewal term. No development that would decrease water quality in the creeks or Barnegat Bay will occur as a result of license renewal. OCGS is in compliance with the rules protecting finfish migrations.

Submerged vegetation habitat 7:7E-3.6

Barnegat Bay supports submerged vegetation. Prohibited activities are all related to development. As stated previously, AmerGen will not develop any part of the OCGS property as a result of license renewal. OCGS is in compliance with the rules protecting submerged vegetation habitat.

7:7E-3.7 Navigation channels

No OCGS operations affect any navigation channels; therefore, these requirements are not relevant.

Canals 7:7E-3.8

Canals are navigation channels for boat traffic through land areas. No navigation channels occur on AmerGen property, and the transmission line does not cross any canals; therefore, these requirements are not relevant.

inlets and the second secon Second 7:7E-3.9 and the second

AmerGen property is not contiguous to and does not include an inlet; therefore, these requirements are not relevant.

. 7:7E-3.10 Marina Moorings

AmerGen has no marina moorings; therefore, these requirements are not relevant.

A AND STATES 7:7E-3.11 Ports

AmerGen has no ports; therefore, these requirements are not relevant.

Page 26 of 33

7:7E-3.12 Submerged infrastructure routes

AmerGen has no submerged infrastructure, nor any property adjacent to submerged infrastructure routes; therefore, these requirements are not relevant.

7:7E-3.13 Shipwreck and artificial reef habitats

AmerGen has no shipwrecks or artificial reef habitats; therefore, these requirements are not relevant.

7:7E-3.14 Wet borrow pits

AmerGen has no wet borrow pits; therefore, these requirements are not relevant.

7:7E-3.15 Intertidal and subtidal shallows

AmerGen has no property with intertidal or subtidal shallows; therefore, these requirements are not relevant.

Special Water's Edge Areas, NJAC 7:7E-3.16 through 3.32

Rule Section 7:7E-3.1 divides Special Water's Edge Areas requirements into the following subcategories:

Oceanfront and Raritan and Delaware Bayfronts, NJAC 7:7E-3,16 through 3.19 - These requirements are not applicable to OCGS certification because OCGS is not located on, and does not affect, the oceanfront or Raritan and Delaware Bayfronts.

Barrier and Bay Islands, NJAC 7:7E-3.20 and 3.21 - These requirements are not applicable to OCGS certification because OCGS is not located on, and does not affect, barrier or bay islands.

<u>Coastwide Special Water's Edge Areas, NJAC 7:7E-3.22 through 3.32</u> - OCGS operations have the potential to affect Coastwide Special Water's Edge Areas of Barnegat Bay, the South Branch of Forked River, and Oyster Creek. AmerGen has no plans that would change these effects as a result of license renewal.

7:7E-3.22 Beaches

Beaches are located at the eastern edge of Finninger Farms property. AmerGen has no plans that would affect these beaches as a result of license renewal.

7:7E-3.23 Filled water's edge

AmerGen has no filled water's edges; therefore, these requirements are not relevant.

7:7E-3.24 Existing lagoon edges

AmerGen has no existing lagoon edges; therefore, these requirements are not relevant.

7:7E-3.25 Flood hazard areas

Neither Oyster Creek nor the South Branch of the Forked River is identified as a flood hazard area in NJAC 7:13 Rules Governing Flood Hazard Areas; therefore, these requirements are not relevant.

7:7E-3.26 Reserved

7:7E-3.27 Wetlands

Vernal habitat mapping by Rutger's Center for Remote Sensing and Spatial Analysis indicates a small vernal pool between the Administration area's parking lot and Route 9. The pool has not been surveyed to determine if it meets NJDEP criteria for exceptional resource wetlands; however, AmerGen evaluated the rules for protection of wetlands.

As stated previously, AmerGen will not develop additional facilities at OCGS as a result of license renewal. AmerGen properly disposes of all solid and liquid wastes generated at the facility. OCGS is in compliance with wetland protection rules. The transmission line crosses several creeks and associated wetlands. FirstEnergy, which owns the transmission line, follows accepted procedures for the control of vegetation in wetlands.

7:7E-3.28 Wetlands buffers

The small vernal pool on AmerGen property has been surveyed for the presence / absence of protected species and a buffer was established. AmerGen will not develop any undeveloped land as a result of license renewal.

7:7E-3.29 and 7:7E-3.30 Reserved

7:7E-3.31 Coastal bluffs

AmerGen property has no coastal bluffs; therefore, these requirements are not relevant.

7:7E-3.32 Intermittent stream corridors

AmerGen property has no intermittent streams; therefore, these requirements are not relevant.

Special Land Areas, NJAC 7:7E-3.33 through 3.35

OCGS operations have the potential to affect Special Land Areas within the OCGS site boundary and within OCGS transmission line corridors. AmerGen has no plans that would change these effects as a result of license renewal.

1 . .

7:7E-3.33 Farmland conservation areas

AmerGen property includes the 650-acre old Finninger Farm site, once an active beef cattle farm, east of Route 9. AmerGen maintains the undeveloped property as a buffer and has no plans to develop it as a result of license renewal. AmerGen is in compliance with the rules governing farmland conservation areas.
Land Use Regulation Program, NJ Department Of Environmental Protection January XXX, 2005, Enclosure 1

Page 28 of 33

7:7E-3.34 Steep slopes

AmerGen property has no steep slopes; therefore, these requirements are not relevant.

7:7E-3.35 Dry borrow pits

AmerGen has no dry borrow pits; therefore, these requirements are not relevant.

Coastwide Special Areas, NJAC 7:7E-3.36 through 3.49

OCGS operations have the potential to affect Coastwide Special Areas within the OCGS site boundary and within OCGS transmission line corridors. AmerGen has no plans, as a result of license renewal activities, that would change any of these current effects.

7:7E-3.36 Historic and archaeological resources

Neither historic or pre-historic archaeological sites, nor any historic or archaeological resources have ever been identified on AmerGen property or the transmission line corridor; therefore, these requirements are not relevant.

7:7E-3.37 Specimen trees

AmerGen property has no specimen trees; therefore, these requirements are not relevant.

7:7E-3.38 Endangered or threatened wildlife or plant species habitats

AmerGen property has no endangered or threatened wildlife or plant species habitats; therefore, these requirements are not relevant.

7:7E-3.39 Critical wildlife habitats

AmerGen property has no critical wildlife habitats; therefore, these requirements are not relevant.

7:7E-3.40 Public open space

AmerGen property includes no public open space; therefore, these requirements are not relevant.

7:7E-3.41 Special hazards area

OCGS uses hazardous substances as defined by NJSA 58:10-23.11b-k, including substances that are corrosive, ignitable, flammable or radioactive. As such OCGS has an evacuation zone out to 10 miles from the OCGS. Therefore these rules are relevant.

Development within the special hazards area must include appropriate mitigating measures to protect public health and safety. OCGS maintains warning sirens, publishes and provides to the community information on what to do in the event of an emergency at the facility, trains first responders, and provides input to an evacuation plan updated with the most recent census and traffic data. For these reasons OCGS is in compliance with these rules.

1.

Land Use Regulation Program, NJ Department Of Environmental Protection January XXX, 2005, Enclosure 1 Page 29 of 33

7:7E-3.42 Excluded Federal lands

No excluded Federal lands are adjacent to the AmerGen property. These requirements are not relevant.

7:7E-3.43 Special urban areas

These requirements apply to development in special urban areas and hence, do not apply to OCGS.

7:7E-3.44 Pinelands National Reserve and Pinelands Protection Area

Lacey Township is partially in the Pinelands National Reserve Area. Rules in this subsection apply to development and the discharge of dredged materials into freshwater wetlands, neither of which OCGS will pursue during the license renewal term. The requirements are not relevant.

7:7E-3.45 Hackensack Meadowlands District

Ocean County is not part of the Hackensack Meadowlands district and therefore these rules are not relevant.

7:7E-3.46 Wild and Scenic Rivers corridors

OCGS is not part of the Great Egg Harbor River or the Maurice River watersheds (the only wild and scenic rivers in New Jersey) and thus, the requirements are not relevant.

7:7E-3.47 Geodetic control reference marks

No geodetic control reference mark is located on AmerGen property. Therefore, the requirements are not relevant.

7:7E-3.48 Hudson River Waterfront Area

Ocean County is not part of the Hudson River waterfront area; therefore, the requirements are not relevant.

1.1.

7:7E-3.49 Atlantic City

OCGS is not located in Atlantic City; therefore, these requirements are not relevant.

Subchapter 3A – Standards for Beach and Dune Activities

Beaches are located at the eastern edge of Finninger Farms. AmerGen has no plans that would affect this resource as a result of license renewal.

Subchapter 3B – Information required in tidal wetland and intertidal and subtidal shallows proposals

Tidal wetlands are located in the eastern part of Finninger Farms property. AmerGen has no plans that would affect this resource as a result of license renewal.

Land Use Regulation Program, NJ Department Of Environmental Protection January XXX, 2005, Enclosure 1

Page 30 of 33

<u>Subchapter 3C – Standards for conducting and reporting the results of an endangered or</u> <u>threatened wildlife or plant species habitat impact assessment and/or an endangered or</u> <u>threatened wildlife species habitat evaluation</u>

No endangered or threatened plant or animal species is known from the AmerGen property. The property does not abut habitats mapped as endangered or threatened wildlife habitats. Therefore, the requirements of this subsection are not relevant.

Subchapter 4 - General Water Areas

OCGS withdraws cooling water from Barnegat Bay via the South Branch of Forked River and discharges water to Barnegat Bay via Oyster Creek. Section 7:7E-4.1(b)iii 5 describes medium rivers, creeks and streams as having watersheds of less than 1,000 square miles. Section 7:7E-4.1(b)iii 7 describes semi-enclosed and back bays. Forked River and Oyster Creek are medium rivers, and Barnegat Bay is a back bay. Requirements for General Water Areas apply.

7.7E-4.2 Aquaculture

AmerGen does not practice aquaculture at OCGS. These requirements are not relevant.

7.7E-4.3 Boat Ramps

AmerGen maintains a private boat ramp on the north shore of Oyster Creek. It is constructed of metal plates and is used to launch boats for periodic biological and water quality sampling by AmerGen environmental staff. A garbage can is provided at the ramp. OCGS is in compliance with the rules governing boat ramps.

7.7E-4.4 Docks and piers for cargo and commercial fisheries

AmerGen does not maintain any docks or piers. These requirements are not applicable. AmerGen does maintain a metal bulkhead on the south shore of Oyster Creek, Immediately downstream of the Rt. 9 bridge. This was used during construction to deliver large and heavy equipment from barges. Currently Ocean County uses the bulkhead to load artificial reef structures onto barges for transport offshore.

7.7E-4.5 Recreational docks and plers

AmerGen does not maintain any docks or piers. These requirements are not applicable.

7.7E-4.6 Maintenance Dredging

Three times since the plant began operations, the intake or discharge canals east of Rt. 9 have been dredged to remove accumulated sediments. It is likely that dredging will be required during the license renewal term. Before initiating any dredging, AmerGen would obtain the appropriate permits from the U.S. Army Corps of Engineers and the NJDEP. OCGS is in compliance with the rules governing maintenance dredging.

7.7E-4.7 New Dredging

AmerGen will not dredge a new channel/canal as a result of license renewal. These requirements are not relevant.

••

Land Use Regulation Program, NJ Department Of Environmental Protection January XXX, 2005, Enclosure 1 Page

Page 31 of 33

1. 22. 5

7.7E-4.8 Dredged material disposal

AmerGen has disposed of dredge spoils in a permitted dredge spoils basin on AmerGen property. AmerGen holds an NJPDES storm water discharge permit for the dredge spoils basin and an NJPDES permit to discharge groundwater from the dredge spoils. In addition the Ocean County Soil Conservation District has certified the AmerGen soil erosion and sediment control plan for the upland dredge site. OCGS is in compliance with the rules governing disposal of dredged material.

7.7E-4.9 Solid waste or sludge dumping

This activity is prohibited. AmerGen does not dispose of solid wastes or sludge in a water area.

7.7E-4.10 Filling

AmerGen will not fill any water area as a result of license renewal. These requirements are not relevant.

7.7E-4.11 Mooring

AmerGen will not construct any mooring for the purpose of anchoring a boat as a result of license renewal. These requirements are not relevant.

7.7E-4.12 Sand and gravel mining

AmerGen will not mine sand nor gravel as a result of license renewal. These requirements are not relevant.

7.7E-4.13 Bridges

AmerGen will not construct any bridges as a result of license renewal. These requirements are not relevant.

7.7E-4.14 Submerged pipelines

AmerGen will not construct any submerged pipelines as a result of license renewal. These requirements are not relevant.

7.7E-4.15 Overhead transmission lines

AmerGen will not construct any overhead transmission lines for the purpose of distributing power from the OCGS switchyard as a result of license renewal. These requirements are not relevant.

7.7E-4.16 Dams and Impoundments

AmerGen dammed Oyster Creek to create an emergency fire pond at the time of plant construction, and continues to maintain the fire pond and dam. Oyster Creek naturally is navigable above the pond only to canoes and kayaks, so the dam does not impede navigation. OCGS is in compliance with this requirement.

Land Use Regulation Program, NJ Department Of Environmental Protection January XXX, 2005, Enclosure 1

Page 32 of 33

7.7E-4.17 Outfalls and Intakes

AmerGen has an intake and several outfalls. The uses associated with the intakes and outfalls meet applicable Coastal Zone management rules. OCGS is in compliance with this requirement.

7.7E-4.18 Realignment of water areas

The volume the circulating water pumps draw into the plant at the OCGS intake reversed the flow of the South Branch of Forked River. This environmental impact was identified in the conceptual design phase of the project and was approved by the regulatory agencies prior to construction. The operating parameters of OCGS will not change as a result of license renewal.

7.7E-4.19 Breakwaters

AmerGen has no breakwaters at the OCGS site and will not construct any as a result of license renewal. These requirements are not relevant.

7.7E-4.20 Submerged cables

AmerGen does not have and will not lay any submerged cables to support OCGS operations as a result of license renewal. These requirements are not relevant.

7.7E-4.21 Artificial reefs

AmerGen does not have and will not construct any artificial reefs as a result of license renewal. These requirements are not relevant.

Subchapter 5 – Requirements for impervious cover and vegetative cover for general land areas and certain special areas

This subchapter applies to development, which AmerGen will not undertake during the license renewal term. Therefore, the requirements are not relevant.

Subchapter 6 – General location rules

This subchapter applies to development, which AmerGen will not undertake during the license renewal term. Therefore, the requirements are not relevant.

Subchapter 7 - Use rules

This subchapter applies to development, which AmerGen will not undertake during the license renewal term. Therefore, the requirements are not relevant.

Subchapter 8 - Resource rules

This subchapter applies to development, which AmerGen will not undertake during the license renewal term. Therefore, the requirements are not relevant.

Land Use Regulation Program, NJ Department Of Environmental Protection January XXX, 2005, Enclosure 1

Page 33 of 33

References

• •

•

- New Jersey Department of Environmental Protection. 2004. Coastal Management E.1 Program. Available at http://ww.nj.gov/dep/cmp. Accessed July 19, 2004. 1 * *
- New Jersey Department of Environmental Protection. 2004. Coastal Management E.2 Program; Federal Consistency Available at http://ww.nj.gov/dep/cmp/czm_federal.html. Accessed July 19, 2004.
- New Jersey Department of Environmental Protection. 2004. Land Use Regulation E.3 Program. Available at http://ww.nj.gov/dep/landuse/coast.html. Accessed July 19, 2004.
- New Jersey Department of Environmental Protection. 2004. CAFRA Boundary Line. E.4 Available at http://www.state.nj.us/dep/landuse/coast/coast.html.

1111111111111 . . . • : • . . .

. .; . .

15

. . e

1.1 4.10 , · ١., . . . • · · ·

11

3, 114, 22 A 11 . ·* . 1996 - 197 20 ٠. -1. 11 m 1 1 2 d a c 1. 1. 1. 1. C ĩ.:

Oyster Creek Generating Station License Renewal Application

Environmental Report Appendix E Coastal Zone Consistency Certification

Keith R. Jury, Director

200 Exclon Way Kennett Square, PA 19348

Licensing and Regulatory Affairs AmerGen Energy Company LLC



Richard J. Codey Acting Governor State of New Jersey

Department of Environmental Protection Land Use Regulation Program P.O. Box 439, Trenton, New Jersey 08625-0439 Telephone # (609) 292-0060 Fax # (609) 292-8115 or (609) 777-3656 www.state.nj.us/deplanduse Bradley M. Campbel Commissioner

March 31, 2005

LICENSING DEPARTMENT

APR 7 2005

REFER TO:

RE: Request for Necessary Data and Information for a Federal Consistency Determination File No. 1500-02-0004.4 CDT050001 Applicant: AmerGen Energy Company LLC Project: Oyster Creek Nuclear Generating Station Location: Lacey Township, Ocean County

Dear Mr. Jury:

Please be advised the Program received the above referenced request on January 21, 2005. As the Program did not issue a deficiency letter within 30 days of the date of receipt, the Program under 15 CFR 930.60(A)(1)(ii) is advising the applicant that the State agency's review has begun, and that the certification or information deficiencies must be cured by the applicant during the State's review period. A decision on this request is due on or before July 21, 2005.

Request for Necessary Data and Information.

The Program requests the following three (3) items under the enforceable Coastal Zone Management Rules (Rules) at N.J.A.C. 7:7E-1.5(a)li, 1viii, 6.2, and 8.2.

1. Submit the data and information and an analysis of that data and information to support the statement on page 4 under the section identified as "Entrainment of fish and shellfish in early life stages" that "Results indicate that the water quality of the Bay, which had been in decline, is recovering and now supports a healthy fish population."

New Jersey is an Equal Opportunity Employer Recycled Paper

Keith R. Jury File No. 1500-02-0004.4 CDT050001

2.

- -3.÷

> 1.1 · · · ·

> > 4

5.

6.

Page 2

Submit the data and information and an analysis of that data and information to support the statement on page 4 under the section identified as "Entrainment of fish and shellfish in early life stages" that "... the impacts of entrainment during current operations are small ... ". Please quantify the term "small" in the previous sentence using the data and information to be submitted.

1.14

Submit the data and information and an analysis of that data and information to support the statement on page 4 under the section identified as "Impingement of fish and shellfish" that "... impacts of impingement during current operations are small ... ". Please quantify the term "small" in the previous sentence using the data and information to be submitted.

Submit the data and information and an analysis of that data and information to support the statements on page 4 under the section identified as "Impingement of fish and shellfish" that the Ristroph traveling screens currently being used reduces the number of fish impinged and impingement mortality.

Submit the data and information and an analysis of that data and information to support the statement on page 5 under the section identified as "Heat shock" that "...impacts of heat shock during current operations are small ...". Please quantify the term "small" in the previous sentence using the data and information to be submitted.

10 12

· · ·

- 3 · · · · · • The Program requests the following item under the enforceable Coastal Zone Management Rules (Rules) at N.J.A.C. 7:7E-1.5(a)1i, 3.38, and 6.2.

Cer in the

Please submit a copy of the results of the NRC's requested re-initiation of Endangered Species Act Section 7 consultation with the National Marine Fisheries Service (NMFS) discussed on page 5 and 7.

The Program requests the following items under the enforceable Coastal Zone Management Rules (Rules) at N.J.A.C. 7:7E-1.5(a) liv, 1viii, 3.41, and 6.2.

Submit the data and information and an analysis of that date and information to 7. support the statements on page 6 under the section identified as "Electromagnetic fields", acute effects (electric shock).

Keith R. Jury File No. 1500-02-0004.4 CDT050001

8. On page 28, the submittal advises "OCGS uses hazardous substances as defined by N.J.S.A. 58:10-23.11b-k, including substances that are corrosive, ignitable, flammable or radioactive." Please submit a listing of those substances and any available data showing the extent and concentrations of their dispersal in to the environment. If any of the substances are being released in amounts lethal to organisms, please list those substances and the organisms potentially impacted and any data or information on the generating station's impact on those organisms.

The Program requests the following items under the enforceable Coastal Zone Management Rules (Rules) at N.J.A.C. 7:7E-1.5(a)1i, 3.5, and 6.2.

- 9. Submit the data and information, including but not limited to the species and numbers of fish killed during cold weather shut downs, and an analysis of that date and information to support the statements on page 25 under the section identified as "Prime Fishing Areas" that supports the statement that "The thermal plume entering the Bay from Oyster Creek has temperatures a few degrees Fahrenheit above the ambient temperature of the Bay and does not interfere with any fish migrations." In addition, please include the date of and ambient bay temperature and plume temperatures at the time of each shut down event.
- 10. Submit data and information and an analysis of that data and information to support the statement on page 25 under the section identified as "Prime Fishing Areas" with regard to the impingement of alewife or river herring (Alosa pseudoharengus), blueback herring (Alosa aestivalis), American shad (Alosa sapidissima), striped bass (Monrone saxatilis), Atlantic sturgeon (Acipenser oxyrhynchus), Shortnose sturgeon (Acipenser brevirostrum) and American eel (Anguilla rostrata) that "OCGS is in compliance with the rules protecting finfish migrations".

The Program requests the following items under the enforceable Coastal Zone Management Rules (Rules) at N.J.A.C. 7:7E-1.5(a)lv and 7:7E-8.11.

11. The submittal does not discuss public access to the waterfront. Please identify any public access to the waterfront provided on property owned by AmerGen. If no public access to the waterfront is available, can public access be provided to Oyster Creek, Forked River or Barnegat Bay through the Finninger Farm? If AmerGen's response is negative, please detail why public access to the waterfront can not be provided.

Page 3

Keith R. Jury File No. 1500-02-0004.4 CDT050001

Page 4

With regard to the data and information requested above, the Program has knowledge that data and information were gathered by Ichthyological Associates (IA) and Environmental Associates (EA) in the 1970s and 1980s. The Program assumes that you will utilize those studies and all other subsequent 316B studies to respond to the above requests.

Should you have any questions or wish to discuss this matter further, please do not hesitate to contact me at the above address or at 609-984-0288.

. . .

Sincerely,

· • • •

Andrew Heyl, Section Chief Bureau of Coastal Regulation

. -

c. Andrew Kugler, Chief of Environmental Section, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Agency, One White Flint, 11555 Rockville Pike, Rockville, Maryland 20555

Oyster Creek Generating Station License Renewal Application

Page E-41

Environmental Report Appendix E Coastal Zone Consistency Certification



AmerGen Energy Company, LLC 200 Exelon Way Kennett Square, PA 19348

June 15, 2005 2130-05-20112

Mr. Andy Heyl Land Use Regulation Program Bureau of Coastal Management NJ Department of Environmental Protection 501 East State Street Trenton, NJ 08625-0439

Subject: Reponse to Request for Necessary Data and Information for a Federal Consistency Determination File No. 1500-02-0004.4 CDT050001 Project: Oyster Creek Generating Station

www.exeloncorp.com

Dear Mr. Heyl:

On January 20, 2005, AmerGen Energy Company, LLC (AmerGen) submitted the Federal Coastal Zone Management Act consistency certification in support of the Oyster Creek Generating Station (OCGS) license renewal application to the New Jersey Department of Environmental Protection (NJDEP) Land Use Regulation Program for review. On March 31, 2005, NJDEP Land Use Regulation Program requested necessary data and information to support statements made by AmerGen in the consistency determination. The attached discussions address each of the requests for necessary data.

After your office reviews the attached information, AmerGen requests a letter concurring with the previously transmitted Federal Consistency Certification for Federal Permit and License Applicants. AmerGen will include a copy of this letter and your response in the license renewal application that we submit to the Nuclear Regulatory Commission.

If you have any questions or require any additional information, please contact Bill Maher at (610) 765-5939.

Sincerely

Pamela B. Cowan / Director - Licensing & Regulatory Affairs AmerGen Energy Company, LLC

NJ DEP, Land Use Regulation Program June 15, 2005 Page 2 Enclosure: Response to Request for Necessary Data and Information for a Federal Consistency Determination CC: Karen Tuccillo, NJ BNE P. S. Tam, USNRC, Senior Project Manager, NRR File No. 05100

Enclosure

Response to Request for Necessary Data and Information for a Federal Consistency Determination

June 15, 2005	Enco 1 -607
	Page 1 of 27
The program requests the following three (3) Items un	der the enforceable Coastal
Zone Management Rules (Rules) at N.J.A.C. 7:7E-1.5(a	a)1i, 1viil, 6.2 and 8.2.
 Submit the data and information and an analysis o to support the statement on page 4 under the secti "Entrainment of fish and shellfish in early life stag that the water quality of the Bay, which had been in now supports a healthy fish population." 	f that data and information ion identified as es" that "Results indicate n decline, is recovering and
The Barnegat Bay Estuary Program Characterization Rep	or (BBEP 2001) indicated that
the priority problems in the estuary were: (1) water supply	and water quality, including
the issues of contaminated stormwater and runoff, nutrien	t loading, pathogen
contamination, groundwater contaminations, and future we	ater supply deficits; (2) habitat
loss and alteration; (3) fisheries decline; and (4) human ac	ctivities and competing uses.
The Barnegat Bay Final Comprehensive Conservation and	<i>d Management Plan</i> (CCMP),
completed in May 2002, laid out an approach for restoring	the Barnegat Bay ecosystem
that was keyed to these priorities (BBEP 2002). It contain	is numerous "action plans" for
improving water quality, slowing habitat loss, restoring ecc	plogical communities, and
balancing the needs of competing users. It also contains	a Monitoring Program Plan
and a framework for tracking progress of the various prog	ram Initiatives.
The Barnegat Bay Estuary Program and its cooperating ag	gencies have already had a
number of successes with regard to water quality. The CO	CMP singled out degraded
storm water management (retention or detention) basins a	as sources of non-point source
pollution and made "retrofit of stormwater basins to increa-	se infiltration and recharge of
rainfall runoff" an Action Item. (BBEP 2002, Chapter 5, Te	able 5-1, Action Item 5.2).
Cooperating county, state, and federal agencies led by the	a Ocean County Planning
Board identified three stormwater basins in the County tha	at were no longer functioning
as designed and restored them, amending soils as necess	sary to lower pH, adding
compost to encourage growth of soil organisms, seeding t	the basins with drought-tolerant
native grasses, and planting native shrubs and trees (EPA	A 2003a). This pilot project
demonstrated that stormwater basins could be quickly and	d cost-effectively restored to
create living systems that effectively treat stormwater while	e creating aesthetically
pleasing areas that provide wildlife habitat. As more and r	more stormwater basins are
retrofitted, the volume of polluted stormwater entering the	Bay will decrease.
Another goal of the BBEP has been the reduction of bacte	rial contamination in Barnegat
Bay. Studies in the 1980s documented only 4 sewage pur	mp-out facilities in all of coastal
New Jersey (EPA 2003b). Since that time, long-term colla	aborative efforts by BBEP
partners have resulted in the installation of more than 70 m	narine sewage pump-out
lacilities in Barnegat Bay and its tributaries. Funding for the	he pump-out facilities was
provided by the New Jersey Clean Vessel Program, which	in turn is funded by the U.S.
Fish & Wildlife Service (Wallop-Breaux monies) and the N	JDEP. The Clean Vessel
Program and other initiatives have reduced the amount of	bacteria entering the Bay and
improve water quality in many Ocean County swimming an	reas.
One of the specific goals of the CCMP was the establishm	ent of a "No Discharge Zone"
o make the discharge of raw sewage from boats illegal. S	Section 312 of the Clean Water
Act provides for these zones. New Jersey DEP petitioned	the EPA in March 2002 to

.

,

• .

ć

Page 2 of 27

make Barnegat Bay a No Discharge Zone. The EPA determined that the Bay's 66 stationary pump-out facilities (many at marinas) and three pump-out vessels were adequate to accommodate the 28,000 recreational vessels using the Bay. On June 12, 2003 the EPA announced that Barnegat Bay had adequate facilities for the safe and sanitary removal and treatment of sewage from all vessels and that the Bay had been officially designated a No Discharge Zone (Federal Register, Volume 68, No. 113, June 12, 2003, pg 35214-35215. Available online at http://access.goo.gove/su_docs/federal/a030612c.html. Accessed 4/22/05).

Another indication of improving water quality in Barnegat Bay is the opening of shellfish beds over the last 4 to 5 years. In late 2000, 5,132 acres in Barnegat Bay previously closed to shellfishing were opened to shellfish harvesting. At that time, State Environmental Protection Commissioner Bob Shinn declared that, "The continued expansion of our shellfish harvesting waters is a clear and reliable yardstick of our progress in improving water quality" (NJDEP News Release dated 11-20-2000). In 2004, another 161 acres of shellfish beds in Barnegat Bay were upgraded, while 85 acres were downgraded, a net increase of 76 acres open to shellfishermen (NJDEP News Release dated 2-20-2004).

The available evidence suggests that Barnegat Bay, once in a state of decline, is beginning to recover. Water quality appears to be improving, benefiting from a number of county, state, and federal initiatives, as well as the work of countless volunteers and several non-profit organizations.

Anecdotal information suggests that many finfish populations are healthy and sport fishing for several species (e.g., striped bass, weakfish, bluefish) in the Bay is excellent (Flyfishing Connection 1999; Fishing and Hunting News 2004; Haughey 2004). One important forage species that is not faring well in Barnegat Bay, the Atlantic menhaden, is in a state of decline up and down the mid-Atlantic and south Atlantic coast. Landings of menhaden in New Jersey increased in the late 1980s and early 1990s, peaking in 1994 at 17,386 metric tons, but have declined steadily since that time, falling to 9,276 metric tons in 2003 (NMFS 2005). The reduction in Atlantic coast menhaden stocks has been attributed to poor recruitment, which may be the result of water quality degradation along the rapidly developing Eastern Seaboard, and to periodic disease outbreaks and mass die-offs in adults, which may also be exacerbated by water quality problems (AMTC 2001; CBEF 2004).

The National Marine Fisheries Service (NMFS) maintains records on recreational landings of important species, including many of the species sought by anglers in Barnegat Bay. These data are organized by region (e.g., north Atlantic, mid-Atlantic, south-Atlantic) and by state, but are not available by watershed or waterbody. Most of the species in question range up and down the mid-Atlantic coast and use Barnegat Bay seasonally; therefore, data for the state of New Jersey are assumed to reflect the state of Barnegat Bay populations.

The NMFS data indicate that striped bass landings in New Jersey reached an all time low in the 1980s, but have exceeded 1,000,000 fish in every year since 1999 (NMFS 2005). In 2004, an estimated 1,760,506 striped bass weighing more than 4.6 million

Enclosure				Page 3 of 27
June 15, 2005			•	
NJ DEP, Land Use Regulation Program	,	•		

pounds were landed in New Jersey. These data, along with widely circulated stories of anglers and outdoor writers, indicate that striped bass fishing along the New Jersey shore and in Barnegat Bay is as good today as it was in the 1960s and 1970s, if not better.

Other species sought by anglers in Barnegat Bay include bluefish, weakfish, and summer flounder. Based on New Jersey recreational landings, bluefish numbers in recent years have been consistently high, more than 3,000,000 fish per year over the 2000 through 2004 period (NMFS 2005). In 2004 an estimated 4,151,920 bluefish weighing 3.3 million pounds were landed by N.J. fishermen. In the 1990s, bluefish landings ranged from 1,217,527 (1993) to 3,557,337 (1991) fish per year. These high bluefish landings are consistent with angler and outdoor writer reports of excellent fishing in Barnegat Bay. Based on anecdotal information, fishing for weakfish is excellent in Barnegat Bay. Data on weakfish landings in New Jersey, however, suggest that weakfish numbers peaked over the 1995-1996 period and have generally declined over the 1997-2004 period (NMFS 2005). Summer flounder landings have been high since 1990, ranging from 3 million to 13 million fish per year (NMFS 2005). No clearcut trend in landings are apparent. In 2004, an estimated 8.8 million summer flounder were landed by recreational fishermen (NMFS 2004).

Page 4 of 27

2. Submit the data and information and an analysis of that data and information to support the statement on page 4 under the section identified as "Entrainment of fish and shellfish in early life stages" that "...the impacts of entrainment during current operations are small..." Please quantify the term "small" in the previous sentence using the data and information to be submitted.

The following material is from the 1984 monograph *Ecology* of *Barnegat Bay, New Jersey*, which was an attempt by a diverse group of utility biologists, academics, and resource agency scientists to assemble and synthesize several decades of research on Barnegat Bay's water quality and aquatic communities.

"Numerous investigations have been performed in Forked River, Oyster Creek, and Barnegat Bay to assess the effects of thermal discharges, impingement, and entrainment of the Oyster Creek Nuclear Generating Station on aquatic communities. Rutgers University scientists studied the bay and adjacent tributaries from 1965 through 1980, and this work produced 9 annual reports, 12 masters theses, and 5 doctoral dissertations. In 1975, Ichthyological Associates, a consultant for the Jersey Central Power and Light Company, initiated investigations of plankton and fish populations and impacts of station operation on these populations. Some of these investigations were continued to 1984...* (page 327, Ecology of Barnegat Bay, New Jersey)

"A five-volume 316(a) and (b) Demonstration report prepared by the Jersey Central Power & Light Company for the New Jersey Department of Environmental Protection...summarized the information and conclusions drawn by these investigations...Conclusions of the report indicate that, while Impacts or aquatic communities have occurred because of the cooling system of the station, these impacts generally are localized to Oyster Creek." (emphasis added) (page 327, *Ecology of Barnegat Bay, New Jersey*)

"...some fishes and macroinvertebrates are affected by impingement on intake screens of the station....Population surveys of fishes and macroinvertebrates indicate that the standing crop lost through impingement was less than 10 percent for species in central Barnegat Bay. No evidence exists that losses of organisms through impingement on intake screens have had a discernible effect on invertebrate and fish communities in Barnegat Bay." (emphasis added) (page 331, Ecology of Barnegat Bay, New Jersey)

"To mitigate future impingement effects, the conventional traveling screens (0.95 cm mesh) on the intake structure of the station were replaced starting in 1979 through 1983 with Ristroph screens composed of a continuously rotating traveling design modified with a low pressure spray wash and fish recovery and return system. The Ristroph screens contain water-tight fish buckets which collect impinged organisms washed from the screens and return them to the discharge canal via a sluiceway. Experimental testing...indicated that the total fish mortality was reduced from 48% to 24%." (page 331, *Ecology of Barnegat Bay, New Jersey*)

NJ DEP, Land Use Regulation Progra	m '
June 15, 2005	
Enclosure	

Page 5 of 27

"Effects of operation of the Oyster Creek Nuclear Station on aquatic communities appear to be restricted to the discharge canal and Oyster Creek. The species composition, abundance, and distribution of phytoplankton, zooplankton, benthic invertebrates, and fishes in these two regions (areas) are substantially different than Barnegat Bay. Fluctuations within Bay communities appear to be due to the natural population dynamics of constituent populations and not due to operation of the station. Aquatic communities in Barnegat Bay parallel those of other mid-Atlantic estuaries which are unaffected by operations of electric generating stations." (emphasis added) (page 331, *Ecology of Barnegat Bay, New Jersey*)

As noted above, extensive data on impingement and entrainment were submitted to NJDEP as part of a Section 316 Demonstration. These data were evaluated by NJDEP and its contractor, Versar. Versar (1988) used three independent population models to assess the impact of impingement and entrainment losses at OCGS: the Equivalent Adult Model, the Production Foregone Model, and the Spawning/Nursery Area of Consequences Model. In each case, Versar/NJDEP concluded that impacts, although non-trivial, were not sufficient to de-stabilize populations. Having evaluated the data as submitted by Jersey Central Power & Light/General Public Utilities Nuclear (GPUN) and having conducted its own analysis employing different assumptions and analytical methods, NJDEP concluded that:

"...the Department has determined that the avoidance of heated areas, impingement and entrainment impacts of the Station do not present an unacceptable, substantial long-term population and/or ecosystem impacts and, in conjunction with limitations generally reflecting current operations, will assure the protection and propagation of a balanced Indigenous population." (OCGS NJPDES Fact Sheet, June 30, 1994, page 71)

The Barnegat Bay Estuary Program, a non-profit environmental organization, reviewed impingement and entrainment studies conducted at OCGS in the 1970s and 1980s in its (2001) *Barnegat Bay Characterization Report*. The author(s) of the BBEP report note that;

"despite the large numbers of eggs, larvae, and small life forms of Barnegat Bay organisms lost via in-plant passage at the OCNGS, these losses have not resulted in detectable impacts on blotic communities in Barnegat Bay. Effects of operation of the OCNGS on aquatic communities appear to be restricted to the discharge canal and Oyster Creek."

For its certification to the U. S. Nuclear Regulatory Commission (NRC), AmerGen will use the NRC definition of "small" in characterizing environmental impacts of OCGS license renewal 10 CFR 51 Subpart A, appendix B, Table B-1, Footnote 3). Page 3 of the certification provides the NRC definition of "small," which states in part the following:

Small – For the issue, environmental effects are not detectable or are so small that they will neither destabilize nor noticeably alter any Important attribute of the resource.

Page 6 of 27

The NRC definition is qualitative, and AmerGen has not quantified the term "small." It is AmerGen's understanding, however, that regardless of whether the Impact is small, at issue is whether the impact is consistent with enforceable provisions of the state's federally approved coastal zone management program. As AmerGen indicated in the certification text, New Jersey regulates OCGS entrainment impacts through its New Jersey Pollutant Discharge Elimination System (NJPDES) program.

To the best of AmerGen's knowledge, OCGS is in compliance with its NJPDES permit. Regulatory and permitting requirements regarding environmental impact control may change during the remainder of the OCGS current NRC license term or during the license renewal term. However, AmerGen is committed to complying with changes to enforceable provisions of the state's federally approved coastal zone management program, and the state has the authority to enforce compliance. These factors form the basis for the AmerGen consistency certification.

Page 7 of 27

3. Submit the data and information and an analysis of that data and information to support the statement on page 4 under the section identified as "impingement of fish and shellfish" that "...the impacts of impingement during current operations are small..." Please quantify the term "small" in the previous sentence using the data and information to be submitted.

As noted in the response to Question 2, studies of impingement and entrainment conducted by Jersey Central Power & Light and GPUN and subjected to considerable scrutiny (including re-analysis by NJDEP's third party reviewer, Versar) indicate that impingement and entrainment losses, which are, for some species, relatively high, do not "present unacceptable, substantial, long-term population or ecosystem impacts." Versar scientists determined that the impact of impingement at OCGS was so small that "the losses due to impingement at the Oyster Creek Generating Station were of no consequence to the [Section 316(b) compliance determination" (Summers et al. 1989, pg. VI-6). Species with relatively high losses (e.g., opossum shrimp, sand shrimp, bay anchovy) are common forage species whose abundance tends to fluctuate widely between years depending on environmental conditions and Intensity of predation. As noted in the Fact Sheet for the 1994 OCGS NJDPDES permit (page 70), "the effects of these losses on the Barnegat Bay food web are small."

As discussed earlier, the Barnegat Bay Estuary Program, a non-profit environmental organization, reviewed Impingement and entrainment studies conducted at OCGS in the 1970s and 1980s in its (2001) *Barnegat Bay Characterization Report.* The BBEP author(s) conclude that:

..."no evidence exists that losses of organisms through impingement on the intake screens have had a discernible effect on invertebrate and fish communities in the bay."

Most organisms impinged in these studies were either invertebrates (e.g., blue crab, sand shrimp, grass shrimp) or small, schooling (forage) fish (e.g., bay anchovy, Atlantic menhaden, Atlantic silverside).

See the response to Question 2 for a discussion of the NRC definition of "small" and AmerGen's use of the term. To the best of AmerGen's knowledge, OCGS is in compliance with its NJPDES permit. Regulatory and permitting requirements regarding environmental impact control may change during the remainder of the OCGS current NRC license term or during the license renewal term. However, AmerGen is committed to complying with changes to enforceable provisions of the state's federally approved coastal zone management program, and the state has the authority to enforce compliance. These factors form the basis for the AmerGen consistency certification.

n and the second sec Second second

۰.

Oyster Creek Generating Station License Renewal Application

Page 8 of 27

4. Submit the data and information and an analysis of that data and information to support the statement on page 4 under the section identified as "Impingement of fish and shellfish" that the Ristroph traveling screens currently being used reduces the number of fish impinged and impingement mortality.

Ristroph traveling screens, which employ water-filled buckets to collect impinged fish, have been installed at power plants from coast to coast. The impinged fish are spilled into a trough or holding tank and then returned to the source waterbody by way of a pipe or sluceway. In its *Technical Development Document for the Final 316(b) Phase I new Facilities Rule* (EPA 821-R-01-036, November 1, 2001. Available on line at http://www.epa.gov/waterscience/316b/technical/technical/dehtml/. Accessed 4/22/05), the EPA describes Ristroph-type screens as a "proven technology" that has been shown to have "good potential for alleviating impingement mortality" (CWIS Technology Fact Sheets, pages A-6 and A-7).

Facilities that have tested or employed Ristroph-type screens in the east include Surry Power Station (Virginia), Indian Point Nuclear Generating Station (New York), Kintigh (aka Somerset) Generating Station in New Jersey, Bowline Point Generating Station (New York), Roseton Generating Station (New York), Danskammer Generating Station (New York), Salem Generating Station (New Jersey), and Calvert Cliffs Nuclear Power Plant (Maryland). In its *Technical Development Document for the Final 316(b) Phase II Existing Facilities Rule* (EPA 821-R-04-007, February 12, 2004. Available on line at <u>http://www.epa.gov/ost/316b/devdoc/final.htm</u>. Accessed 4/22/05), the EPA discusses the relative effectiveness of modified traveling screens of the Ristroph type at 10 U.S. power plants and concludes (p. 4-9) that:

"Studies conducted at steam electric power generating facilities over the last three decades have built a sizable record demonstrating the performance potential for modified traveling screens that include some form of fish return. Comprehensive studies...have shown that modified screens can achieve an increase in the post-impingement survival of aquatic organisms that come under the influence of cooling water intake structures. Hardier species, as might be expected, have exhibited survival rates as high as 100 percent. More fragile species, which are typically smaller and more numerous in the source waterbody, understandably have lower survival rates."

In this context, "hardler species" would include many of the recreationally-important fish and shellfish impinged at OCGS: blue crab, striped bass, white perch, bluefish, croaker, spot, and flounder. More fragile species would include the various small, schooling species that serve as forage for sport fish in Barnegat Bay, with bay anchovy, and Atlantic menhaden being the most important.

Both of the previously-mentioned EPA reports present data that demonstrate the effectiveness of Ristroph screens in reducing impingement mortality.

As noted previously in Response 2, experimental testing in the mid-1980s indicated that total fish mortality at the OCGS cooling water intake structure was reduced from 48% to

NJ DEP, La	nd Use Regulation	n Program	
June 15, 20	05		
Enclosure			

Page 9 of 27

24% after Ristroph screens were installed (page 331, *Ecology of Barnegat Bay, New Jersey*). In the case of some species, however, impingement survival was improved dramatically. Studies by EA Engineering, Science, and Technology (1986; page 4-11) showed that the installation of Ristroph traveling screens at OCGS produced a three-fold increase in the total survival of impinged bay anchovy when compared to previous studies of impingement on the conventional traveling screens.

•

Page 10 of 27

5. Submit the data and information and an analysis of that data and information to support the statement on page 5 under the section identified as "Heat shock" that "...impacts of heat shock during current operations are small..." Please quantify the term "small" in the previous sentence using the data and information to be submitted.

NJDEP hired Versar, Inc. in 1987 to review the Oyster Creek 316 Demonstration (composed of 1974, 1978, and 1986 submittals), evaluate potential impacts of OCGS operation on aquatic communities, and recommend appropriate limitations on cooling water withdrawals and discharge temperatures to meet the intent of Section 316 of the Clean Water Act. With regard to thermal impacts, the 1989 Versar report noted that OCGS effluents were not in compliance with state surface water quality standards (N.J.A.C. 7:9B-1.1 et seq.) but "the potential adverse effects of the thermal discharges on the Barnegat Bay ecosystem were determined and they were localized and had little or no regional significance" (Summer et al. 1989, pg IV-65).

Based on the 316 Demonstration and the Versar study, NJDEP determined that thermal discharges (specifically the avoidance of heated areas) from OCGS did not jeopardize aquatic populations and that water quality-based effluent limitations would be more stringent than necessary to assure the protection and propagation of the balanced indigenous population (community):

"The Department is therefore, granting GPUN's request for a variance pursuant to Section 316(a) and is proposing thermal limitations which will allow the continued operation of the existing once-through cooling system." [OCGS NJPDES Fact Sheet, June 30, 1994, page 71]

These included limitations on effluent temperature (daily maximum of 106°F with 4 circulating water pumps operating), temperature rise across the condenser (daily maximum of 23°F with 4 pumps operating), and heat addition (daily maximum of 5,420 MBTU/hr with 4 pumps operating) (OCGS 1994 NJPDES permit, Outfall Number DSN 001).

Oyster Creek uses dilution pumps to moderate water temperatures in its discharge; in accordance with NPDES permit requirements. Procedures are in place to ensure that a dilution pump is activated when the temperature in Oyster Creek reaches 87°F, as measured four feet below the surface at the Route 9 bridge. If, two hours later, the temperature still exceeds 87°F, a second dilution pump is put into operation. So long as the plant is operated according to plant operating procedures, there is little chance of heat shock in the plant's discharge canal and even less chance of heat shock further downstream, east of the Route 9 bridge. There have been some infrequent instances of fish kills in the plant's discharge canal caused by high temperatures which occurred because dilution pumps were deactivated when temperatures in the discharge reached the (87°F) setpoint established by NJDEP. In addition to paying a substantial fine as a result of a 2002 heat-shock fish kill, AmerGen committed to improved training and increased vigilance where operation of the dilution pumps was concerned. After a lengthy discussion of potential impacts (OCGS NJPDES Fact Sheet, June 30, 1994, page 71), the permit writers conclude that:

NJ DEP, Land Use Regulation Program	•
June 15, 2005	
Enclosure	

Page 11 of 27

"...the Department has determined that the avoidance of heated areas, impingement and entrainment impacts of the Station do not present an unacceptable, substantial long-term population and/or ecosystem impacts and, in conjunction with limitations generally reflecting current operations, will assure the protection and propagation of a balanced indigenous population."

This language, crafted by NJDEP, is consistent with AmerGen's assertion that impacts of heat shock are small, using the criteria employed by the NRC at 10 CFR 51, Appendix B, Table B-1. These criteria state that "environmental effects are so minor that they will neither de-stabilize or noticeably alter any important attribute of the resource."

See the response to Question 2 for a discussion of the NRC definition of "small" and AmerGen's use of the term. To the best of AmerGen's knowledge, OCGS is in compliance with its NJPDES permit. Regulatory and permitting requirements regarding environmental impact control may change during the remainder of the OCGS current NRC license term or during the license renewal term. However, AmerGen is committed to complying with changes to enforceable provisions of the state's federally approved coastal zone management program, and the state has the authority to enforce compliance. These factors form the basis for the AmerGen consistency certification.

Page 12 of 27

The Program requests the following items under the enforceable Coastal Zone Management Rules (Rules) at N.J.A.C. 7:7E-1.5(a)11v, 1viil, 3.41 and 6.2

 Please submit a copy of the results of the NRC's requested re-initiation of Endangered Species Act Section 7 consultation with the National Marine Fisheries Service (NMFS) discussed on page 5 and 7.

As of this date, NMFS has not completed its Biological Opinion, therefore, results are not available. The NRC sent its Biological Assessment (BA) to NMFS on March 29, 2005. A copy of the BA was sent to Mr. Kent Tosch, Chief, New Jersey Department of Environmental Protection, Bureau of Nuclear Engineering. The NRC ADAMS document accession number is ML050900162.

NMFS has, however, recommended that, until the Biological Opinion gets issued, the NRC continue to implement the requirements identified in the July 21, 2001 Opinion and the August 29, 2001 amended ITS. Attachment 6-1 is a copy of this recommendation.

·Page 13 of 27

The Program requests the following items under the enforceable Coastal Zone Management Rules (Rules) at N.J.A.C. 7:7E-1.5(a)1iv, 1vili, 3.41 and 6.2

7. Submit the data and information and analysis of that data and information to support the statements on page 6 under the section identified as "Electromagnetic fields", acute effects (electric shock). .

Attachment 7-1 to this document is the calculation package for the electric shock analysis that was prepared as part of the license renewal application. It includes input data, methodology, and copies of the results of the ACDC analysis, the computer model used to calculate the shock potential.

Page 14 of 27

8. On page 28, the submittal advises "OCGS uses hazardous substances as defined by N.J.S.A.58:10-23.11b-k, including substances that are corrosive, ignitable, flammable or radioactive." Please submit a listing of those substances and any available data showing the extent and concentrations of their dispersal in to the environment. If any of the substances are being released in amounts lethal to organisms, please list those substances and the organisms potentially impacted and any data or information on the generating station's impact on those organisms.

In accordance with the Superfund Amendments and Reauthorization Act, AmerGen reports OCGS hazardous chemical information to the NJDEP, Office of Pollution Prevention and Right to Know. The report for 2004 lists bromotrifluoromethan (fire extinguishing compound), diesel fuel, sodium hypochlorite (water treatment additive), propane, nitrogen liquid, gasoline, lead and sulfuric acid (in batteries), dichlorofluoroethane (air conditioning system fluid), and motor oil. Attachment 8-1 to this document is a copy of the cover letter for the 2004 report. OCGS toxic releases are below the SARA Title III thresholds that would trigger release inventory reporting requirements.

OCGS is a small-quantity generator of hazardous waste and reports waste types and quantities to the NJDEP. OCGS is also subject to NJDEP inspection. Attachment 8-2 of this document is a copy of the cover letter for the recent report that identifies the following as OCGS hazardous waste types: ignitable, corrosive, reactive, various heavy metals, tetrachloroethylene, spent halogenated and non-halogenated solvents, and other discarded commercial chemical products.

The 1994 NJPDES permit required an effluent characterization study. AmerGen (then GPUN) completed the study in 1998 and submitted the results to NJDEP on June 3, 1999. The measure of effluent toxicity that NJDEP and AmerGen rely on for current OCGS discharges is the annual effluent acute toxicity testing required by the NJPDES permit (Attachment 8-3). Results of these tests support the conclusion that releases of chemicals at OCGS do not pose a problem to aquatic organisms. In 2004, the survival of the test organisms met or exceeded that of the control organisms.

The U. S. Nuclear Regulatory Commission (NRC) regulates OCGS use of radioactive materials. AmerGen annually reports OCGS radioactive releases (Annual Radioactive Effluent Release Report) and measurements of radioactivity in the OCGS environment (Annual Radiological Environmental Operating Report). Attachments 8-4 and 8-5 are copies of the cover letters for recent reports. Concurrent with transmittal to NRC, AmerGen provides copies to Kent Tosch, Chief, Bureau of Nuclear Engineering, NJDEP.

The Barnegat Bay Estuary Program, a non-profit environmental organization, evaluated the impacts of the operation of OCGS on the Barnegat Bay Estuary (BBEP 2001). According to the report, the concentration of radionuclides released from OCGS "...is too low to be hazardous to aquatic organisms or humans who consume contaminated seafood from the bay."

OCGS use of corrosive, ignitable, flammable, and other hazardous substances is regulated by the NJDEP. The NRC regulates radioactive substances. To the best of AmerGen's knowledge, OCGS releases no substances in amounts lethal to organisms.

٠.

Oyster Creek Generating Station License Renewal Application

Page 16 of 27

The Program requests the following items under the enforceable Coastal Zone Management Rules (Rules) at N.J.A.C. 7:7E-1.5(a)11, 3.5 and 6.2.

9. Submit the data and information, including but not limited to the species and number of fish killed during cold weather shutdowns, and an analysis of that data and information to support the statements on page 25 under the section identified as "Prime Fishing Areas" [sic] that supports the statement that "The thermal plume entering the Bay from Oyster Creek has temperatures a few degrees Fahrenheit above the ambient temperature of the Bay and does not interfere with any fish migrations." In addition, please include the date of and ambient bay temperature and plume temperatures at the time of each shutdown event.

The BBEP Characterization Report (2002) discusses OCGS's circulating water system and heated discharge. It also discusses the station's dilution pumps, which are designed to temper discharge temperatures and reduce impacts to aquatic blota in the receiving waters. The Report notes that the station's thermal plume is confined to roughly a 1.6-kilometer (one mile) radius about the mouth of Oyster Creek. On calm days, the plume "fans out" from the mouth of the creek; strong winds from the north or south cause the plume to be compressed against the shoreline. At times of peak operation, water temperatures are 3 to 5°C above ambient at the mouth of Oyster Creek (Chizmadia et al. 1984; BBEP 2002).

The Fact Sheet to the 1994 NJPDES permit contains excerpts of a 1989 Versar review of the OCGS 316(a) studies and quotes the Versar report's findings relative to the thermal plume and avoidance studies conducted by GPUN. Quoting the Fact Sheet:

"Although Versar found that best methods reasonably available to assess "avoidance effects" were not used because avoidance studies were not conducted with opossum shrimp and sand shrimp, Versar concluded that 'avoidance effects' were not a serious problem. Specifically, Versar stated that:

the overall exclusionary effect of the thermal plume was localized and small. The exclusion of fish was primarily confined to the Discharge Canal which comprised about 2-4% of the total volume of Barnegat Bay. The avoidance temperatures used in the 316 Demonstration were the lowest of several available estimates and should be protective of the resource. Finally, the entire thermal plume in August is small relative to the total area of Barnegat Bay (6-10%)."

Table 1 lists fish kills at OCGS that were believed to be related to cold shock or cold-weather shutdowns of the station. The last of these fish kills was in November 2001.

Frequently Asked Questions About Natural Heritage Priority Sites

What are Natural Heritage Priority Sites? Through its Natural Heritage Database, the Office of Natural Lands Management (ONLM) identifies critically important areas to conserve New Jersey's biological diversity. The database provides detailed, up-to-date information on rare species and natural communities to planners, developers, and conservation agencies for use in resource management, environmental impact assessment, and both public and private land protection efforts.

Using the database, ONLM has identified Natural Heritage Priority Sites that represent some of the best remaining habitat for rare species and exemplary natural communities in the state. These areas should be considered to be top priorities for the preservation of biological diversity in New Jersey. If these sites become degraded or destroyed, we may lose some of the unique components of our natural heritage.

ONLM has identified 410 priority sites over the course of more than 10 years. We have received assistance from many partner individuals and agencies over this time. The Nature Conservancy and the DEP Endangered and Nongame Species Program have provided key information or assisted with the delineation of a number of the sites.

How are Natural Heritage Priority Site maps used in conservation of biological diversity? Natural Heritage Priority Site maps are used by individuals and agencies concerned with the protection and management of land. The maps have been used by municipalities preparing natural resource inventories; public and private conservation organizations preparing open space : acquisition goals; land developers and consultants identifying environmentally sensitive lands; and public and private landowners developing land management plans.

Natural Heritage Priority Sites contain some of the best and most viable occurrences of endangered and threatened species and natural communities, but they do not cover all known habitat for endangered and threatened species in New Jersey. If information is needed on whether or not endangered or threatened species have been documented from a particular piece of land, a Natural Heritage Database search can be requested by contacting the Office of Natural Lands Management at the address below.

What do the boundaries of the sites contain? The boundaries of each Natural Heritage Priority Site are drawn to encompass critical habitat for the rare species or natural communities. Often the boundaries extend to include additional buffer lands that should be managed to protect the habitat. A justification for the boundary is provided for each site. The term "primary bounds" is sometimes used to refer to boundaries enclosing critical habitat. The term "secondary bounds" is sometimes used to refer to boundaries enclosing additional buffer. In maps where both primary and secondary boundaries are described, only the outermost boundary is provided in the mapping.

What is the background map that the sites are drawn upon?

The sites are portrayed on background maps produced from a digital copy of the U.S. Geological Survey 7.5 minute topographic maps. The background maps contain topographic lines as well as streams, lakes, roads, towns and place names. These background maps do not always reflect recent changes in land development. Some may be more than 20 years old. Some sites appear to be shifted in position against this topo map. This shift is due to the fact that most sites have been digitized against a background of rectified aerial photography, and some of the digitized USGS topo maps do not align with this photography.

What do "public lands" depict on the maps? The "public lands" shaded on these maps are stateowned open space lands that have been digitized as a GIS coverage by the state Green Acres Program. This information is provided to show patterns of State land ownership in the vicinity of the Priority Site. The public lands are areas such as State Parks and Forests, Wildlife Management Areas, and Natural Lands Trust preserves. They do not currently include lands owned by other state agencies, federal, county or municipal governments

.....

Oyster Creek Generating Station License Renewal Application or nonprofit conservation organizations. This GIS coverage is constantly being updated, and therefore future editions of the maps will likely contain additional public lands that are not currently mapped as such.

What is the biodiversity significance rank and how is it used?

Each site is ranked according to its significance for biological diversity using a scale developed by The Nature Conservancy and the network of Natural Heritage Programs. The ranks can be used to distinguish between sites that are of global significance for conservation of biological diversity vs. those that are of state significance. The scale ranges from B1 to B5 with sites ranked B1-B3 generally being of global significance and sites ranked B4-B5 being of state significance. The specific definitions for each rank are as follows;

B1 - Outstanding significance, generally the "last of the least" in the world, such as the only known occurrence of any element (species or natural community), the best or an excellent occurrence of an element ranked critically imperiled globally, or a concentration (4+) of good or excellent occurrences of elements that are imperiled or critically imperiled globally. The site should be viable and defensible for the elements or ecological processes contained.

B2 - Very high significance, such as the most outstanding occurrence of any natural community. Also includes areas containing other occurrences of elements that are critically imperiled globally, a good or excellent occurrence of an element that is imperiled globally, an excellent occurrence of an element that is rare globally, or a concentration (4+) of good occurrences of globally imperiled elements.

B3 - High significance, such as any other viable occurrence of an element that is globally imperiled, a good occurrence of a globally rare element, an excellent occurrence of any natural community, or a concentration (4+) of good or excellent occurrences of elements that are critically imperiled in the State.

B4 - Moderate significance, such as a viable occurrence of a globally rare element, a good occurrence of any natural community, a good or excellent occurrence or only viable state occurrence of an element that is critically imperiled in the State, an excellent occurrence of an element that is imperiled in the State, or a concentration (4+) of good occurrences of elements that are imperiled in the State or excellent occurrences of elements that are rare in the State.

B5 - Of general biodiversity interest.

How can I obtain Natural Heritage Priority Site maps for an area of interest to me? Natural Heritage Priority Site hard copy maps can be obtained by submitting a written request accompanied by a check or money order made payable to the Office of Natural Lands Management at the following address:

Office of Natural Lands Management P.O. Box 404 Trenton, NJ 08625-0404 Phone: 609-984-1339; Fax: 609-984-1427

Individual 8.5" X 11" maps are available at the following rate:

1 - 10 site maps & reports:	\$1.50/site
11 - 20 site maps & reports:	\$1.00/site ·
> 20 sites:	\$0.50/site

Digital GIS Coverage of Natural Heritage Priority Sites

A digital version of the ArcView GIS file of Natural Heritage Priority Sites is also available. The zipped version of the file is approximately 1 MB in size. The 2001 version of Natural Heritage Priority Sites will be emailed upon request. The 1999 version of the digital files can be obtained on the internet at the following address: http://www.state.nj.us/dep/gis/ -Click on "GIS Data Downloads" and then "Select a data layer" and then "Natural Heritage Priority Sites". There is no

charge for emailing or downloading the GIS data.

How often are the maps updated? The Natural Heritage Priority Site information is constantly being updated in the Natural Heritage Database. A new edition of the maps will be made . available after significant revisions or additions to the Database.

April 9, 2002

NJ Department of Environmental Protection Division of Parks and Porestry Natural Lands Management

.

.

Enclosure			Page	19 of 27	·
Table 1. Know	m fish kills at OCC	S associated with cold	weather shutdowns,		
DATE	NUMBER i	SPECIES	SIZE RANGE (mm)	PROBABLE CAUSE	INTAKE TEMPERATURE •
	3	ladyfish	292.7*		
·	2	Northern kinglish	•		
	1	gray snapper	118.0		
	1	American eel			
: *	1	mojarra	221.0		
12/10/81	13	bluefish	-	Thermal Shock	3.6 (38.5)
	. 12	Atlantic menhaden	•		
	5	spot			
· · ·	[.] 3	butterfish	-		
	2	scup			
	2	jack			
	İ	striped mullet			
· • .		ч. С			
12/10/82	5,000 (estimate)	bluefish	274-476	Thermal Shock	8.9 (48.0)
	2,655 (estimate)	crevalle jack	, 110-204	•	·2 · · · ·
	80	blue runner	171-218	• • • •	
	28	Atlantic neddlefish	250-661		
				- و ۰ ۰ ۰	
	. •		•.	·	
					·

• .

.

.

Environmental Report Appendix E Coastal Zone Consistency Certification

.

.

NJ DEP, Land Use Regulation Program	
June 15, 2005	
Enclosure	•

Page 20 of 27

Table 1. Known fish kills at OCGS associated with cold-weather shutdowns.

•

DATE	NUMBER	SPECIES	SIZE RANGE (mm)	PROBABLE CAUSE	INTAKE TEMPERATURE *C (*F
	9	scup	205-247		
	1	ladytish	410		
	1	Northern kinglish	185		
2/2/85	16	Atlantic menhaden	150-275	Thermal Shock	2.2 (36.0)
	1	blueback herring			
12/15/85	52	weakfish	_	Thermal Shock	4.3 (39.7)
	1	black sea bass			
	1	toqa	•		
· .	1	white perch		•	
12/8/89	2,641	Atlantic menhaden	152-305	Thermal Shock	1.1 (34)
	166	bluefish	216-521		
	5	weakfish	495-533		
	3	spotted seatrout	464-597		
	7	northern kinglish	203-356		
	1	spot	165		
	500-1,000	crevalle jack	•		
	4	red drum			•
	2	American eel			

.

Page E-64

NJ DEP, Land June 15, 2005	Use Regulation Program
Enclosure	

.

Page 21 of 27

Table 1.	Known fish kills at OC	CGS associated with cold	-weather shutdowns.					
DATE	NUMBER	SPECIES	SIZE RANGE (mm)	PROBABLE. CAUSE	INTAKE TEMPERATURE °C (°F)			
	1	spiny dogfish						
2/15 -2/16/91	1,114	bluefish	220-910	Thermal Shock	2.4-5.8 (36.4-42.4)			
	20	spot	120-140		-			
	11	spotted seatrout	480-525					
	3	smooth dogfish	250-300		· ·			
	1	northern kingfish	300					
	1	weakfish						
	1	Atlantic herring	•		• • • • •			
12/18/95	. 6	bluefish	308-457	Thermal Shock	1.7 (35)			
	5	black drum	210-290					
	3	spotted sea trout	435-560					
	3	smooth dogfish	600-668		• •			
	· 1	weakfish	430	·	•			
	1.	scup	210					
				\ - .				

:

. . . .

. . .

÷

.

Page 22 of 27

.

: .

Table 1. Known fish kills at OCGS associated with cold-weather shutdowns.

DATE	NUMBER	SPECIES	SIZE RANGE (mm)	PROBABLE CAUSE	INTAKE TEMPERATURE *C (*F)
12/27-12/28/95	620	striped bass	296-758	Thermal Shock	·1.2 (29.9)
	. 229	white perch	228-361		
	5	American eel	640-714		
	1	gizzard shad	365		
03/20/98	30	bluefish	575-758	Thermal Shock	6.1-7.4 (43-45.5)
01/21/00 - 02/01/00	2981	Striped bass	338-860	Thermal Shock	-1.5 - 0.5 (29.22-32.94)
	305	White perch	285-299		
	117	Biack drum	185-525		
	34	Biuefish	360-648		
	9	Striped muliet	285-524		
	8	Gizzard shad	280-305		
	7	American eel	510-660		
	5	Mummichog	35-52		
	4	Tautog	225-342		
	2	Atlantic herring	252-258		
	2	Spotted seatrout	433-502	. *	

Environmental Report Appendix E Coastal Zone Consistency Certification

(

ς.

.

.

Enclosure		Page 23 of 27				
Table 1.	Known fish kills at OCGS associated with cold-weather shutdowns		eather shutdowns.			
DATE	NUMBER	SPECIES	SIZE RANGE (mm)	PROBABLE	INTAKE TEMPERATURE *C (*F)	
	2	Weakfish	560-608			
	2	Winter flounder	232-295			-
	1	Cunner	60			
	1	Red drum	446			
	· 1	Smooth dogfish	580			
	66	Unidentified	Unknown			
11/11/01-11/14/01	1306	Crevalle jack / Blue runner	128-214	Thermal Shock	· .	8.99 - 13.09 (48.19-65.56)
	78	Lookdown	117-155		۰.	
	11	Bluefish	328-384	•	•	•
	7	Bluespotted cometfish	340 ,			
	2.	Greater amberjack	470-495			•
	1	Southern stingray	310			
	1	Spanish mackerel	324			
	1	Spotfin butterflyfish	83	•		· · · · ·
	. ·				:	•
						:
				• • •		· ·
		· .				

•
NJ DEP, Land Use Regulation Program June 15, 2005 Enclosure

Page 24 of 27

10. Submit data and information and an analysis of that data and information to support the statement on page 25 under the section identified as "Prime Fishing Areas" [sic] with regard to the impingement of alewife or river herring (Alosa pseudoharengus), blueback herring (A. aestivalis), American shad (A. sapidissima), striped bass (Morone saxatilis), Atlantic sturgeon (Acipenser oxyrhynchus), shortnose sturgeon (A. brevirostrum), and American eel (Anguilla rostrata) that "OCGS is in compliance with the rules protecting finfish migrations."

AmerGen has not conducted any recent studies on the impingement of fish at OCGS. However, the 316(b) determination and the issuance of an NJPDES permit by the state of New Jersey are implicit concurrence by the state that the operation of OCGS is in compliance with the rules protecting finfish migrations. See Question 2 for a more complete discussion of the impingement of organisms at OCGS.

AmerGen also notes that the NRC, in performing its generic review of impacts of nuclear plant operation and license renewal, characterized plant impact on finfish migrations as small (NRC 1996).

NJ DEP, Land Use Regulation Program		•	
June 15, 2005			· · ·
Enclosure	 • .		Page 25 of 27

11. The submittal does not discuss public access to the waterfront. Please identify any public access to the waterfront provided on property owned by AmerGen. If no public access to the waterfront is available, can public access be provided to Oyster Creek, Forked River, or Barnegat Bay through the Finninger Farm? If AmerGen's response is negative, please detail why public access to the waterfront can not be provided.

AmerGen recognizes that the CZMA generally contemplates consideration be given to a wide range of uses of the coastal zone - but it does not mandate that every approved use of the coastal zone allow for multipurpose uses and widespread access at every location. Sometimes multipurpose uses can coexist, but in other circumstances, only one activity may be conducted in a particular location. When dealing with a major preexisting project, other uses of that portion of the coastal zone are limited, especially for the very special situation of a pre-existing nuclear power plant. Finninger Farm is currently the state-approved location for placement of dredged spoils for the plant's intake structure, and intake and discharge canals. The New Jersey Bureau of Nuclear Engineering (NJBNE) maintains a radiation monitor on the Finninger Farm. NJBNE should be consulted about what additional uses could be made at this location.

As stated in AmerGen's Federal Consistency Certification For Federal Permit And License Applicants, dated January 20, 2005, Enclosure page 2, AmerGen has not identified any refurbishment activities necessary to allow operation for an additional 20 years, and have identified no significant environmental impacts from programs and activities for managing the effects of aging.

Further, in AmerGen's certification, Enclosure page 23, In consideration of Coastal Permit Program Rules (NJAC 7:7), AmerGen states that they are not performing any activities (construction within the coastal area, dredging, excavation, or deposition of material, and erection of any structure in any coastal wetlands; and filling or dredging, or construction in certain upland areas adjacent to tidal wetlands) as a result of license renewal, has no plans to perform such activities as a result of license renewal, and is not seeking a coastal permit for such activities.

Finally, in AmerGen's certification, Enclosure page 32, under Subchapter 8 – Resource Rules, AmerGen states that, since this subchapter applies to development, which AmerGen will not undertake during the license renewal term, the requirements are not relevant. The rationale for AmerGen's statement come from NJAC 7:7E8-1(a), where it states, Purpose and scope, in addition to satisfying the location and use rules, a proposed development must satisfy the requirements of this subchapter. This subchapter contains the standards the Department utilizes to analyze the proposed development in terms of its effects on various resources of the built and natural environment of the coastal zone, both at the proposed site as well as in its surrounding region (emphasis added).

NJ DEP, Land Use Regulation Program June 15, 2005 Enclosure

Page 26 of 27

REFERENCES

- Atlantic Menhaden Technical Committee (AMTC). 2001. 2001 Status of Atlantic Menhaden Stock and Fishery. Atlantic Menhaden Technical Committee of Atlantic States Marine Fisheries Commission (ASMFC). July 1.
- Barnegat Bay Estuary Program (BBEP). 2001. The Barnegat Bay Estuary Program Characterization Report. Prepared by the Barnegat Bay National Estuary Program's Scientific and Technical Advisory Committee. January. Available on line at <u>www.bbcp.org</u>.
- Barnegat Bay Estuary Program (BBEP). 2002. Final Comprehensive Conservation and Management Plan. Available on line at <u>www.bbcp.org</u>.
- Chesapeake Bay Ecological Foundation (CBEF). 2004. Atlantic menhaden (*Brevoortia tyrannus*). Available on line at <u>http://www.chesbay.org</u>.
- Chizmadia, P. A., M. J. Kennish, and V. C. Ohori. 1984. "Physical description of Barnegat Bay" *in Ecology of Barnegat Bay* (M. J. Kennish and R. A. Lutz, eds), Springer – Verlag, New York.
- EA Engineering, Science and Technology, Inc. (EA). 1986. Entrainment and impingement studies at Oyster Creek Nuclear Generating Station, 1984-1985. Prepared for GPU Nuclear Corporation, Parsippany, New Jersey. EA Report GPU 44G.
- Environmental Protection Agency (EPA). 2003a. "A 'ground-breaking' partnership for the Barnegat Bay Estuary Program." National Estuary Program website. Available on line at <u>http://www.epa.gov/nep/coastlines/nov03/barbay.html</u>.
- Environmental Protection Agency (EPA). 2003b. "Controlling Bacterial Contamination in Barnegat Bay, New Jersey." National Estuary Program website. Available on line at <u>http://www.epa.gov/nep/coastlines/apr03/controlling.html</u>.
- Environmental Protection Agency (EPA). 2004a. "National Estuary Program." Available on line at <u>http://www.epa.gov/nep/</u>.
- Environmental Protection Agency (EPA). 2004b. "Comprehensive Conservation and Management Plans." National Estuary Program website. Available on line at http://www.epa.gov/owow/estuaries/ccmp/.
- Fishing and Hunting News. 2004. "Beachcombers aren't only summer migrants." Orig. published in Fishing and Hunting News. Available on line at http://cspn.go.com/outdoors/fishing/s/f_map_NJ_Barnegat_bay.html.
- Flyfishing Connection. 1999. "Saltwater Fly Fishing New Jersey's Barnegat Bay." Available on line at <u>http://www.flyfishingconnection.com/barnegatbay.html</u>.

NJ DE June Enclos	P, Land Use Regulation Program 15, 2005 sure Page 27 of 27
Haugh	ney, John. 2004. "Time to make way for Oyster Creek Stripers.{" Orig. published in Fishing and Hunting News. Available on line at http://espn.go.com/outdoors/fishing/s/f_map_NJ_Barnegat_bay.html.
NMFS	(National Marine Fisheries Service). 2003. Annual Commercial Landing Statistics for Atlantic menhaden. Fisheries Statistics & Economics Division NOAA Fisheries. Available on line at http://www.st.nmfs.gov/st1/commercial/index.html.
NMFS	(National Marine Fisheries Service). 2004. Marine Recreational Fisheries Statistics Fisheries Statistics & Economics Division NOAA Fisheries. Available on line at <u>http://www.st.nmfs.gov/st1/recreational/data.html</u> .
NRC	Nuclear Regulatory Commission). 1996. Generic Environmental Impact Statement for License Renewal of Nuclear Plants. NUREG-1437. Office of Nuclear Regulatory Research. Washington DC. May.
Sumn	Hers, J. K., A. F. Holland, S. B. Weisberg, L. C. Wendling, C. F. Stroup, R. L. Dwyer, M. A. Turner, and W. Burton. 1989. Technical review and evaluation of thermal effects studies and cooling water intake structure demonstration of impact for the Oyster Creek Nuclear Generating Station, Revised Final Report, Volume I – Text. Prepared by Versar, Inc. for New Jersey Department of Environmental Protection Division of Water Resources. Trenton, NJ.
Versa	r (Versar, Inc.) 1988. Technical review and evaluation of thermal effects studies and cooling water intake structure demonstration of impact for the Oyster Creek Nuclear Generating Station. Final Report. Volume I – Text. Prepared for the New Jersey Department of Environmental Protection, Division of Water Resources Transformer New Jersey Protection, Division of Water

.

NJ DEP, Land Use Regulation Program June 15, 2005 Attachment

Attachment 6-1

Oyster Creek Nuclear Generating Station, Formal Section 7 Consultation Initiation

Rec'd 6-10 05 MB



UNITED STATES DEPARTMENT OF COMMERCE National Oceanic and Atmospheric Administration NATIONAL MARKE REMAINS SERVICE NOTHELAST INCOM Ove Bacthour Drive (Income M Organ 220)

JUN - 3 200

Pas-Tsin Kuo, Program Director License Renewal and Environmental Impacts Program Division of Regulatory Improvement Programs Office of Nuclear Regulatory Commission U.S. Nuclear Regulatory Commission Washington, D.C. 20555-0001

Re: Oyster Creek Nuclear Generating Station, Formal Section 7 Consultation Initiation

Dear Mr. Kuo:

This correspondence acknowledges the receipt of your March 29, 2005 letter regarding the reinitiation of formal consultation pursuant to section 7(a)(2) of the Endangered Species Act (ESA) of 1973, as amended, for continued operation of the Oyster Creek Nuclear Generating Station (OCNGS). Previous section 7 consultation was completed with the issuince of a biological opinion (Opinion) on July 18, 2001. The 2001 Opinion along with the revised incldental take statement (ITS) issued on August 29, 2001 authorized the annual take of five loggerhead, four Kemp's ridley, and two green sea turtles during the annual operation of OCNGS. During 2004, eight Kemp's ridley sea turtles occurred at OCNGS, exceeding the authorized TTS. Due to the number of Kemp's ridley sea furthe takes, the Nuclear Regulatory Commission (NRC) has requested reinitiation of formal consultation.

The Biological Assessment dated March 2005, enclosed with your letter, has provided information for this consultation. Upon review of the submitted information, it is NOAA's National Marine Fisheries Services' (NMFS) determination that all of the information required to initiate formal consultation has been received.

NMFS will prepare an Opinion analyzing whether or not the continued use of the OCNGS is likely to jeopardize listed sea turtles. Your March 29, 2005 letter was received by NMFS Northeast Region, Protected Resources Division on April 28, 2005, which will serve as the commencement date of the formal consultation process. The ESA and the section 7 regulations require that formal consultation be concluded within 90 calendar days of initiation, and the biological opinion be delivered to the action agency within 45 days after the conclusion of formal consultation. As such, we expect to provide you with our biological opinion no fater than September 10, 2005. As a reminder, the NRC must not make any irreversible or irretrievable economitments of resources that would prevent NMFS from proposing or implementing any reasonable and prudent alternatives to avoid jeopardizing sea turtles.



Until the final biological opinion is completed and signed, NMFS recommends that the Nuclear Regulatory Commission continue to implement the requirements identified in the July 21, 2001 Opinion and the August 29, 2001 amended ITS.

If you have any questions concerning these comments or the section 7 consultation requirements, please contact Sara McNulty of my staff at (978) 281-9300 x6520.

Sincerely,

Mra Mary Colligan

Assistant Regional Administrator. for Protected Resources

cc: Malcolm Browne, AmerGen Collins, GCNE Williams, GCNE Riportella, F/NER-SII Scida, F/NER Nash, NRC

Hite code: NKC - Oyner Crief, relationlon latter, 2004

Page E-74

NJ DEP, Land Use Regulation Program June 15, 2005 Attachment

١

.'

۰. .

Attachment 7-1

Calculation Package for Oyster Creek Transmission Line Induced Current Analysis

•

Oyster Creek Generating Station License Renewal Application

- Page E-75

Calculation Package for Oyster Creek Transmission Line Induced Current Analysis

July 8, 2004

Prepared for:

Exclon Nuclear Lacey Township, New Jersey

Prepared by:

Steven J. Connor Tetra Tech NUS Aiken, South Carolina

L. Problem Statement

These calculations were performed in support of Applicant's Environmental Report, Operating License Renewal Stage, Oyster Creek Nuclear Generating Station, specifically section 4.13 on induced current. NRC regulations and guidance for preparing license renewal environmental reports requires that licensees demonstrate that their transmission lines comply with the induced shock provisions of the National Electrical Safety Code (NESC) in Part 2, Rules 232Clc and 232D3c. NESC requires that vertical clearances for transmission lines exceeding 98-kilovolts be sufficient to ensure that the induced current due to electrostatic effects is not greater than 5 milliamperes for the largest anticipated truck, vehicle, or equipment parked beneath the lines.

The Oyster Creek transmission lines consist of two 230 kV lines that are hung on double-circuit towers in a vertical configuration. The lines run 11.1 miles from the Oyster Creek 230 kV substation to the Manitou Substation.

II. Model Input Data

The computer code ACDCLINE by the Electric Power Research Institute was used for the calculations. The inputs necessary for running ACDCLINE were obtained from the following drawings provided by First Energy (2004).

- Plan and Profile drawings D-48825, Manitou-Oyster Creek 230 kV Transmission Line, sheets 1 -12.
- Standard 230 kV Transmission Line Sag & Tension Charts A-35801 through A-35805 and A-35928 through A-35932.
- 230 kV Double Circuit Transmission Line Suspension Tower Type KR, Drawing T-11070

In general, the plan and profile drawings for each line were used to identify two types of locations: (1) at all paved roads (2) any location with clearance lower than the least road clearance, regardless of terrain or structures beneath. The candidate locations are cataloged in Table 1 along with the data used for selecting locations to analyze.

Table 1. C	andidate analysis locations	
Location	Description	Clearance (ft)
27+68	Proposed 3 rd Avenue	48
30+07	Proposed 2 nd Avenue	48
32+48	Proposed 1 [#] Avenue	60
51+05	Intersection of Hill Street and proposed 5th Avenue	35
54+33	Proposed Mill Street	52
57+28	Proposed Shepherd Street	73
61+10	Intersection of Proposed 6th Avenue and Emanuel	. 39
64+55	Proposed Johnson Street	52
68+00	Proposed Ingard Street	72
71+40	Proposed Factory Street	49
74+78	Dover Road	51
122+69	Proposed Milton Avenue	47
193+63	Pinewald-Keswick Road	51
350+14	Proposed Alpine Street	54
352+63	Proposed Chesler Street	58
355+13	Proposed Clifton Street	· 54
357+63	Proposed Elwood Street	54
360+13	Proposed Center Street	59
362+63	Proposed Hoyt Street	52
365+13	Proposed Devon Street	40
367+86	Proposed River Street	49 -
431+17	 Proposed Clearview Street 	61
433+91	Proposed Fairview Street	39 -
436+63	Proposed Ocean Street	40
439+34	Proposed State Street	. 64
442+50	Proposed Cedar Avenue	46
444+77	Proposed Grove Street	37
518+38	Estimated parking position on Garden State Parkway - southbound	42
523+67	Estimated parking position on Garden State Parkway - northbound	50 .
102+00	Edge of swamp land - no road	32
177+00	Medium woods - no road	29
187+00	Medium woods - no road	29

Examination of the data in Table 1 resulted in selection of the locations identified in Table 2 for analysis. These locations should yield the bounding case among those identified in Table 1. Additional locationspecific data needed for analysis are also provided.

Table 2. Data for locations selected for analysis.

Location	Description	Clearance (ft)	Span (ft)	Sag ¹ (ît)	Angle ²	Conductor Height ³ (ft)	Tower Type
51+05	Intersection of Hill Street and proposed 5 th Avenue	35	1100	@167° 44 @120° 41	45°	79*	KR-KR
444+77	Proposed Grove Street	. 37	1050	@167°42 @120°38	30°	78".	KR-KR
177+00	Medium woods - no road	29	1000	@167°36 @120°34	NA	. 67	KR-KR

1. Plan and Profile drawings indicate 167°F sag. Sag at 120°F determined from sag charts.

 Angle of transmission line to road. Due to an error in ACDCLINE, the value entered into the code is the complementary angle.

 Weighted average height of lowest conductor attachment to towers, above road or location of interest. See Attachment A for calculation of these values.

The Type KR towers were the only ones used at the locations of interest. Data on these towers are provided in Table 3. The conductors are arranged in a vertical configuration with one circuit occupying each side of the tower phased A-B-C, top-to-bottom on both sides.

Table 3. Ty	pe KR Tower Dimensio	ns	_	
Phase	Horizontal Distance from Centerline (ft)	Connection Height Above Lowest Conductor (ft)		
Left static	-10.5	63 .	•••	•
Left A	-18	42		
Left B	-20.5	21	•	
Left C	-18	0		•
Right static	+10.5	63		
Right A	+18	42		
Right B	+20.5	21		
Right C	+18	0		

As identified on the Plan and Profile drawings, the conductors are 1590 MCM 45/7 ACSR Lapwing. The static wires are 7#6 AW. ACDCLINE selected the parameters for these conductors and static wires from its library.

III. Methods

In most cases the elevation of the two towers of a span of interest were different, and the elevation of the location of interest was different than the nearest tower base. Because AC/DCLINE does not accommodate non-level geometries, a surrogate geometry was constructed that uses weighted average height for conductor attachments above the location of interest. The surrogate geometry had the two towers at the same elevation. This surrogate geometry would not have identical impact with that of the actual geometry, but it should be close. Calculations of weighted average heights for the surrogate geometry are found in Attachment A.

The code was first run to give electric field with no coupled objects to find the transverse location with the highest electric field strength. The code was then rerun with a long box coupled object with dimensions of the largest tractor-trailer truck that is expected to be on the roads, 12 by 8 by 65 feet. The 12-foot height is a weighted average of the cab and the trailer. At the non-road location, a combine of dimensions 11.5 by 7.5 by 30 feet was used. The truck or combine was placed at the longitudinal location of interest and at the transverse location with the highest electric field strength.

IV. Results

Analytical results for each analysis is provided in the table below to three significant digits, as provided in the ACDCLINE printouts in Attachment B. All values are in compliance with the NESC limit, which is presented as one significant digit, 5 milliamperes.

Survey Location	Description	Induced Current (millamps)
51+05	Intersection of Hill Street and proposed 5th Avenue	2.76
444+77	Proposed Grove Street	2.75
177+00	Medium woods – no road	2.10

References

.

.

First Energy, 2004. Letter from Barry Sensenig, First Energy to William D. Maher, Exclon, with attachments, First Energy, Reading, Pennsylvania, June 1.

. . .

.

. . . .

Attachment A Calculation of Weighted Average Heights

-

Oyster Creek Induced Current Analysis Weighted Average Conductor Heights

Location 51+05		Location 444+77		Location 175+00	
Tower 93	feet	Tower 134	feet	Tower 106	feet
conductor elevation	138	conductor elevation	114	conductor elevation	132
distance to road	555	distance to road	477	distance to road	500
Tower 94		Tower 135		Tower 107	
conductor elevation	140	conductor elevation	122	conductor elevation	130
distance to road	545	distance to road	573	distance to road	500
road elevation	60	road elevation	40	road elevation	64
Span	1100	Span	1050	Span	1000
Weighted average		Weighted average		Weighted average	
elevation	139	olevation	118	elevation	131
Weighted average					
height above road -		Weighted average		Weighted average	
lowest conductor	79	height above road	78	height above road	67
Weighted average		Weighted average		Weighted average	
height above road -		height above road -		height above road -	
middle conductor	100	middle conductor	99	middle conductor	88
Weighted average		Weighted average		Weichted average	
height above road -		height above road -		beight above road -	
highest conductor	121	highest conductor	120	highest conductor	109
Weighted average		Weighted average		Weighted average	
height above road -		height above road -		height above road -	
static wire	142	static wire	141	static wire	130

:

Attachment B ACDCLINE Printouts

Results of AC/DCLINE program EFION (EPRI/HVTRC 7-93) for: ELECTRIC FIELD & IONS WITHOUT SHIELDING OBJECTS

.

Configuration file name: C:\TLN30\ACDCLINE\DATA\ACT93 Date: 7/ 8/2004 Time: 15:33

T93 Intersection of Hill Street and 5th Avenue at 51+05

,														
1	BUNDLE INFORMATION *.													
	BNDL #	CIRC #	Voltage Voltage (kV)	AGE ANGLE (DEG)	CURR LOAD (A)	ent Angle (Deg)	# OF COND	BCNDLE X (feet)	COORDINJ Y (feet)	ATES SAG (feet	PH)			
•	1 2 3 6 7 8 4 5	1 1 2 3 4 1 2	230.0 230.0 230.0 230.0 230.0 230.0 230.0 .0	0. 240. 120. 0. 240. 120. 0. 0.	500. 500. 500. 500. 500. 1000. 0.	0. 240. 120. 0. 120. 0.	1 1 1 1 1 1 1	-18.0 -20.5 -18.0 18.0 20.5 18.0 -10.5 10.5	121.0 100.0 79.0 121.0 100.0 79.0 142.0 142.0	41. 41. 41. 41. 41. 35. 35.	0 A 0 B 0 C 0 A 0 B 0 C 0 C 0 C 0 GND 0 GND			
	 MINIMUM GROUND CLEARANCH = 38.00 feet POWER SYSTEM FREQUENCY = 60. Hz SOIL RESISTIVITY = 100. chma meter 													
1	•		SI	JBCONDI	JCTOR IN	FORMATI	CN -	REGULAR S	BUNDLES					
ļ	BNDL	α	ONDUCTOR NAME	DIA (in	METER ;	SPACING (inch)	3 D((d	RESIST	AC RESI (ohm/mi	ST .1e)	AC REA (ohm/mi	CT		
	1 2 3 6 7 8 4	LAPI LAPI LAPI LAPI LAPI LAPI	Aing Aing Aing Aing Aing Aing Aing		L.500 L.500 L.500 L.500 L.500 L.500 L.500	18.000 18.000 18.000 18.000 18.000 18.000		.0580 .0580 .0580 .0580 .0580 .0580	.06	20 20 20 20 20 20 20	.36 .36 .36 .36 .36 .36 .36 .36	40 40 40 40 40 10		
	5	7#67	AW	1	.490	18.000		1.5070	1.53	60	.72	10		

Oyster Creek Generating Station License Renewal Application

۰.

**

			•		•	-	• .
	*****	********	***********	********	• •		
	•			•	•		
	•	AC ELECT	RIC FIELD PRO	FILE	•		•
	* a	t 3.28 :	feet above gro	ound	•		
					•	•	
	. • long	itudinal	distance: 54	5.00 feet	•		
					•		•
			*************	********	•		
1.31	FRRAT.	MAYTMEN	MINOP /MAJOP			COLCE .	
DIST	CANCE	FIELD	RLLIPSE AVES	VERTICAL	HORIZONTAL	DOTENTIAL.	•
(feet)	(meters)	(kV/m)	(ratio)	(kV/m)	(kV/m)	(by)	
					(,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		
-50.0	-15.24	.861	.035	.848	.155	.853	
-45.0	-13.72	1.115	.030	1.100	.182	1.105	
-40.0	-12.19	1.407	.025	1.392	.204	1.396	
-35.0	-10.67	. 1.725	.020	1.712	.215	1.712	•
-30.0	-9.14	2.049	.016	2.038	.209	2.034	
-25.0	-7.62	2.346	.011	2.339	.181	2.331	
-20.0	-6.10	2.588	.006	2.584	.137	2.573	
-15.0	-4.57	2.755	.002	2.754	.087	2.743	
-10.0	-3.05	2.850	.000	2.850	045	2.841	··· · ·
-5.0	-1.52	2.892	.000	2.892	.017	2.887	
.0	.00	2.903	.000	2.903	.000	2.899	
5.0	1.52	2.892	.000	2.892	.017	2.887	
10.0	3.05	2.850	.000	2.850	.045	2.841	
15.0	4,57	2.755	.002	2.754	.087	2.743	
20.0	6.10	2.588	.006	2.584	137	2.573	
25.0	. 7.62	2.346	.011	2.339	.181	2.331	
30.0	9.14	2.049	.016	2.038	.209	2.034	•
35.0	10.67	1.725	.020	-1.712	.215	1.712	
40.0	12.19	1.407	:025	1.392	.204	1.396	
45.0	13.72	1.115	.030	1.100	182	1.105	
50.0	15.24	.861	.035	.848	.155	.853	•
100.0	30.48	.090	.102	.090	.013	.089	
150.0	45.72	.118	.009	118	.002	.118	
100.0	30.48	.090	.102	.090	.013	.089	
150.0	45.72	.118	.009	.118	002	.118	

. .

.

. . .

Oyster Creek Generating Station License Renewal Application

.

.

.

------------Results of AC/DCLINE program COUPLE (EPRI/HVTRC 7-93) for: COUPLING to OBJECTS & SHIELDING by OBJECTS

Configuration file name: C:\TLW30\ACDCLINE\DATA\ACT93 Date: 7/ 8/2004 Time: 15:33

DATE: 7/ 8/2004 TIME: 15:33 • • • • . . . ELECTRICAL COUPLING TO OBJECTS

INCLUDING EFFECTS OF 6 SHIELDING OBJECTS OBJECT TYPE = 2 LONG BOX (LONG VEHICLE)

EQUIVALENT COUPLED OBJECT AREA = 3255.98 ft**2 CALCULATED CAPACITANCE TO GROUND = 2500. pF CALCULATED RESISTANCE TO GROUND = .72 kohms (1% RESISTANCE VALUE MEASURED FOR VEHICLES WITH THE SAME CAPACITANCE, IN DIFFERENT WEATHER CONDITIONS AND ON DIFFERENT PAVEMENTS - NORTHEAST USA)

. . -

.

AC SHORT CIRCUIT CURRENT -2.76 mA

. . .

THEORETICAL MAXIMUM AC VOLTAGE TO GROUND -2925. V 11 AC VOLTAGE TO GROUND = 1644. V 50% AC VOLTAGE TO GROUND -243. V

Oyster Creek Generating Station License Renewal Application

Page E-87

Results of AC/DCLINE program EFION (EPRI/HVTRC 7-93) for: ELECTRIC FIELD & IONS WITHOUT SHIELDING OBJECTS

Configuration file name: C:\TLW30\ACDCLINE\DATA\ACT134 Date: 7/ 8/2004 Time: 15:37

T134 Grove Street at 444+77

VOLTAGE CURRENT # BUNDLE COORDINATES												
	CIRC #	VOLTAGE (kV)	ANGLE (DEG)	LOAD (A)	ANGLE (DEG)	COND	X (feet)	Y (feet)	SAG (feet)	PH		
1 1 230.0 0. 500. 0. 1 -18.0 120.0 38.0 A												
2	1 1	230.0	240.	500.	240.	1 1	-20.5	99.0	38.0	в		
. 3	. 1	230.0	120.	500.	120.	1 1	-18.0	78.0	38.0	С		
6	2	230.0	0.	500.	٥.	1	18.0	120.0	38.0	A		
7	З	230.0	240.	500.	0.	1	20.5	99.0	38.0	в		
8	-4	230.0	120.	1000.	120.	1	18.0	78.0	38.0	С		
4	1	.0	0.	0.	0.	1	-10.5	141.0	32.0	GND		
5	2	.D	D.	0. *******	0.		10.5 ********	141.0	32.0	GND		
		MIN	NIMUM G	ROUND CI	LEARANC	- 3C	40.00	feet				
. • .		PO	TER SYS	TEM FRE(JOENCA		60.	Hz				
		SO	IL RESI	STIVITY		-	100.	ohm mete	τ.			
****	****		*****	*******	******	*****	*******	*******	******	****		

.3640
.3640
.3640
0 .3640
0 .7210 0 .7210

			•				
	******	********	***********	********	★ .		
	• •	• •	•		•		
	•]	AC ELECTI	RIC FIELD PROP	FILE .	• • • • • •		
	* ai	E · 3.28 1	leet above gro	bund	• .	•	
			-		• .	•	
	* long:	itudinal	distance: 47	7.00 feet	•		
	*				•		
	******	*********		********	*		
LA	FERAL	MAXIMUM	MINOR/MAJOR			SPACE	
DIST	PANCE	FIELD	BLLIPSE AXES	VERTICAL	HORIZONTAL	POTENTIAL	
(feet)	(meters)	(kV/m)	(ratio)	(kV/m)	(kV/m)	()xV)	
							-
-50.0	-15,24	.856	.030.	.855	.144	.859	
-45.0	-13.72	1.101	.026	1.089	.166	1.093	
-40.0	-12.19	1.366	.022	1.354	.184	1.356	
-35.0	-10.67	1.651	.018	1.640	.191	1.640	•
-30.0	9.24	1.937	.014	1.928	.184	1,925	
-25.0	-7.62	2.200	.010	2.194	.161	2.187	•
-20.0	-6.10	2.416	.006	2.413	.125	2.404	
-15.0	-4.57	2.572	.003	2.571	.084	2.561	
-10.0	-3.05	2.668	.001	2.667	.047	2.660	
-5.0	-1.52	2,715	.000	2.715	.020	2,710	
.0	.00	2.729	.000	2.729	.000	2.724	
5.0	1.52	2,715	.000	2.715	.020	2.710	
10.0	3.05	2.668	.001	2.667	.047	2.660	
15.0	4.57	2.572	003	2.571	.084	2.561	•
20.0	6.10	2.416	.005	2.413	.125	2.404	
25.0	7.62	2,200	.010	2,194	.161	2,187	•
30.0	9.14	1,937	.014	1.928	.184	1,925	
35.0	10.67	1,651	.018	1.640	.191	1.640	•••
40.0	12.19	1.366	.022	1.354	.184	1.356	
45.0	13.72	1.101	.026	1.089	.166	1.093	•
50.0	15.24	.866	.030	.855	.144	.859	
100.0	30.48	.071	.145	.070	.014	.069	
150.0	45.72	.110	.010	.110	.002	.110	
100.0	30.48	.071	.145	.070	.014	.069	
150.0	45.72	.110	.010	.110	.002	.110	•

Oyster Creek Generating Station License Renewal Application Page E-89

.....

Results of AC/DCLINE program COUPLE (EPRI/HVTRC 7-93) for: COUPLING to OBJECTS & SHIELDING by OBJECTS

Configuration file name: C:\TLW30\ACDCLINE\DATA\ACT134 Date: 7/ 8/2004 Time: 15:37

DATE: 7/ 8/2004 TIME: 15:37 ***** ************************* BLECTRICAL COUPLING TO OBJECTS INCLUDING EFFECTS OF 6 SHIELDING OBJECTS OBJECT TYPE = 2 LONG BOX (LONG VEHICLE) ************** EQUIVALENT COUPLED OBJECT AREA = 3255.98 ft**2 EQUIVALENT COUPLED OBJECT AREA = 3255.96 IL--2 CALCULATED CAPACITANCE TO GROUND = 2500. pF CALCULATED RESISTANCE TO GROUND = .72 kohms (1% RESISTANCE VALUE MEASURED FOR VEHICLES WITH THE SAME CAPACITANCE, IN DIFFERENT WEATHER CONDITIONS AND ON DIFFERENT PAVEMENTS - NORTHEAST USA) LATERAL AND LONGITUDINAL DISTANCE TO OBJECT CENTER = .00 477.00 feet AC SHORT CIRCUIT CURRENT = 2.75 mA THEORETICAL MAXIMUM AC VOLTAGE TO GROUND = 1% AC VOLTAGE TO GROUND = 50% AC VOLTAGE TO GROUND = 2915. V 1638. V . • 242. V

Results of AC/DCLINE program BFION (EPRI/HVTRC 7-93) for: ELECTRIC FIELD & IONS WITHOUT SHIELDING OBJECTS

Configuration file name: C:\TLW30\ACDCLINE\DATA\ACT106 Date: 7/ 8/2004 Time: 15:42

T106 least clearance, no road - 175+00

*****	****	*******	*****	*****	*******	*****	********	*******	*****	******	
•				BUNI	LE INF	ORMAT	ION				•
1		VOLT	GE	CUI	RENT	#	BUNDLE	COORDIN	TES		i
BNDL	CIRC	VOLTAGE	ANGLE	LOAI) ANGLE	OF	X	Y	_ SAG	PH	1
] #]	#	(kV)	(DEG)	(A)	(DEG)	COND	(feet)	(feet)	(feet)) [.	1
*****	****	*******	*****	*****	******	*****	********	*******	*****	******	÷
1 1	1	230.0	0.	500). 0.	1	-18.0	109.0	36.	0 A	1
2	1	230.0	240.	500	1. 240.	1	-20.5	88.0	36.	o B	Ĺ
3	1 1	230.0	120.	500). 120.	1 1	-18.0	67.0	36.	0 C	
6	2	230.0	0.	500). 0.	1 1	18.0	109.0	36.	O A	1
7	3	230.0	240.	500).] 0.	1 1	20.5	88.0	36.	ој в	1
8	4	230.0	120.	1000). 120.	1 1	18.0	67.0	36.	oj c	1.
4	1) · .0	0.).] 0.	1	-10.5	130.0	29.1	GND	1
5	2	• .0	σ.) ().] 0.	1	10.5	130.0	29.	O GND	İ
•		MII POI SOI	IIMUM (VER SYS IL RESI	BROUND STEM FF	CLEARAN EQUENCY Y	CB =	31.00 60. - 100.	feet Hz ohm mete		•••••	• • • •
• ·	*****	50	BCONDU	CTOR 1	NFORMAT	ION -	REGULAR	BUNDLES	*****	******	***
BNDL	1 0	NDUCTOR	DIAN	ETER	SPACIN		C RESIST	AC RESI	ST	AC REA	CT
1 #	1 I	NAME] (ir	ich)	(inch)	1 6	ohm/mile)	(ohm/mi	le)	(ohm/mi	1e)
*****	****	********	*****	*****	******		*******	******	*****	*****	***
1 1	LAP	AING	1 1	L.500	18.00	0	.0580	.06	20	.36	40
2	LAP	RING	1 1	.500	18.00	οj	.0580	.06	20	.36	40
3	LAP	AING	1 1		18.00	0	.0580	.06	20	.36	40
6	LAP	TING	1 1	500	18.00	0	.0580	.06	20	.36	40.
1 7	LAP	ING	1 1	500	18.00	0	.0580	.06	20	.36	40
8	LAPI	ING	1 1	.500	18.00	0	.0580	.06	20 j	.364	40
4	7#63	AM .	Í	.490	18.00	0	1.5070	1.53	60	.72	10
5	7#63	AM .	1	.490	18.00	0	1.5070	1.53	60	.72	10

AC ELECTRIC PIELD PROFILE at 3.28 feet above ground longitudinal distance: 500.00 feet

LAT	TERAL	MAXIMUM	MINOR/MAJOR			SPACE
, DIST	TANCE	FIELD	BLLIPSE AXES	VERTICAL	HORIZONTAL	POTENTIAL
(feet)	(meters)	(kV/m)	(ratio)	(kV/m)	(kV/m)	(kV)
-50.0	-15.24	.807	.060	.786	.188	.795
-45.0	-13.72	1.122	048	1.099	.237	1.108
-40.0	-12.19	1,514	.039	1.488	.285	1.496
-35.0	-10.67	1.972	.031	1,947	.320	1.950
-30.0	-9.14	2.462	.023	2.441	.322	2.436
-25.0	-7.62	2.921	.014	2.908	.277	2.893
-20.0	-6.10	3.274	.007 -	3.269	.186	3.246
-15.0	-4.57	3.470	.000	3.469	.083	3.448
-10.0	-3.05	3.525	.003	3.525	.015	3.513
-5.0	-1.52	3.507	.003	3.507	.017	3.505
.0	.00	3.490	.000	3.490	` . 000	3.493
5.0	1.52	3.507	.003	3.507	.017	3.505
10.0	3.05	3.525	.003	3.525	.015	3.513
15.0	4.57	3.470	.000	3.469	.083	3.448
. 20.0	6.10	3.274	.007	3.269	.186	3.246
25.0	7.62	2.921	.014	2.908	·.277	2.893
. 30.0	9.14	2.462	.023	2.441	.322	2.436
35.0	10.67	1.972	.031	1.947	.320	1.950
40.0	12.19	1.514	.039	1.488	285	1.496
45.0	13.72	1.122	.048	1.099	.237	1.108
50.0	15.24	.807	.060	.786	.188	.795
100.0	30.48	.158	.050	.158	.009	.157
150.0	45.72	.140	.008	.139	.003	.139
100.0	30.48	.158	.050	.158	.009	.157
150.0	45.72	.140	.008	.139	.003	.139

> Results of AC/DCLINE program COUPLE (EPRI/HVTRC 7-93) for: COUPLING to CBJECTS & SHIELDING by OBJECTS

Configuration file name: C:\TLW30\ACDCLINE\DATA\ACT106 Date: 7/ 8/2004 Time: 15:42 DATE: 7/ 8/2004 TIME: 15:42 *************

ELECTRICAL COUPLING TO OBJECTS INCLUDING EFFECTS OF 6 SHIELDING OBJECTS

OBJECT TYPE = 2 LONG BOX (LONG VERICLE)

********************************** EQUIVALENT COUPLED OBJECT AREA = 1864.91 ft**2 CALCULATED CAPACITANCE TO GROUND = 1000. pF CALCULATED RESISTANCE TO GROUND = 1.80 kohms (1% RESISTANCE VALUE MEASURED FOR VEHICLES WITH THE SAME CAPACITANCE, IN DIFFERENT WEATHER CONDITIONS AND ON DIFFERENT PAVEMENTS - NORTHEAST USA)

LATERAL AND LONGITUDINAL DISTANCE TO OBJECT CENTER -10.00 500.00 feet 1 · · · · · · , î ۰.

AC SHORT CIRCUIT CURRENT -2.10 mA

THEORETICAL MAXIMUM AC VOLTAGE TO GROUND = 1% AC VOLTAGE TO GROUND = 50% AC VOLTAGE TO GROUND = 5582. V 3137. V 463. V

Oyster Creek Generating Station License Renewal Application

Page E-95

NJ DEP, Land Use Regulation Program June 15, 2005 Attachment

Attachment 8-1

SARA Right to Know 2004 Survey Cover Letter

.

Sec. 2.5. · . . . AmerCen Energy Company, LLC ----- **ACOM** An Exclon Company Opsicr Ersch, Als Rolding South, MC, Bought, Forted River, NJ 0823-0388 • February 28, 2005 2120-052-2889 New Jersey Department of Environmental Protection Office of Pollution Prevention and Right to Know P.O. Box 405 Trenton, NJ 08625-0405 Trenton, NJ 08625-0405 Dear Sir or Madam: Subject: OYSTER CREEK GENERATING STATION (OCXIS) 2004 SARA TITLE III, SECTION 312 REPORT · . In accordance with the reporting requirements of SARA Title III, Section 312, attached is the following Information for hazardous chemicals used by AmerGen at the OCGS. Section 312 - Community Right-to-Know Survey for 2004 If there are any questlyps rygarding this submittal, please contact me at (609) 971-4029. If there are any questions togarding this submittal, please contact me at (609) 971-4029. Sincerely, Donglas R Weigle Environmental Specialist Chemistry/Radwaste Attachment cc: Chief William A: Nally Lacey Township Office of Etherpency Management Chief William A. Nally Lacey Township Office of Emergency Management P.O. Box 184 Forked River, NJ 08731

February 28, 2005 2120-052-2889 New Jersey Department of Environmental Protection Page 2 cs: Occan County Health Department Community Right-to-Know Coordinator P.O. Box 2191 Torus River, NJ 08754 Chief, Forked River Fire Department Chief, Forked River Fire Department P.O. Box. 32 Forked River, NJ 08731 Laccy Police Department 108 West Laccy Road Forked River, NJ 08731 ..



.

Amer

File#05009

2130-05-20076

An Exelon Company

ArrenGen Energy Company, UC Oyster Creek US Route 9 South, PCD, Box 388 Forted River, NJ 08 331-0388

April 12, 2005

2120-052-2896

State of New Jersey Department of Environmental Protection Division of County Environmental and Waste Enforcement Programs Bureau of Hazardous Waste Compliance and Enforcement 300 Horizon Center P.O. Box 407 Trenton, NJ 08625-0407

אייאי באפוסיינסידף במוז

Attention: Ms. Anceta Sakheja

Dear Ms Sakheja:

Artached is completed USEPA Form 8700-13 for the year 2003, pertaining to the Oyster Creek Generating Station in Lacey Township, Ocean County, NJ. This form is being forwarded to you in response to the request made during the conference call that occurred on March 22, between yourself and Theresa Pagodin of the DEP and the following members of the station environmental staff – Lynn Newton, Douglas Weigle and Zigmund Karpa. We appreciate your time and attention to resolving the matter regarding the station status as a Small Quantity Generator (SQG) of hazardous waste.

During the conference call it was agreed that upon receipt of this USEPA Form 8700-13, that the station would receive a written confirmation that the Notice of Violation, dated January 21, 2005, would be rescinded. Please send this correspondence to Mr. Douglas R Weigle of our Chemistry Department. If you have any further questions, please do not hesitate to contact Mr. Weigle at (609) 971-4029.

Thank you for your assistance.

Very truly yours,

Randich Mr. James J. Randich

Mr. James J. Randich Plant Manager - Oyster Creek

cc. Theresa Pagodin Kim Moyer

.



Oyster Creek Generating Station License Renewal Application

 $\overline{\bigcirc}$

TI ILD OFFICE OC A08;				
	609971446 8;	APR-29-05 11:01;	PAGE 2	
• 	• 4••			
•				
· ·				
(GPU		GPU Nuc U.S. Rout	iser, ing, a de South	
NUCLEAR		Post Office	Box 388	
		Tal 609-97	1-4000	
Mr. Jeffrey Their	<i>.</i>	6530-99	2-2373	
New Jersey Department of E	invironmental Protection	JUN • 1	7329	
PO Box 029	itting Region I			
401 East State Street, 2" Flo	or East Wing			
17enton, NJ 08625-0029	~			
Deer Ma That	• •	•		
Dear Mr. Inem:		• •		
Subject: GPUN	luciear Inc. (GPUN)	· .	• •	
NIPDE	Creek Nuclear Generating St	ation (OCNOS)	• .	
Effuen	t Characterization Study Fina	50 I Report	•	
·	•	•		
GPU Nuclear, Inc. hereby sub-	mits the Effluent Characteriza	tion Study Final Report in Sus	11	
	Part IV-B/C of the subject .	and the second second second		
data collected during the Refu		ermit. This report summarizes	100	
data collected during the Efflue parameter analyzed. We will b	ent Characterization Study by to meet with the NII	each outfall/sampling point for	the reach	
of standardinal Requirement 2 of data collected during the Efflue parameter analyzed. We will b would care to discuss any aspe	ent Characterization Study by the happy to meet with the NII et of the report.	ernst. This report summarized each outfall/sampling point fly DEP, at your convenience, if yo	ing reach U	
of runnormal Requirement 2 of data collected during the Efflue parameter analyzed. We will b would care to discuss any aspe- lf you have any questions, pleas	ent Characterization Study by a happy to meet with the NJI ct of the report. se contact Malcolm Browne	ternat. This report summarizes each outfall/sampling point for DEP, at your convenience, if yo	ibe reach U	•
data collected during the Efflue parameter analyzed. We will b would care to discuss any aspe- lf you have any questions, pleas (609) 971-4021 of our Environ	ent Characterization Study by a happy to meet with the NII et of the report. se contact Malcolm Browne mental Affairs Department.	eennt. This report summarized each outfall/sampling point fly DEP, at your convenience, if yo (609) 971-4124, or Jay Vougit	ins cach u	•
of standarding Requirement 2 of data collected during the Efflue parameter analyzod. We will b would care to discuss any aspo- lf you have any questions, plea- (609) 971-4021 of our Environ	ent Characterization Study by a happy to meet with the NII et of the report. se contact Malcolm Browne mental Affairs Department.	eenat. This report summarizes 'each outfall/sampling point for DEP,' at your convenience, if yo (609) 971-4124, or Jay Vouglit	ine each U	
d standonal Requirement 2 of data collected during the Efflue parameter analyzod. We will b would care to discuss any aspe- lf you have any questions, pleas (609) 971-4021 of our Environ	ent Characterization Study by the happy to meet with the NII et of the report. se contact Malcolm Browne mental Affairs Department.	eenat. This report summarized each outfall/sampling point for DEP, at your convenience, if yo (609) 971-4124, or Jay Vougit	ine each U	
of Andriborial Requirement 2 of data collected during the Efflue parameter analyzod. We will b would care to discuss any area if you have any questions, pleat (609) 971-4021 of our Environ	ent Characterization Study by a happy to meet with the NJ et of the report. se contact Malcolm Browne mental Affairs Department. Very to	vernat. This report summarizes veach outfall/sampling point for DEP, at your convenience, if yo (609) 971-4124, or Jay Vouglit uby yours,	ine each u oir	
of Auditorial Requirement 2 of data collected during the Efflue parameter analyzed. We will b would care to discuss any aspe- lf you have any questions, pleas (609) 971-4021 of our Environ	ent Characterization Study by the happy to meet with the NII et of the report. se contact Malcolm Browne imental Affairs Department. Very in Wery in	vernat. This report summarized i each outfall/sampling point for DEP, at your convenience, if yo (609) 971-4124, or Jay Vougit uby yours,	ine each u	• •
of Auditorial Requirement 2 of data collected during the Efflue parameter analyzed. We will b would care to discuss any aspe- lf you have any questions, pleas (609) 971-4021 of our Environ	ent Characterization Study by the happy to meet with the NII et of the report. se contact Malcolm Browne (mental Affairy Department, Very the Michael	vernal. This report summarized i each outfall/sampling point for DEP, at your convenience, if yo (609) 971-4124, or Jay Vouglit uly yours, Lul B Rocke B. Roche	ine each U	• •
of Andriborial Requirement 2 of data collected during the Efflue parameter analyzod. We will b would care to discuss any area If you have any questions, pleat (609) 971-4021 of our Environ	ent Characterization Study by the happy to meet with the NJ et of the report. se contact Malcolm Browne importal Affairs Department. Very the Michael Vice Pro	Vernal. This report summarized veach outfall/sampling point for DEP, at your convenience, if you (609) 971-4124, or Jay Vouglit uby yours, hul B Rocke B. Roche essident & Director, OC	ine cach u	• • •
MBR/MEB/ew	ent Characterization Study by the happy to meet with the NII set of the report. se contact Malcolm Browne i ministal Affairy Department. Very the Vk.J Michael Vice Pre	Vernat. This report summarizes i each outfall/sampling point for DEP, at your convenience, if yo (609) 971-4124, or Jay Vougät uby yours, hul B Rocke B. Rocke scident & Director, OC	ine each ti	• •
MBR/MEB/ew	ent Characterization Study by the happy to meet with the NII tet of the report. se contact Malcolm Browne in mental Affairy Department. Very the Michael Vice Pre	vernal. This report summarizes veach outfall/sampling point for DEP, at your convenience, if you (609) 971-4124, or Jay Vouglit uhy yours, hul B Rocke B. Roche essident & Director, OC	ine cach u ois	•
MBR/MEB/ew	ent Characterization Study by the happy to meet with the NII set of the report. se contact Malcolm Browne : mental Affairy Department. Very in Vice In Michael Vice Pro	vernal. This report summarizes veach outfall/sampling point for DEP, at your convenience, if you (609) 971-4124, or Jay Vouglit uty yours, lul B Rocke B. Roche exident & Director, OC	ine each ti	•
MBR/MEB/ew	ent Characterization Study by the happy to meet with the NII set of the report. se contact Malcolm Browne ministal Affairy Department. Very the Vk.2 Michael Vice Pre	Vernal. This report summarizes veach outfall/sampling point for DEP, at your convenience, if you (609) 971-4124, or Jay Vouglit uby yours, Lul B Rocke B. Rocke Scient & Director, OC	ine each ti	• •
MBR/MEE/ew	ent Characterization Study by the happy to meet with the NII set of the report. se contact Malcolm Browne mental Affairy Department. Very the Michael Vice Pre	Vernal. This report summarized veach outfall/sampling point for DEP, at your convenience, if you (609) 971-4124, or Jay Vouglit uly yours, Lul B Rocke B. Roche esident & Director, OC	ine reach U	•
MBR/MEB/ew	ent Characterization Study by the happy to meet with the NII tet of the report. se contact Malcolm Browne umental Affairy Department. Very the Michael Vice Pro	vernal. This report summarized veach outfall/sampling point for DEP, at your convenience, if yo (609) 971-4124, or Jay Vouglit uly yours, lul B Rocke B. Roche exident & Director, OC	ine reach Dis	•

Page E-102

.

•,• •	•	•	
		. •	
		AmerC	on
AmerCen Energy Company, LLC www.	meloncorp.com	- MILLING	
Oyster Criet	• • •	An Excion (Commany
Forbad River, NI climanas			
			•
	•	•	
2120 040 0044		· · ·	•
2120-042-2800			•
		DEC 10 2004	· ·
NU Department of Environmental P	rotection		
LAVIEION OF Water Quality			-
Providence of Standard Permitting	1.11 1.11 1.		
F.U. BOX 029			
1 renton, NJ 08625-0029		•	
Ann: Industrial Biomonitoring Prog	78-00	. • •	
		•	•
THE STL OL WEGHT.		•	•
	•	•	•
SUBJECT: AMERGEN ENERGY CO	MPANY, LLC		
OYSTER CREEK GENER	ATENG STATION		• •
NUPDES DSW PERMIT NO	D. NJ 0005550		
In accordance with Part IV-B/C of the the following forms for discharge point	c 1-2004 e above aubject permit, ple niz DSN001, DSN002, an	use find enclosed two copies of I DSN004 for 2004:	•
In accordance with Part IV-B/C of the the following forms for discharge point NIPDES Biomonitoring R	cI-2004 e above subject permit, ple nit DSN001, DSN002, an sport Form - Acute Bioss	ase find enclosed two copies of I DSN004 for 2004: Fays (Ammuni)	
In accordance with Part IV-B/C of the the following forms for discharge point • NIPDES Biomonitoring R If you have any questions concerning Browne of our Chemistry/Radwaste D	c1-2004 above subject permit, ple nix DSN001, DSN002, an eport Form - Acute Biossi this report, please do not h repartment at (609) 971-41	ase find enclosed two copies of I DSN004 for 2004: tays (Amnual) estime to contact Mr. Malcolm 24.	
In accordance with Part IV-B/C of the the following forms for discharge point NIPDES Biomonitoring R If you have any questions concerning Browne of our Chemistry/Radwaste D	(I-2004 e above aubject permit, pie nix DSN001, DSN002, an sport Form - Acute Bioss this report, please do not h repartment at (609) 971-41 Very traly yours,	ase find enclosed two copies of d DSN004 for 2004: says (Ammual) estime to contact Mr. Malcolm 24.	
In accordance with Part IV-B/C of the the following forms for discharge point NIPDES Biomonitoring R If you have any questions concerning Browne of our Chemistry/Radwaste D	CI-2004 e above subject permit, pie nis DSN001, DSN002, an eport Form - Acute Bioast this report, please do not h repartment at (609) 971-41 Very traly yours, PMI	use find enclosed two copies of d DSN004 for 2004: tays (Ammuil) estime to connect Mr. Malcoim 24.	
In accordance with Part IV-BAC of the the following forms for discharge point • NIPDES Biomonitoring R If you have any questions concerning (Browne of our Chemistry/Radwaste D	c1-2004 e above subject permit, pie nis DSN001, DSN002, an sport Form - Acute Biossi this report, please do not h repartment at (609) 971-41 Very traiy yours, Wether for	use find enclosed two copies of d DSN004 for 2004: says (Ammual) estime to connect Mr. Malcoira 24.	
In accordance with Part IV-BAC of the the following forms for discharge point • NIPDES Biomonitoring R If you have any questions concerning Browne of our Chemistry/Radwaste D	(I-2004 a above subject permit, ple nix DSN001, DSN002, and sport Form - Acute Bions this report, please do not h repartment at (609) 971-41 Very traly yours, Witchnet I biosco	use find enclosed two copies of d DSN004 for 2004: says (Ammuel) exitate to contact Mr. Malcoira 24.	
In accordance with Part IV-B/C of the the following forms for discharge pol NIPDES Biomonitoring R If you have any questions concerning (Browne of our Chemistry/Radwaste D	CI-2004 a above subject permit, pie nits DSIN001, DSIN002, and sport Form - Acute Bioass this report, please do not h repartment at (609) 971-41 Very truly yours, Michael J. Massaro Plant Monseer	ase find enclosed two copies of d DSN004 for 2004: says (Amnual) exitate to contact Mr. Malcoira 24.	
In accordance with Part IV-B/C of the the following forms for discharge point NIPDES Biomonitoring R If you have any questions concerning Browne of our Chemistry/Radwaste D	CI-2004 a above subject permit, ple nits DSN001, DSN002, and aport Form - Acute Biossi this report, please do not h repartment at (609) 971-41 Very traiy yours, Witchel J. Massaro Plant Manager Ovate Creat	ase find enclosed two copies of I DSN004 for 2004: Hays (Amnual) estimate to connect Mr. Malcoira 24.	
In accordance with Part IV-B/C of the the following forms for diacharge point NIPDES Biomonitoring R If you have any questions concerning Browne of our Chemistry/Radwaste D	CI-2004 a above subject permit, ple nits DSN001, DSN002, and aport Form - Acute Biossi this report, please do not a heperiment at (609) 971-41 Very traly yours, Witchel J. Massaro Plant Manager Oyster Creek	and find enclosed two copies of d DSN004 for 2004: tays (Ammuel) reliting to contact Mr. Malcoim 24.	
In accordance with Part IV-B/C of the the following forms for diacharge point NIPDES Biomonitoring R If you have any questions concerning Browne of our Chemistry/Radwaste D	CI-2004 a above subject permit, ple nits DSN001, DSN002, and sport Form - Acote Biossi this report, please do not a reportment at (609) 971-41 Very traly yours, Wery traly yours, Michael J. Mansaro Plant Manager Oyster Creek	not find enclosed two copies of d DSN004 for 2004: tays (Amnual) estimate to contact Mr. Malcoira 24.	
In accordance with Part IV-B/C of the the following forms for discharge point NIPDES Biomonitoring R If you have any questions concerning Browne of our Chemistry/Radwaste D MIM/MEB/dm Attachment	CI-2004 a above subject permit, ple nis DSN001, DSN002, and report Form - Acute Biossi this report, please do not h reportment at (609) 971-41 Very traly yours, Wery traly yours, Michael J. Manager Oyster Creek	ase find enclosed two copies of I DSN004 for 2004: Fays (Ammuel) editate to contact Mr. Malcoim 24.	
In accordance with Part IV-BAC of the the following forms for discharge point NIPDES Biomonitoring R If you have any questions concerning (Browne of our Chemistry/Radwaste D MJM/MER/dm Atlachment	c1-2004 e above subject permit, ple nis DSN001, DSN002, an eport Form - Acute Bioass this report, please do not h repartment at (609) 971-41 Very traly yours, Micbael J. Massaro Piant Manager Oyster Creek	nest find enclosed two copies of I DSN004 for 2004: Fays (Ammuni) retitute to commer Mr. Malcoim 24.	
In accordance with Part IV-BAC of the the following forms for discharge point NIPDES Biomonitoring R If you have any questions concerning Browne of our Chemistry/Radwaste D MJM/MEB/dm Attachment ce: Geoffrey Pritchard	(I-2004 a above subject permit, pie nix DSN001, DSN002, and seport Form - Acute Bioast this report, please do not h repartment at (609) 971-41 Very traly yours, Witcheel J. Massaro Plant Manager Oyster Creek	nest find enclosed two copies of d DSN004 for 2004: rays (Ammuni) estimate to connect Mr. Malcoira 24.	
In accordance with Part IV-B/C of the the following forms for discharge point NIPDES Biomonitoring R If you have any questions concerning Browne of our Chemistry/Radwaste D MDM/MEB/dm Attachment ce: Geoffrey Pritchard NJ Dept of Environmental Protectio	c1-2004 a above subject permit, ple nix DSN001, DSN002, and seport Form - Acute Biossi this report, please do not h repartment at (609) 971-41 Very traiy yours, Wery traiy yours, Michael J. Massaro Plant Manager Oyster Creek	ase find enclosed two copies of d DSN004 for 2004: tays (Ammuel) editate to contact Mr. Malcoim 24.	
In accordance with Part IV-BAC of the the following forms for discharge point NIPDES Biomonitoring R If you have any questions concerning Browne of our Chemistry/Radwaste D MIM/MEB/dm Attachment cc: Geoffrey Pritchard NJ Dept. of Environmental Protectio Central Bureau of Water Compliano	CI-2004 a above subject permit, pie nis DSN001, DSN002, and seport Form - Acute Bioast this report, please do not h repartment at (609) 971-41 Very traly yours, Witcheel J. Massaro Plant Manager Oyster Creek 20 e & Enforcement	nest find enclosed two copies of d DSN004 for 2004: rays (Ammuni) retitute to commer Mr. Malcoim 24.	
In accordance with Part IV-BAC of the the following forms for discharge pol NIPDES Biomonitoring R If you have any questions concerning (Browne of our Chemistry/Radwaste D MDM/MEBAhn Attachment cc: Geoffrey Pritchard NJ Dept. of Environmental Protectio Central Bureau of Water Compliance P.O. Box 407	CI-2004 a above subject permit, pie nis DSN001, DSN002, and sport Form - Acute Bioass this report, please do not h repartment at (609) 971-41 Very truly yours. Withduff Michael J. Massaro Plant Manager Oyster Creek 20 e & Enforcement	nest find enclosed two copies of d DSN004 for 2004: rays (Ammuni) estime to connect Mr. Malcoira 24.	
In accordance with Part IV-BAC of the the following forms for discharge poli- NIPDES Biomonitoring R If you have any questions concerning (Browne of our Chemistry/Radwaste D MIMs/MEB/dm Attachment cc: Geodfrey Pritchard NJ Dept. of Environmental Protection Central Burean of Water Compliance P.O. Box 407 Trenton, NJ 08625-0407	CI-2004 a above subject permit, pie nits DSIN001, DSIN002, and report Form - Acute Biossi this report, pienes do not h Repartment at (609) 971-41 Very truly yours, Michael J. Massaro Piant Manager Oyster Creek 20 e & Enforcement	ase find enclosed two copies of d DSN004 for 2004: tays (Amauzi) relitate to contact Mr. Malcoira 24.	
MJM/MEB/dm MJM/MEB/dm Attachment ce: Geodfrey Pritchard NJ Dept. of Environmental Protection Central Bureau of Water Compliance P.O. Box 407 Trenton, NJ 08625-0407	CI-2004 a above subject permit, ple nits DSN001, DSN002, and seport Form - Acute Biossi this report, please do not a heperiment at (609) 971-4] Very traly yours, Witchael J. Massaro Plant Manager Oyster Creak	not find enclosed two copies of d DSN004 for 2004: tays (Ammuel) retitute to contact Mr. Malcoira 24.	
In accordance with Part IV-BAC of the the following forms for diacharge point NIPDES Biomonitoring R If you have any questions concerning Browne of our Chemistry/Radwaste D Browne of our Chemistry/Radwaste D MJM6/MEBAdm Attachment ce: Geoffrey Pritchard NJ Dept. of Environmental Protectio Central Bureau of Water Compliance P.O. Box 407 Trenton, NJ 08625-0407	CI-2004 a above subject permit, ple nits DSN001, DSN002, and seport Form - Acote Biossi this report, please do not a heperiment at (609) 971-4] Very traly yours, Witchael J. Massaro Plant Manager Oyster Creak	not find enclosed two copies of d DSN004 for 2004: tays (Ammuel) estimate to contact Mr. Malcoira 24.	•
In accordance with Part IV-BAC of the the following forms for discharge point NIPDES Biomonitoring R If you have any questions concerning (Browne of our Chemistry/Radwaste D Browne of our Chemistry/Radwaste D MIM/MEB/dm Attachment cc: Geodfrey Pritchard NJ Dept. of Environmental Protection Central Bureau of Water Compliance P.O. Box 407 Trenton, NJ 08625-0407	c1-2004 a above subject permit, ple nix DSN001, DSN002, and sport Form - Acote Biossi this report, please do not a reportment at (609) 971-41 Very traly yours, Witcheel J. Mansaro Plant Manager Oyster Creek 20 e & Enforcement	nose find enclosed two copies of d DSIN004 for 2004: Hays (Ammuel) estimate to contact Mr. Malcoira 24.	

Oyster Creek Generating Station License Renewal Application

L

Page E-103
Environmental Report Appendix E Coastal Zone Consistency Certification

NJ DEP, Land Use Regulation Program June 15, 2005 Attachment

Attachment 8-4

2003 Annual Radioactive Effluent Release Report Cover Letter



An Exelon Company

AmerGen Energy Company, LLC Oyster Creek US Route 9 South, P.O. Box 388 Forked River, NJ 08731-0388

Technical Specification 6.9.1.e

April 29, 2004 2130-04-20096 2120-042-2823

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

Oyster Creek Generating Station Facility Operating License No. DPR-16 NRC Docket No. 50-219

www.exeloncom.com

Subject:

Enclosed is a copy of the Annual Radiological Environmental Operating Report for calendar year 2003, for the Oyster Creek Generating Station. This submittal is made in accordance with Oyster Creek Generating Station Technical Specification 6.9.1.e.

Annual Radiological Environmental Operating Report - 2003

If any further information or assistance is needed, please contact David Fawcett at 609-971-4284.

Since Mada

C. N. Swenson Vice President, Oyster Creek Generating Station

CNS/DW/DIF Enclosure

CC:

H. J. Miller, Administrator, USNRC Region I P. S. Tam, USNRC Senior Project Manager, Oyster Creek R. J. Summers, USNRC Senior Resident Inspector, Oyster Creek

File No. 04004

Oyster Creek Generating Station License Renewal Application

IE25

NJ DEP, Land Use Regulation Program June 15, 2005 Attachment

Attachment 8-5

2004 Annual Radiological Environmental Operating Report Cover Letter

AmerGen.

An Exelon Company

AmerGen Energy Company, LLC Oyster Creek US Route 9 South, PO. Box 388 Forked River, NJ 08731-0388

Technical Specification 6.9.1.e

April 29, 2005 2130-05-20082 2120-052-2904

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

> Oyster Creek Generating Station Facility Operating License No. DPR-16 NRC Docket No. 50-219

wexeloncorp.com

Subject:

Annual Radiological Environmental Operating Report - 2004

Enclosed is a copy of the Annual Radiological Environmental Operating Report for calendar year 2004, for the Oyster Creek Generating Station. This submittal is made in accordance with Oyster Creek Generating Station Technical Specification 6.9.1.e.

If any further information or assistance is needed, please contact David Fawcett at 609-971-4284.

Sincerely

C. N. Swenson Vice President, Oyster Creek Generating Station

CNS/DRW/DIF Enclosure

cc: S. J. Colllins, Administrator, USNRC Region I P. S. Tam, USNRC Senior Project Manager, Oyster Creek R. J. Summers, USNRC Senior Resident Inspector, Oyster Creek File No. 05004

APPENDIX F

Severe Accident Mitigation Alternatives

Oyster Creek Nuclear Generating Station

TABLE OF CONTENTS

Section

<u>Page</u>

F.1 Methodology	⊦-2
F.1.1 Oyster Creek Specific SAMA	F-4
F.1.2 Quantitative Strategy for External Event Assessment	
F.2 Oyster Creek PRA Model	F-8
F.2.1 PRA Model Changes Since IPE Submittal	F-9
F.2.2 Current Level 1 Internal Events PRA Model	F-11
F.2.3 External Events Modeling	F-16
F.2.3.1 Fires	F-16
F.2.3.2 Seismic	F-19
F.2.3.3 Other External Events	F-23
F.2.4 Current Level 2 Oyster Creek PRA Model	F-28
F.2.4.1 Consequence Bins: Source Term Severity	F - 28
F.2.4.2 Consequence Bins: Timing of Release	F - 29
F.2.4.3 Oyster Creek Level 2 PRA Radionuclide Release Categories	F-29
F.2.4.4 Oyster Creek Level 2 PRA Source Terms	F-38
F.2.5 PRA Model Review Summary	F-41
F.3 Level 3 PSA Analysis	F-45
F.3.1 Analysis	F-45
F.3.2 Population	F-46
F.3.3 Economy	F-47
F.3.4 Food and Agriculture	F-48
F.3.5 Nuclide Release	F-49
F.3.6 Evacuation	F-50
F.3.7 Meteorology	F-54
F.3.8 MACCS2 Results	F-56
F.3.8.1 Base Case	F-56
F.3.8.2 Sensitivity Cases	F-56
F.4 Baseline Risk Monetization	F-62
F.4.1 Off-Site Exposure Cost	F-63
F.4.2 Off-Site Economic Cost Risk (OECR)	F-64
F.4.3 On-Site Exposure Cost Risk	F-65
F.4.4 On-Site Cleanup and Decontamination Cost - Risk	F-67
F.4.5 Replacement Power Cost - Risk	F-68
F.4.6 Total Cost - Risk	F-69
F 5 Phase I SAMA Analysis	F-70
F 5 1 SAMA Identification	F_71
E 5 1 1 Level 1 Ovster Creek Importance List Review	F-72
F 5 1 2 Level 2 Ovster Creek Importance List Review	F-72
F513 Industry Phase II SAMAs	F_00
E 5 1 A Oveter Creek IPE	F-00
E 5 1 5 Oveter Creek IPEEE	E_100
E 5 1 6 Ovster Creek System Manager Inpute	I -100 E-101
E 5.2 Approximate Implementation costs	E 402
F.5.2 Approximate implementation costs	F-102
F.O.O FHASE I AHAIYSIS	F-103
F.U FIIdse II SAIVIA Alidiysis	
F.O.2 SAMA IU. Passive Overpressure Relief	

TABLE OF CONTENTS (CONTINUED)

Section

Page

F.6.3	SAMA 18: Improved Ability To Cool The Containment Spray System	
	Heat Exchangers	.F-161
F.6.4	SAMA 20: Re-Open MSIVs to Restore the Main Condenser as a Heat Sink	.F-163
F.6.5	SAMA 23: Diversify The Explosive Valve Operation	.F-165
F.6.6	SAMA 25: Bypass Low Pressure Permissive	.F-166
F.6.7	SAMA 67: Safety Related Condensate Storage Tank	. F-167
F.6.8	SAMA 84: Manually Operate Containment Vent Valves	. F-16 9
F.6.9	SAMA 88: Containment Vent	.F-171
F.6.10	SAMA 89: Improve Procedure For Aligning SDC Given High DW Pressure	.F-173
F.6.11	SAMA 91: Allow 4160 VAC Bus IC And ID Crosstie	.F-174
F.6.12	SAMA 92: Allow Operators To Maximize CRD Flow	. F-176
F.6.13	SAMA 94: Increase Success Probability For Fire Protection Alignment	. F-178
F.6.14	SAMA 95: Add Procedural Clarification Related To 5 Psid CSS Alarm	.F-180
F.6.15	SAMA 99: Provide an Alternate Method for IC Shell Water Level Determination	. F-1 81
F.6.16	SAMA 100: Connect SBO Transformer to Both AC Divisions.	.F-183
F.6.17	SAMA 101: Provide A Procedure For Determining RPV Level Using Fuel Zone	
	Level Indicators A and C With SLC Operating	. F-185
F.6.18	SAMA 102: Revise ATWS EOP To Provide RPV Level Correction Based On Power .	. F-187
F.6.19	SAMA 104: Improve Loss Of Circulating Water Response	.F-188
F.6.20	SAMA 106: Improve Direction For Cooldown In Loss Of RBCCW	. F-190
F.6.21	SAMA 107: Reduce Potential for Loss of CST Inventory following Loss of	
	Instrument Air	.F-192
F.6.22	SAMA 108: Reduce Fuel Zone Level Instrument Error Band	.F-193
F.6.23	SAMA 109: Portable DC Battery Charger To Preserve IC And EMRV Operability	
	Along With Adequate Instrumentation	.F-195
F.6.24	SAMA 110: Delete High Drywell Pressure Signal From SDC Isolation	.F-197
F.6.25	SAMA 111: Provide Alternate Drywell Spray Injection Source	. F-198
F.6.26	SAMA 112: Intake Structure	. F-1 99
F.6.27	SAMA 124: Reinforcement Block Wall 53	. F-200
F.6.27	7.1 Two Approaches	.F-200
F.6.27	7.2 Approach 1	.F-200
F.6.27	7.3 Approach 2	.F-200
F.6.27	7.4 Summary	.F-203
F.6.28	SAMA 125: Reduce Fire Impact in Higher Risk Fire Areas	.F-204
F.6.29	Not Used	.F-213
F.6.30	SAMA 127: Operator Training	.F-214
F.6.31	SAMA 128: IC Fouling	.F-215
F.6.32	SAMA 129: Internal Flooding Procedure Enhancements	.F-216
F.6.33	SAMA 130: Protect Combustion Turbines	.F-218
F.6.34	SAMA 132: Reduce Probability Of Multi-CT Operation	.F-220
F.6.35	SAMA 133: Increase Hotwell Makeup Capability	.F-222
F.6.36	SAMA 134: Upgrade Fire Pump House Structural Integrity	.F-224
F.6.37	SAMA 136: Provide Alternate Power To Condensate Transfer Pumps	.F-226
F.6.38	SAMA 138: Protect Transformers	.F-227
F.6.39	Combined Impact of SAMAs	.F - 229
F.6.39	9.1 Review of Cost Beneficial SAMA That Are Reduced In Benefit By Other SAMA	.F-229
F.6.39	9.2 Synergies Among Non-Cost-Beneficial SAMAs	.F - 240
F.6.39	9.3 Summary of Combinations	.F - 243
F.6.40	Phase II SAMA Analysis Summary	. F-2 45
F.7 Ser	nsitivity Analysis	.F - 248

Oyster Creek Generating Station License Renewal Application .

TABLE OF CONTENTS (CONTINUED)

Section

<u>Page</u>

F.7.1	Real Discount Rate	F-249
F.7.2	95 th Percentile PRA Results	F-250
F.8 Cor	nclusions	F-272
F.8.1	Overview	F-272
F.8.2	Best Estimate Results	F-273
F.8.3	Sensitivity Analysis Results	F-275
F.8.3.	1 RDR Change: A Sensitivity Evaluation	F-275
F.8.3.	2 Risk Profile Changes: A Sensitivity Evaluation	F-275
F.9 Ref	erences	F-277
Addendum F	A External Events Excerpts From NUREG-1437 Vol I	F-282

List of Tables

<u>Table</u>

F-1	Accident Class Distribution Table (2004B PRA Model)	F-12
F-2	Contribution of the Top Ten Seismic Model Failures	F-22
F-3	Contribution of Top Fragilities in Seismic Scenarios	F-22
F-4	Release Severity And Timing Classification Scheme ⁽¹⁾	F-33
F-5	Release Severity And Timing Classification Matrix	F-34
F-6	Summary Of Oyster Creek Level 2 Release Categories (/Yr)(1), (2)	F-35
F-6A	Accident Sequence Timings as a Function of Consequence Category	
	(2004B Oyster Creek PRA)	F-36
F-7	Öyster Creek Source Term Summary	F-39
F-8A	Estimated Population Distribution Within a 10-Mile Radius of Oyster Creek, Year 2029	F-51
F-8B	Estimated Population Distribution Within a 50-Mile Radius of Oyster Creek, Year 2029	F-52
F-9	MACCS2 Release Categories vs. Oyster Creek Release Categories	F - 53
F-10	MACCS2 Base Case Mean Results	F-59
F-11	Accident Sequence Timings As A Function Of Consequence Category - Base Case	F-60
F-12	MACCS2 Sensitivity Cases Results	F-61
F-13	Level 1 Importance List Review	F-73
F-14	Level 2 Importance List Review (Based on LERF RRW)	F-85
F-15	Phase I SAMA Evaluation	F-104
F-16	Phase II SAMA Disposition Summary	F-146
F-17	Summary of Fire Impacts Added to Base Model	F - 209
F-18	Evaluation of Combinations of SAMAS	F-231
F-19	Summary of the Detailed Phase II SAMA Analyses	F - 246
F.7-1	Summary of Sensitivity Review of Phase I Screened SAMA	F-252
F.7 - 2	Summary of SAMA Discount Sensitivity	F-266
F.7-3	Summary of 95 th Percentile Sensitivity Analysis	F-268
F.7-4	Summary of "New" Cost Beneficial SAMAs if CDF Increased to 95th Percentile	F-270
F.8-1	Cost Beneficial SAMAS When Considered Separately	F-273
F.8-2	Summary of Additional Cost Beneficial SAMA if RDR Changed to 3%	F-275
F.8-3	Summary of Additional Cost Beneficial SAMA if CDF Increased to 95th Percentile	F-276

<u>Page</u>

List of Figures

Figure

<u>Page</u>

-

F-1	SAMA Screening Process	F-3
F-2	Ovster Creek Contribution to CDF by Initiator (2004B Model)	F-13
F-3a	System RAW Ranking (CDF)	F-14
F-3b	System Fussell-Vesely Ranking (Model 2004B)	F-15
F-4	Approach for Other External Hazards	F-24
F-5	Summary of Release Magnitudes	F-37

Appendix F Severe Accident Mitigation Alternatives

This appendix outlines the general methodology for completing the Severe Accident Mitigation Alternatives (SAMA) evaluation in support of License Renewal and its implementation for Oyster Creek. The basis for the methodology comes from past SAMA submittals along with substantial input provided by NRC Requests for Additional Information (RAI).

The requirements for a SAMA evaluation are derived from the 1969 National Environmental Protection Act (NEPA) and the following Code of Federal Regulations (CFR):

- The environmental report must contain a consideration of alternatives to mitigate severe accidents "...if the staff has not previously considered severe accident mitigation alternatives for the applicant's plant in an environmental impact statement or related supplement or in an environmental assessment..." 10 CFR 51.53(c)(3)(ii)(L)
- "...The probability weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to ground water, and societal and economic impacts from severe accidents are small for all plants. However, alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives..." 10 CFR 51, Subpart A, Appendix B, Table B-1, Issue 76

The severe accident mitigation alternatives (SAMA) analysis discussed in 4.20 is presented below.

F.1 Methodology

The methodology selected for this analysis involves identifying SAMA candidates that have the potential for reducing core damage frequency and person-rem and determining whether or not the implementation of those mitigation candidates is beneficial on a cost-risk reduction basis compared with implementation costs. This process consists of the following steps:

- Oyster Creek Probabilistic Risk Assessment (PRA) Model Use the Oyster Creek Internal Events PRA model as the basis for the analysis. Incorporate External Events contributions using IPEEE Submittal [F-22] (Section F.2).
- Level 3 PRA Analysis Use Oyster Creek Level 1 and 2 Internal Events PRA output and site-specific meteorology, demographic, land use, and emergency response data as input in performing a Level 3 probabilistic safety assessment (PRA) using the MELCOR Accident Consequences Code System Version 2 (MACCS2) (Section F.3).
- **Baseline Risk Monetization** Use NRC regulatory analysis techniques, calculate the monetary value of the unmitigated Oyster Creek severe accident risk. This becomes the maximum averted cost-risk that is possible (Section F.4).
- Phase I SAMA Analysis Identify potential SAMA candidates based on the Oyster Creek PRA, IPEEE, plant specific aging issues, and documentation from the industry and the NRC. Screen out Phase I SAMA candidates that are not applicable to the Oyster Creek design or are of low benefit in boiling water reactors (BWRs) such as Oyster Creek, candidates that have already been implemented at Oyster Creek or whose benefits have been achieved at Oyster Creek using other means, and candidates whose estimated cost exceeds the maximum possible averted cost-risk (Section F.5).
- Phase II SAMA Analysis Calculate the risk reduction attributable to each remaining SAMA candidate and compare to a more detailed cost analysis to identify any net cost benefit. Probabilistic risk assessment (PRA) insights are also used to screen SAMA candidates in this phase (Section F.6).
- Sensitivity Analysis Evaluate how changes in the SAMA analysis assumptions might affect the cost/benefit evaluation (Section F.7).
- **Conclusions** Summarize results and identify conclusions. In addition, list plant modifications and procedural changes (if any) that have or will be implemented to reduce the severe accident dose consequence risk (Section F.8).

The steps outlined above are described in more detail in the subsections of this appendix. Figure F-1 provides a graphical representation of the SAMA process.



⁽¹⁾ Risk significant system in this analysis is any system, structure, or component with a risk reduction worth (RRW) greater than 1.01.

F.1.1 OYSTER CREEK SPECIFIC SAMA

One of the initial steps in the SAMA process is to identify practical physical plant modifications and plant procedural and administrative changes that can reduce severe accident dose consequence risk. For each modification or change, estimate the approximate reduction in risk.

The initial list of SAMA candidates for Oyster Creek was developed from a combination of resources. These include the following:

- Oyster Creek PRA results [F-25]
- Industry Phase II SAMAs [F-6, F-7, F-8, F-11, F-13]
- Oyster Creek IPEEE [F-22]
- NUREG-1742 [F-45]
- Aging Issues⁽¹⁾

These resources are judged to provide a list of potential plant changes that are most applicable and most likely to yield potential candidates that reduce risk in a cost-effective manner for Oyster Creek.

The emphasis in the SAMA evaluation process has been on ensuring that Oyster Creek specific plant features are assessed using the available Oyster Creek PRA tools. This is judged to be the most appropriate source of potential SAMA items. Generic lists of SAMAs are also reviewed to ensure that proper attention is given to useful SAMAs identified at similar BWRs. The details of the SAMA identification process are provided in Section F.5.1.

⁽¹⁾ The License Renewal process includes an extensive process for assessing the aging effects on the plant and providing adequate methods for addressing them.

F.1.2 QUANTITATIVE STRATEGY FOR EXTERNAL EVENT ASSESSMENT

External events have been identified by the nuclear industry as small, but non-negligible contributors to plant risk. (See Addendum FA.) The following summary is excerpted from NUREG-1437 (as noted in Addendum FA):

"..., the commission concludes that the risk from sabotage and beyond design basis earthquakes at existing nuclear power plants is small and additionally, that the risks from other external events, are adequately addressed by a generic consideration of internally initiated severe accidents."

While the focus of nuclear PRA applications has typically been on internal events models, efforts have been made to expand the types of PRA insights used in the SAMA analysis to include external events issues.

The Oyster Creek Individual Plant External Events Examination (IPEEE) [F-22] has not been maintained as a "living" analysis. The documentation and results are limited to what was produced during the performance of the Individual Plant External Events Examination (IPEEE). As a result, any qualitative insights or quantitative estimates related to external events used in the SAMA analysis is usually extrapolated from outdated information.

Another disadvantage of not maintaining a living external events model is that the latest PRA techniques and plant changes are not incorporated into the available results. On a larger scale, given that the industry has generally not pursued external events modeling at a level consistent with internal events models, the technology for external events analysis is not as robust or refined. The result is that the core damage frequencies calculated for the internal and external events models are not necessarily comparable. External events models are considered to be useful tools for identifying important accident sequences and mitigative equipment, but the quantitative results should not be directly compared with those from the internal events models. In this analysis, External Events contributions are estimated for the reasons described above.

Recognizing the need: (1) to include SAMAs specifically addressing external events; and, (2) to address the impacts of all SAMAs on the external event risk profile, a multi-prong approach is implemented for Oyster Creek. This multi-prong approach consists of the following:

- <u>Step 1:</u> Make use of the up-to-date and operational PRA logic models that encompass internal events and internal floods and which have been constructed using the ASME PRA Standard Supporting Requirements.
- <u>Step 2:</u> Recognize that external events contribute additional risk to plant operation that must be accounted for.
- <u>Step 3:</u> Approximate the quantitative measure of the external event risk, even if it has a conservative bias.
- <u>Step 4:</u> Ensure that the conservatively biased external event risk does not unduly bias the value impact assessment of any SAMAs.
- <u>Step 5:</u> Derive plant specific SAMAs to address external event risk directly from the IPEEE submittal, the NRC SER on IPEEE, and NUREG-1742.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

• <u>Step 6:</u> Evaluate the external event SAMA risk reduction with the most appropriate risk tool available.

Implementation of this strategy has taken the following form:

- <u>Step 1:</u> The available PRA logic model is used in the SAMA evaluations to reflect the current PRA plant configuration, procedures, data, and operating philosophy. See Section F.2.
- <u>Steps 2 & 3:</u> The external events risk has been conservatively quantified in the IPEEE submittal as revised through interactions with the NRC and documented in RAI responses and the NRC SER. This quantification of approximately ten years ago is as follows:

Contributor	Frequency (per/yr)
Fire	1.9E-5
Seismic	4.7E-6
Total	2.4E-5

This ten year old estimate is judged to be conservatively biased because of older fire initiating event data, the EPRI FIVE methodology, and the lack of credit for effective fire suppression.

- Steps 4: The conservative CDF for external events is a factor of 2.3 times the internal events CDF. Considering that this is a conservative characterization of the CDF and that any SAMA impact derived for internal events will, in general, have a smaller relative impact on the external event risk profile. It is judged that a doubling of the internal events CDF is a realistic method of providing a surrogate risk measure that can be used in cost benefit analysis⁽¹⁾ for those SAMAs aimed primarily at internal event risk contributors.⁽²⁾
- <u>Step 5:</u> The SAMAs that influence the external event risk profile are identified from the IPEEE, NUREG-1742, and the NRC SER on the IPEEE. These SAMAs are added to the list of SAMAs. See Section F.2.3.

⁽¹⁾ A SAMA derived to address the internal events risk profile will, in general, have a less profound impact on the external event risk profile. By assuming a one-to-one correspondence, the benefit to be obtained from the SAMA will be overestimated. This could falsely indicate a net value where it is only a reflection of the "conservative" bias. To avoid this trap, a multiplier of two on the internal events CDF is used to characterize the portion of the external event risk spectrum that could reasonably be affected by internal events related SAMAs.

⁽²⁾ While a SAMA may be derived based on internal event risk contributors, it is recognized that it may also be at least partially beneficial in external event accident mitigation. Therefore, the use of a surrogate risk measure is desired.

<u>Step 6:</u>

All SAMAs are evaluated for their risk reduction using the best available risk model. For most SAMAs, the internal events logic model (including internal floods) is used with the averted cost risk doubled to account for potential impacts on the external event risk profile.⁽²⁾

For external event SAMAs, the CDF and radionuclide releases are explicitly quantified using the best available characterization of the CDF and radionuclide release impact. The existing IPEEE results are used to estimate the external event risk contribution that could be eliminated if the SAMA is implemented. This evaluation process is supplemented by available insights as a result of Oyster Creek's continuing risk management program which includes initial efforts to update the fire PRA.⁽¹⁾

In summary, in order to account for the external events contributions in the SAMA analysis, a two stage process has been implemented to provide estimates of the averted cost-risk based on external events accidents.

The first stage is used in the Phase I analysis and is based on the assumption that the risk posed by external and internal events is approximately equivalent. Given that the risk is assumed to be equal, the maximum averted cost-risk calculated for the internal events model has been doubled to account for external events contributions. This total is referred to as the "modified maximum averted cost-risk" or MMACR. The MMACR is used in the Phase I screening process to identify and screen SAMAs that could not be cost beneficial even if all risk related to power operations was eliminated. These are the SAMAs with costs of implementation that are greater than the MMACR.

The second stage of the strategy is used in the Phase II analysis and uses the assumption that the external events component of the averted cost-risk for a given SAMA is equivalent to the averted cost-risk based on internal events. This requires that any averted cost-risk calculated for a SAMA be multiplied by two to approximate the corresponding external event averted cost-risk. For some specific cases where only external events are affected, the averted cost-risk is explicitly calculated rather than using the factor of two assumption.

⁽¹⁾ Analysis in Section F.6 of SAMAs 124 and 125 are examples of the external event SAMA evaluation process using available logic models and the latest information.

F.2 Oyster Creek PRA Model

The 2004B Oyster Creek Level 1 and Level 2 Probabilistic Risk Assessment (PRA) is used as the basis for the SAMA analysis. In this version of the PRA, the base Core Damage Frequency (CDF) is 1.05x10⁻⁵ events per year and the Large Early Release Frequency (LERF) is 5.80x10⁻⁷ events per year [F-25]. As a result of the Oyster Creek PRA maintenance process, the model has evolved since the submittal of the IPE. This section provides an overview of the model changes since the IPE, the current risk profiles, and the model review history.

The following subsections are provided to address these topics:

- PRA Model changes since the IPE Submittal (Section F.2.1)
- Current Level 1 Oyster Creek PRA model (Section F.2.2)
- External Events Modeling (Section F.2.3)
- Current Level 2 Oyster Creek PRA model (Section F.2.4)
- PRA model review summary (Section F.2.5)

F.2.1 PRA MODEL CHANGES SINCE IPE SUBMITTAL

The internal events PRA used for the SAMA evaluation is based on an updated version of the PRA used for the IPE (1992). The PRA model was updated in 1998 (partial update), 2001, and 2004.

The 2004B update to the Oyster Creek PRA is the most recent evaluation of the risk profile at Oyster Creek for internal event challenges. It is a regular scheduled update, in accordance with AmerGen internal guidance, ER-AA-600-1015, "FPIE PRA Model Update." There have been a series of probabilistic evaluations beginning with the Individual Plant Examination (IPE) issued in 1992 as requested by the NRC in Generic Letter 88-20. These probabilistic evaluations and their associated risk metrics can be summarized as follows:

Model	Date	CDF (Per Yr)	LERF (Per Yr)
• IPE	8/92	3.69E-06	5.8E-07 ⁽¹⁾
Revision 2001A	1/02	6.27E-06	1.2E-06 ⁽²⁾
Revision 2004B	3/05	1.05E-05	5.8E-07

The major differences in the PRA model between the original IPE and the PRA updates through the current update are the following:

- 2001 PRA update included:
 - Resolution of Oyster Creek PRA Peer Review comments
 - Update and inclusion of Internal Flooding in Base PRA internal events model
 - Data update
 - Level 2 re-assessment with a simplified LERF model
- 2004 PRA update included:
 - Conversion of the software platform from RISKMAN to CAFTA
 - Revised component failure data including extensive use of plant-specific component failure data gathered from the Oyster Creek Maintenance Rule program
 - Revised initiating events data utilizing the latest Oyster Creek operating experience (Includes the addition of AC and DC bus failure initiating events)
 - Addition of AC and DC initiating events
 - Added alternate configuration logic for all systems with alternate / standby trains
 - Extensive HRA re-assessment based on operating crew interviews using the latest EOPs and support procedures

⁽¹⁾ P. 8-4 of IPE, large early is 15.8% of CDF.

⁽²⁾ March 2003 for simplified LERF model which conservatively included releases in the High/Early (LERF) category.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

- Incorporation of dependent HEP evaluation
- Addition of Pre-Initiating Human Error Events into the model
- Use of MAAP 4.0.5 deterministic calculations to support the success criteria and HRA calculations
- Maintenance unavailability data based on the most recent plant operating experience
- Bayesian updated initiating event frequencies utilizing Oyster Creek most recent operating experience
- Individual component random failure probabilities Bayesian updated (as applicable) based upon the most recent plant specific data
- Addition of more detailed modeling of extreme weather and its impact on offsite AC power, the Combustion Turbine Building, and the Diesel Fire Pump Building.
- Common cause failure (CCF) calculations revised to incorporate the updated individual random basic event probabilities and the most up to date Alpha parameters from NUREG/CR-5497 and NUREG/CR-5485
- Revised LOOP analysis for initiating event frequencies and non-recovery probabilities including the 2003 Northeast Blackout
- Revised mechanical and electrical ATWS probabilities, based on information in NUREG/CR-5500
- Self-Assessment against the ASME PRA Standard
- Addition of recirculation pump seal leakage scenarios
- More detailed ATWS analysis
- Development of a time phase SBO model
- The LERF model was upgraded to a full Level 2 model with a spectrum of possible radionuclide releases to support license extension calculations for SAMA and eliminate conservative bias

F.2.2 CURRENT LEVEL 1 INTERNAL EVENTS PRA MODEL

The results reported for the 2004B PRA model [F-25] indicate that the CDF is 1.05x10⁻⁵ per year. The remainder of this section provides a summary of the 2004B model results.

Results Summary:

The functional accident classes (Level 1 end states) and the contribution of each to CDF are summarized in Table F-1 for the average maintenance model.

The 2004B PRA average maintenance model includes 57 initiating events (truncated at 1E-11 per year). Figure F-2 summarizes this information, which identifies the initiating event and its percent contribution to the CDF.

Figure F-3a summarizes the ten most risk significant systems, based on the increase in core damage frequency if each system were unavailable to perform its function. This measure of risk significance is the risk achievement worth (RAW). It is the ratio of CDF with the system failed to the nominal CDF value. For example, if a system has a risk achievement worth of 3, then the CDF increases by a factor of 3 when the system is unavailable.

Figure F-3b summarizes the ten most risk significant systems, based on the Fussell-Vesely (FV) importance measure. The FV importance measure represents the frequency of cutsets with the system failed divided by the frequency of all cutsets for the CDF risk metric.

Level 2 PRA results for the 2004B model are also provided here as key inputs to the Level 3 consequence calculations as follows:

- Section F.2.4.3 provides the Level 2 PRA radionuclide release categories and their frequencies.
- Section F.2.4.4 provides the radionuclide source terms for impact to the consequence code, MACCS.

Class	Description	Frequency (per year)	Percent of Total
IA (Early)	Transient leading to core damage with reactor at high pressure (early)	1.51E-06	14.4%
IA (Late)	Transient leading to core damage with reactor at high pressure (late)	1.06E-6	10.1%
IBE	SBO leading to early core damage (less than 4 hours)	3.86E-06	36.8%
IBL	SBO leading to late core damage (4 hours or longer)	6.15E-07	5.9%
IC	ATWS leading to core damage in an intact containment (Included in IA-Early)		
IÐ	Transient leading to core damage with reactor at low pressure	1.66E-07	1.6%
II	Loss of containment heat removal and core damage induced post containment failure (transient/small LOCA model)	1.65E-06	15.7%
IIIB	LOCA leading to core damage with the reactor at high pressure	9.19E-07	8.8%
IIIC	LOCA leading to core damage with the reactor at low pressure	4.81E-07	4.6%
IIID	LOCA with vapor suppression failure	2.08E-08	0.2%
IV	Reactor power control failure in the transient model challenges containment and induces core damage post containment failure.	1.81E-07	1.7%
V	LOCA bypassing containment leading to core damage	3.23E-08	0.3%
	Total	1.05E-05	· · · · ·

Table F-1 Accident Class Distribution Table (2004B PRA Model)

Environmental Report Appendix F Severe Accident Mitigation Alternatives

Event Name	Description	% of CDF		
%LOOP	LOSS OF OFFSITE POWER INITIATING EVENT	39.8%		
%RTM	MANUAL SHUTDOWNS	6.5%		
%MBI	MEDIUM LOCA - BELOW CORE INSIDE DRYWELL	6.2%		
%RT	REACTOR TRIP	5.5%		
%LO1C	LOSS OF 4160 VAC BUS 1C	5.0%		
%FT2A	COND BAY AREA FEEDWATER FLOOD	4.7%		
%LO1D	LOSS OF 4160 VAC BUS 1D	4.3%		
%TTRIP	TURBINE TRIP	3.3%		
%LOCW	LOSS OF CIRCULATING WATER	3.3%		
%LOFW	LOSS OF FEEDWATER	3.2%		
OTHER	REMAINING INITIATING EVENTS	18.2%		





Notes:

- ⁽¹⁾ % of CDF is the Fussell-Vesely (FV) importance value for each initiator.
- ⁽²⁾ The total contribution to CDF from %LOOP initiator and the conditional LOOP given a LOCA or transient is 42%.

.



•

Figure F-3a System RAW Ranking (CDF) (Model 2004B)

.



(,

Appendix F

Oyster Creek Generating Station License Renewal Application

Page F-15

ł

١

Environmental Report Appendix F Severe Accident Mitigation Alternatives

F.2.3 EXTERNAL EVENTS MODELING

The IPEEE was used in the Oyster Creek SAMA analysis primarily to identify the highest risk accident sequences and the potential means of reducing the risk posed by those sequences. The IPEEE identified that some of the external events that were reviewed were screened based on inapplicability to the plant, low frequency of occurrence, or because the events or consequences of the events are already addressed by the PRA. These events include:

- Severe temperature transients (extreme heat, extreme cold)
- Severe storm (ice, hail, snow, dust, and sand storms)
- Lightning
- External Fires
- Extraterrestrial Activity (meteors, man-made objects entering earth's atmosphere)
- Volcanic activity
- Earth movement (avalanche, landslide)

After the elimination of the preceding events, the external events requiring further investigation at Oyster Creek were limited to:

- Internal Fires
- Seismic events
- High wind events
- External Flooding
- Transportation and nearby facility accidents

F.2.3.1 <u>Fires</u>

Overview of Fire PRA Development

As discussed above, the techniques used to model external events vary according to the type of initiator being analyzed. A typical fire model shares many of the same characteristics as the internal events model, but limitations on the state of technology may produce results that are significantly biased in the more conservative direction than the internal events model. The following summarizes fire PRA topics where quantification of the CDF may introduce different levels of modeling bias and uncertainty than the internal events PRA.

General Fire Model Limitations

Fire PRAs are useful tools to identify design or procedural items that could be clear areas of focus for improving the safety of the plant. Fire PRAs use a structure and quantification technique similar to that used in the internal events PRA.

Since less industry resources and standards development have historically been accorded to fire PRAs, conservative modeling is common in a number of areas of the fire analysis to provide a "bounding" methodology for fires. This concept is contrary to the base internal events PRA which has had more analytical development and is judged to be closer to a realistic assessment (i.e., best estimate) of the plant.

There are a number of fire PRA topics involving technical inputs, data, and modeling that prevent the effective comparison of the calculated core damage frequency figure of merit between the internal events PRA and the fire PRA. These areas are identified as follows:

Initiating Events:	The frequency of fires and their severity are generally conservatively overestimated. A revised NRC fire events database indicates the trend toward lower frequency and less severe fires. This trend reflects the improved housekeeping, reduction in transient fire hazards, and other improved fire protection steps at utilities.
System Response:	Fire protection measures such as sprinklers, CO ₂ and fire brigades may be given minimal (conservative) credit in their ability to limit the spread of a fire.
	Cable routings are typically characterized conservatively because of the lack of data regarding the routing of cables or the lack of the analytic modeling to represent the different routings. This leads to limited credit for balance of plant systems that are extremely important in CDF mitigation.
Sequences:	Sequences may subsume a number of fire scenarios to reduce the analytic burden. The subsuming of initiators and sequences is done to envelope those sequences included. This results in additional conservatism.
Fire Modeling:	Fire damage and fire spread are conservatively characterized. Fire modeling presents bounding approaches regarding the immediate effects of a fire (e.g., all cables in a tray are always failed for a cable tray fire) and fire propagation.
HRA:	There is little industry experience with crew actions under conditions of the types of fires modeled in fire PRAs. This has led to conservative characterization of crew actions in fire PRAs. Because the CDF is strongly correlated with crew actions, this conservatism has a profound effect on the calculated fire PRA results.
Level of Detail:	The fire PRAs may have reduced level of detail in the mitigation of the initiating event and consequential system damage.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

Quality of Model: The peer review process for fire PRAs is less well developed than for internal events PRAs. For example, no industry standard, such as NEI-00-02, exists for the structured peer review of a fire PRA. This may lead to less assurance of the realism of the model.

Overview of Oyster Creek Fire PRA Development

A Modified EPRI Fire Induced Vulnerability Evaluation (FIVE) assessment was developed for the IPEEE. A probabilistic process, based on the FIVE Methodology, was employed to evaluate plant fire areas. Fire areas were reviewed in progressive detail and once an area was shown to contribute less than 1E-6/yr to total core damage frequency, it was screened from further analysis. In addition, areas that were retained included significant conservatisms. Due to this approach, the IPEEE cannot be used to estimate a total fire CDF comparable to that used in the internal events portion of the PRA. Noting that probabilistic values in the Fire IPEEE are considered upper bound values due to conservatism and level of detail in the analysis, the IPEEE reports a core damage frequency of 7.7E-6/yr. The NRC notes that this value was revised to 1.9E-5/yr in their SER [F-36].

Areas that required detailed analysis are presumed to be those with the greatest risk significance. The detailed fire analysis included a probabilistic treatment of fire severity, fire detection and suppression, growth and propagation as well as equipment impacts. Seven fire areas required detailed analysis. These areas were:

- Reactor Building 51' Elevation (RB-FZ-1D)
- Reactor Building Main Floor 23' Elevation (RB-FZ-1E)
- Cable Spreading Room 36' Elevation (OB-FZ-1E)
- Control Room 46'6" Elevation (OB-FZ-5)
- "A" 480 VAC Switchgear Room (OB-FZ-6A)
- A and B Battery Room, Tunnel and Electric Tray Room 35' Elevation (OB-FZ-8C)
- Turbine Building Basement (TB-FZ-11D)
- Battery Room South of 4160 VAC Switchgear (TB-FA-26)

Of these areas, two could not be screened within the IPEEE analysis:

- Cable Spreading Room 36' Elevation (OB-FZ-1E)
- "A" 480 VAC Switchgear Room (OB-FZ-6A)

The IPEEE report notes that these unscreened areas contribute 62.6% of fire CDF. Relative to potential SAMA, the IPEEE does not provide information regarding specific improvements to reduce risk related to these areas. However, AmerGen has reviewed these results for the purpose of the SAMA evaluation. Based on this review of the Oyster Creek fire IPEEE results, the following SAMAs have been identified for inclusion on the SAMA list:

- SAMA 116 Transient Combustible housekeeping
- SAMA 122 Consider training operations and fire brigade to cope with fire scenarios
- SAMA 125 Reduce fire impact in dominant fire areas

F.2.3.2 Seismic

A seismic PRA (SPRA) was performed for the Oyster Creek IPEEE. The overall approach in performing a seismic PRA consists of a seven step process:

Step 1: Determination of site specific seismicity characteristics. This step involves the development of the frequencies of occurrence and magnitude of seismic events for the site. Site structure analysis, including block wall evaluation, and soil liquefaction assessments have also been performed. The resulting frequencies and magnitudes of seismic events are the initiating events for the SPRA. EPRI Seismic Hazard Curves [F-24] are used to establish the initiating event frequency. Site structure responses are input into step 5 where the capacity of components which impact risk are calculated.

Step 2: Identification of those components important to plant safety, including equipment, structures and procedures. The original Level 1 PRA developed for Oyster Creek was utilized to determine those components which impact risk. Other studies such as the A-46 Safe Shutdown Equipment List (SSEL) as well as a qualitative review of systems, structures and components which may impact the probability of core damage due to seismic initiators were also used to ensure that the list of components which impact risk is comprehensive.

Step 3: An initial plant walkdown of the identified systems and components has been performed, and any plant seismic system interactions and unique plant features which may impact risk were identified.

Step 4: Develop plant logic models. The plant logic models were developed using the Level 1 Oyster Creek PRA with the addition of the failure rates of components due to seismically initiated events. The Level 1 model was modified to ensure that the independent as well as seismic failures are accounted for in the logic model.

Step 5: A second plant walkdown was performed to verify plant models and to collect data to determine component capacities. Fragility curves which plot the peak ground acceleration at which the component is expected to fail have been developed primarily from analysis and engineering judgment, supported by limited test data. This evaluation included the assessment of essential relays.

Step 6: Analyze the plant models to determine seismic initiated accident sequences and their frequency. This step involved the assembly and quantification of the plant logic models as well as the reporting and analyzing of the results.

Step 7: Identify plant seismic vulnerabilities. This step defined any site specific vulnerabilities which are discovered as a result of the performance of the study.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

Results from the SPRA show a seismic CDF of 4.7E-6/yr. Since the IPEEE model was modified significantly as part of the NRC review process, the model outlined in the NRC SER [F-36] is described here.

The top ten seismic scenarios are summarized below where the seismic initiating events have been binned into four categories of increasing seismic magnitude (SEISI to 4):

- Sequence 1 is defined by the seismic failure of the turbine building following a SEIS2 initiating event. This sequence contributes 19%. (See also sequence number 22.)
- Sequence 2 is defined by the seismic failure of the turbine building following a SEIS4 initiating event. This sequence contributes 14%. (See also sequence number 4.)
- Sequence 3 is defined by the seismic failure of the turbine building following a SEIS3 initiating event. This sequence contributes 13%. (See also sequence number 10.)
- Sequence 4 is defined by the seismic failure of the turbine building following a SEIS4 initiating event and the failure of the recirculation pump supports. This sequence is non-minimal since the failure of the turbine building is assumed to result in core damage. This sequence contributes 7%. (See also sequence number 2.)
- Sequence 5 is defined by the seismic failure of the turbine building following a SEIS2 initiating event. This sequence contributes 6%.
- Sequence 6 is defined by the seismic failure of the turbine building following a SEIS1 initiating event. This sequence contributes 3%.
- Sequence 7 is defined by the seismic failure of the turbine building following a SEIS3 initiating event. This sequence contributes 6%. (See also sequence number 21.)
- Sequence 8 is defined by the seismic failure of the turbine building following a SEIS4 initiating event. This sequence contributes 6%. (See also sequence number 14.)
- Sequence 9 is defined by the independent failure of the EMRVs to reclose following initial post trip pressure relief followed by the independent failure of the core spray system following a SEIS1 initiating event. This sequence is the first independent failure scenario. Since main feedwater is assumed failed in seismic events and fire protection is not modeled as providing vessel inventory in seismic events, core damage results. This sequence contributes 1.6% to the seismic core damage frequency.
- Sequence 10 is defined by the seismic failure of the turbine building and the recirculation pump supports following a SEIS3 initiating event. This sequence is non-minimal since core damage is assumed following the failure of the turbine

• ,

building. This sequence contributes 1.5% to the seismic core damage frequency. (See also sequence number 3.)

Table F-2 shows the contribution from the top seismic related failures and Table F-3 shows the top fragilities within the seismic sequences.

•

.

.

Oyster Creek Generating Station License Renewal Application :• /

			Risk		
	Тор	Fussell-	Achievement	Risk	Top Event
No.	Event	Vesely	Worth	Reduction	Description
1	TZ	3.54E-01	1.57E+03	6.46E-01	Seismic Turbine Building Failure
2	RZ	9.69E-02	1.57E+03	9.03E-01	Seismic Reactor Building Failure
3	EW	8.61E-02	1.63E+00	9.14E-01	Seismic 4160 VAC 1C Failure
4	MU	6.56E-02	1.63E+00	9.34E-01	Independent Iso Cond Makeup
					Failure
5	SX	5.48E-02	1.34E+00	9.45E-01	Seismic Condensate Tank Failure
6	XX	5.34E-02	1.05E+00	9.47E-01	Seismic Long Term 125 VDC B
					Failure
7	IY	5.12E-02	4.48E+00	9.49E-01	Seismic Failure of Offsite Pwr
					Recovery
8	VR	4.40E-02	1.66E+00	9.56E-01	Indep Failure of EMRVs to Reclose
9	FX	3.55E-02	1.89E+00	9.65E-01	Seismic Fire Protection Failure
10	OX	3.42E-02	1.32E+00	9.66E-01	Seismic Offsite Power Failure

 Table F-2
 Contribution of the Top Ten Seismic Model Failures

			Risk		10% Median	
Fragility	Тор	Fussell-	Achievement	Risk	Acceleration	Top Event
ID	Event	Vesely	Worth	Reduction	Decrease	Description
FRAG39	TZ	2.97E-01	1.57E+03	7.03E-01	1.14E+00	Turbine Building – column
FRAG37	RZ	9.64E-02	1.57E+03	9.04E-01	1.05E+00	Reactor Building - column
FRAG05	EW	8.61E-02	1.63E+00	9.14E-01	1.02E+00	Switchgear room fan
FRAG10	SX	5.48E-02	1.34E+00	9.45E-01	1.01E+00	Condensate storage tank
FRAG04	XX	5.34E-02	1.05E+00	9.47E-01	1.01E+00	Battery room fans
FRAG18	IY	5.12E-02	4.48E+00	9.49E-01	1.02E+00	Isolation condenser
FRAG38	TZ	4.11E-02	1.57E+03	9.59E-01	1.04E+00	Turbine building – shear
FRAG00	FX	_3.55E-02	1.89E+00	9.65E-01	1.01E+00	Generic fragility for others
FRAG01	OX	3.42E-02	1.32E+00	9.66E-01	1.00E+00	Offsite power
FRAG00	RX	3.27E-02	2.80E+00	9.67E-01	1.01E+00	Generic fragility for others

Based on a review of the IPEEE seismic results and NUREG-1742, the following SAMAs have been identified for inclusion on the SAMA list:

- SAMA 21 Increase seismic ruggedness of plant components (the specific components to be investigated are listed under the individual SAMAs listed below)
- SAMA 67 Safety related condensate storage tank
- SAMA 114 Check bolt tightness on CT Fin-Fan Coolers
- SAMA 115 Consider battery spacers for CT battery compartments
- SAMA 117 Consider upgrading high pressure CO2 cylinders in turbine building; potential missiles

- SAMA 118 Consider additional support for oil filter on turbine generator hydrogen seal oil unit
- SAMA 119 Review anchorage for Arrowhead demineralizer trailer. Walkdown issue apparently related to seismic housekeeping
- SAMA 120 Consider upgrading high pressure CO2 rack in turbine building; potential missiles
- SAMA 121 Consider replacing fire protection deluge valves that can be spuriously actuated in a seismic event
- SAMA 123 Consider replacing relays that had chatter <0.3g
- SAMA 124 Consider reinforcement for Block Wall 53

F.2.3.3 Other External Events

For the high winds, floods, transportation, and nearby facility accidents, hereafter referred to as "other hazards", portion of the Oyster Creek IPEEE, the methodology outlined in NUREG-1407 [F-26] was used. This methodology is best described as a progressive screening approach. In this approach, each issue is evaluated in greater detail for each subsequent step of the analysis until it can be shown to be either low risk or a vulnerability. For each type of potential hazard, the evaluation requires, at a minimum, a review of the plant relative to the hazard, a review of changes since the issuance of the plant's operating license (OL), and a review of the plant against the 1975 Standard Review Plant (SRP) [F-27]. Per NUREG-1407, the scope of the analysis includes high winds, external flooding, and transportation and nearby facility accidents. These events are discussed in the following sections.

Overall, the analysis breaks down into eight tasks, the first three of which were summarized in the above paragraph. Task 1 requires the analyst to review available information regarding the plant design and licensing basis relative to the hazard under evaluation. Task 2 requires the analyst to extend the set of information above by considering changes since the issuance of the plant's OL. Specifically, the review should evaluate changes with respect to military and industrial facilities within 5 miles (~8 km) of the plant, onsite storage or other activities involving hazardous materials, transportation, and development that could affect the original design conditions. In addition, a plant walk-down is performed to identify any additional relevant information. In Task 3, the analyst reviews the information obtained above relative to 1975 SRP criteria. If the plant conforms to the 1975 SRP criteria and no potential vulnerabilities are identified in Task 2, the hazard is screened and is considered to pose a negligible risk.

If the hazard is not screened based on SRP criteria, then three types of detailed analysis are considered. If the hazard can be screened by any of the three detailed analysis approaches, then it is considered a negligible risk.

The three detailed analyses are: Task 4 - hazard frequency analysis, Task 5 - bounding analysis, and Task 6 - probabilistic risk assessment (PRA). In the hazard frequency analysis, the analysis considers the probability of the hazard occurring. If the event frequency can be shown to be less than 1E-5 per year with conditional core damage probability of 1E-1 per event, then the hazard can be screened. This amounts to showing that the hazard related core

Environmental Report Appendix F Severe Accident Mitigation Alternatives

damage frequency is less than 1E-6 per year. If the hazard under review does not screen, then one of the other two detailed analysis approaches is used.

The second type of detailed analysis is called bounding analysis and it considers the consequence of the hazard. If it can be shown that the hazard could not result in core damage, then it can be screened as a negligible risk. If it cannot be screened, then PRA is considered.

In the PRA, detailed fault trees and/or event trees are developed to model the frequency of the event and the probability that the plant equipment and operators respond to mitigate the event prior to core damage.

Figure F-4 shows a simplified representation of the approach for the other External Hazards analysis. This figure was taken from NUREG-1407 and modified slightly. As shown in the figure, Tasks 4 through 6 are optional tasks. One of the optional tasks, at a minimum, is used, at the discretion of the analyst, for any hazard that does not screen based on the SRP review. Two or three of the optional tasks may be used if the hazard is not screened. If the hazard cannot be screened by the SRP review or any of the detailed analyses, then modification to the plant and/or procedures is considered in Task 7.

The final task is documentation of the analysis. The remainder of this section describes the analysis and provides summary documentation of the analysis and results.



Figure F-4. Approach for Other External Hazards

Page F-24

High Winds

Since tornados were not considered as part of the Oyster Creek design basis, a probabilistic assessment was performed for high winds as part of the IPEEE. The probabilistic assessment included wind-induced missiles and resulted in a CDF of approximately 4.9E-7/yr. High winds were screened from further consideration as part of the IPEEE based on contributing less than 1E-6/yr to overall CDF.

However, it is noted that severe weather has been included in the internal events PRA because of the impact on offsite AC power, the Diesel Fire Pump Building, and the Combustion Turbine Building. This 2004 PRA update item is considered to be part of the treatment of the LOOP initiator consistent with recent INEL data work. [F-44].

External Flooding and Probable Maximum Precipitation

Oyster Creek meets the intent of the SRP in terms of external flooding [F-28]. With regard to revised Probable Maximum Precipitation (PMP) estimates, which include higher rainfall intensities over short time intervals, potential flooding has been considered. Based on walk-downs, it was concluded that overland runoff will not enter buildings housing equipment that could lead to core damage. Also, roof ponding was determined to be a negligible hazard.

Global warming and glacier melting impacts on the site were considered negligible.

Transportation and Nearby Facility Accidents

The hazards due to natural gas pipelines, airfields, and transportation near the site are addressed below.

Natural Gas Pipelines

· • •

· •

There are four natural gas pipelines in the vicinity of Oyster Creek. They are located along US Route 9 approximately 0.25 miles from the plant. There are one six inch pipeline, one eight inch pipeline, and two sixteen inch pipelines. One of the sixteen inch pipelines runs adjacent to the intake canal and supplies the combustion turbines.

An analysis performed for the Tennessee Valley Authority (TVA), NUREG-0014 [F-29] was compared to Oyster Creek. Based on the distance from the plant and size of the pipeline, it was concluded that the pipelines posed a minimal hazard.

Hydrogen Water Chemistry Storage Facility

A hydrogen water chemistry system was installed to mitigate potential cracking in the nuclear steam supply system. The main storage area is more than 620 feet away from the nearest safety related structure. The system was evaluated against EPRI guidelines [F-30] for water chemistry installations and found to be adequate. Based on the assessment, the system was screened as a minimal hazard.

Aircraft Hazard Evaluation

There are no missile sites within a 10-mile radius of the Oyster Creek site. Nine airfields are located within 20 miles of the plant. Two of the airfields are military installations: (1) McGuire Air Force Base, also used by the U.S. Air Force, U.S. Air National Guard, and the Military Air Transport Service, 25 miles to the northwest of the site and (2) Lakehurst Naval Air Station, 20 miles north-northwest of the site. Other airports listed by the Federal Aviation Administration (FAA) are Breton Woods, 17 miles north; Eagle's Nest, 12 miles south-southwest; Coyle Tower, 10 miles west: Ocean City, 9 miles north-northwest; Manahawkin, 9 miles south-southwest; and Beechwood, 8 miles north-northwest. In addition, there is a sod strip 2 miles northeast of Forked River.

Aircraft strike probabilities have been estimated for three size categories including small general aviation. Medium sized commercial, and large (heavy) commercial or military aircraft. The nearest airports of significance are at Lakehurst, 16 miles north-northwest and McGuire Air force Base about 24 miles northwest. At these distances there is no significant hazard due to landing and takeoff activities. Low-level military training routes in the area must be kept more than five miles from the plant by agreement between the military and the NRC. There is little traffic along these routes, and at this distance they represent an extremely low hazard to the plant (UFSAR).

Based on evaluation of the available information on air traffic conditions at the site, it was concluded that the only significant hazard is from the traffic along the "Victor Air Lane 312" airway and general aviation in the area. Probabilities for a strike on the plant were developed for three sizes of aircraft based on available traffic information for each size. The largest mean frequency was from general aviation at 4.0 X 10^{-7} (UFSAR).

The "Victor Air Lane 312," which is aligned east-west and passes over the site, has been screened based on Reference F-28, which states that because the aircraft strike probabilities are extremely low, aircraft traffic does not pose a significant threat to the Oyster Creek plant.

The FAA lists three restricted areas in the vicinity of the plant. Two of these areas, R5001A and R5001B, are contiguous to Fort Dix, which is 15 miles to the north-northwest of the site. These restricted areas are used mainly as firing ranges for small arms, artillery, and mortars. The third area, R5002, at Warren Grove is a low-level aerial target range, used by the U.S. Air National Guard. Its closest boundary to the plant is 7.5 miles. Bombs, rockets, and 20-millimeter guns are used in the target range. The bombs are dummies that give off a flash, but no explosive charge. The rockets do not have explosive charges, only a propellant to deliver the rocket on target, and shells used in the 20-millimeter guns have solid heads without explosives. The likelihood of any of these hazards having any impact on Oyster Creek is judged to be extremely low.

Transportation Hazard Evaluation

The nearest transportation route to the station is U.S. Route 9, which is located approximately 0.25 miles east of the reactor building. There were no industries in close proximity to the plant site that were expected to use or store large amounts of explosive or hazardous material. Additionally, Route 9 is a local road with many traffic lights and low speed limits, especially where it passes through towns. Through traffic generally uses the Garden State Parkway, a limited access toll road that runs parallel to Route 9. The parkway is about 1.25 miles west of the plant.

The staff stated in an SER dated April 6, 1993, [F-34] that "In view of the above [GPU analysis on transportation accidents], and the licensee's Procedure 2000-ABN-3200.33, "Toxic Material/Flammable Gas Release – No Radiation Involved," the staff finds that the risk due to hazardous truck shipments near the OCNGS is acceptably low and the staff considers this issue resolved."

NUREG-0737, "Clarification of TMI Action Plan Requirements," Task Action Plan Item III.D3.4, "Control Room Habitability," requires that the operators in the control room be adequately protected against the effects of accidental releases of toxic and radioactive gases.

In a Technical Specification change request dated, October 18, 1989, as supplemented on February 21, 1990, GPUN addressed items related to control room habitability. In this submittal GPUN also described modifications that had been made to the Oyster Creek control room HVAC system. With the issuance of POL Amendment 139 dated May 29, 1990 and its accompanying SER, the staff found the licensee's provisions acceptable to resolve this NUREG-0737 item [F-32].
F.2.4 CURRENT LEVEL 2 OYSTER CREEK PRA MODEL

The core damage frequency (CDF) model provides a tool for estimating the likelihood or frequency of core damage. Because consequences of a core damage event can range from minimal (as in the case of the Three Mile Island event in 1979) to more severe (as in the case of the Chernobyl event in 1986), this is not enough information to assess risk. Therefore, the PRA model is designed to identify underlying causes of containment failure for severe accidents and the associated release pathways and their frequencies.

The Oyster Creek containment event trees allow core damage scenarios defined in the CDF model to be further developed into consequence bins. Separating scenarios this way allows results of plant risk calculations to be presented in simple, meaningful terms. Consequence bins are based on the severity of the source term and the timing of the release relative to the time a general emergency is declared, as described in the Oyster Creek Level 2 Notebook. The characteristics of these bins are then used as input for the Level 3 model. The following subsections summarize the breakdown of the bins and the Level 2 results.

The IPE employed what some would call a simplistic Level 2 methodology based on a small number of MAAP cases. Many accident progression phenomena or failure modes are eliminated from consideration.

To support License Renewal which requires Level 3 calculations, Exelon developed a full Level 2 PRA model for Dresden that meets standard industry practices. The full Level 2 model is used for the License Renewal analyses, and that model also has now been incorporated in the 2004B Oyster Creek PRA model. It is also the basis for LERF calculations for risk assessment.

A brief summary of the current Level 2 model compared to the 2001 Level 2 model follows:

- Dependencies on Level 1 scenarios are explicitly treated
- The end states are expanded to cover the spectrum of radionuclide release end states
- Significant increase in discrimination of mitigating actions are included
- The ASME PRA Standard self assessment process endorsed by RG 1.200 is implemented

F.2.4.1 Consequence Bins: Source Term Severity

The radionuclide release categories are defined based on two parameters: timing and severity. Timing of the release for each sequence is based on MAAP calculations of the sequence chronology. The classification of release magnitude is also based on MAAP 4.0.5 calculations.

The inputs for determining the plant specific characteristics of the radionuclide release bins are the following:

- The plant model
- The MAAP 4.0.5 plant specific calculations
- The Oyster Creek Emergency Plan, e.g., the Emergency Action Levels (EALs)

- The magnitude of releases that can contribute to public health effects
- The evacuation timing

The magnitude of the radionuclide releases for purposes of binning sequences is characterized in terms of the radionuclide release fraction for CsI. This is a dominant contributor to both prompt and latent health effects. The CsI release fraction also correlates well with other contributors to offsite effects. For consequence calculations, additional radionuclides are included as inputs to the release. (See Section F.3.5.) The bins used to define the release magnitude spectrum are as follows:

	Characterization	Designator	Csl Release Fraction
•	High	H .:	> 10%
	Medium	М	> 1% and <u><</u> 10%
	Low	L	> .1% and <u><</u> 1%
	Low-Low	· LL	<u><</u> .1%

The resulting definitions of the radionuclide release end states are summarized in Table F-4.

Using these results and the Level 2 containment event trees, the radionuclide release categories are assigned to each CET sequence end state.

The determination of end state consequences is performed using the MAAP computer code for most of the end state assessments. Therefore, the Modular Accident Analysis Program (MAAP) is used to estimate the radionuclide release consequences of accident scenarios, and results are documented in the Level 2 Thermal Hydraulic Analysis Notebook. For phenomena which are not well modeled by MAAP (e.g., steam explosions), conservative MAAP evaluations are used to characterize the release. This is confirmed by comparison with surrogate plant analysis. Each Level 2 accident sequence from the radioactive release event trees is characterized by a MAAP case.

F.2.4.2 Consequence Bins: Timing of Release

Each sequence that leads to a radioactive release from containment is classified as "early", "intermediate", or "late". This designation is intended to reflect mitigation of consequences by evacuating people from the area, as appropriate. It is assumed for the purpose of the risk analysis that 6 hours are required from the time a general emergency is declared to the time radioactive material is released from containment to effectively reduce consequences by evacuation. Based on this assumption, radioactive releases within 6 hours of general emergency declaration are considered "early", and releases after 6 hours are categorized as intermediate. Long term releases at greater than 24 hours after the declaration of a GE are considered "late". Release timing is summarized in Table F-4.

F.2.4.3 Oyster Creek Level 2 PRA Radionuclide Release Categories

Classifications of radionuclide releases need to be adequate to distinguish the severe accident scenarios that can result in potentially high public consequence versus those that have public consequences below measurable values. Therefore, the Oyster Creek PRA model has been

Environmental Report Appendix F Severe Accident Mitigation Alternatives

expanded to be a full Level 2 model with a spectrum of radionuclide release categories. This knowledge of consequences, coupled with the quantification of the accident sequence frequencies, results in the ability to characterize the public risk and the potential for cost-beneficial modifications.

As mentioned previously, the quantification of the source terms associated with each of these release severity categories is accomplished through the use of Oyster Creek specific calculations. A review of existing consequence analyses performed in previous IDCOR studies, PRAs, and NRC studies containing detailed consequence modeling was also performed to confirm the reasonableness of the radionuclide releases.

A broad spectrum of accident sequences have been postulated that could lead to core damage and potentially challenge containment. The Oyster Creek Level 1 PSA has calculated the frequency of those accident sequences that contribute to the core damage frequency for Oyster Creek using system oriented (systemic) event trees. Each of these sequences may result in different challenges to containment. However, many of these challenges to containment have similarities in their functional failure characteristics. This has been confirmed in individual BWR PRAs including NUREG-1150. The result is that these studies have categorized these containment challenges into a finite, discrete group of accident sequence bins, which have similar functional failures. While the Level 1 sequences are binned into accident classes, this represents only a convenience for summarizing Level 1 results. The transfer of information from Level 1 to Level 2 is on a cutset by cutset basis to ensure dependencies are accurately treated between Level 1 and Level 2.

As pointed out in past BWR PRAs, different portions of the spectrum of postulated core damage accidents represent substantially different challenges to the containment depending upon the system failures and phenomena that have contributed to the sequence. Therefore, the containment event tree response must be capable of reflecting the entire spectrum of challenges to ensure that the following are explicitly incorporated:

- System failures in the Level 1 evaluation (including support systems)
- Phenomenological interaction due to the type of core melt progression
- RPV conditions
 - Pressures
 - Decay heat level
- Containment conditions
- Timing of the sequence of events (i.e., core damage and containment failure (if applicable)).

Core Damage Functional Classes

An event sequence classification into thirteen accident sequence functional classes (including containment intact) can be performed using the functional events as a basis for selection of end states. The description of functional classes is presented in Table F-1 discussed in Section F.2.2. The basic types of challenges to containment evaluated based on the Level 1 output (Table F-1) are the same accident classes referenced in Table F-6, Column 1.

Each CET end state can then be associated with a radionuclide source term bin, which covers a spectrum of similar potential scenarios and timing. Theoretically, it would be desirable in determining the point estimates of risk to evaluate the source terms for each sequence of each accident plant damage state. However, for purposes of risk presentation, the CET end states can also be characterized in such a manner as to combine similar "consequence impact" sequences within a single CET end state.

The discrete nature of the radionuclide release categories means that the severe accident spectrum is divided up into bins, which then represent a group of severe accidents that have similar characteristics. These characteristics result in similar public health consequences. It has been found in the past that the public health consequences are affected by a large number of governing features. The following portrays the radionuclide release category characterization used for Oyster Creek.

Radionuclide Release Categories (CET End States)

The spectrum of possible radionuclide release scenarios is represented by a discrete set of categories or bins. The end states of the containment and phenomenological event sequences may be characterized according to certain key quantitative attributes that affect offsite consequences. These attributes include two important factors:

- Timing (e.g., early or late releases); and,
- Total quantity of fission products released.

Therefore, the containment event tree end states represent the source term magnitude and relative timing of the radionuclide release. The number of categories used for Oyster Creek (i.e., 13) in the source term characterization offers a level of discrimination similar to that included in numerous published PRAs.

Timing Bins

Three timing categories are used, as follows:

- Early (E) Less than time when evacuation is effective
- Intermediate (I) Greater than or equal to Early, but less than 24 hrs
- Late (L) Greater than or equal to 24 hours.

The definition of the categories is based upon past experience concerning offsite accident response:

- Early is conservatively assumed to include cases in which minimal offsite protective measures have been observed to be performed in non-nuclear accidents.
- Intermediate is a time frame in which much of the offsite nuclear plant protective measures can be assured to be accomplished.
- Late (>24 hours) are times at which the offsite measures can be assumed to be fully effective.

Radionuclide Release Magnitude Bins

The assessment of plant response under postulated severe accident scenarios is a complex integrated evaluation. The primary and secondary containment building responses are sensitive to pressures, temperatures, flows, and event timings. These parameters also affect the operator action timings, the radionuclide release timings, and the mitigating system performance assessments. Therefore, the proper plant specific characterization of the severe accident progression is important to the realistic representation of the plant and highly desirable for the Level 2 assessment. These deterministic calculations provide the following information:

- The pressures and temperatures for various accident scenarios in the RPV, the drywell, the wetwell, and the reactor building;
- The time to reach these pressures and temperatures which is key to the assessment of recovery; (The time windows available for recovery actions must be estimated.)
- The source term magnitude and timing.

Five severity classifications associated with volatile or particulate releases are defined as follows:

- <u>High</u> (H) A radionuclide release of sufficient magnitude to have the potential to cause prompt fatalities.
- <u>Medium or Moderate</u> (M) A radionuclide release of sufficient magnitude to cause nearterm health effects.
- Low (L) A radionuclide release with the potential for latent health effects.
- Low-Low (LL) A radionuclide release with undetectable or minor health effects.
- <u>Negligible</u> (OK) A radionuclide release that is less than or equal to the containment design base leakage.

A relationship was then developed with the five release severity categories. The results of this partitioning are shown in Table F-4.

The frequency of radionuclide release is characterized by the quantification of the Level 1 and Level 2 PRA models. The Level 2 radioactive release frequency event tree end states are delineated by the magnitude and timing bins of the calculated radionuclide release, as described above. Therefore, the containment event tree end states are characterized using a two-term matrix (severity, time) as shown in Table F-5.

Given this characterization strategy, the Level 2 quantification can be summarized in complementary tables (F-4, F-5 and F-6). Tables F-4 and F-5 provide the nomenclature used in the definition of radionuclide release categories. Table F-6 provides a quantitative summary of the radioactive release frequency event tree results. For each of the release categories from Table F-5, the corresponding frequency is provided. Table F-6 provides quantitative information that is useful in the interpretation of the current containment capability given the spectrum of core damage sequences calculated in the Level 1 PRA.

The quantification provides a yardstick with which to measure the best estimate of containment performance given that severe accidents could progress to beyond core damage. The quantification may include some conservatisms to account for the inability of current models and experiments to predict certain severe accident related phenomena.

A fraction (approximately 26 percent) of the core damage accidents transferred from Level 1 PRA are effectively mitigated such that releases are essentially contained within an intact containment (i.e., negligible release bin). In addition, approximately 94 percent of the postulated accidents do not have "large" releases occurring before protective action can be taken (i.e., approximately 94 percent of the accidents do not result in LERF).

Figure F-5 summarizes in graphical form a histogram comparing the total core damage frequency (i.e., the results of the Level 1 PRA) with the frequencies for each of the radionuclide release categories from Level 2. A substantial fraction of the core damage end states (approximately 60 percent) lead to "small" (low or low-low) or negligible releases categories from Level 2.

MACCS2 calculations are performed to provide the ex-plant consequences. The resulting explant consequence bins have been derived and are reduced from the fourteen Level 2 end states to ten consequence bins. The ten consequence bins used for ex-plant consequence evaluation are described in Table F-6A. The source terms used as input to the MACCS computer code for these ten consequence bins are provided in Section F.2.4.4.

Release S	everity	Release Timing					
Classification Category	Cs lodide % in Release	Classification Category	Time of Initial Release ⁽²⁾ Relative to Time for General Emergency Declaration				
High (H)	Greater than 10	Late (L)	Greater than 24 hours				
Medium or Moderate (M)	1 to 10	Intermediate (I)	6 to 24 hours				
Low (L)	0.1 to 1	Early (E)	Less than 6 hours				
Low-low (LL)	Less than 0.1						
Intact (OK)	Leakage						

Table F-4 Release Severity And Timing Classification Scheme⁽¹⁾

⁽¹⁾ The combinations of severity and timing classifications results in one OK release category and 12 other release categories of varying times and magnitudes.

⁽²⁾ The accident initiation is used as the surrogate for the time when EALs are exceeded.

Time of	Magnitude of Release						
Release	н	М	L	LL			
E	H/E	M/E	L/E	LL/E			
1	H/I	M/I	L/I	LL/I			
L	H/L	M/L	L/L	LL/L			

 Table F-5
 Release Severity And Timing Classification Matrix

Table F-	6. Summa	ary Of Oy	/ster Cre	ek Level	2 Relea	se Cate	gories (/	Yr)(1), (2)						
Class	Base CDF	Intact	LL/E	LL/I	LL/L	L/E	L/I	L/L	M/E	M/I	M/L	H/E	H/I	H/L	Total Release
IA (Early)	1.51E-06	1.14E-06	N/A	2.06E-07	5.87E-08	2.03E-08	1.61E-08	N/A	5.13E-08	N/A	N/A	2.01E-08	1.66E-09	N/A	3.74E-07
IA (Late)	1.06E-06	2.09E-08	N/A	0.00E+00	1.34E-07	N/A	6.95E-07	1.90E-10	N/A	3.20E-08	N/A	N/A	1.77E-07	• N/A	1.04E-06
IBE	3.86E-06	7.05E-07	N/A	1.24E-07	1.37E-09	1.10E-06	7.88E-07	N/A	6.70E-07	N/A	N/A	3.07E-07	1.58E-07	N/A	3.15E-06
IBL	6.15E-07	9.82E-08	N/A	2.05E-08	0.00E+00	N/A	3.80E-07	N/A	N/A	3.53E-08	N/A	N/A	8.10E-08	N/A	5.17E-07
!D	1.66E-07	1.01E-07	N/A	3.26E-09	7.07E-10	1.16E-09	1.27E-09	N/A	5.56E-08	N/A	N/A	2.83E-09	0.00E+00	N/A	6.48E-08
11	1.65E-06	0.00E+00	N/A	N/A	N/A	N/A	1.36E-08	N/A	N/A	1.55E-06	N/A	N/A	1.09E-07	N/A	1.67E-06
111B ⁽³⁾	9.19E-07	6.35E-07	N/A	N/A	0.00E+00	4.42E-09	N/A	3.33E-10	3.36E-08	2.23E-08	6.87E-10	4.88E-08	8.50E-08	8.84E-08	2.84E-07
IIIC	4.81E-07	8.69E-09	N/A	N/A	0.00E+00	8.01E-10	N/A	3.04E-11	1.42E-08	1.80E-08	9.85E-10	1.43E-07	1.74E-07	1.22E-07	4.73E-07
IIID	2.08E-08	0.00E+00	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	2.08E-08	N/A	N/A	2.08E-08
IV	1.81E-07	0.00E+00	N/A	N/A	N/A	1.11E-09	0.00E+00	N/A	1.74E-07	N/A	N/A	5.50E-09	N/A	N/A	1.81E-07
v	3.23E-08	0.00E+00	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.23E-08	N/A	N/A	3.23E-08
Total	1.05E-05	2.71E-06	0.00E+00	3.54E-07	1.95E-07	1.13E-06	1.89E-06	5.53E-10	9.99E-07	1.66E-06	1.67E-09	5.80E-07	7.86E-07	2.10E-07	7.81E-06

(1) Based on results of PRAQuant file OC-L2-SEQ.QNT. Level 2 quantified at a truncation value of 1E-11/yr.
 (2) N/A indicates that the accident class did not contribute to release of that specific category.
 (3) Non-minimal cutsets eliminated from Class IIIB results compared to Class IIIC results (due to event OH-IC-SBO).

Oyster Creek Generating Station License Renewal Application

Consequence Category	Dominant Release Category	MAAP Case	Time to TAF	Time to Core Damage	Time of Initial Release	Time of Gen. Emg. Declaration	Time of End of Release	EAL Basis Provided in Notes	Frequency (per yr)
L2-1	H/E(LERF) (52%) ⁽¹⁾	OC0500 IA-L2-1A-NSPR	23 min	1.3 hr	6.5 hr	~ 1.0 hr	38 hr	(2)	5.48E-7 ⁽⁴⁾
L2-2	H/I (26%)	OC0525 IB-L2-SBO-2B	8.8 hr	9.9 hr	21 hr	36 min	72 hr	(2)	7.86E-7
L2-3	Ĥ/L (49%)	OC0513 IIA-L2-9B-DW	7 sec	31.4 hr	32.0 hr	8.0 hr	72 hr	(3)	2.10E-7
L2-4	M/E (5.07%)	OC0523 IVA-L2-14X2-A	2 min	1.7 hr	2.0 hr	~ 1.5 hr	38 hr	(2) or (3)	9.99E-7
L2-5	M/I (3.2%)	OC0509 IA-L2-7B-NSPR-IC	1.4 hr	3.7 hr	12.0 hr	36.0 min	40 hr	(2)	1.66E-6
L2-6	M/L (5.9%)	OC0510 IIA-L2-9A-WWA	23 min	38.8 hr	39.0 hr	8.0 hr	72 hr	(3)	1.67E-9
L2-7	L/E, LL/E, L/I or LL/I (0.72%)	OC0505 ID-L2-7B-NSPR	23 min	52 min	7.0 hr	~ 1.0 hr	38 hr	(2)	3.37E-6
L2-8	L/L or LL/L (0.03%)	OC0501a IA-L2-2A-SPRY-A	23 min	1.3 hr	28.7 hr	~ 1.0 hr	38 hr	(2)	1.96E-7
L2-9	Class V (LERF) (92%)	OC0521b V-L2-17	36 sec	12 min	0.5 hr	20 min	38 hr	(2)	3.23E-8 ⁽⁴⁾
L2-10	Intact (0.01%)	OC0522 IB-L2-22	10 min	31 min	1.0 hr	~ 1.0 hr	38 hr	(2) or (3)	2.71E-6

TABLE F-6A. Accident Sequence Timings as a Function of Consequence Category (2004B Oyster Creek PRA)

Page F-36

NOTES TO TABLE F-6A:

- (1) Cumulative Percent CsI released at end of release.
- (2) RPV Level ≤ 30" TAF for 2 minutes or longer. NOTE: This condition is indicative of a "loss of 2 out of 3 fission product barriers with a potential loss of the third". An EAL update after the freeze date of the PRA changed this criterion to -20". Therefore these characterizations of Release Timing are slightly conservative.
- (3) Shutdown occurs, but all decay heat removal capability is lost. Significant cladding failure or fuel melt <u>could</u> occur in 10 hours with subsequent containment failure.
- (4) The total LERF is the sum of two consequence categories, Category L2-1 and L2-9



Figure F-5. Summary of Release Magnitudes Summary of Oyster Creek Level 2 Release Categories (/yr)

Environmental Report Appendix F Severe Accident Mitigation Alternatives

.

F.2.4.4 Oyster Creek Level 2 PRA Source Terms

The input to the Level 3 Oyster Creek model provided by the Level 2 model is a combination of radionuclide release fractions, the timing of the radionuclide releases relative to the declaration of a general emergency, and the frequencies at which the releases occur. This combination of information is used in conjunction with other Oyster Creek site characteristics in the Level 3 model to evaluate the consequences of a core damage event.

The Level 1 functional accident sequences leading to core damage are summarized in Table F-1. These functional accident sequences contain many individual sequences that are transferred directly to the Level 2 evaluation to ensure dependencies are correctly treated. The functional accident sequences are then displayed in Table F-6 as to their contribution to each of the radionuclide release categories.

Source terms are developed for the ten release categories identified in Table F-6A and shown in Table F-7. Table F-7 provides a summary of the Level 2 results that are used as Level 3 input for the Oyster Creek SAMA analysis. This table includes the following information:

- Radionuclide Release frequency (per year)
- Oyster Creek Modular Accident Analysis Program (MAAP) case identifier (for reference)
- Airborne release for each of the fission product groups provided by MAAP
- Start time of the airborne release (measured from the time of accident initiation)
- End time of the airborne release (measured from the time of accident initiation)

The consequences corresponding to each of these source terms are provided in section F.3.

The energy of release and height of release are described in Section F.3.5.

It is noted that the warning time and treatment of evacuation are discussed in Section F.3.6.

Then, Section F.4 calculates the impacts of these severe accident consequences in economic terms.

Table F-7. Oyster Creek Source Term Summary

					Release Ca	ategory ^(1, 2, 3)				
							L2-7			
	L2-1 H/F	L2-2 H/I	L2-3 H/I	L2-4	L2-5 M/I	L2-6 M/I	L/E, LL/E,	L2-8	L2-9	L2-10
Bin Frequency	5.48E-7	7.86E-7	2.10E-7	9.99E-7	1.66E-6	1.67E-9	3.38E-6	1.96E-7	3.23E-8	2.71E-6
MAAP Run	500	525	513	523	509	510	505	501a	521b	522
Time after Scram when General Emergency is declared	~1.0 hr	36 min.	8.0 hr	1.5 hr	36 min.	8.0 hr	~1.0 hr	~1.0 hr	20 min.	~1.0 hr
Fission Product Group:										
1) Noble										
Total Release % at 36 Hours after core damage	78	72	100	100	72	100	43	100	100	0.42
Start of Release (hr)	6.5	21.0	32.0	2.0	12.0	39.	7.0	28.7	0.5	1.0
End of Release (hr)	7.5	22.0	40.0	5.0	13.0	50.	8.0	29.7	3.0	17.0
2) Csl	1946. 									
Total Release % at 36 Hours after core damage	52	26	49	5.0	3.2	5.9	0.72	3.2E-2	92	0.01
Start of Release (hr)	6.5	21.0	32.0	2.0	12.0	39.	7.0	28.7	0.5	1.0
End of Release (hr)	16.5	50.0	65.0	28.5	32.0	50.	22.0	38.0	3.0	3.0
3) TeO2										
Total Release % at 36 Hours after core damage	24	1.7	29	4.0	1.2	2.8	0.90	1.7E-3	75	6.8E-3
Start of Release (hr)	6.5	21.0	32.0	2.0	12.0	39.0	7.0	28.7	0.5	1.0
End of Release (hr)	9.5	50.0	65.0	18.5	32.0	50.0	22.0	29.7	3.0	7.0
4) SrO							5. B			
Total Release % at 36 Hours after core damage	2.2	0.5	0.69	3.2	1.0	1.3	2.5	1.6E-7	2.5	3.8E-5
Start of Release (hr)	6.5	32.5	32.0	8.5	12.0	57.	7.0	28.7	0.5	1.0
End of Release (hr)	9.5	40.0	65.0	18.5	32.0	67.	12.0	29.7	10.0	7.0
5) MoO2										
Total Release % at 36 Hours after core damage	5.5E-3	0.4E-2	0.67	6.2E-2	1.7E-3	0.13	1.5E-4	6.6E-7	4.5	1.4E-4
Start of Release (hr)	6.5	21.0	32.0	2.0	12.0	39.0	7.0	28.7	0.5	1.0
End of Release (hr)	7.5	22.0	40.0	5.0	12.0	50.0	7.0	29.7	3.0	7.0
6) CsOH				agronagest, second						
Total Release % at 36 Hours after core damage	36	5.1	36	6.4	5.4	2.9	3.6	5.1E-2	69	5.9E-3
Start of Release (hr)	6.5	21.0	32.0	2 hr	12.0	39.0	7.0	28.7	0.5	1.0
End of Release (hr)	16.5	50.0	65.0	28.5	32.0	67.0	22.0	38.0	3.0	7.0

Page F-40

Table F-7. Oyster Creek Source Term Summary

						Release Ca	ategory ^(1, 2, 3)				
								L2-7			
		L2-1	L2-2	L2-3	L2-4	L2-5	L2-6	L/E, LL/E,	L2-8	L2-9	L2-10
Dia Franciana		H/E	H/I	9 10E 7	N/E	1 665 6	1 67E 0	2 29E 6	1 06E 7	2 22E 9	
Bin Frequency		5.40E-7	1.00E-1	2.102-7	5.552-7	1.00E-0	F10	5.502-0	1.90E-7	5.232-0	2.712-0
MAAP Run		500	020 26 min	015 0.0 hr	15 br	26 min	9 0 br	-10 hr	501a	321D	522
declared		~1.0 m	30 mm.	0.0 11	1.5 11	30 mm.	6.0 Mi	~1.011	~1.0 11	20 11111.	~1.0 1
Fission Product Group:											
7) BaO Eluci di Lenjo				4010							
Total Release % at 36 Hours after core	damage	0.96	0.22	1.3	1.5	0.46	0.71	1.1	8.4E-7	5.6	2.4E-4
Start of Rele	ease (hr)	6.5	32.5	32.0	8.5	12.0	39.0	7.0	28.7	0.5	1.0
End of Rele	ease (hr)	9.5	40.0	65.0	18.5	22.0	67.0	12.0	29.7	10.0	7.0
8) La2O3	ana (na	1.1	4010	644	10.0				501		
Total Release % at 36 Hours after core	damage	6.7E-2	2.3E-3	9.7E-3	0.13	6.1E-3	2.4E-2	4.1E-2	3.5E-8	0.10	4.4E-6
Start of Rele	ease (hr)	6.5	32.5	32.0	8.5	12.0	45.0	7.0	28.7	0.5	1.0
End of Rele	ease (hr)	9.5	40.0	65.0	18.5	22.0	67.0	12.0	29.7	10.0	7.0
9) CeO2	008sa (1.1)	- C.	90.5	<u>61.0</u>		10	EU U				
Total Release % at 36 Hours after core	damage	1.3	0.12	0.16	1.6	0.27	0.54	0.77	2.0E-7	0.7	6.2E-6
Start of Rele	ease (hr)	6.5	32.5	32.0	8.5	12.0	57.0	7.0	28.7	7.0	1.0
End of Rele	ease (hr)	9.5	40.0	65.0	18.5	22.0	67.0	22.0	29.7	10.0	7.0
10) Sb End G Ede	ese (pr	16.0	87.0	45.0	28.5	E9 0	40	10.0	2810		90
Total Release % at 36 Hours after core	damage	30	28	54	19	27	12	11	6.7E-5	74	1.2E-4
Start of Rele	ease (hr)	6.5	21.0	32.0	2.0	12.0	39.0	7.0	28.7	0.5	1.0
End of Rele	ease (hr)	9.5	40.0	65.0	28.5	32.0	67.0	22.0	29.7	20.0	7.0
11) Te2	0986 (11)		2770	- 1 Pe	8 V						10.6
Total Release % at 36 Hours after core	damage	1.9	4.8E-3	2.8E-2	1.3	1.2	0.66	1.2	3.2E-6	1.0	9.1E-7
Start of Rele	ease (hr)	6.5	32.5	4.0	8.5	12.0	57.0	7.0	28.7	7.0	7.0
End of Rele	ease (hr)	9.5	40.0	65.0	18.5	22.0	67.0	12.0	29.7	20.0	17.0
12) UO2											
Total Release % at 36 Hours after core	damage	4.6E-3	2.0E-4	2.2E-4	7.9E-3	4.8E-4	1.6E-3	2.6E-3	6.0E-13	2.6E-3	4.8E-10
Start of Rele	ease (hr)	6.9	32.5	55.0	8.5	12.0	57.0	7.0	28.7	7.0	7.0
End of Rele	ease (hr)	9.5	40.0	65.0	18.5	22.0	67.0	12.0	29.7	10.0	17.0

(1)

See Section F.3.5 for additional discussion of the radionuclide release characterization. Evacuees are assigned to begin evacuating 30 minutes after General Emergency declaration. See Section F.3.6 for additional discussion of (2) population evacuation.

(3) The airborne releases are those cumulative fission product releases to the environment calculated for times of 36 hours past core damage.

Environmental Report Appendix F Severe Severe Accident Mitigation Alternatives

603

F.2.5 PRA MODEL REVIEW SUMMARY

This section summarizes the reviews of the Oyster Creek PRA model and the results of the reviews.

NRC IPE Review

The NRC review of the Oyster Creek Individual Plant Examination (IPE) was issued on August 2, 1994 [F-35]. The Staff Evaluation Report (SER) concluded the following regarding the Oyster Creek IPE:

- The Oyster Creek IPE meets the intent of Generic Letter 88-20 and associated Supplement 1.
- The submittal is deficient because the treatment of pre-initiating event human errors is lacking.
- GPUN plans to evaluate connection of the fire protection system to drywell spray as part of accident management.
- Recirculation pump seal LOCA should be modeled.
- The following "low-cost" improvement initiatives were noted by the NRC:
 - Develop an emergency procedure for Loss of Offsite Power
 - Develop an emergency procedure for Loss of DC Power
 - Increase training on the importance of the core spray system
 - Change maintenance scheduling for the core spray system
 - Institute programs to reduce blockage and fouling of the isolation condensers
 - Modify the Reactor Overfill Protection System
 - Consider the development of specific guidance, training, and procedures for reactor overfill transients
 - Increase emphasis in training on key operator actions as defined by the IPE
 - Consider alternate containment heat removal capability to maintain minimal NPSH as part of accident management
 - Consider alternate water supply for drywell sprays (Accident Management)
 - Consider Internal Flooding Procedure Enhancements
 - Consider Portable DC Charger

Many of the initiatives and improvements noted by the NRC have been completed as discussed below:

- <u>Pre-Initiating Events</u> These have been formally added to the PRA model.
- <u>Fire Protection System connection to Drywell Spray</u> Not implemented but added as SAMA item (See SAMA Item 111).
- <u>Recirc Pump Seal LOCA</u> This has been formally added to the PRA model.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

- <u>Loss of Offsite Power Procedure Development</u> Completed (Abnormal Operating Procedure ABN-36, Also ABN-37 for SBO).
- Loss of DC Power Procedure Development Completed (Abnormal Operating Procedures ABN-53, 54, 55).
- Core Spray Importance Training SAMA 127
- <u>Core Spray Maintenance Scheduling</u> This item is addressed by on-line maintenance planning associated with the a(4) portion of the maintenance rule program.
- Isolation Condenser Blockage and Fouling program SAMA 128
- Reactor Overfill Modification An RPV Level setdown modification has been installed.
- <u>Reactor Overfill Protection Procedures</u> The Reactor SCRAM abnormal operating procedure (ABN-1) has been modified to address RPV overfill. For example, step 3.10 includes direction to trip feedwater pumps.
- Key Operator Action Training SAMA 127
- <u>Alternate Containment Heat Removal</u> Not implemented but added as SAMA items (See SAMA Items 18, 111).
- <u>Alternate water supply for drywell sprays</u> Not implemented but added as SAMA item (See SAMA Item 111).
- Internal Flooding Procedure Enhancements SAMA 129
- <u>Portable DC Charger</u> Not implemented but added as SAMA item (See SAMA Item 109).

NRC IPEEE Review

The NRC review of the Oyster Creek Individual Plant Examination for External Events (IPEEE) was issued on February 8, 2001 [F-36]. The Staff Evaluation Report (SER) concluded the following regarding the Oyster Creek IPEEE:

- The OC IPEEE meets the intent of Generic Letter 88-20 Supplement 4
- In Response to NRC Requests for Additional Information (RAI), Reactor and Turbine Building failures were considered and were determined to dominate results
- In Response to NRC RAI, Fire analysis was reconsidered and dominant contributors to risk due to fire initiating events became:

- Cable Spreading room (CDF = 8.6E-6/yr)
- 480 VAC Switchgear Room (CDF = 5.1E-6/yr)
- Turbine Building Basement (CDF = 1.9E-6/yr)
- NUREG-1407 based screening of "other" external hazards was appropriately implemented
- The following potential improvements to cope with IPEEE "findings" were noted by the NRC:
 - Review Combustion Turbine Fin-Fan bolts
 - Consider additional battery spacers for Combustion Turbine battery compartment
 - Upgrade anchorage for CO2 system
 - Upgrade anchorage for CO2 racks in turbine building
 - Add supports for turbine-generator seal oil unit
 - Replace drop-weight actuated deluge valves
 - Modification of the anchorage for the Arrowhead demineralizer trailer
 - Provide operator training on IPEEE results.

All of the improvements noted by the NRC have been completed or an analysis performed to support the existing configuration as discussed below. (Closeout of these items is listed in the Oyster Creek Licensing Action Request (LAR) database):

- Review Combustion Turbine Fin-Fan bolts Complete (LAR 88242.19)
- Consider additional battery spacers for Combustion Turbine battery compartment Reevaluated and determined not necessary (LAR 88242.20)
- Upgrade anchorage for CO2 system Re-evaluated and determined not necessary (LAR 88242.22)
- Upgrade anchorage for CO2 racks in turbine building Complete (LAR 88242.25)
- Add supports for turbine-generator seal oil unit Re-evaluated and determined not necessary (LAR 88242.23)
- Replace drop-weight actuated deluge valves Complete (LAR 88242.26)
- Modification of the anchorage for the Arrowhead demineralizer trailer Complete (LAR 88242.24)
- Provide operator training on IPEEE results Complete (LAR 88242.27)

BWROG PRA Peer Review

In September 1997, a BWROG PRA Peer Certification Review was performed on the Oyster Creek PRA model. The overall conclusion was positive and stated that the Oyster Creek PRA can be effectively used to support applications involving relative risk significance.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

The "Facts and Observations" for Oyster Creek have been evaluated and addressed by the Oyster Creek PRA Program as part of the last two PRA updates. There were three "A" and nineteen "B" Facts and Observations. All twenty-two Facts and Observations have been resolved by model changes. No outstanding model issues exist outside of the normal PRA maintenance program and none are known to have the potential to impact the SAMA conclusions.

PRA Self-Assessment Analysis Review

Following the issuance of the ASME PRA Standard [F-9] and its endorsement by the NRC in RG 1.200, AmerGen undertook a detailed review of the Oyster Creek PRA model and documentation. This review was performed using the NEI recommended self-assessment process as endorsed by the NRC in RG 1.200.

The objective of the Oyster Creek self-assessment is to achieve a Capability Category II for all Supporting Requirements.

The 2004 review against the ASME PRA Standard [F-9] produced a number of items for update. Most of the items have been addressed as part of the most recent PRA update and none of the remaining resource intensive items are judged to affect the SAMA evaluation.

Conclusion

The BWROG PRA Peer Review and the self assessment analysis resolutions were incorporated into the 2004B PRA update used for the SAMA evaluation.

F.3 Level 3 PSA Analysis

This section addresses the critical input parameters and analysis of the Level 3 portion of the probabilistic risk assessment. In addition, Section F.3.8 summarizes the base case results and a series of sensitivity evaluations to potentially critical parameters.

F.3.1 ANALYSIS

The MACCS2 code [F-37] was used to perform the Level 3 probabilistic risk assessment (PRA) for the Oyster Creek Nuclear Station. Oyster Creek specific parameters are used for population distribution and economic parameters. Other input parameters given with the MACCS2 "Sample Problem A", formed the basis for the present analysis. Plant-specific release data included the time-dependent nuclide distribution of releases and release frequencies. The behavior of the population during a release (evacuation parameters) was based on plant and site-specific set points. These data were used in combination with site-specific meteorology to simulate the probability distribution of impact risks (both exposures and economic effects) to the surrounding 50-mile radius population as a result of the release accident sequences at Oyster Creek.

F.3.2 POPULATION

The population surrounding the Oyster Creek site was estimated for the year 2029.

Population projections within 50 miles of Oyster Creek were determined using SECPOP2000 [F-38], utilizing a geographic information system (GIS), U.S Census block-group level population data allocated to each sector based on the area fraction of the census block-groups in each sector, and population growth rate estimates. U.S. Census data from 1990 and 2000 were used to determine an annual average population growth estimate for each of the 50-mile radius rings. The annual population growth estimate for each ring was applied uniformly to all sectors in the ring to calculate the year 2029 population distribution.

The distribution is given in terms of population at distances to 1, 2, 3, 4, 5, 10, 20, 30, 40 and 50 miles from the plant and in the direction of each of the 16 compass points (i.e., N, NNE, NE.....NNW).

The total year 2029 population for the 160 sectors (10 distances × 16 directions) in the region is estimated as 5,411,150. The population multiplier (in parenthesis) and distribution of the population is given for the 10-mile radius from Oyster Creek and for the 50-mile radius from Oyster Creek in Tables F-8A and F-8B, respectively.

F.3.3 ECONOMY

MACCS2 requires the spatial distribution of certain economic data (fraction of land devoted to farming, annual farm sales, fraction of farm sales resulting from dairy production, and property value of farm and non-farm land) in the same manner as the population. This was done by using the SECPOP2000 code [F-38] for each of the counties surrounding the plant to a distance of 50 miles. SECPOP2000 utilizes economic data from the U.S. Department of Agriculture, "1997 Census of Agriculture" [F-39] and from other 1998 and 1999 data sources. Economic values for up to 97 economic zones were calculated and allocated to each of the 160 sectors.

In addition, generic economic data that are applied to the region as a whole were revised from the MACCS2 sample problem input when better information was available. These revised parameters include per diem living expenses (applied to owners of interdicted properties and relocated populations), relocation costs (for owners of interdicted properties), and value of farm and non-farm wealth. These values were updated to the year 2000 value using the Consumer Price Index ratio.

F.3.4 FOOD AND AGRICULTURE

Food ingestion was modeled using the COMIDA2 methodology consistent with Sample Problem A. The COMIDA2 model utilizes national based food production parameters derived from the annual food consumption of an average individual such that site specific food production values are not utilized. The fraction of population dose due to food ingestion is typically small compared to other population dose sources. For Oyster Creek, approximately 4% of the total population dose is due to food ingestion. A sensitivity case was performed to determine the impact of using site specific food production data. The results are discussed in Section F.3.8.

F.3.5 NUCLIDE RELEASE

The core inventory at the time of the accident is based on a plant specific ORIGEN 2.1 calculation. The core inventory corresponds to the best estimate, end-of-cycle values (i.e., 24 month fuel cycle) for the Oyster Creek core.

Oyster Creek nuclide release categories are related to the MACCS categories as shown in Table F-9. All releases are modeled as occurring at 0.0 meters. The thermal content of each of the releases are assumed to be the same as ambient; i.e., buoyant plume rise is not modeled.

A MACCS2 release height sensitivity case was run using a release height of 44.8m (top of reactor building) for high containment failure cases (i.e., drywell head failure) and 0.0m for low containment failure cases (i.e., wetwell or shell melt through failures). The results are discussed in Section F.3.8.

F.3.6 EVACUATION

Reactor scram signal begins each evaluated accident sequence. A General Emergency is declared when plant conditions degrade to the point where it is judged that there is a credible risk to the public. Therefore, the timing of the General Emergency declaration is sequence specific and ranges from 20 minutes to 8 hours for the release sequences evaluated.

The MACCS2 User's Guide input parameters of 95 percent of the population within 10 miles of the plant (Emergency Planning Zone) evacuating and 5 percent not evacuating were employed. These values have been used in similar studies (e.g., Hatch, Calvert Cliffs, References F-5 and F-3) and are conservative relative to the NUREG-1150 study, which assumed evacuation of 99.5 percent of the population within the emergency planning zone. The evacuees are assumed to begin evacuating 30 minutes after a General Emergency has been declared and are evacuated at an average radial speed of 1.3 miles per hour (0.57 m/sec). This speed is the time weighted value accounting for season, day of the week, time of day, weather conditions, and special events. The evacuation time weighted average of 501 minutes is for the full 0-10 mile EPZ, an assumed 15 minute notification time, and 15 minutes for evacuation preparation [F-42].

Two evacuation sensitivity cases were also performed to determine the impact of evacuation assumptions. One sensitivity case reduced the evacuation speed by a factor of two (0.29 m/sec). The second sensitivity case assumed a 90 minute delay (in lieu of 30 minute delay) prior to the start of physical evacuation movement. The results are discussed in Section F.3.8

Sector	0-1 mile (1.378) ⁽¹⁾	1-2 miles (1.33)	2-3 miles (1.495)	3-4 miles (1.916)	4-5 miles (1.481)	5-10 miles (1.563)	10-mile total
N	0	1917	4741	2826	855	38079	48418
NNE	478	1446	3437	4503	2304	35127	47295
NE	187	1104	1897	3757	3443	3893	14281
ENE	0	1677	601	904	0	0	3182
E	0	842	387	0	0	5	1234
ESE	120	1112	0	0	0	42	1274
SE	496	1226	202	0	0	1771	3695
SSE	0	789	1437	270	0	902	3398
S	0	281	1443	4192	1678	2362	9956
SSW	152	40	423	4209	3406	20893	29123
SW	0	0	0	2018	1687	14845	18550
WSW	0	13	21	11	6	1790	1841
W	0	0	0	0	0	28	28
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	569	569
NNW	0	379	2262	0	44	4384	7069
Total	1433	10826	16851	22690	13423	124690	189913

Table F-8A.	Estimated Population	n Distribution Within a
	10-Mile Radius of Ov	ster Creek, Year 2029

⁽¹⁾ Radial population multiplier applied to year 2000 census data to develop year 2029 estimate.

Environmental Report Appendix F____Severe Accident Mitigation Alternatives

Sector	0-10 miles	10-20 miles (1.422) ⁽¹⁾	20-30 miles (1.346)	30-40 miles (1.374)	40-50 miles (1.172)	50-mile total
N	48418	162020	135089	212027	393492	951046
NNE	47295	149321	170467	183999	19442	570524
NE	14281	11461	0	0	0	25742
ENE	3182	0	0	0	0	3182
E	1234	0	0	0	0	1234
ESE	1274	0	0	0	0	1274
SE	3695	0	0	0	0	3695
SSE	3398	920	0	0	0	4318
S	9956	12725	3	0	0	22684
SSW	29123	28375	23559	170768	33216	285041
SW	18550	1864	25994	69876	11983	128267
WSW	1841	479	3108	40610	114051	160089
W	28	1089	18411	176684	598898	795110
WNW	0	3949	53627	224109	923745	1205430
NW	569	22469	32655	245559	327893	629145
NNW	7069	52842	34704	135208	394546	624369
Total	189913	447514	497617	1458840	2817266	5411150

Table F-8B.	Estimated Population Distr	ribution Within a
	50-Mile Radius of Oyster C	reek, Year 2029

⁽¹⁾ Radial population multiplier applied to year 2000 census data to develop year 2029 estimate.

니페니

MACCS Release Categories	Oyster Creek Release Categories				
1-Xe/Kr	noble gases				
2-1	Csl				
3-Cs	CsOH				
4-Te	Sb (TeO2 & Te2 fractions are included)				
5-Sr	SrO				
6-Ru	MoO2 (Mo is in Ru MACCS category)				
7-La	La2O3				
8-Ce	CeO2 (included UO2 in this category)				
9-Ba	BaO				

Table F-9.	MACCS2 Release	Categories vs.	Oyster Creek	Release Catgegories
		<u> </u>		

F.3.7 METEOROLOGY

Annual Oyster Creek meteorology data from year 2003 was used in MACCS2 for the base case results. Year 2003 was the most complete and contained Oyster Creek site specific precipitation data as well as mid tower data.(1) The 2003 Oyster Creek meteorological data set contained eleven gaps of missing dates (179 total hours, representing 2.04% of the hourly readings). Five of the gaps contained more than six consecutive hours of missing data and were filled by substituting data from previous hours or days. Six of the gaps contained six or fewer consecutive hours of missing dates and were filled by interpolation. The year 2003 meteorological data set was utilized for the Oyster Creek base case MACCS2 analysis based on the fact that the year 2003 provided the highest population dose risk and offsite economic cost risk and is judged to be the most conservative.

The year 2003 meteorological data set consisted of 11 gaps of missing data (179 hours, 2.04%). Traditionally, up to 10% of missing data is considered acceptable. Of the missing gaps, six gaps consisted of 6 hours or fewer and interpolation was used to fill in the missing meteorological data. Four gaps consisted of 7 to 18 hours of missing data. One gap consisted of 100 hours of missing data. Missing meteorological data gaps of more than 6 hours were filled based on substituting data from the same time of day from the period just before or after the missing data in order to account for seasonal variations and the onset of severe weather. It is noted that MACCS results used in the SAMA analysis are the statistical mean of 369 weather sequences (each sequence contains 120 hours of data) chosen at random from pre-sorted weather bins. Due to the large number of samples analyzed, the adjustment of any particular weather sequence has negligible impact on the mean results.

Oyster Creek MACCS2 analysis evaluated three meteorological data sets (Calendar years 2000, 2001, and 2003) to ensure that the meteorological data set used in the analysis is adequate. The use of the most conservative data set (year 2003) accounts for any weather sequences that may have been misrepresented by substitute data. Based on the multiple years analyzed, minimum data gaps in the year 2003 meteorological data, and the sampling methodology used, the reported mean results are judged acceptable and appropriate for use in averted cost risk calculations.

Meteorological data was prepared for MACCS2 input as follows:

- 1. Wind speed and direction from the 10-meter sensor of the site tower were combined with precipitation (hourly cumulative). If the lower wind direction was unavailable, mid and/or upper directions were used to estimate the lower wind direction. Precipitation from the Atlantic City International Airport was used to supplement the Oyster Creek precipitation data for any unavailable hours.
- 2. If a brief period (i.e., few hours) of missing data existed for all tower sensors, interpolation was used between hours.
- 3. For larger data voids (i.e., days), tower data from the previous or following week was utilized to fill data gaps (for the same time of day).
- 4. Atmospheric stability was calculated according to the vertical temperature gradient of the tower temperature data.

⁽¹⁾ Based on the meteorological sensitivity cases, year 2003 MET data was found to result in the highest population cost and highest dose and was therefore chosen for the Base Case.

5. Atmospheric mixing heights were specified for morning and afternoon hours. These values were taken from Reference F-46 for New York, New York (approximately 50 miles from Oyster Creek).

This source defined morning as being the four-hour period from 0200 to 0600 Local Standard Time and afternoon as being the four-hour period from 1200 to 1600 Local Standard Time.

The Code Manual for MACCS2: Volume 1 (from Appendix A, pages A-1 and A-2) states the following:

The first of these two values corresponds to the morning mixing height and the second to the afternoon height. In the current implementation, the larger of these two values and the value of the boundary weather mixing height is used by the code.

In its present form, that atmospheric model implemented in MACCS2 does not allow a change in the mixing layer to occur during transport of the plume. Mixing layer height is assumed to be constant and therefore only a single value is used by the code.

For the Oyster Creek MACCS2 analyses, these conditions mean that, generally, only the afternoon mixing height is used since it is normally larger that the morning mixing height. Note that the boundary weather mixing height, wind speed and stability category are only used when there is no meteorological data. These fixed boundary weather values are ignored by the code when an hourly meteorological data file is supplied by the user, as was the case in the MACCS2 runs for Oyster Creek.

As noted above, site meteorological data for years 2000 and 2001 are also evaluated as sensitivity cases to ensure year 2003 data is an appropriate data set. For years 2000 and 2001 no site specific precipitation data is available, therefore, data from nearby Atlantic City International Airport is utilized. The results are discussed in Section F.3.8.

F.3.8 MACCS2 RESULTS

F.3.8.1 Base Case

Table F-10 shows the mean off-site doses and economic impacts to the region within 50 miles of Oyster Creek for each of ten release categories calculated using MACCS2. These impacts are multiplied by the annual frequency for each release category and then summed to obtain the frequency-weighted mean doses and economic costs.

Table F-11 provides a summary of the Oyster Creek Level 2 PRA results which provide the base case radionuclide release frequencies and timing as the input to the offiste dose and economic impact calculations.

These inputs are supplied to support the calculation of:

- The offsite Exposure Cost (uses offsite dose input)
- The offsite Economic Cost Risk (uses offsite economic impacts)

F.3.8.2 Sensitivity Cases

Table F-12 provides summary results of the MACCS2 sensitivity cases evaluated. The sensitivity cases include the following types of sensitivities:

- Meteorological (MET2000; MET20001)
- Population (30INC)
- Evacuation (Slow Evac; 90Delay)
- Radionuclide release height (OCATM6)
- Food Production (OCCROP)
- Recovery, decontamination, resettlement (Intermediate Phase) (CHR1, CHR3)

Two risk metrics are provided in Table F-12:

- The Population Dose Risk used to quantify the costs associated with dose to the public
- The offsite clean-up cost-risk which quantifies the costs associated with offsite economic impacts

The costs associated with these two risk metrics are additive along with the other smaller cost contributors discussed in Section F.4 which remain the same for these sensitivity cases.

The meteorological sensitivity cases demonstrate minimal impact on population and dose results (\pm 3%), as expected for mean results.

The population sensitivity case (30INC) demonstrates the expected significant dependency because population dose and offsite costs are primarily driven by the regional population.

The evacuation sensitivity cases (SlowEvac and 90Delay) demonstrate minor population dose impacts associated with evacuation assumptions due to the relatively slow base case Oyster Creek evacuation. Evacuation assumptions do not impact MACCS2 offsite economic cost-risk estimates because MACCS2 calculated cost-risks are based on land contamination levels which remain unaffected by evacuation assumptions and the number of people evacuating. The dose received by individuals is accounted for in the population dose (person-rem) total calculated by MACCS2.

The release height sensitivity case (OCATM6) shows a 0% change in the dose risk and an increase of 0.67% in the economic cost risk. The sensitivity case modeled a release height of 44.8m (top of reactor building) for high containment failure release categories (H/L and L-LL/L) and the intact case. The remaining containment failure release categories utilized a zero release height in the sensitivity case based on the projected containment failure phenomena of the representative MAAP case (e.g., shell melt through, wetwell failure).

The food production sensitivity case (OCCROP) shows a negligible change in dose risk (< - 0.1%) and economic cost risk (0.0%). The sensitivity case utilized food production data developed for the Oyster Creek surrounding counties (i.e., 50 mile radius) in lieu of the national averages used in the COMIDA base case modeling. The negligible change is expected because the impacts of food ingestion on the population dose and economic costs are generally observed to be small (e.g., approximately 4% of the total population dose is due to food ingestion).

The Intermediate Phase, as modeled by MACCS2, is the time period beginning after the early phase (one week emergency phase) and extends to the time when recovery actions such as decontamination and resettlement are started (long term phase). MACCS2 allows the habitation of land during the intermediate phase unless the projected dose criterion is exceeded. If the projected dose criterion is exceeded during the intermediate phase, the individual is relocated. MACCS2 allows an intermediate phase ranging from no intermediate phase to one (1) year. The Intermediate Phase related sensitivity cases (CHR1 and CHR3) show significant dependence in relation to economic impact, and are therefore further discussed:

- The No Intermediate Phase case (CHR1) was developed based on the NUREG-1150 modeling approach. However, it is judged too optimistic in that the land decontamination efforts are modeled as starting one week after the accident (i.e., after the early phase ends and the long term phase begins) such that a significant portion of population relocation costs are omitted (e.g., costs associated with temporary housing while decontamination strategies are developed and decontamination teams are contracted). It is believed that NUREG-1150 studies omitted the intermediate phase because the MACCS intermediate phase coding was not validated at that time. The population dose increases because people are allowed to re-occupy the land sooner.
- The 1 Year Intermediate Phase case (CHR3) was developed based on the maximum length of time allowed by MACCS2 for the intermediate phase. A long intermediate phase can be unrealistic in that re-occupation of the contaminated land is not performed during this phase even if contamination levels decrease (by natural radioactive decay) to levels which would allow it (i.e., resettlement is

evaluated as part of the long term phase, not the intermediate phase). Therefore, population relocation costs may be over estimated using a long (i.e., one year) intermediate phase, but population dose values would be lower.

• The six month intermediate phase (base case) is judged to be a best estimate approach in that it provides a reasonable time for both decontamination efforts and resettlement to begin. The sensitivity cases demonstrate that this six month modeling approach is mid-range of the modeling choices available.

.

MAAP Case	Release Category	Dose (P-Sv)	Costs(\$)	Frequency (per year)	Wtd. Dose Risk (p-rem/yr)	Wtd. Cost Risk (\$/yr)
OC0500	H/E	7.93E+04	3.77E+10	5.48E-07	4.35E+00	2.07E+04
OC0525	H/I	4.19E+04	1.09E+10	7.86E-07	3.29E+00	8.57E+03
OC0513	H/L	7.50E+04	3.76E+10	2.10E-07	1.58E+00	7.90E+03
OC0523	M/E	5.79E+04	1.91E+10	9.99E-07	5.78E+00	1.91E+04
OC0509	M/I	4.20E+04	1.27E+10	1.66E-06	6.97E+00	2.11E+04
OC0510	M/L	3.53E+04	9.63E+09	1.67E-09	5.90E-03	1.61E+01
OC0505	L-LL/E	4.02E+04	1.18E+10	3.37E-06	1.35E+01	3.98E+04
OC0501A	L-LL/L	1.48E+03	1.21E+08	1.96E-07	2.90E-02	2.37E+01
OC0521B	CLASS V	1.24E+05	3.62E+10	3.23E-08	4.01E-01	1.17E+03
OC0522	INTACT	2.50E+02	9.91E+06	2.71E-06	6.78E-02	2.69E+01
Frequency Weighted Totals 1.05E					3.60E+01	1.18E+05

Table F-10. MACCS2 Base Case Mean Results

Consequence Category	OC MAAP CASE	Dominant Release Category	Time of Gen. Emergency Declaration ⁽¹⁾	Time of Initial Release ⁽¹⁾	Plume Duration	Release Frequency (Per Rx Yr)
L2-1	OC0500	H/E	~1.0 hr	6.5 hr	1.0, 3.0, and 10 hr	5.48E-07
L2-2	OC0525	H/I	36 min	21 hr	1.0, 7.5, and 10 hr	7.86E-07
L2-3	OC0513	H/L	8.0 hr.	32 hr	3.0, 5.0, and 10 hr	2.10E-07
L2-4	OC0523	M/E	~1.5 hr	2.0 h r	3.0, 10, and 10 hr	9.99E-07
L2-5	OC0509	M/I	36 min	12 hr	1.0, 10, and 10 hr	1.66E-06
L2-6	OC0510	M/L	8.0 hr	. 39 hr	6.0, 5.0, and 10 hr	1.67E-09
L2-7	OC0505	L-LL/E	~1.0 hr	7.0 hr	1.0, 5.0, and 10 hr	3.37E-06
L2-8	OC0501A	L-LL/L	~1.0 hr	28.7 hr	1.0, 9.3, and 9.3 hr	1.96E-07
L2-9	OC0521B	CLASS V	20 min	30 min	2.5, 3.0, and 10 hr	3.23E-08
L2-10	OC0522		~1.0 hr	1.0 hr	1.0, 4.0, and 10 hr	2.71E-06

Table F-11. Accident Sequence Timings As A Function Of Consequence Category – Base Case

⁽¹⁾ Warning Time is the time of initial release minus the time of General Emergency declaration.

니머니

		Pop. Dose Risk		Offsite Economic Cost Risk	
Case	Description	(Per-rem/yr)	∆ Base	(\$/yr)	∆ Base
Base Case (2004B)	Base Case (Year 2003 MET data)	36.0		1.18E+05	
MET2000	Year 2000 MET data	35.8	-0.56%	1.15E+05	-2.54%
MET2001	Year 2001 MET data	35.1	-2.5%	1.14E+05	-3.39%
30INC	Year 2029 population values increased uniformly 30% over base case.	46.3	28.6%	1.46E+05	23.7%
SlowEvac	Evacuation speed decreased 50% to 0.63 mph, 0.28 m/sec (Base Case is 1.25 mph).	39.0	8.33%	1.18E+05	0%
90Delay	Evacuation begins 90 minutes after declaration of General Emergency (Base Case is 30 minutes).	36.5	1.39%	1.18E+05	0%
CHR1	No Intermediate Phase; Long Term Phase starts immediately after the Early Phase is over	41.3	14.7%	7.38E+04	-37.5%
CHR3	1 Year Intermediate Phase following the Early Phase	32.2	-10.6%	1.60E+05	35.6%
OCATM6	Release height of 44.8m (top of reactor building) for high containment failure cases (H/L, L-LL/L) and intact case	36.1	0.28%	1.19E+05	0.85%
OCCROP	Site specific food production data (Base case uses national food production data)	36.0	< -0.1%	1.18E+05	0%

Table F-12. MACCS2 Sensitivity Cases Results

F.4 Baseline Risk Monetization

This section explains how the monetized value of the status quo (i.e., accident consequences without SAMA implementation) is calculated. This analysis is also used to establish the maximum benefit that a SAMA could achieve if the SAMA eliminated all Oyster Creek risk.

F.4.1 OFF-SITE EXPOSURE COST

The baseline annual off-site exposure risk was converted to dollars using the NRC's conversion factor of \$2,000 per person-rem [F-2], and discounting to present value using the NRC standard formula [F-2]:

 $W_{pha} = C \times Z_{pha}$

Where:

W_{pha} = monetary value of public health risk after discounting

 $C = [1-exp(-rt_f)]/r$

t_f = years remaining until end of facility life = 20 years

r = real discount rate (as fraction) = 0.07/year

Z_{pha} = monetary value of public health (accident) risk per year before discounting (\$/year)

The Level 3 analysis showed an annual off-site population dose risk of 36.0 person-rem. The calculated value for C using 20 years and a 7 percent discount rate is approximately 10.76. Therefore, calculating the discounted monetary equivalent of accident risk involves multiplying the dose (person-rem per year) by \$2,000 and by the C value (10.76). The calculated present value of the off-site exposure cost is \$774,929.
F.4.2 OFF-SITE ECONOMIC COST RISK (OECR)

The Level 3 analysis showed an annual off-site economic risk of \$118,000. Calculated values for off-site economic costs caused by severe accidents must be discounted to present value as well. This is performed in the same manner as for public health risks and uses the same C value. The resulting value is \$1,270,022.

F.4.3 ON-SITE EXPOSURE COST RISK

Occupational health was evaluated using the NRC methodology in Reference F-2, which involves separately evaluating "immediate" and long-term doses.

<u>Immediate Dose</u> - For the case where the plant is in operation, the equation that NRC recommends using [F-2] is:

Equation 1:

 $W_{IO} = R{(FD_{IO})_{s} - (FD_{IO})_{A}}{[1 - exp(-rt_{f})]/r}$

Where:

- W_{IO} = monetary value of accident risk avoided due to immediate doses, after discounting
- R = monetary equivalent of unit dose (\$/person-rem)
- F = accident frequency (events/yr)
- D_{io} = immediate occupational dose (person-rem/event)
- s = subscript denoting status quo (current conditions)
- A = subscript denoting after implementation of proposed action
- r = real discount rate
- t_f = years remaining until end of facility life.

The values used in the Oyster Creek analysis are:

R = \$2,000/person-rem

- r = 0.07
- D₁₀ = 3,300 person-rem/accident (best estimate, as documented in Reference F-2)

t_f = 20 years (license extension period)

 $F = 1.05 \times 10^{-5}$ (total core damage frequency)

For the basis discount rate, assuming F_A is zero, the best estimate of the immediate dose cost is:

 $W_{IO} = R (FD_{IO})_{S} \{ [1 - exp(-rt_{f})]/r \}$

- $= 2,000*1.05\times10^{-5}*3,300*\{[1 \exp(-0.07*20)]/0.07\}$
- = \$746

Long-Term Dose - For the case where the plant is in operation, the NRC equation [F-2] is:

Equation 2:

 $W_{LTO} = R{(FD_{LTO})_{s} - (FD_{LTO})_{A}} {[1 - exp(-rt_{f})]/r}{[1 - exp(-rm)]/rm}$

Where:

W_{IO} = monetary value of accident risk avoided long-term doses, after discounting, \$

m = years over which long-term doses accrue

The values used in the Oyster Creek analysis are:

R = \$2,000/person-rem

r = 0.07

- $D_{LTO} = 20,000 \text{ person-rem/accident}$ (best estimate, as documented in Reference F-2)
- m = "as long as 10 years"
- t_f = 20 years (license extension period)
- $F = 1.05 \times 10^{-5}$ (total core damage frequency)

For the basis discount rate, assuming F_A is zero, the best estimate of the long-term dose is:

$$W_{LTO} = R (FD_{LTO})_{S} \{ [1 - exp(-rt_{f})]/r \} \{ [1 - exp(-rm)]/rm \}$$

= 2,000*1.05×10⁻⁵ *20,000*{ [1 - exp(-0.07*20)]/0.07}
{[1 - exp(-0.07*10)]/0.07*10}
= \$3,251

<u>Total Occupational Exposure</u> - Combining Equations 1 and 2 above and using the above numerical values, the total accident related on-site (occupational) exposure avoided (W_0) is:

 $W_0 = W_{10} + W_{LT0} = (\$746 + \$3,251) = \$3,997$

F.4.4 ON-SITE CLEANUP AND DECONTAMINATION COST - RISK

The net present value that NRC provides for cleanup and decontamination for a single event is \$1.1 billion, discounted over a 10-year cleanup period [F-2]. NRC uses the following equation to integrate the net present value over the average number of remaining service years:

 $U_{CD} = [PV_{CD}/r][1-exp(-rt_f)]$

Where:

 PV_{CD} = net present value of a single event

r = real discount rate

t_f = years remaining until end of facility life.

The values used in the Oyster Creek analysis are:

$$PV_{CD} = $1.1 \times 10^9$$

r = 0.07
t_f = 20

The resulting net present value of cleanup integrated over the license renewal term, \$1.18×10¹⁰, must be multiplied by the total core damage frequency of 1.05×10⁻⁵ to determine the expected value of cleanup and decontamination costs. The resulting monetary equivalent is \$124,312.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

F.4.5 REPLACEMENT POWER COST - RISK

Long-term replacement power costs was determined following the NRC methodology in Reference F-2. The net present value of replacement power for a single event, PV_{RP} , was determined using the following equation:

 $PV_{RP} = [$1.2 \times 10^8/r] * [1 - exp(-rt_f)]^2$

Where:

 PV_{RP} = net present value of replacement power for a single event, (\$)

r = 0.07

t_f = 20 years (license renewal period)

To attain a summation of the single-event costs over the entire license renewal period, the following equation is used:

 U_{RP} = $[PV_{RP}/r] * [1 - exp(-rt_f)]^2$

Where:

 U_{RP} = net present value of replacement power over life of facility (\$-year)

After applying a correction factor to account for Oyster Creek's size relative to the "generic" reactor described in NUREG/BR-0184 [F-2] (i.e., 630 MWe/910 MWe), the replacement power costs are determined to be 5.46×10^{9} (\$-year). Multiplying this value by the CDF (1.05×10^{-5}) results in a replacement power cost of \$57,357.

F.4.6 TOTAL COST - RISK

The sum of the baseline costs is as follows:

Off-site exposure cost	=	\$774,929
Off-site economic cost	=	\$1,270,022
On-site exposure cost	=	\$3,997
On-site cleanup cost	=	\$124,312
Replacement Power cost	=	\$57,357
Total cost	=	\$2,230,616

This is the Maximum Averted Cost-Risk (MACR) based on internal events contributions. This is rounded to next highest thousand (\$2,231,000) for SAMA calculations.

As described in section F.1.2, the internal events MACR is doubled to account for external events contributions. The resulting modified MACR (MMACR) is \$4,462,000 and was used in the Phase I screening process to eliminate SAMAs that are not economically feasible. If the estimated cost of implementing a SAMA exceeded \$4,462,000, it was excluded from further analysis.

Exceeding this threshold would mean that a SAMA would not have a positive net value even if it could eliminate all severe accident costs. On the other hand, if the cost of implementation is less than this value, then a more detailed examination of the potential fractional risk benefit that can be attributed to the SAMA is performed.

F.5 Phase I SAMA Analysis

The SAMA evaluation process was discussed in Appendix F.1. It includes two "phases". This subsection discusses the Phase I evaluation process of the SAMA evaluation. This includes the following tasks:

- Identify an initial list of candidate SAMAs (Section F.5.1)
- Determine the approximate implementation costs (Section F.5.2)
- Disposition the SAMAs (Section F.5.3) by determining one of the following:
 - Applicability to Oyster Creek
 - Status at Oyster Creek of implementation
 - Cost of implementation in relation to cost-risk averted

F.5.1 SAMA IDENTIFICATION

The SAMA identification process is described in this subsection. It includes the following sources:

- The Oyster Creek 2004B Level 1 PRA update using the CDF importance list (Section F.5.1.1)
- The Oyster Creek 2004B Level 2 PRA Update using the LERF importance list (Section F.5.1.2)
- Industry Phase II SAMA evaluations (Section F.5.1.3)
- The original Oyster Creek IPE insights (Section F.5.1.4)
- The original Oyster Creek IPEEE insights (Section F.5.1.5)
- NUREG-1742 (Section F.5.1.5)
- Oyster Creek System Managers input (Section F.5.1.6)

The SAMA identification process for Oyster Creek is primarily based on the PRA importance listings and potential improvements identified in the Oyster Creek updated PRA (2004B), the IPE, and IPEEE submittals. In addition to these plant specific sources, selected industry SAMA analyses were reviewed to identify any Phase II SAMAs from other plants that were determined to be cost beneficial. Also, a general review of the PRA model, focusing on aspects that affect results, was undertaken to identify potential improvements. The following subsections provide a more detailed description of the SAMA candidate identification process.

The SAMA identification process examines generic sources of information that address the spectrum of potential radionuclide releases. In addition, the plant specific PRA provides a method to examine the spectrum of releases using the two risk metrics: (1) CDF (See subsection F.5.1.1), and (2) LERF (See subsection F.5.1.2). The CDF changes or impacts result in changes affecting the following:

- Offsite population dose (primarily latent health effects)
- Offsite economic costs (including clean up)
- On-site clean up costs
- On-site dose effects

The LERF risk metrics result in identifying changes that impact offsite population dose (the early health effects costs).

There are also potential impacts of mitigation systems or phenomena associated with core melt progression that could influence the same averted cost risk parameters as the CDF risk metric mentioned above. These effects have been evaluated by scrutinizing the detailed Level 2 and the resulting contributors to the dominant averted cost release categories to assess whether

Environmental Report Appendix F Severe Accident Mitigation Alternatives

additional SAMAs beyond those identified by CDF and LERF should be identified. Those identified for consideration are the following:

- DW sprays (enhancements for external sources or passive features)
- Inerted containment
- Filtered containment vent

These SAMAs have been previously identified and are either generically dispositioned or are explicitly addressed in the SAMA list.

F.5.1.1 Level 1 Oyster Creek Importance List Review

The Oyster Creek PRA update (2004) was used to generate a list of events sorted according to their Risk Reduction Worth (RRW). The top events in this list are those events that would most reduce the Oyster Creek CDF if the failure probability were set to 0.0. The events were reviewed down to the RRW of 1.01 level (FV of 0.01), which approximately corresponds to a 1 percent change in the CDF given 100 percent reliability of the event. If the dose-risk and offsite economic cost-risk were also assumed to be reduced by 1 percent, the corresponding averted cost-risk would be approximately \$45,000. This includes a doubling factor to estimate the potential impact of External Events (refer to Section F.1.2). Systems, structures, or components (SSCs) with RRW less than 1.01 are not considered to be likely candidates for cost effective implementation because the implementation cost is judged to exceed this \$45,000 potential maximum cost-risk. No further review of the importance listing was performed below the 1.01 level. Table F-13 documents the disposition of each event in the Level 1 Oyster Creek RRW list.

F.5.1.2 Level 2 Oyster Creek Importance List Review

A similar review was performed on the importance listings from the LERF results. The LERF contributors were reviewed to identify other potential SAMA.

The LERF RRW values were also reviewed down to the RRW of 1.01. As described for the Level 1 RRW list, events below the 1.01 cutoff value are estimated to yield an averted cost-risk less than \$45,000 and are not considered to be likely candidates for identifying cost effective SAMAs. As such, the events with RRW values below 1.01 were not reviewed. Table F-14 documents the disposition of each event in the Level 2 Oyster Creek RRW list.

Event Name	Probability	RRW Description	SAMA Discussion
%LOOP	4.62E-02	1.662 LOSS OF OFFSITE POWER INITIATING EVENT	Switchyard work and other potential plant-centered initiators are included in the On-line maintenance review process performed for the a(4) portion of the maintenance rule program. The following SAMAs affecting %LOOP or its mitigation are identified:
			Bury offsite power lines (SAMA 57)
			Transformer protection (SAMAs 100 and 138)
			 Make CTs more responsive (SAMAs 56, 100, 130, and 132)
			Cross tie of Div. 1 and 2 (SAMAs 33 and 91)
			Grid stability (SAMA 131)
			No other means of reducing the LOOP frequency have been identified.
LOOP-IE-XW	4.00E-02	1.491 PROBABILITY OF LOOP DUE TO EXTREME WEATHER EVENT	This is a phenomenological factor for which operators have no control. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109, 130, 132, 134.
OSPR3HR-XW	7.43E-01	1.378 FAILURE TO RECOVER OSP WIT 2.5 HOURS (EXTREME WEATHE LOOP EVENT)	THIN Included as OC SAMA 130. R
OH-IC-SBO	9.00E-01	1.208 OPERATORS FAIL TO LOCALLY OPERATE IC (LOSS OF LONG TE DC)	Included as OC SAMAs 81 and 99. ERM
C-CATF-INP	4.40E-01	1.181 CONT. CATASTOPHIC FAILURE MODE	This event relates to the ultimate capability of primary containment. Improvements to decrease failure rate are judged to involve dramatic design improvements to primary containment such that the cost far exceeds any potential benefit.

Event Name	Probability	RRW Description	SAMA Discussion
ACP-OSP-LOCA-IND	2.40E-02	1.144 CONDITIONAL PROBABILITY OF LOOP (LOCA EVENT)	Included as OC SAMA 131.
DGEDG0001S	1.40E-02	1.142 DIESEL GEN. EDG-1 FAILS TO START	The EDGs are subject to an extensive testing and preventative maintenance process that is directed at maximizing system reliability. The PRA team could not identify other meaningful improvements regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 33, 56, 81, 91, 100, 109, 130, 132, 134.
DGEDG0002S	1.40E-02	1.138 DIESEL GENERATOR EDG-2 FAILS TO START	The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109, 130, 132, 134.
DGEDG0001R	1.04E-02	1.102 DIESEL GEN. EDG-1 FAILS TO RUN	The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109, 130, 132, 134.
DGEDG0002R	1.04E-02	1.098 DIESEL GENERTOR EDG-2 FAILS RUN	TO The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109, 130, 132, 134.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

Page F-74

	Table F-13.	Level	1 Imp	ortance	List	Review
--	-------------	-------	-------	---------	------	--------

Event Name	Probability	RRW	Description	SAMA Discussion
CCFDG1DG2R	3.86E-04	1.096	CCF OF DIESEL GENERATORS TO RUN	The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109, 130, 132, 134.
CCFDG1DG2S	3.74E-04	1.093	CCF OF DIESEL GENERATORS TO START	The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109, 130, 132, 134.
OH-DEP-ICMU- DHR4	5.00E-07	1.085	DEPENDENT HEP - FAILURE OF DHR, IC SHELL MAKEUP, AND USE OF MODE SWITCH	Addressed by SAMA 127.
ICWATERHMR	5.00E-01	1.085	ICs FAILED BY WATER HAMMER GIVEN HIGH RPV LEVEL	This is a phenomenological factor for which operators have no control other than to limit overfill. Plant modification and procedural improvement related to RPV level setdown has been implemented. These actions reduce the potential for an overfill event. Further, additional crew actions to address overfill prevention and mitigation are encompassed by SAMA 127. Oyster Creek could be modified to make the ICs more rugged but refitting of ICs and/or connected piping is judged to exceed the maximum benefit.
%RTM	1.73E+00	1.07	MANUAL SHUTDOWNS	Considered addressed by normal plant management processes.
SLSEALLOCA	5.00E-02	1.068	SEAL LOCA OCCURS DURING SBO	OC has installed improved recirc pump seals. The PRA team is not aware of any more reliable seals or seal configuration that could be implemented as a SAMA. Also, SAMA 106 addresses loss of component cooling contribution to seal unreliability.
EDEDG2MM	9.96E-03	1.067	DIESEL GENERATOR EDG-2 IN MAINTENANCE	Considered addressed by the maintenance rule.

(

Oyster Creek Generating Station License Renewal Application

Page F-75

Event Name	Probability	RRW	Description	SAMA Discussion
%MBI	2.36E-04	1.066 M IN	EDIUM LOCA - BELOW CORE ISIDE DRYWELL	The PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures, such as failure to manually depressurize, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 3, 7, and 127.
OH-DEP-S1	1.10E-01	1.064 M (N	ANUAL RPV DEPRESSURIZATION MEDIUM LOCA BELOW TAF)	Addressed by SAMAs 3 and 127.
RVNR108-SORV	1.50E-01	1.063 F/ R	AILURE OF EMRV TO RECLOSE ON EDUCED PRESSURE	The only options identified involved EMRV replacement with a more reliable design or addition of block valves to allow closure of the lines, as necessary. No significantly more reliable design was identified and addition of block valves is expensive and introduces competing risks. For example, block valves can increase the probability of line rupture by isolating the relief lines and can also decrease the reliability of blowdown by introducing block valve failed closed failure modes.
DGRECOV	5.00E-01	1.062 D W	IESEL GENERATOR RECOVERY /ITHIN 4 HOURS	The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109, 130, 132, 134.
%RT	1.01E+00	1.058 R	EACTOR TRIP	Considered addressed by normal plant management processes.
OHECD1	2.90E-01	1.056 O B	P FAILS TO OPEN CRD MANUAL YPASS VALVE V-15-30 (BLOCK_B)	Addressed by SAMAs 92 and 127.
OH-DEP-SORV	3.80E-03	1.056 M (I	IANUAL RPV DEPRESSURIZATION ORV/MLOCA ABOVE TAF)	Addressed by SAMAs 3 and 127.
ECEDG1MM	8.07E-03	1.053 D M	IESEL GENERATOR EDG-1 IN IAINTENANCE	Considered addressed by the maintenance rule.

Event Name	Probability	RRW	Description	SAMA Discussion
%LO1C	5.53E-03	1.053 LOS	S OF 4160 VAC BUS 1C	The PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These sequences involve operation of the ICs with no support equipment. These SAMAs relate to this event indirectly. See SAMAs 81, 109.
%FT2A	1.24E-02	1.05 CON FLOO	D BAY AREA FEEDWATER DD	SAMA 129 addresses internal flooding. Also, other SAMAs have been identified to reduce the impact on flood sequences of other failures, such as failure to manually depressurize, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 3 and 127.
LOOP-IE-PC	5.60E-01	1.049 CON PLAN	D. PROBABILITY LOOP DUE TO NT CENTERED EVENT	Included as SAMA 131.
RVNR108- SORVNISO	1.60E-02	1.045 SOR EVEI	V GIVEN NON-ISOLATION NT OR SUCCESS OF IC	The only options identified involved EMRV replacement with a more reliable design or addition of block valves to allow closure of the lines, as necessary. No significantly more reliable design was identified and addition of block valves is expensive and introduces competing risks. For example, block valves can increase the probability of line rupture by isolating the relief lines and can also decrease the reliability of blowdown by creating block valve failed closed failure modes.
%LO1D	5.53E-03	1.045 LOS	S OF 4160 VAC BUS 1D	The PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These sequences involve operation of the ICs with no support equipment. These SAMAs relate to this event indirectly. See SAMAs 81, 109.
OH-DEP-FW-DHR	5.00E-07	1.044 DEP LVL, AND	HEP - FAILURE TO CONTROL INITIATE TORUS COOLING, VENT CONT.	Addressed by SAMAs 3 and 127.

Oyster Creek Generating Station License Renewal Application

Page F-77

Event Name	Probability	RRW	Description	SAMA Discussion
OH-DEP-X-ICMU	9.90E-06	1.04 I	DEPENDENT HEP - FAILURE TO DEPRESS. RPV AND INITIATE IC MAKEUP	Addressed by SAMAs 3 and 127.
LOOP-IE-SW	2.00E-01	1.035 (COND. PROBABILITY LOOP DUE TO SEVERE WEATHER EVENT	This is a phenomenological factor for which operators have no control.
GRID30MIN	6.07E-01	1.035 I	FAILURE TO RECOVER GRID WITHIN 30 MINUTES	Included as SAMA 132.
%TTRIP	6.09E-01	1.035	TURBINE TRIP	Considered addressed by normal plant management processes.
%LOCW	1.93E-02	1.034	LOSS OF CIRCULATING WATER	The PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures, such as failure to manually depressurize, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 3, 104, 112, and 127.
%LOFW	4.39E-02	1.033 I	LOSS OF FEEDWATER	The PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures, such as failure to manually depressurize, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 3, 7, and 127.
ACP-OSP-TRANS	2.40E-03	1.032 (I	CONDITIONAL PROBABILITY OF LOOP (TRANSIENT EVENT)	Included as SAMA 131.
QMSCRAMFAIL	2.10E-06	1.03	MECHANICAL SCRAM FAILURE (Qm)	Reactor SCRAM reliability has been the subject of extensive industry review. The PRA team is not aware of any outstanding alternatives for increasing mechanical SCRAM reliability. The PRA team could not identify a meaningful improvement regarding this failure mode.
OSPR30MIN-PC	5.68E-01	1.03 F 3 1	FAILURE TO RECOVER OSP WITHIN 30 MINUTES (PLANT CENTERED LOOP EVENT)	Included as SAMA 132.

Page F-78

Table 1-10. Level 1 importance List Neview	Table F-13.	Level	1 Importance	List Review
--	-------------	-------	--------------	-------------

Event Name	Probability	RRW Description	SAMA Discussion
%MAIMS	1.63E-03	1.025 MEDIUM LOCA - ABOVE CORE INSIDE DRYWELL	The PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures, such as failure to manually depressurize and/or provide alternate injection, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 3, 7, and 127.
OH-DEP-X-ICMU2	1.20E-05	1.024 DEP. HEP - FAILURE TO DEPRESS. RPV AND ALIGN FPS FOR IC MU	Addressed by SAMAs 3, 94, and 127.
LOOP-IE-GR	2.00E-01	1.023 COND. PROBABILITY LOOP DUE TO GRID RELATED EVENT	This is a phenomenological factor for which operators have no control.
CT-OP-1AND2	5.80E-02	1.023 BOTH CTS INITIALLY OPERATING	Included as SAMA 132.
%SBI	5.43E-03	1.023 SMALL LOCA - BELOW CORE INSIDE DRYWELL	This is a relatively small contributor and is unlikely to have a cost beneficial method of removing this failure mode. In addition, the PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 3 and 127.
OSPR30MIN-XW	8.51E-01	1.022 FAILURE TO RECOVER OSP WITHIN 30 MINUTES (EXTREME WEATHER LOOP EVENT)	Included as SAMA 130.
CT52G001R	9.02E-02	1.022 Combustion turbine NO 1 fails	This is a relatively small contributor and is unlikely to have a cost beneficial method of removing this failure mode. In addition, the PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109.

• .

ſ

Event Name	Probability	RRW	Description	SAMA Discussion
%LOFC	1.69E-01	1.02	LOSS OF FEEDWATER CONTROL (HIGH LEVEL)	The PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures, such as failure to manually depressurize, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 3, 7, and 127.
CV0390001D	7.60E-05	1.017	CHECK VALVE V-39-1 FAILS TO OPEN ON DEMAND	Related to fuel oil for EDGs. The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOSP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109.
CCG02MCAMM	1.40E-02	1.016	CONTAINMENT SPRAY SYSTEM 2 IN MAINTENANCE	Considered addressed by the maintenance rule.
RVNR108-SORVISO	5.40E-02	1.015	SORV GIVEN ISOLATION EVENT AND FAILURE OF IC	This is a relatively small contributor and is unlikely to have a cost beneficial method of removing this failure mode. In addition, the only options identified involved EMRV replacement with a more reliable design or addition of block valves to allow closure of the lines, as necessary. No significantly more reliable design was identified and addition of block valves is expensive and introduces competing risks. For example, block valves can increase the probability of line rupture by isolating the relief lines and can also decrease the reliability of blowdown by creating block valve failed closed failure modes.
OSPR8HR-XW	6.30E-01	1.015	FAILURE TO RECOVER OSP WITHIN 8 HOURS (EXTREME WEATHER LOOP EVENT)	Included as OC SAMA 130.
OSPR8HR-SW	2.59E-01	1.015	FAILURE TO RECOVER OSP WITHIN 8 HOURS (SEVERE WEATHER LOOP EVENT)	Included as OC SAMA 130.

Page F-80

Event Name	Probability	RRW	Description	SAMA Discussion
OH-DEP-CS	2.70E-04	1.015	DEPENDENT HEP - FAILURE TO CONTROL MIN. FLOW VIA CS A AND B	Addressed by SAMA 127.
FNEFSF10021RCC	4.73E-04	1.015	Exhaust fan FN56-21 & supply fan FN- 56-21 fail to run due to CCF	Switchgear room cooling failure. ARP T-6-a provides annunciator response for high room temperature. Procedure 328 provides system level direction to open doors to promote natural circulation and to use portable fans as necessary. PRA team could identify no additional meaningful procedure or plant modifications to directly relate to this failure mode. (See SAMA 77.) However, manual IC operation appears in the same cutset and is addressed by SAMA 81.
CT52G002R	9.02E-02	1.015	Combustion turbine NO 2 fails	The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109.
OH-DEP-X-FW	1.10E-05	1.014	DEPENDENT HEP - FAILURE TO DEPRESS. RPV AND IMPLEMENT RPV LEVEL CONTROL	Addressed by SAMAs 3 and 127.
LPCOMBTURB2 MM	1.25E-01	1.014	COMBUSTION TURBINE 2 UNAVAILABLE DUE TO MAINTENANCE	Considered addressed by the maintenance rule.
OSPR30MIN-SW	7.46E-01	1.013	FAILURE TO RECOVER OSP WITHIN 30 MINUTES (SEVERE WEATHER LOOP EVENT)	Included as OC SAMA 130.
OHEOF1	7.20E-01	1.013	OPERATOR FAILS TO RECOVER FROM FEED REG VALVE LOCKUP	Addressed by SAMA 127.
OH-DEP-ICMU- DHRD	5.00E-07	1.013	DEP. HEP - FAILURE TO INITIATE IC MU AND INITIATE TORUS COOL, AND VENT CONT.	Addressed by SAMA 127.
*				· · · · ·

Page F-81

Event Name	Probability	RRW	Description	SAMA Discussion
EBXR34500SBR MM	8.97E-04	1.013 S [.] D M	TART UP TRANSFORMER SB FAILS URING OPERATION IN AINTENANCE	Considered addressed by the maintenance rule.
OSPR30MIN-GR	7.04E-01	1.012 F/ 30 E ^v	AILURE TO RECOVER OSP WITHIN D MINUTES (GRID RELATED LOOP VENT)	The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109, 130, 132, 134.
CCCB01A1BO	1.47E-05	1.012 C O	CF OF BREAKERS 1A AND 1B TO PEN ON DEMAND	The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109, 130, 132, 134.
%SAI	3.23E-03	1.012 Si D	MALL LOCA - ABOVE CORE INSIDE RYWELL	The PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures, such as failure to manually depressurize and/or provide alternate injection, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 3, 7, and 127.
%FT2BL	3.11E-03	1.012 C	OND BAY AREA LARGE CW FLOOD	SAMA 129 addresses internal flooding. Also, other SAMAs have been identified to reduce the impact on flood sequences of other failures, such as failure to manually depressurize, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 3 and 127.
%FT2B	3.06E-03	1.012 C Fl	OND BAY AREA VERY LARGE CW LOOD	SAMA 129 addresses internal flood. Also, other SAMAs have been identified to reduce the impact on flood sequences of other failures, such as failure to manually depressurize, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 3 and 127.

Page F-82

Event Name	Probability	RRW	Description	SAMA Discussion
EAXR34500SAR MM	7.46E-04	1.011	START UP TRANSFORMER SA FAILS DURING OPERATION IN MAINTENANCE	Considered addressed by the maintenance rule.
CB4KV001DT	1.99E-05	1.011	BREAKER 1D TRANSFERS OPEN	The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOSP/SBO scenarios and operation of ICs without support. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109, and 130.
CB4KV001CT	1.99E-05	1.011	BREAKER 1C TRANSFERS OPEN	The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOSP/SBO scenarios and operation of ICs without support. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109, and 130.
OSPR8HR-PC	6.40E-02	1.01	FAILURE TO RECOVER OSP WITHIN 8 HOURS (PLANT CENTERED LOOP EVENT)	The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOSP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 99, and 109.
OSPR25HR-XW	4.90E-01	1.01	FAILURE TO RECOVER OSP WITHIN 25 HOURS (EXTREME WEATHER LOOP EVENT)	The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOSP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, 109, 130, 132, and 134.
OH-DEP-TR	1.95E-04	. 1.01	MANUAL RPV DEPRESSURIZATION (TRANSIENT)	Addressed by SAMAs 3 and 127.

.

•

Table F-13. Level 1 Importance List Review

Oyster Creek Generating Station License Renewal Application

Page F-83

Event Name	Probability	RRW	Description	SAMA Discussion
%LBI	1.83E-04	1.01 LARG DRYV	E LOCA - BELOW CORE INSIDE VELL	This is a relatively small contributor and is unlikely to have a cost beneficial method of removing this failure mode. In addition, the PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 7 and 127.
OH-DEP-AT	1.10E-01	1.009 MANU (ATW	JAL RPV DEPRESSURIZATION (S)	Addressed by SAMAs 3 and 127.
%PLOFW	1.71E-01	1.009 LOSS (LOW	OF RPV LEVEL CONTROL	Addressed by SAMAs 3 and 127.
%LOIS	5.12E-03	1.009 LOSS GRAS	OF INTAKE FLOW DUE TO SSING	Addressed by SAMA 112.

Table F-14.	Level 2 Importance List Review (Based on LERF RRW)	
-------------	--	--

Event Name	Probability	RRW	Description	Potential SAMAs
%LOOP	4.62E-02	2.071	LOSS OF OFFSITE POWER INITIATING EVENT	No SAMA for reducing loss of offsite power frequency have been identified. However, SAMA 132 addresses improved recovery likelihood.
3VSY-GVFAIL-F	1.00E+00	2.03	FAILURE OF GV (CLASSES IBE, IBL)	SAMA 84
.OOP-IE-XW	4.00E-02	1.854	PROBABILITY LOOP DUE TO EXTREME WEATHER EVENT	No SAMA for making offsite power more rugged have been identified. However, modifying CT structure has been considered, SAMA 130.
C-L2-OP-SL	7.40E-01	1.804	OP FAILS TO RESTORE AC POWER DURING BOIL-OFF (EARLY) - SEAL LOCA OR DC FAILS	SAMAs 127 and 132.
)SPR3HR-XW	7.43E-01	1.738	FAILURE TO RECOVER OSP WITHIN 2.5 HOURS (EXTREME WEATHER LOOP EVENT)	SAMAs 127, 130, and 132.
)H-DEP-ALTD	1.00E+00	1.731	ALTERNATE DEPRESS. METHODS NOT CREDITED	SAMA 3
)PPH-PRESBK-F	9.90E-01	1.731	NO PRESSURE INDUCED FAILURE OF PRIMARY SYSTEM	This is a success term included in the model to allow for appropriate endstate binning. No specific failure applies for SAMA consideration.
			·	•

Page F-85

Event Name	Probability	RRW	Description	Potential SAMAs
OPPH-SORVF	4.10E-01	1.731	INDUCED SORV	No means for cost-effective improvement of EMRV ruggedness have been identified. The only options identified involved EMRV replacement with a more reliable design or addition of block valves to allow closure of the lines, as necessary. No significantly more reliable design was identified and addition of block valves is expensive and introduces competing risks. For example, block valves can increase the probability of line rupture by isolating the relief lines and can also decrease the reliability of blowdown by introducing block valve failed closed failure modes.
OPPH-TEMPBK-F	5.00E-01	1.731	NO HIGH TEMP. INDUCED FAILURE OF PRIMARY SYS	This is a success term included in the model to allow for appropriate endstate binning. No specific failure applies for SAMA consideration.
OP-SEAL	9.00E-01	1.731	RECIRC PUMP SEAL DOES NOT FAIL	This is a success term included in the model to allow for appropriate endstate binning. No specific failure applies for SAMA consideration.
AC-L2-SI-SL	4.40E-01	1.558	COND. PROB. OF NO AC RECOVERY FOR SI TIME FRAME (EARLY) - SEAL LOCA OR DC FAILS	SAMAs 127 and 132.
L2GVINERT	9.85E-01	1.553	CONTAINMENT INERTED; VENTING NOT REQUIRED	This is a success term included in the model to allow for appropriate endstate binning. No specific failure applies for SAMA consideration.
ACP-OSP-LOCA-IND	1.00E+00	1.479	CONDITIONAL PROBABILITY OF LOOP (LOCA EVENT)	SAMA 131
OPPH-OP3-NOTFSU	2.40E-02	1.479	SUCCESSFUL RPV DEPRESSURIZATION (CLASS III)	This is a success term included in the model to allow for appropriate endstate binning. No specific failure applies for SAMA consideration.
SIHU-RCVRH	9.00E-01	1.422	FAILURE TO RECOVER A WATER SYSTEM	SAMAs 2, 7, 111, and 127

Potential SAMAS
ot contain a complete core melt. No effective improvement of sump have
ost-effective improvement of shell have Benefit of water is addressed for U-RCVRH, above.
nprovement of internal drywell barriers dentified. Benefit of water is asic event SIHU-RCVRH, above.
rator reliability is considered very mprovements in the reliability are not ible. The PRA team could not identify provement regarding this failure mode mitigation of LOOP/SBO scenarios. SAMAs have been identified to reduce her failures in sequences where this ears. These SAMAs relate to this See SAMAs 81, 91, and 109.
arator reliability is considered very mprovements in the reliability are not ible. The PRA team could not identify provement regarding this failure mode mitigation of LOOP/SBO scenarios. SAMAs have been identified to reduce her failures in sequences where this ears. These SAMAs relate to this See SAMAs 81, 91, and 109.
· · · ·

Event Name	Probability	RRW	Description	Potential SAMAs
CCFDG1DG2R	3.86E-04	1.187	CCF OF DIESEL GENERATORS TO RUN	The common cause failure of the diesels is a relatively small probability. Further reduction in the CCF probability are not considered cost effective. The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, and 109.
CCFDG1DG2S	3.74E-04	1.18	CCF OF DIESEL GENERATORS TO START	The common cause failure of the diesels is a relatively small probability. Further reduction in the CCF probability are not considered cost effective. The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, and 109.
DGEDG0001R	1.04E-02	1.173	DIESEL GEN. EDG-1 FAILS TO RUN	The diesel generator reliability is considered very good. Further improvements in the reliability are not considered feasible. The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOOP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, and 109.

Environmental Report
Appendix F Severe Accident Mitigation Alternatives

Table F-14. Level 2 Importance List Review (Based on LERF RRW)

Event Name	Probability	RRW	Description	Potential SAMAs
DGEDG0002R	1.04E-02	1.162	DIESEL GENERTOR EDG-2 FAILS TO RUN	The diesel generator reliability is considered very good. Further improvements in the reliability are not considered feasible. The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOSP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, and 109.
%SBI	5.43E-03	1.153	SMALL LOCA - BELOW CORE INSIDE DRYWELL	The PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures, such as failure to manually depressurize and/or provide alternate injection, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 2, 3, 7, and 127.
EDEDG2MM	9.96E-03	1.114	DIESEL GENERATOR EDG-2 IN MAINTENANCE	Addressed by maintenance rule.
OPPH-OPE-NOTFSU	8.60E-01	1.112	SUCCESSFUL RPV DEPRESSURIZATION (CLASS IBE)	SAMA 3.
LERF-COND-PROB	1.00E+00	1.101	CONDITIONAL PROBABILITY FOR HIGH/EARLY RELEASE (CLASS V)	No SAMA for allowing containment bypass sequences to be re-binned have been identified.
RXRX-FRECINJH	9.00E-01	1.091	OPERATOR FAILS TO RECOVER INJECTION BEFORE RPV MELT	SAMA 127
ECEDG1MM	8.07E-03	1.089	DIESEL GENERATOR EDG-1 IN MAINTENANCE	Addressed by maintenance rule.

.

Table F-14. Level 2 Importance List Review (Based on LERF RRW)

•

۰.

.

.

Event Name	Probability	RRW	Description	Potential SAMAs
%SAI	3.23E-03	1.085	SMALL LOCA - ABOVE CORE INSIDE DRYWELL	The PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures, such as failure to manually depressurize and/or provide alternate injection, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 2, 3, 7, and 127.
CZPH-VBRKFCAF	1.40E-02	1.085	ONE VACUUM BREAKER FAILS TO CLOSE DURING ACCIDENT	SAMA 68
CZPH-DEIN-O2F	1.50E-02	1.082	OPERATION DEINERTED OR O2 INTRODUCED	An inerted containment provides an effective method to prevent containment failure due to combustible gas deflagration. The plant minimizes the time deinerted. Increasing the time deinerted results in a direct increase in LERF because early large releases are likely if combustible gases are not effectively controlled. No feasible SAMA for changing the technical specification allowed operation De-inerted during start-up and shutdown have been identified. No feasible SAMA to reduce potential for O2 introduction have been identified.
CZPH-H2-DEFGF	1.00E+00	1.082	HYDROGEN DEFLAGATION OCCURS GLOBALLY	SAMA 6
CZPH-STMINRTF	5.00E-01	1.082	CONTAINMENT NOT STEAM INERTED	No feasible SAMA for increasing the likelihood of this phenomenological factor have been identified.
F-CMBUST-GAS-VNT	1.00E+00	1.082	COMBUSTIBLE GAS VENTING FAILS	SAMA 84
SLSEALLOCA	5.00E-02	1.079	SEAL LOCA OCCURS DURING SBO	OC has installed improved recirc pump seals and PRA team is not aware of any more reliable seals or seal configuration.

Event Name	Probability	RRW	Description	Potential SAMAs
%MAIMS	1.63E-03	1.068	MEDIUM LOCA - ABOVE CORE INSIDE DRYWELL	The PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures, such as failure to manually depressurize and/or provide alternate injection, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 3, 7, and 127.
LOOP-IE-PC	5.60E-01	1.042	COND. PROBABILITY LOOP DUE TO PLANT CENTERED EVENT	SAMA 131
QMSCRAMFAIL	2.10E-06	1.037	MECHANICAL SCRAM FAILURE (Qm)	The PRA team could not identify a meaningful improvement regarding this failure mode.
OSPR30MIN-PC	5.68E-01	1.034	FAILURE TO RECOVER OSP WITHIN 30 MINUTES (PLANT CENTERED LOOP EVENT)	SAMAs 127 and 132.
CT-OP-1AND2	5.80E-02	1.03	BOTH CTS INITIALLY OPERATING	SAMA 132.
CV0390001D	7.60E-05	1.03	CHECK VALVE V-39-1 FAILS TO OPEN ON DEMAND	Related to fuel oil for EDGs. The PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOSP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81 91, and 109.
OSPR30MIN-XW	8.51E-01	1.03	FAILURE TO RECOVER OSP WITHIN 30 MINUTES (EXTREME WEATHER LOOP EVENT)	SAMAs 127, 130, and 132.
	•			

.

Event Name	Probability	RRW	Description	Potential SAMAs
%MBI	2.36E-04	1.029	MEDIUM LOCA - BELOW CORE INSIDE DRYWELL	The PRA team could not identify a meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures, such as failure to manually depressurize and/or provide alternate injection, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 3, 7, and 127.
PI-CONTF	2.70E-03	1.027	Pre-Existing Containment Boundary Failure	Existing methods of inspection and testing of the containment boundary ensure that containment isolation remains a very small contributor to the risk profile. No feasible SAMA for increasing the likelihood of this phenomenological factor have been identified.
%LBI	1.83E-04	1.025	LARGE LOCA - BELOW CORE INSIDE DRYWELL	LOCAs contribute to the small residual risk at Oyster Creek. This fact reinforces the need for continued vigilance in the in-service inspection (ISI) program. Oyster Creek has an effective ISI program. The PRA team could not identify additional meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 7 and 127.
%LAIMS	3.02E-04	1.024	STEAM OR FEEDWATER LINE BREAK IN DRYWELL	LOCAs contribute to the small residual risk at Oyster Creek. This fact reinforces the need for continued vigilance in the in-service inspection (ISI) program. Oyster Creek has an effective ISI program. The PRA team could not identify additional meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 7 and 127.
				event appears. These SAMAs relate to this event indirectly. See SAMAs 7 and 127.

Probability	RRW	Description	Potential SAMAs
5.91E-03	1.024	SMALL ABOVE CORE BREAK (IC TUBE)	LOCAs contribute to the small residual risk at Oyster Creek. This fact reinforces the need for continued vigilance in the in-service inspection (ISI) program. Oyster Creek has an effective ISI program. The PRA team could not identify additional meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures, such as failure to manually depressurize and/or provide alternate injection, in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 2, 3, 7, and 127.
8.30E-01	1.024	OPERATOR FAILS TO RESTORE AC POWER DURING BOIL-OFF (LATE)	SAMAs 127 and 132.
7.10E-01	1.024	CONDITIONAL PROB. OF NO AC RECOVERY FOR SI TIME FRAME (LATE)	SAMAs 127 and 132.
1.50E-01	1.024	FAILURE OF EMRV TO RECLOSE ON REDUCED PRESSURE	The only options identified involved EMRV replacement with a more reliable design or addition of block valves to allow closure of the lines, as necessary. No significantly more reliable design was identified and addition of block valves is expensive and introduces competing risks. For example, block valves can increase the probability of line rupture by isolating the relief lines and can also decrease the reliability of blowdown by creating block valve failed closed failure modes.
	Probability 5.91E-03 8.30E-01 7.10E-01 1.50E-01	Probability RRW 5.91E-03 1.024 8.30E-01 1.024 7.10E-01 1.024 1.50E-01 1.024	ProbabilityRRWDescription5.91E-031.024SMALL ABOVE CORE BREAK (IC TUBE)8.30E-011.024OPERATOR FAILS TO RESTORE AC POWER DURING BOIL-OFF (LATE)7.10E-011.024CONDITIONAL PROB. OF NO AC RECOVERY FOR SI TIME FRAME (LATE)1.50E-011.024FAILURE OF EMRV TO RECLOSE ON REDUCED PRESSURE

Event Name	Probability	RRW	Description	Potential SAMAs
%LAOIC	1.44E-04	1.022	IC STEAMLINE BREAK IN REACTOR BUILDING	LOCAs contribute to the small residual risk at Oyster Creek. This fact reinforces the need for continued vigilance in the in-service inspection (ISI) program. Oyster Creek has an effective ISI program. The PRA team could not identify additional meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 7 and 127.
OH-DEP-S1	1.10E-01	1.021	MANUAL RPV DEPRESSURIZATION (MEDIUM LOCA BELOW TAF)	SAMA 3.
OH-L2-FPS	5.40E-01	1.02	OP FAILS TO ALIGN ALT. INJ. SOURCES IN LEVEL 2	SAMA 127.
LOOP-IE-SW	2.00E-01	1.017	COND. PROBABILITY LOOP DUE TO SEVERE WEATHER EVENT	No SAMA for making offsite power more rugged have been identified. However, modifying CT structure has been considered, SAMA 130.
OPPH-OP1-NOTFSU	8.40E-01	1.016	SUCCESSFUL RPV DEPRESSURIZATION (CLASS IA, IE)	SAMA 3.
SSECCSSUCTIONLOC	1.00E-04	1.016	ECCS SUCTION STRAINER FAILURE (LOCA EVENTS)	Oyster Creek has implemented a redesigned ECCS suction strainer to dramatically decrease the probability of clogging of the suction strainer. In addition, the cleanliness of the torus water has been significantly improved. No feasible SAMA for further improving ECCS suction strainer reliability have been identified but providing additional injection not dependent on the suction strainers is included as

SAMA 7.

Table F-14. Level 2 Importance List Review (Based on LERF RRW)

Environmental Report
Appendix F Severe Accident Mitigation Alternatives

_

Event Name	Probability	RRW	Description	Potential SAMAs
ICWATERHMR	5.00E-01	1.015	ICs FAILED BY WATER HAMMER GIVEN HIGH RPV LEVEL	This is a phenomenological factor for which operators have no control other than to limit overfill. Limiting overfill operator action is Addressed by SAMA 127. Plant could be modified to make the ICs more rugged but refitting of ICs and/or connected piping is judged to exceed the maximum benefit.
LOOP-IE-GŔ	2.00E-01	1.015	COND. PROBABILITY LOOP DUE TO GRID RELATED EVENT	SAMA 131.
OHECD1	2.90E-01	1.015	OP FAILS TO OPEN CRD MANUAL BYPASS VALVE V-15-30 (BLOCK_B)	SAMA 127.
OH-DEP-SORV	3.80E-03	1.014	MANUAL RPV DEPRESSURIZATION (IORV/MLOCA ABOVE TAF)	SAMAs 3 and 127.
%LAICS	1.64E-04	1.013	CORE SPRAY LINE BREAK INSIDE DRYWELL	LOCAs contribute to the small residual risk at Oyster Creek. This fact reinforces the need for continued vigilance in the in-service inspection (ISI) program. Oyster Creek has an effective ISI program. The PRA team could not identify additional meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 7 and 127.
OH-IC-SBO	9.00E-01	1.013	OPERATORS FAIL TO LOCALLY OPERATE IC (LOSS OF LONG TERM DC)	SAMA 99.
OSPR30MIN-GR	7.04E-01	1.013	FAILURE TO RECOVER OSP WITHIN 30 MINUTES (GRID RELATED LOOP EVENT)	SAMAs 127 and 132.
OSPR30MIN-SW	7.46E-01	1.013	FAILURE TO RECOVER OSP WITHIN 30 MINUTES (SEVERE WEATHER LOOP EVENT)	SAMAs 127, 130, and 132.
•		:		

Oyster Creek Generating Station License Renewal Application

Page F-95

Appendix F Environmental Report Severe Accident Mitigation Alternatives

Event Name	Probability	RRW	Description	Potential SAMAs
%FT2A	1.24E-02	1.012	COND BAY AREA FEEDWATER FLOOD	SAMA 129 addresses internal flooding. Also, other SAMAs have been identified to reduce the impact on flood sequences of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 3, 7 and 127.
MISLBB	5.00E-01	1.012	IC BREAK AFFECTS ISOLATION CONDENSER B	LOCAs contribute to the small residual risk at Oyster Creek. This fact reinforces the need for continued vigilance in the in-service inspection (ISI) program. Oyster Creek has an effective ISI program. The PRA team could not identify additional meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 7 and 127.
RVNR108-SORVISO	1.60E-02	1.012	SORV GIVEN ISOLATION EVENT AND FAILURE OF IC	The only options identified involved EMRV replacement with a more reliable design or addition of block valves to allow closure of the lines, as necessary. No significantly more reliable design was identified and addition of block valves is expensive and introduces competing risks. For example, block valves can increase the probability of line rupture by isolating the relief lines and can also decrease the reliability of blowdown by creating block valve failed closed failure modes.
RVNR108-SORVNISO	5.40E-02	1.012	SORV GIVEN NON-ISOLATION EVENT OR SUCCESS OF IC	The only options identified involved EMRV replacement with a more reliable design or addition of block valves to allow closure of the lines, as necessary. No significantly more reliable design was identified and addition of block valves is expensive and introduces competing risks. For example, block valves can increase the probability of line rupture by isolating the relief lines and can also decrease the reliability of blowdown by creating block valve failed closed failure modes.

Event Name	Probability	RRW	Description	Potential SAMAs
ACP-OSP-TRANS	2.40E-03	1.011	CONDITIONAL PROBABILITY OF LOOP (TRANSIENT EVENT)	SAMA 131.
CFE-TNK-VF-HITMP	1.00E-05	1.011	SUPPRESSION POOL WATER UNAVAILABLE DUE TO HIGH WATER TEMP	SAMAs 7, 18, and 111.
CFE-TNK-VF-LOLVL	1.00E-05	1.011	SUPPRESION POOL WATER LEVEL BELOW DOWNCOMERS	SAMAs 7, 18, and 111.
MISLBA	5.00E-01	1.011	IC BREAK AFFECTS ISOLATION CONDENSER A	LOCAs contribute to the small residual risk at Oyster Creek. This fact reinforces the need for continued vigilance in the in-service inspection (ISI) program. Oyster Creek has an effective ISI program. The PRA team could not identify additional meaningful improvement regarding this failure mode. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 7 and 127.
OH-DEP-X-ICMU	9.90E-06	1.011	DEPENDENT HEP - FAILURE TO DEPRESS. RPV AND INITIATE IC MAKEUP	SAMA 127
1DIDW-CONTFL-F	1.00E+00	1.01	DW NOT INTACT DUE TO LOSS OF VSS OR ATWS (CLASS IIID, IV)	This is a flag marker type basic event included in the model to allow for appropriate endstate binning. No specific failure applies for SAMA consideration.
1NCPH-L1CNTFLF	1.00E+00	1.01	LG CONT. FAILURE GIVEN CONT. FAILED IN LEVEL 1 (CLASS II, IIID, IV)	This is a flag marker type basic event included in the model to allow for appropriate endstate binning. No specific failure applies for SAMA consideration.
				· · · · · ·

Event Name	Probability	RRW	Description	Potential SAMAs
CT52G001R	9.02E-02	1.01	Combustion turbine NO 1 fails	This is a relatively small contributor and is unlikely to have a cost beneficial method of removing this failure mode. In addition, the PRA team could not identify a meaningful improvement regarding this failure mode which relates to mitigation of LOSP/SBO scenarios. However, other SAMAs have been identified to reduce the impact of other failures in sequences where this basic event appears. These SAMAs relate to this event indirectly. See SAMAs 81, 91, and 109.
RXSY-RXFAIL-F	1.00E+00	1.01	FAILURE OF RX (CLASSES II, IIID, IV)	This is a flag marker type basic event included in the model to allow for appropriate endstate binning. No specific failure applies for SAMA consideration.
CZPH-VBRKFRCF	2.00E-03	1.009	ONE VACUUM BREAKER FAILS TO REMAIN CLOSED	SAMA 68.
OH-CSS-VSS-S1	4.10E-02	1.009	DW SPRAY INITIATION MEDIUM LOCA WITH VSS FAIL	SAMA 111
OH-CT-30M	2.10E-02	1.009	OPS FAIL TO START AND ALIGN CTS WITHIN 30 MIN.	SAMA 127.

F.5.1.3 Industry Phase II SAMAs

Phase II SAMAs are those plant changes that require more detailed analysis than what is performed in the Phase I screening process for proper disposition. While many of these SAMAs are shown not to be cost-beneficial, some are close contenders and a small number have been shown to be cost-beneficial at other plants. Use of the Oyster Creek importance ranking should identify the types of changes that would most likely be cost beneficial for Oyster Creek, but review of selected industry Phase II SAMAs may capture potentially important changes not identified for Oyster Creek due to PRA modeling differences. Given this potential, it was considered prudent to include a review of selected industry Phase II SAMAs in the Oyster Creek SAMA identification process.

The Phase II SAMAs from the following U.S. nuclear sites have also been reviewed:

- Monticello [F-13]
- Dresden [F-7]
- Quad Cities [F-8]
- Peach Bottom [F-6]
- Nine Mile Point Unit 1 [F-11]

The above selection of five BWR sites is chosen from similar BWRs with available documentation to serve as one of the Phase I SAMA sources for Oyster Creek. Two of these sites use Isolation Condensers. Not all of the Phase II SAMAs from these sources need to be included in the initial SAMA list. For example, many of the industry Phase II SAMAs are already represented by other SAMAs in the plant specific list, or if the industry Phase II SAMA indicated it to be a large non-cost beneficial change it can be judged that they would not be close contenders for Oyster Creek.

F.5.1.4 Oyster Creek IPE

Performance of the Oyster Creek IPE generated a list of risk-based insights and potential plant improvements. Typically, changes identified in the IPE process are implemented and closed; however, there are some items that are not completed due to high projected costs or other criteria. As the criteria for implementation of a SAMA may be different than what was used in the post IPE decision-making process, these SAMAs are re-examined in this analysis. Eight improvements were not verified complete and were added to the SAMA list. These SAMAs include:

- Connection of the fire protection system to drywell spray (SAMA 111)
- Increased training on the importance of the core spray system (SAMA 127)
- Programs instituted to reduce blockage and fouling of the isolation condensers (SAMA 128)
- Increased emphasis in training on key operator actions as defined by the IPE (SAMA 127)
- Consideration of alternate containment heat removal capability to maintain minimal NPSH as part of accident management (SAMA 18)
- Alternate water supply for drywell sprays (SAMA 111)
- Internal Flooding Procedure Enhancements (SAMA 129)
- Addition of a Portable DC Charger (SAMA 109)

F.5.1.5 Oyster Creek IPEEE

Similar to the IPE, the Oyster Creek IPEEE generated a list of risk-based insights and potential plant improvements. As the criteria for implementation of a SAMA may be different than what was used in the post IPEEE decision-making process, these SAMAs are re-examined in this analysis. Thirteen improvements were added to the Phase I SAMA list. These SAMAs include:

- Ensure all bolts on the Forked River combustion turbine fin-fan coolers are installed and torqued properly. (SAMA 114)
- Consider the addition of battery spacers in the CT battery compartments. (SAMA 115)
- Review current housekeeping policy/procedures and walk-down plant to review housekeeping and controls for transient combustibles. (SAMA 116)
- Consider upgrading the high pressure CO2 system in the turbine building. These cylinders could potentially become missiles. (SAMA 117)
- Consider additional support of a small oil filter on the Turbine generator hydrogen seal oil unit. The unit is supported by a vertical stanchion but has no lateral support. (SAMA 118)
- Review the basis for the Arrowhead demineralizer trailer. During the IPEEE walkdowns the anchorage chain was not attached to the embedded eyehook. (SAMA 119)
- Consider anchoring the high pressure generator purge CO2 rack outside the turbine building. This rack can become a missile. (SAMA 120)
- Consider replacement of fire protection drop-weight actuated deluge valves. Following a seismic event these valves could spuriously actuate and cause flow diversion of fire water and/or spurious spray of critical equipment. (SAMA 121)
- Consider training fire brigade and operators on dominant fire scenarios. (SAMA 122)
- The following relays had chatter HCLPF <0.3 g and should be considered for replacement: PNL-ER18A-2HFA51A, PNL-ER8A-2HFA51A, PNL-ER8B-2HFA51A. (SAMA 123)

- Block wall 53 has a HCLPF of 0.27g and should be considered for reinforcement. This block wall can impact 125 VDC. (SAMA 124)
- A fire in the cable spreading room can have a number of impacts. Rerouting cable or installing fire barriers can reduce the impacts of the fire. (SAMA 125)
- A fire in the 480 VAC "A" Switchgear room can have a number of impacts. Rerouting cable or installing fire barriers can reduce the impacts of the fire. (SAMA 125)

F.5.1.6 Oyster Creek System Manager Inputs

The Oyster Creek system managers provided input into both the PRA and the SAMA process in two ways:

- 1. The system managers were interviewed as part of the PRA update process. This interview process yielded both information regarding the Oyster Creek system models and also served to identify issues related to the systems that could be enhanced via a procedure or plant modification.
- 2. The system managers reviewed the SAMA list of the DRAFT Appendix F and provided revised cost estimates and additional SAMAs to factor into the evaluation.

Therefore, the system managers helped identify SAMAs through participation in each of the two separate process elements.

F.5.2 APPROXIMATE IMPLEMENTATION COSTS

The implementation costs associated with the identified SAMAs are developed from a variety of sources:

- Generic estimates
- Other similar plant estimates
- Plant specific estimates (e.g., system managers' input)
- Engineering judgment

F.5.3 PHASE I ANALYSIS

The initial list of SAMA candidates is presented in Table F-15 for consideration in a Phase I cost benefit screening evaluation. This list was developed as described in Section F.5.1 and is used as the starting point for the Oyster Creek SAMA review. The screening process used in this analysis is summarized in Figure F-1.

The purpose of the Phase I analysis is to use high level knowledge of the plant and SAMAs to preclude the need to perform detailed cost-benefit analyses for each candidate SAMA. The following criteria are used in the Phase I analysis to eliminate SAMAs from further consideration:

- Applicability to the Plant (N/A): If a proposed SAMA does not apply to the Oyster Creek design, it is not retained. For example, inclusion of an improved ESW method for D/G cooling would not require further analysis for a plant like Oyster Creek that has air cooled diesel generators.
- Cost (C): If a SAMA requires extensive changes that are known to exceed any
 possible benefit, they are screened without developing an estimated cost of
 implementation. For example, the cost of installing an additional, buried offsite
 power source over a path of fifty miles is known to exceed any potential benefit and
 would be immediately disqualified. A present value screening averted cost risk of
 \$4,462,000 is used when compared to the cost of an improvement (See section F.4).
- Already Implemented at Oyster Creek (D): If an improvement has already been implemented at Oyster Creek, it is screened from further consideration.
- Cost Exceeds Benefit (F): If the cost obviously exceeds the benefit or if the benefit is negligible, the SAMA is screened from further consideration.
- Addressed by a Similar Item (I): If a SAMA is included within another SAMA, it is screened if the other item completely subsumes it.

Those retained (R) for further evaluation are identified with a "Yes" in the last column.

While Table F-15 provides the initial screening (Phase I), the sensitivity cases described in Section F-7 provide variations in the inputs to Table F-15 that require reassessment. Therefore, in addition, to the baseline review of Table F-15, there are two additional reviews of the disposition of these SAMAs based on:

- Change in real discount rate
- Use of upper CDF uncertainty bound (95% bound)

Table F-15 provides a description of how each SAMA is dispositioned in Phase I. Those SAMAs that are not screened out and require a more detailed assessment are transferred to Phase II and are evaluated in Section F.6.

Table F-15. Phase I	SAMA	Evaluation
---------------------	------	------------

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
1	Enhanced DC Power Availability	DC power availability is important for several reasons at another BWR, including 1) maintaining high pressure injection, 2) maintaining low pressure injection (SRVs as well as control power), and 3) supporting containment venting. These functions are important for several accident scenarios and improving DC availability could reduce the risk resulting from failure of each of them. Several options are available to improve DC availability, including: a) Provide an independent battery for SRVs and Hard Pipe Vent (HPV) b) Provide a portable generator to support SRVs and HPV c) Proceduralize use of car batteries for SRVs and bypass HPV DC dependency with manual vent control d) Practice and test separate DC generator backfeed to the battery chargers e) Provide a direct connection from DG-13 to required loads	Monticello Application for License Renewal [F-13]	 I – Included in Oyster Creek specific SAMA Item 109. Oyster Creek already has multiple batteries in the A-B division. Also, batteries and chargers are of diverse design, minimizing potential for CCF. Note item b) noted in the Monticello SAMA is selected as the feasible SAMA and is evaluated in SAMA item 109. Item a): The cost associated with additional batteries, the routing of the associated cable, the procedure impact, the required surveillance testing and preventive maintenance, and the need to find a location for the batteries is judged to make the addition of two batteries prohibitive. Therefore, item b) is selected as the candidate SAMA. Item c): The use of car batteries (from outside the security fence) and the procedure to implement this is considered feasible, but the success probability is much less than Item b). This relates to the limited capability and the need for significant movement (i.e., accessibility) within the plant. If Item b) proves not cost beneficial, then Item c) could be reassessed. 	No (See SAMA 109)

Environmental Report Appendix F Severe Accident Mitigation Alternatives

.

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
1 (cont'd)				Also, such a use does not address instrumentation without additional separate batteries. This process is judged unduly cumbersome compared to Item b).	
				Item d) requires a method of power generation judged better met by Item b).	
				Item e) is plant-specific to Montecello and is not applicable to Oyster Creek.	
2	Additional HP Injection System	An additional high pressure injection system would increase high pressure injection diversity and reduce the probability of requiring RPV depressurization early in an accident. An additional HP injection system would also impact the contribution of liner melt-through sequences in the Level 2 evaluation by reducing the frequency of high pressure core melt accident class. The benefit of this SAMA would be increased if the pump was 1) diesel powered, 2) could provide power to operate its own injection valves, and 3) be located in a flood safe zone.	Monticello Application for License Renewal [F-13]	F, I –Installation of another high pressure injection system is costly and is not offset by benefits. Benefits associated with an additional high pressure injection source are minimized by the Oyster Creek features of IC and CRD. IC is a passive high pressure inventory control method and the Oyster Creek CRD includes a dedicated bypass line that allows significant flow. SAMA improvement related to CRD is included in Item 92. Improving CRD flow would provide an additional high pressure injection system for scenarios wherein CRD is not currently credited.	No (See SAMA 92)
		· .		Cost of a self-powered, high pressure injection system, located in a separate fire and flood zone is expected to cost \$10,000,000. This is in excess of the maximum averted cost.	
		:	<i>:</i>	· · ·	· .
	•		· ·		

,

Oyster Creek Generating Station License Renewal Application

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
3	Enhance Depressurization and Injection Cues	RPV depressurization, while a reliable action, is an important contributor to plant risk. The cognitive portion of this action is specifically identified as an important contributor for another BWR. Potential means of improving the probability of identifying the need for depressurization include: adding a unique audible alarm and/or a highly visible alarm light to denote the need for depressurization. Installation of a large, graphical core display for water level is an additional enhancement.	Monticello Application for License Renewal [F-13]	F – Monticello estimated the cost of this modification to be about \$700,000. This is the result of combining the costs of performing the training/procedural changes and the required hardware changes. Procedural changes are generally on the order of \$50,000 to \$100,000 [F-20] and the hardware costs are estimated based on the \$600,000 cost of installing computer aided instrumentation in the main control room. This will not significantly reduce operator error rate as annunicators are currently in place and improvement potential is minimal.	No
4	Additional Fan and Louver pair for EDG HVAC	Providing an additional HVAC train for the EDG building would improve cooling reliability. Low cost, alternate means of cooling that require local operator actions, such as the use of portable fans, have been excluded as the sprinkler system would start and damage the EDGs before the actions could be completed.	Monticello Application for License Renewal [F-13]	N/A – Oyster Creek EDG room cooling requires only operation of fans.	No

5 Improved EDG- ESW Pumping Common cause failure of the EDG-ESW pumps is a large contributor to the system Monticello Application for N/A – Oyster Creek EDGs are air- cooled. No	
Capability failure, which results in the loss of the EDGs. Installing a diverse, engine driven EDG-ESW pump would address CCF issues. Alternatively, a cross-tie to the SW system or Fire Service Water system could be implemented to back-up EDG-ESW. Given the relatively rapid heatup of the EDGs' cooling water without an active heat sink, the existing connection to SW is not credited. The SW pumps are shed on loss of power and the EDGs would fail before the pumps could be re-started and aligned to the EDGs through the cross-tie. A potential means of crediting the SW cross- tie would be to install a high temperature trip on the EDGs to prevent damage while the SW system was re-started and aligned. This would result in a temporary loss of AC power, which is undesirable. Finally, the FSW system could be modified to backup the cooling function. No load shed problems would exist, but new piping would have to be installed. Locating cross-tie controls in the main control room would allow for rapid alignment. License Renewal [F-13]	
 6 Drywell Igniters or Passive Hydrogen Ignition System 6 Drywell Igniters or Passive Hydrogen Ignition System 7 His SAMA would provide a means to reduce the chance of hydrogen detonation. 8 Amount of the chance of hydrogen detonation. 9 Application for License Renewal [F-13] 9 Amount of the chance of hydrogen detonation. 9 Amount of	
renewal [F-3] estimates the cost of a passive hydrogen ignition system to be \$760,000.	

Appendix F

Environmental Report Severe Accident Mitigation Alternatives

.

Oyster Creek Generating Station License Renewal Application

.

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
7	Enhance Alternate Injection Reliability	The capability exists at another BWR to provide flow from the RHRSW and Fire Protection systems to the RHR system; however, the reliability of the cross-tie could potentially be improved by including the cross-tie valves in the maintenance program so that the operability of the valves is monitored and tested.	Monticello Application for License Renewal [F-13]	R – OC has a hard pipe cross tie from the Fire Protection System to support RPV injection through the Core Spray system. An additional cross-tie capability from SW or ESW would provide further alternate injection capability. Development of cross-tie to SW or ESW may be feasible.	Yes

Environmental Report Appendix F Severe Accident Mitigation Alternatives

Table F-15. Phase I SAMA Evaluation

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
8	Additional DFP for Fire Service Water System	An additional diesel fire pump would provide another source of water for RPV injection and containment spray. This could be achieved through the implementation of a procedure to direct the pressurization of the Fire Protection system using a fire truck.	Monticello Application for License Renewal [F-13]	D – Oyster Creek currently has 1 electric and 2 diesel fire pumps. The electric pump is powered from normal AC power and uses a tank with limited volume. The two-diesel fire pumps are located outside the protected area in a standard metal sided building with concrete foundation.	No (See SAMA 111)
				 F – Addition of a third diesel fire pump is judged to have exceedingly small incremental benefit for RPV injection. This is because: OC has numerous injection sources 	
				 Common-cause failure among the fire pumps dominates regardless if there are 2 or 3 pumps. 	
				The containment spray enhancement is treated under SAMA 111.	
				·· ·	
				• • • • • • • • •	

Appendix F

Environmental Report Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
9	Enhance, Test and Train on Alternate Boron Injection	Another BWR has the capability to use the RWCU and CRD systems to inject boron into the RPV; however, these alignments are not practiced. The RWCU alignment is not credited in the PRA model due to the length of time required for alignment.	Monticello Application for License Renewal [F-13]	I – Oyster Creek has a reliable SLC system and the proceduralized capability for two alternate injection pathways.	No
		Changes to make these connections permanent and capable of being aligned from the MCR would improve their reliability. Additional training and practice of the alignments in the simulator and with mock-up test rigs would also improve alternate boron injection reliability.		F - The cost of making the available options directly operable from the control room is expected to cost \$4,000,000. This includes making the proceduralized hose connections of the alternate systems into hard pipe connections. The benefit is minimal because the RPS is reliable and the existing SLC system provides an adequately reliable backup.	
10	Passive Overpressure Relief	This SAMA would reduce the risk of catastrophic failure of the containment. The current Torus Hard Pipe Vent includes a rupture disk beyond an isolation valve; however, an alternate path to the Torus Hard Pipe Vent could be made in the wetwell using a rupture disk that would fail at about 60 psid. Alternatively, the containment vent valves could be changed so that they "fail open" on loss of support. Given this change, the vent path would be open on loss of support with the exception of the rupture disk. To prevent premature opening of the vent path during scenarios with loss of vent valve support, the strength of the rupture disk could be increased so that it is closer to the EOP vent pressure.	Monticello Application for License Renewal [F-13]	R – while expected to be costly and of limited benefit, this item can not be declared obviously non-cost-beneficial at this point and is retained. Oyster Creek is designed with no rupture disk in the hard pipe vent path.	Yes

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
11	Refill CST	Develop a procedure for the replenishment of the water in the CSTs (in emergency conditions). This would provide a cool suction source in LOCA or extended SBO conditions when the suppression pool becomes saturated, or for ISLOCAs, additional inventory. The benefit of this SAMA is likely limited due to the fact that 1) for SBO, the 200,000 gallon CST volume is adequate for about 3 days of boiloff makeup flow, and 2) for a LOCA, the containment level limits would be surpassed early in an accident if volume were added from outside containment.	Monticello Application for License Renewal [F-13]	D – Oyster Creek has the ability to makeup to the CST from the fire protection system, i.e., the feature already exists at Oyster Creek.	No
12 	Include a High Water Level Interlock to Open the Door from the TB931E Area to the Cold Machine Shop	Given a flood in the TB931E area, water level will rise and flood rooms critical to DC and AC power distribution. Floor failure is also possible from ponding effects. Installation of an interlock to open the door to the Cold Machine Shop on high water level and changing its swing direction will prevent these flooding consequences by diverting water to a "safe" area.	Monticello Application for License Renewal [F-13]	N/A – Monticello plant specific item which is not applicable to Oyster Creek.	No
-	Modify RCIC so that it is Capable of Operating Without Electrical Support	The important flooding scenarios at Monticello result in loss of DC and, in some cases, also AC power. This fails motor driven injection and eventually SRV operation. While RCIC is capable of injecting to the RPV when it is at high pressure (given loss of SRVs), it is currently dependent on DC power. If the electrical dependency could be removed so that the system could be operated with local, manual control, injection could be maintained for a longer period of time.	Monticello Application for License Renewal [F-13]	 I - While RCIC is not a part of the Oyster Creek design, Oyster Creek has an Isolation Condenser (IC) that provides RPV inventory control following a forced shutdown. The Oyster Creek IC can be operated under loss of support conditions using local operator actions. Also, note that local shell level indication improvement is addressed in SAMA 81 and 100. 	No (See SAMA 81 and 100)
	•	1			

Appendix F

Environmental Report Severe Accident Mitigation Alternatives

Oyster Creek Generating Station License Renewal Application

_

Table F-15.	Phase	I SAMA	Eva	luation
-------------	-------	--------	-----	---------

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
14	Post an Operator at the ASDS Panel Full Time	In the event that a fire in the Main Control Room requires evacuation to the ASDS panel, having a full time operator at the panel would allow for a more rapid transition to alternate reactor control. This is important for loss of injection cases where there is currently not enough time for the operators to evacuate the main control room and assume control at the ASDS panel (Class 1A).	Monticello Application for License Renewal [F-13]	C - The cost of implementation for this SAMA is based on an estimated base salary and the cost of benefits for 5 additional licensed operators. Five operators are justified considering that personnel are required to cover all shifts, 7 days a week and that 20 percent of operator time is spent in training. Assuming that an operator's salary and benefits cost \$100,000 per year and that the panel will be manned for the 20 year license renewal period, the cost of implementation would be \$10 million, not including raises. This cost is above the maximum averted cost for Oyster Creek.	No
15	Enhance the ASDS Panel to Include Additional System Controls	Fire scenarios that result in control room evacuation require reactor control from the ASDS panel. Given that only one division of controls is available at the panel, a single additional system failure would result in the loss of a safety function and core damage would ensue. If controls for the opposite division were added, single division failures would be eliminated as a failure mode. This is important for loss of injection cases in which the operators have time to initially take control of the plant from the ASDS panel and depressurize the RPV (Class 1D).	Monticello Application for License Renewal [F-13]	D – In addition to the remote shutdown panel (RSP), Oyster Creek IC can be operated locally as well. This limits the benefit of additional controls at the RSP. Also, note that local shell level indication improvement is addressed in SAMA 99. Since Oyster Creek has redundant success paths (IC RSP, IC local) for control room fire mitigation, this SAMA is considered implemented at Oyster Creek. Development of additional success paths is costly and not considered beneficial.	No

(

Environmental Report Appendix F Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
16	Add an Emergency Level Control System to the Hotwell	This system would actuate on low level in the main condenser (well outside of the normal operating range) and automatically provide makeup so that the FW/Condensate system will have a long term suction source. This would relegate the operator action that is currently required to align the CST to the main condenser to a backup action and improve the reliability of main condenser makeup. This is important for accident class II cases in which the FW/Condensate is initially established but fails in the long term due to lack of hotwell inventory.	Monticello Application for License Renewal [F-13]	I – Included under SAMA 133. Oyster Creek has the capability for hotwell makeup via both gravity drain (vacuum drag) and pumped system.	No (See SAMA 133)
17	Enhance loss of component cooling procedure	Enhance loss of component cooling procedure to present desirability of cooling down reactor coolant system (RCS) prior to seal LOCA.	Dresden Application for License Renewal [F-7]	I – Included as Item 106	No (See SAMA 106)
18	Improved ability to cool the residual heat removal heat exchangers.	This SAMA would reduce the probability of a loss of decay heat removal by implementing procedure and hardware modifications to allow manual alignment of the fire protection system or by installing a component cooling water cross-tie.	Dresden Application for License Renewal [F-7]	R – Cross-tie of fire water to containment spray heat exchangers can not be declared non-cost-beneficial at this point.	Yes
		A portable diesel-driven pump is under consideration to provide cooling water to a LPCI heat exchanger. This was discussed in the EPU correspondence as the tentative plan for dealing with the seismic outlier of Dresden Island Lock & Dam, i.e., loss of UHS, by Fall 2003.			
			· ·		•
				· · · ·	· ·
		· · · · · · ·	• •.		

.

Appendix F

Environmental Report Severe Accident Mitigation Alternatives

Oyster Creek Generating Station License Renewal Application

_

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
19	Develop an enhanced drywell spray system.	This SAMA would provide a redundant source of water to the containment to control containment pressure, when used in conjunction with containment heat removal. A potential enhancement would be to proceduralize the cross-tie between the containment spray path of one unit to the LPCI system of the opposite unit. Another alternative is the addition of a connection between containment spray and the plant's fire protection system.	Dresden Application for License Renewal [F-7]	I – See Item 111.	No (See SAMA 111)
20	Re-open MSIVs	SAMA would allow regaining the main condenser as a heat sink by re-opening the MSIVs. There are two important aspects of the MSIV closure response: For non-ATWS conditions, the ability to rapidly respond to MSIV closure and restore the main condenser as a heat sink is not explicitly directed. For ATWS conditions, Dresden EOPs direct MSIV low level closure bypass in order to	Dresden Application for License Renewal [F-7]	R – Potentially cost-beneficial.	Yes
		retain the main condenser as a heat sink; however, this assumes the MSIVs have not yet closed. For both cases, explicit procedural direction to re-open the MSIVs could be included.			
21	Increase seismic ruggedness of plant components.	Increase the seismic capacity of components on the safe shutdown paths with capacities less than 0.3g.	Dresden Application for License Renewal [F-7]	I – See Oyster Creek specific Items 123, 124, and item 67.	No (See SAMAs 67, 123, and 124)

Environmental Report Appendix F Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
22	Passive Overpressure Relief	This SAMA will prevent catastrophic failure of the containment. Controlled relief through a selected vent path has a greater potential for reducing the release of radioactive material than through a random break.	Dresden Application for License Renewal [F-7]	D, I – For benefits of passive venting, see SAMA Item 10. Oyster Creek has already implemented a hard pipe containment vent.	No (See SAMA 10)
23	Diversify the explosive valve operation	An alternate means of opening a pathway to the RPV for SBLC injection would improve the success probability for reactor shutdown.	Dresden Application for License Renewal [F-7]	R – This cannot be declared non-cost- beneficial at this point.	Yes
24	Enrich Boron	The increased boron concentration will reduce the time required to achieve the shutdown concentration. This will provide increased margin in the accident timeline for successful operator activation of SBLC.	Dresden Application for License Renewal [F-7]	D – Oyster Creek already has highly enriched Boron. Further enrichment is not expected to significantly impact the PRA.	No
25	Bypass Low Pressure Permissive	LPCI and CS injection valves require a permissive signal from the same 2 pressure sensors in order to open. The instruments are currently specified as diverse. However, because this is a "pinch point" for all CS and LPCI injection, it is judged prudent to consider a plant modification to allow a bypass switch (1/division) to insert the permissive if the sensors fail to perform their function. A few other BWRs currently have this capability (e.g., Perry).	Dresden Application for License Renewal [F-7]	R – This cannot be declared non-cost- beneficial at this point.	Yes

.

Appendix F

Environmental Report Severe Accident Mitigation Alternatives

-

 \mathcal{D}^{+}

. ..

• •

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
26	Supplemental Air Supply for the Containment Vent	The containment vent function is among the last resort methods currently specified in BWRs to remove heat from containment and control containment pressure under extremely adverse circumstances. The Dresden air compressors are required to support the containment vent function. The air compressors in turn require cooling, normally from TBCCW/SW. An alternative method to supply air to the vent valves for opening would be desirable if SW were to become inadequate.	Dresden Application for License Renewal [F-7]	 D – Oyster Creek has dedicated air accumulators for containment venting AOVs in the hard pipe vent path. F – Oyster Creek does have secondary vent pathways that would be used to vent and purge combustible gases from containment. However, because Oyster Creek operates with an interted containment atmosphere the NRC has previously determined that Mark I combustible gas venting is not risk significant. This is supported by the Oyster Creek PRA. Therefore, this plant modification would not be cost beneficial. 	No
27	Supplemental Air Supply for Containment Vent Under SBO Conditions	The containment vent function is among the last resort methods currently specified in BWRs to remove heat from containment and control containment pressure under extremely adverse circumstances. Many plants require a long term source of air or nitrogen and a DC power source to allow venting in an SBO.	Dresden Application for License Renewal [F-7]	I – Oyster Creek has dedicated air accumulators for containment venting AOVs. Venting in an SBO is not a significant contributor because of the dominance by shorter term failures. SAMA 84 addresses handwheels for containment vent valves which would allow system operation in SBO.	No (See SAMA 84)
28	Demonstrate RCIC Operability Following Depressurization	This SAMA would increase the operators' options for injection with the vessel at low pressure. Given Monticello's ability to power the battery chargers with the 480v AC generator, the limiting factor for RCIC injection appears to be depressurization at HCTL. If it could be shown that a limited depressurization to about 100 psid could be performed and allow continued injection with RCIC, injection could be maintained for a longer period during an SBO.	Quad Cities Application for License Renewal [F-8]	N/A – Not applicable to Oyster Creek design. No RCIC at Oyster Creek.	No

Page F-116

Environmental Report Appendix F Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
29	Control Containment Venting Within a Narrow Band of Pressure	This SAMA would establish a narrow pressure control band that would thereby prevent rapid containment depressurization when venting is implemented. Venting in this manner would avoid adverse impacts on the low pressure ECCS injection systems taking suction from the torus.	Quad Cities Application for License Renewal [F-8]	I – see Item 88.	No
30	Provide means for alternate SSMP room cooling	The SSMP requires room cooling at extended times. This SAMA would allow SSMP operation late in accidents when normal room cooling has failed. Evaluate the benefit of providing alternate SSMP room cooling. These options may include: - Controls in the Main Control Room for remote alignment of SW or FPS to SSMP room cooling - Procedures for opening SSMP room doors and using portable fans for SSMP room cooling	Quad Cities Application for License Renewal [F-8]	N/A – Quad Cities plant specific item not applicable to Oyster Creek. It is noted that ECCS pumps at Oyster Creek can survive without room cooling for the PRA mission time of 24 hours.	No
31	Develop an enhanced drywell spray system.	SAMA would provide a redundant source of water to the containment to control containment pressure, when used in conjunction with containment heat removal. The Fire Protection system can already provide water to the RHR system at Quad Cities; however, no procedures have been developed to use it as a containment spray source. The containment spray function could be further enhanced at Quad Cities.	Quad Cities Application for License Renewal [F-8]	I – See Item 111.	No (See SAMA 111)

.

. . .

Appendix F

Environmental Report Severe Accident Mitigation Alternatives

-

Table F-13, Flidse I SAMA LValuation	Table F-15.	Phase	I SAMA	Evaluation
--------------------------------------	-------------	-------	--------	------------

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
32	Use fuel cells instead of lead-acid batteries.	SAMA would extend DC power availability in an SBO.	Quad Cities Application for License Renewal [F-8]	I, F – Oyster Creek has diverse battery design presently. The system is already reliable. Evaluation of a portable DC charger is viewed as more beneficial. See Item 109. Also, note that the fuel cell option is new technology, never used in such a manner. It is judged expensive. A small, engine driven charger is considered a more cost-efficient and proven approach.	No (See SAMA 109)
33	Improve 4.16-kV bus cross-tie ability.	Enhance procedures to direct 4kV bus cross-tie. If this procedural step already exists, investigate installation of hardware that would perform an automatic cross-tie to the opposite 4kV bus given failure of the dedicated diesel.	Quad Cities Application for License Renewal [F-8]	I – See Item 91. Procedure step does not currently exist and automatic cross-tie is not pursued in favor of manual actuation. Auto- closure is more expensive and, in this case, may increase the potential to auto-close into a fault. The PRA team's assessment is that the preferred course of action is for the operators to manually diagnose and control the evolution based on actual plant conditions.	No (See SAMA 91)
34	Create a backup source for diesel cooling. (Not from existing system)	This SAMA would provide a redundant and diverse source of cooling for the diesel generators, which would contribute to enhanced diesel reliability.	Quad Cities Application for License Renewal [F-8]	N/A – Oyster Creek EDGs are air cooled.	No
35	Provide procedures for (a) bypassing major DC buses; (b) locally starting equipment	This SAMA would allow for powering specific loads given a DC bus failure and/or the ability to start equipment locally that normally requires DC power for a control room start.	Quad Cities Application for License Renewal [F-8]	D – Oyster Creek has procedures for Operating breakers manually (See ABN-53).	No
36	Delete High DW Pressure Signal from SDC isolation	This SAMA would allow the initiation of SDC when the drywell is at elevated pressures.	Quad Cities Application for License Renewal [F-8]	I See Item 90 for disposition.	No (See SAMA 90)

Environmental Report Appendix F Severe Accident Mitigation Alternatives

..

Page F-118

(

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
37	Develop procedures to control Feedwater flow without 125 VDC power to prevent tripping Feedwater on High/Low level	This SAMA increases the functionality of Feedwater in loss of DC scenarios and increases the probability of successful level control.	Quad Cities Application for License Renewal [F-8]	D Oyster Creek has a procedure for local manual control of feedwater.	No
38	Remove Loop Select Logic	In the event that there is no break in the recirc loops and there is a Loop "B" injection path failure, the Loop "A" injection path is precluded from use. Removal of the LPCI Loop Select Logic or installation of a bypass switch would allow use of the "A" loop for injection in the event of a "B" injection path failure.	Quad Cities Application for License Renewal [F-8]	N/A – Not applicable to Oyster Creek design.	No
39	Diversify the explosive valve operation	An alternate means of opening a pathway to the RPV for SBLC injection would improve the success probability for reactor shutdown.	Quad Cities Application for License Renewal [F-8]	I – See Item 23 for disposition.	No (See SAMA 23)
40	Enrich Boron	The increased boron concentration will reduce the time required to achieve the shutdown concentration. This will provide increased margin in the accident timeline for successful operator activation of SBLC.	Quad Cities Application for License Renewal [F-8]	I – See Item 24 for disposition.	No (See SAMA 24)
41	Passive Overpressure Relief	This SAMA will prevent catastrophic failure of the containment. Controlled relief through a selected vent path has a greater potential for reducing the release of radioactive material than through a random break.	Quad Cities Application for License Renewal [F-8]	I – See Item 10 for disposition.	No (See SAMA 10)
	- :	· · · · · · · · · · · · · · · · · · ·	<u>-</u> . <u>-</u>	· · · · · · · · · · · · · · · · · · ·	

•

١

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
42	Enhance Procedural Guidance for Use of Cross-tied Service Water Pumps	Enhancement of procedures directing the use of the Service Water system as a back up for 1) ESW and 2) EDG/ESW. Updated procedures and training on their use may improve the reliability of the cross-ties.	PBAPS Application for License Renewal [F-6]	D – Oyster Creek has procedures for swapping Circulating Water system cooling of TBCCW to SW and for use of fire water to cool air compressors. No cooling water cross-tie procedural weaknesses have been noted.	No
				 F – Section F.6.3 included a number of sensitivity assessments regarding service water and emergency service water cross-tie. These sensitivities show that these cross-ties produce minimal benefit and are not cost-beneficial. 	
				N/A - OC DGs do not require cooling water.	
43	Improved ability to cool the residual heat removal heat exchangers.	This SAMA would reduce the probability of a loss of decay heat removal by implementing procedure and hardware modifications to allow manual alignment of the fire protection system or by installing a component cooling water cross-tie.	PBAPS Application for License Renewal [F-6]	I – See Item 18 for disposition.	No (See SAMA 18)
44	Install an independent method of suppression pool cooling.	This SAMA would decrease the probability of loss of containment heat removal.	PBAPS Application for License Renewal [F-6]	F - IC provides an alternate method of DHR that eliminates heat discharge to the torus for non-LOCA scenarios. Development of another means beyond containment spray is viewed as limited benefit compared to a high cost for such a modification. An independent system is judged to cost \$5,000,000. This is in excess of the maximum averted cost.	No

Environmental Report
Appendix F Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
45	Install a filtered containment vent to remove decay heat.	This SAMA would provide an alternate decay heat removal method for non-ATWS events, with the released fission products being scrubbed. Option 1: Gravel Bed Filter Option 2: Multiple Venturi Scrubber	PBAPS Application for License Renewal [F-6]	F – Cost is high at > \$4M as assessed for Shoreham. The benefits in dose reduction are limited because of the Mark I shell failure mode and ATWS challenges that would fail containment. SAMA would not address core damage and does not address Noble gas release. This was not found cost- beneficial for Peach Bottom. Estimated to cost in excess of the maximum averted cost.	No
46	Install a containment vent large enough to remove ATWS decay heat.	Assuming that injection is available, this SAMA would provide alternate decay heat removal in an ATWS event.	PBAPS Application for License Renewal [F-6]	F – Cost is high and benefits, in terms of dose reduction, are limited because of the small ATWS contribution to the risk profile. Containment vent size is sufficient to prevent containment failure as long as reactivity management tasks are completed as modeled in the PRA (i.e., RPV level control and SLC initiation). ATWS power levels without reactivity control would be in the range of 10% to 40% of full power. This requires a substantially larger containment vent than the current hard pipe vent. To achieve an operational "ATWS Vent" of hard pipe configuration and adequate size is estimated to cost in excess of \$2M. This is above the benefit to be achieved for elimination of the small ATWS contribution to risk at Oyster Creek.	No
47	Use the fire protection system as a backup source for the containment spray system	This SAMA would provide redundant containment spray function without the cost of installing a new system.	PBAPS Application for License Renewal [F-6]	I - See Item 111 for disposition.	No (See SAMA 111)
	spidy system.	· · · · · · · · · · · · · · · · · · ·		··· · ·· ·	

Appendix F

Environmental Report Severe Accident Mitigation Alternatives

Oyster Creek Generating Station License Renewal Application

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
48	Install a passive containment spray system.	This SAMA would provide redundant containment spray method without high cost.	PBAPS Application for License Renewal [F-6]	F – High cost modification. Gravity feed system would provide limited benefit beyond that considered in Item 111 and would likely increase internal flooding risk.	No (See SAMA 111)
49	Construct a building to be connected to primary/secondary containment that is maintained at a vacuum.	This SAMA would provide a method to depressurize containment and reduce fission product release.	PBAPS Application for License Renewal [F-6]	C – This item is viewed as having a very large cost (> \$10 Million) and is well beyond the maximum averted cost for Oyster Creek.	No
50	Proceduralize alignment of spare diesel to shutdown board after loss of offsite power and failure of the diesel normally supplying it.	This SAMA would reduce the SBO frequency.	PBAPS Application for License Renewal [F-6]	D - Oyster Creek has previously installed Combustion Turbines (CTs) as an alternate AC power source to supplement the emergency diesel generators. The CTs are credited in the OC Station Blackout (SBO) analysis. The alignment of the alternate AC sources are proceduralized and allow connection to one of the in-plant AC buses (1B) in response to LOOP or SBO. SAMA 91 addresses the cross tie of these AC sources (CTs) to both in-plant AC divisions.	No (See SAMA 91 and 140)
51	Provide an additional diesel generator.	This SAMA would increase the reliability and availability of onsite emergency AC power sources.	PBAPS Application for License Renewal [F-6]	C – Cost of an additional building and diesel is estimated at more than \$5M. This is greater than the maximum cost averted benefit.	No

Environmental Report Appendix F Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
52	Provide additional DC battery capacity.	This SAMA would ensure longer battery capability during an SBO, reducing the frequency of long-term SBO sequences.	PBAPS Application for License Renewal [F-6]	I –Oyster Creek already has multiple batteries in the A-B division. Also, batteries and chargers are of diverse installation. Additional batteries are costly, require a location for installation, and must be inter-connected with the current system. Also, as with the currently installed batteries, they eventually become exhausted in long- term SBO scenarios. Evaluation of a portable battery charger is viewed as more beneficial for Oyster Creek. Included in Item 109 for disposition.	No (See SAMA 109)
53	Use fuel cells instead of lead-acid batteries.	This SAMA would extend DC power availability in an SBO.	PBAPS Application for License Renewal [F-6]	I, - See SAMA 32	No (See SAMA 32)
54	Increase/improve DC bus load shedding.	This SAMA would extend battery life in an SBO event.	PBAPS Application for License Renewal [F-6]	D – Oyster Creek already has multiple batteries in the A-B division. DC load shedding is part of LOOP and SBO proceduralized responses. DC load shedding has been reviewed by the PRA Team as part of crew interviews to support the Human Reliability Analysis (HRA) and no additional enhancements or improvements in the procedure were noted. The potential benefit from enhancements is considered to be a relatively small increase in time available with DC power (e.g., approximately 1 to 2 hours). Such small changes in time available for AC recovery has a very small impact on the risk profile. Therefore, this SAMA is not considered cost beneficial.	No

Oyster Creek Generating Station License Renewal Application

Environmental Report
Appendix F Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
55	Develop procedures to repair or replace failed 4-kV breakers.	This SAMA would offer a recovery path from a failure of the breakers that perform transfer of 4.16-kV non-emergency busses from unit station service transformers, leading to loss of emergency AC power.	PBAPS Application for License Renewal [F-6]	D – Viewed as within electrical maintenance capability for repairable equipment failures.	No
56	Install gas turbine generator.	This SAMA would improve onsite AC power reliability by providing a redundant and diverse emergency power system.	PBAPS Application for License Renewal [F-6]	D - Oyster Creek has previously installed Combustion Turbines (CTs) as an alternate AC power source to supplement the emergency diesel generators. The CTs are credited in the OC Station Blackout (SBO) analysis.	Νο
57	Bury offsite power lines.	This SAMA could improve offsite power reliability, particularly during severe weather.	PBAPS Application for License Renewal [F-6]	 D – The Power line supply from the CTs is already underground. Obviously, the offsite power grid and its connection to the on-site transformers is above ground. It is considered that the intent of the SAMA includes addressing only the alternate AC power source (e.g., the Conowingo Dam at Peach Bottom). 	No
58	Proceduralize intermittent operation of HPCI.	This SAMA would allow for extended duration of HPCI availability.	PBAPS Application for License Renewal [F-6]	N/A – Not applicable to Oyster Creek; No HPCI at Oyster Creek.	No
59	Install motor-driven feedwater pump.	This SAMA would increase the availability of injection subsequent to MSIV closure.	PBAPS Application for License Renewal [F-6]	D – Oyster Creek condensate and feedwater pumps are all motor driven. Because already implemented, no significant incremental benefit from additional feedwater pumps.	No
60	Enhance procedure to instruct operators to trip unneeded RHR/CS pumps on loss of room ventilation.	This SAMA increases availability of required RHR/CS pumps. Reduction in room heat load allows continued operation of required RHR/CS pumps, when room cooling is lost.	PBAPS Application for License Renewal [F-6]	D – It is noted that ECCS pumps at Oyster Creek can survive for the PRA mission time of 24 hours without room cooling.	No

Page F-124

Environmental Report Appendix F Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
61	Increase the safety relief valve (SRV) reseat reliability.	This SAMA addresses the risk associated with dilution of boron caused by the failure of the SRVs to reseat after standby liquid	PBAPS Application for License	D – EMRV reseat failure is a significant risk contributor to Oyster Creek.	No
		control (SLC) injection. The SAMA benefit extends to non-ATWS conditions where the IC is a critical inventory control method. The SORV would adversely impact IC availability.	Renewal [F-6]	Oyster Creek has staggered the EMRV and safety valve pressure setpoints to minimize the number of challenges to EMRVs. In addition, operators have clear procedural direction to reduce RPV pressure to minimize the number of EMRV challenges reducing the need for a low-low set modification. In addition, Oyster Creek IC operation limits the number of EMRV challenges. The only other means for significant reduction for this failure mode would be a complete replacement of EMRV design. No other designs have been	
		- -		noted to be significantly more reliable so benefit is judged negligible at this time. The normal maintenance process takes into account vendor recommended maintenance. No additional modifications or	
62	Modify Reactor Water Cleanup (RWCU) for use as a decay heat removal system and proceduralize use.	This SAMA would provide an additional source of decay heat removal.	PBAPS Application for License Renewal [F-6]	C – The RWCU system is currently proceduralized and used "as is" to provide decay heat removal over a portion of the spectrum of shutdowns. However, the RWCU system has very small heat removal capability and therefore, does not have the capability to provide a significant benefit.	No
	· ·	· · ·	· · ·	No options for significant capacity improvement have been identified that would cost less than \$4M.	

Oyster Creek Generating Station License Renewal Application

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
63	Increase seismic ruggedness of plant components.	This SAMA would increase the availability of necessary plant equipment during and after seismic events.	PBAPS Application for License Renewal [F-6]	 I – See Items 114, 117, 118, 120, 121, 123, 124. The seismic analysis submitted as part of the IPEEE was reviewed to assess whether any plant specific SAMAs should be added to the evaluation. The results of the review included the identification of additional SAMAs. 	No (See SAMAs 114, 11, 118, 120, 121, 123 and 124)
64	Passive High Pressure System	This SAMA will improve prevention of core melt sequences by providing additional high pressure capability to remove decay heat through an isolation condenser type system	PBAPS Application for License Renewal [F-6]	D – Oyster Creek already has isolation condensers installed. These represent a form of passive decay heat removal.	No
65	Suppression Pool Jockey Pump	This SAMA will improve prevention of core melt sequences by providing a small makeup pump to provide low pressure decay heat removal from the RPV using the suppression pool as a source of water.	PBAPS Application for License Renewal [F-6]	F – Not viewed as a significant benefit. The small pump with suction from the suppression pool could provide water to the RPV. The flow rate may be adequate to supply MRDIR flow dictated in the SAMGs but is not considered sufficient for the prevention of core damage. Support systems for the pump will govern its availability to fulfill this role. No measurable risk decrease is judged achievable.	No
66	Additional Active High Pressure System	This SAMA will improve reliability of high pressure decay heat removal by adding an additional system.	PBAPS Application for License Renewal [F-6]	I – See Item 2 for disposition.	No (See SAMA 2)

Environmental Report Appendix F Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
67	Safety Related Condensate Storage Tank	This SAMA will improve availability of CST following a Seismic event	PBAPS Application for License Renewal [F-6]	 R – Oyster Creek does not use CST for RCIC/HPCI/HPCS as is common for other BWRs. However, Oyster Creek uses CST for condensate/feedwater, CRD, and IC makeup. OC also has an option to align the CST to the suction of core spray. Condensate and feedwater are likely to be failed in seismic event because of low fragility for offsite power and CTs. IC could be failed because of seismic acceleration amplification (Large tank-type configuration located high in building). Also, fire pump makeup is possible if the fire system and IC survive but CST does not. The CS alignment to the CST can also be used to cope with failure of the torus, ECCS suction strainer plugging, and to supplement containment flooding. These issues are considered to be of low probability and represent marginal additional benefits. Therefore, it would appear that benefit is driven by CRD significance primarily. HCLPF for CST is 0.09 and strengthening cannot be ruled out as cost beneficial. 	Yes
	· •		•••		
				·• ·*	

Appendix F

Environmental Report Severe Accident Mitigation Alternatives

.

Oyster Creek Generating Station License Renewal Application

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
68	Improved Vacuum Breakers (redundant valves in each line)	This SAMA reduces the probability of a stuck open vacuum breaker.	PBAPS Application for License Renewal [F-6]	F - Oyster Creek has 14 single torus to drywell vacuum breakers arranged in 7 parallel lines, which can impact vapor suppression. Adding valves in series is highly expensive and reduces the success probability for the open on demand function. Benefit impacts only low frequency accident sequences. Added redundancy has only minor impact on the risk profile. Cost estimated by system manager to be \$2,000,000.	No
69	Improved MSIV Design	Replace MSIVs with improved design.	PBAPS Application for License Renewal [F-6]	C – Replacing MSIVs is estimated by system manager to cost \$10 million which is beyond the maximum averted cost.	No
70	Steam Driven Turbine Generator	This SAMA would provide a steam driven turbine generator which uses reactor steam and exhausts to the suppression pool. If large enough, it could provide power to additional equipment.	PBAPS Application for License Renewal [F-6]	C – Adding such a system is judged to require a new building and therefore, involves a cost greater than \$10 million which is beyond the maximum averted cost.	No
71	Improved Uninterruptible Power Supplies	This SAMA would provide increased reliability of power supplies supporting front- line equipment, thus reducing core damage and release frequencies.	PBAPS Application for License Renewal [F-6]	D – Oyster Creek has automatic transfer switches that allow 120V AC and 125V DC to be powered from multiple sources for many vital components. Oyster Creek on DC power as a primary backup for vital instrumentation. Oyster Creek 125 VDC is diverse based on battery installation and charger design (static chargers and MG Sets). Any marginal improvement is judged to rely primarily on the portable charger included as Item 109.	No (See also SAMA 109)

(_____

Environmental Report Appendix F Severe Accident Mitigation Alternatives

×-

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
72	Dedicated RHR (bunkered) Power Supply	Install new electric distribution subsystem.	PBAPS Application for License Renewal [F-6]	C – There may be some benefit for security or seismic related challenges but the cost of implementation far exceeds the maximum averted cost. A bunkered power supply is judged to require a new building and involve a cost greater than \$5 million.	No (See SAMA 109)
	· ·			While the IC is a decay heat removal system in addition to an inventory control system, it is not an RHR system. The IC can operate independent of all electric support. A portable battery charger would allow operators to utilize the ICs during a long-term loss of all AC electrical subsystems with higher reliability. Therefore, one alternative is judged to reside with the portable charger included as Item 109.	
73	Dedicated DC Power Supply	This SAMA addresses the use of a diverse DC power system such as an additional battery or fuel cell for the purpose of providing motive power to certain components (e.g., RCIC).	PBAPS Application for License Renewal [F-6]	I – See Items 1, 32, 52 for disposition.	No (See SAMAs 1, 32, and 52)
		· · · ·	·	· · ·	

ì

Appendix F

Environmental Report Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
74	DC Cross-ties	This SAMA would improve DC power reliability.	PBAPS Application for License Renewal [F-6]	D – OC currently has cross-ties for Divisions A and B for selected components. Some SSCs are not provided with this cross tie capability.	No (See SAMA 109)
				Cross tie to Division C is judged to introduce unacceptable competing risks. Therefore, this SAMA is not pursued.	
				Adding a portable charger, capable of supporting either division is judged the most cost-beneficial means of improving DC reliability rather than additional cross ties.	
75	Additional training on the loss of component cooling.	This SAMA would potentially improve the success rate of operator actions after a loss of component cooling (to restore RCP seal damage).	Nine Mile Point 1 Application for License Renewal [F-11]	I – See Item 106 for disposition.	No (See SAMA 106)
76	Improved ability to cool the residual heat removal heat exchangers	This SAMA would reduce the probability of a loss of decay heat removal by implementing procedure and hardware modifications to allow manual alignment of the fire protection system or by installing a component cooling water cross-tie.	Nine Mile Point 1 Application for License Renewal [F-11]	I – See Item 18	No (See SAMA 18)
77	Procedures for actions on loss of HVAC.	This SAMA would provide for improved credit to be taken for loss of HVAC sequences (improved affected electrical equipment reliability upon a loss of Control Building HVAC).	Nine Mile Point 1 Application for License Renewal [F-11]	D, F – Oyster Creek has procedures for opening doors and installing portable fans as appropriate. No additional improvements have been identified. ⁽¹⁾	No
78	Modify RWCU for use as a decay heat removal system and proceduralize use.	This SAMA would provide an additional source of decay heat removal.	Nine Mile Point 1 Application for License Renewal [F-11]	I – See Item 62.	No (See SAMA 62)

Page F-130

Environmental Report Appendix F Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
79	Use of CRD for alternate boron injection.	This SAMA provides an additional system to address ATWS with SLC failure or unavailability.	Nine Mile Point 1 Application for License Renewal [F-11]	F – Alternate methods of boron injection already exist for Oyster Creek. Additional alternate systems would not provide a cost-beneficial option.	No
				D – Oyster Creek has a reliable SLC system and the proceduralized capability for two alternate injection pathways.	
	14 M. 			C - The cost of making the available options directly operable from the control room is expected to cost \$4,000,000. This includes making the proceduralized hose connections of the alternate systems hard pipe connections. The benefit is minimal because the RPS is reliable and the existing SLC system provides adequately reliable as a backup.	
80	Improved drywell head bolts	Replace drywell head bolts with stronger material.	Nine Mile Point 1 Application for License Renewal [F-11]	F - The Oyster Creek Drywell Head bolt failure mode is an insignificant contributor to containment failure at low temperatures (200 °F), but its contribution increases and becomes more significant as a function of temperature up to 800 °F. However, other important failure modes such as	No
		4 A A	•	Mark I shell failure, penetrations, hatches, the pedestal, and RPV skirt at these temperatures are also via the	
				failure modes limits the benefit of the improved head bolts such that the benefit is judged to be outweighed by	

.

Oyster Creek Generating Station License Renewal Application Ì

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
81	Improve training on Alternate Instruments	NMP1 alternate instruments in East and West instrument rooms are significant assets in PRA, augmented training for IC operation could be valuable.	Nine Mile Point 1 Application for License Renewal [F-11]	I – Included as SAMA 99.	No (See SAMA 99)
82	Reduce fire risk	Reduction in sources, relatively simple cable re-routing, and/or additional use of thermography could reduce CDF.	Nine Mile Point 1 Application for License Renewal [F-11]	I – See Items 125, 126 for disposition.	No (See SAMAs 125 and 126)
83	Reduce Offsite power recovery dependency on Div 11 DC	Add DC source or justify manual manipulation for offsite AC power recovery	Nine Mile Point 1 Application for License Renewal [F-11]	N/A – Plant specific item for NMP1.	No
84	Manually operate containment vent valves	Provide capability to vent primary containment without support systems with procedure/training	Nine Mile Point 1 Application for License Renewal [F-11]	R – Oyster Creek has dedicated air accumulators for Containment hard pipe vent valves as well as redundant (AC and DC) power supply for the related solenoid valves. While this is a highly reliable configuration which leads to a low risk impact, the use of handwheels could potentially be cost- beneficial and is retained for further analysis.	Yes
85	Provide an alternate DC charger	Portable unit for temp alignment to divisional batteries with procedure/training	Nine Mile Point 1 Application for License Renewal [F-11]	I – See Item 109 for disposition.	No (See SAMA 109)
86	Improve AC power load management	Provide training on potential impact of PB16A &16B crosstie (17A &17B)	Nine Mile Point 1 Application for License Renewal [F-11]	 Plant specific issue for NMP1, transformer loading limitation. Note that an Oyster Creek specific AC cross- tie is included as SAMA 91. 	No (See SAMA 91)
87	Improve procedures/training for loss of air	Improve reliability of operator action to ensure that feedwater is available as RPV makeup source on loss of air	Nine Mile Point 1 Application for License Renewal [F-11]	D – Oyster Creek has a procedure for local manual control of feedwater. The CST to hotwell valves fail open (fail safe for FW operation) given a loss of air. ⁽¹⁾	No

Environmental Report Appendix F Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
		OYSTER CREEK SPECIFIC SAMA	ITEMS IDENTI	FIED VIA PRA, IPE, OR IPEEE	
88	Containment vent	The primary alternative identified is that the vent be opened and closed to control containment pressure approximately 10 psig below EOP Figure J. The vent procedure could be modified to explicitly include this restriction, plus add to the operating crew training cycle specific techniques to be used to maintain a vent control band.	Oyster Creek PRA Review (Section F.5)	R – Improvement for containment vent control is likely to be cost-beneficial.	Yes
		Another alternative is to include mechanical stops on the large vent valves to reduce the flow area from the vent, thus minimizing the discharge of steam flow rate for containment venting.			
89	Improve procedure for aligning SDC with high DW pressure	Perform a Safety Evaluation that allows Operating Procedure 305 to be implemented "as-is" with the elimination of the requirement for operators to invoke 50.54(x).	Oyster Creek PRA Review (Section F.5)	R – Improvement for containment vent control or explicit direction in the SDC AOP may be cost-beneficial. See also Item 110 for disposition.	Yes
90	Not Used			-	
91	Allow 4160 VAC bus IC and ID crosstie	Perform a Safety Evaluation that allows procedure 337 to be modified to allow operators to cross-tie buses 1C and 1D under emergency conditions which require operation of critical equipment.	Oyster Creek PRA Review (Section F.5)	R - Improvement for 4160 VAC cross- tie may be cost-beneficial provided plant modification is not required and there are not appreciable competing risks.	Yes
92	Allow operators to maximize CRD flow	Modify EOP 1, Support Procedure 3 to eliminate the 150 gpm flow limitation and replace with a caution to monitor the system for pump runout when system flow is greater than 150 gpm.	Oyster Creek PRA Review (Section F.5)	R – Potentially cost-beneficial.	Yes

.

-

Environmental Report
Appendix F Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
93	EAL modification	 The prerequisite for a General Emergency action statement could consider the following: Containment pressure approaching PCPL and containment venting will be required. (Declare GE 6 hours before vent action is anticipated.) The main condenser and Containment Spray System systems are unavailable and not recoverable before PCPL will be exceeded. (Declare GE 6 hours before PCPL to be exceeded.) Declare General Emergency when HCTL is exceeded. 	Oyster Creek PRA Review (Section F.5)	D – Already implemented in Oyster Creek EAL.	No
		A combination of the above			
94	Increase success probability for fire protection alignment	Modify EOPs 1a and 1b to provide a cue or note to operators that fire protection system alignment takes longer to establish than other potential sources of RPV injection.	Oyster Creek PRA Review (Section F.5)	R – Potentially cost-beneficial.	Yes
95	Add procedural clarification related to 5 psid CSS alarm	Modify the 5 psid CSS alarm response procedure (B-5-A, B-5-B) and procedure 310 to include a caution that CSS should not be secured if being utilized for accident mitigation.	Oyster Creek PRA Review (Section F.5)	R – Potentially cost-beneficial.	Yes
96	Improve direction for cooldown in LOOP	Revise ABN-36 step 3.1.7 to require a $<10^{\circ}$ F/hr cooldown only when high pressure makeup is not available and decouple the $<10^{\circ}$ F/hr cooldown from IC shell makeup criteria.	Oyster Creek PRA Review (Section F.5)	D – Procedure change completed by Oyster Creek.	No
97	Guideline modification to SAGs for drywell sprays priority	The purpose of this insight is to list drywell spray initiation as among the priority actions that should be taken if allowed by the SAG-2 and other restrictions in Legs 3 and 4 of SAG-1.	Oyster Creek PRA Review (Section F.5)	D – Already implemented by Oyster Creek in SAG-2 in 3 legs based on temperature, pressure, and radiation.	No

Environmental Report Appendix F Severe Accident Mitigation Alternatives $| \sim |$

Page F-134

ľ

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
98	CRD flow enhancement	Ensure sufficient flow to the RPV such that CRD alone is adequate to support RPV injection for all non-LOCA events.	Oyster Creek PRA Review (Section F.5)	I – See Item 92 for disposition.	No (See SAMA 92)
99	Provide an alternate method for IC shell level determination	The IC shells could be modified to include a permanent, passive local shell level indication such as available at Dresden. This, combined with adequate procedures and training, would allow IC operation should AC and DC power be unavailable	Oyster Creek PRA Review (Section F.5)	R – Potentially cost-beneficial	Yes
100	Connect SBO transformer to both AC divisions.	Currently the SBO transformer, which is powered from the combustion turbines, is connected only to the "B" switchgear. Connecting the transformer to the "A" bus will add redundancy.	OC System Manager Review	R ~ Potentially cost-beneficial	Yes
101	Provide a procedure for determining RPV level using fuel zone level indicators A/C with SLC operating	Additional guidance should be evaluated for operators to consider temporarily securing SLC pumps, as necessary, to record RPV level. This approach must balance SLC pump start frequency requirements as well as RPV level trends against the downsides of RPV flooding.	Oyster Creek PRA Review (Section F.5)	R – Applies to very low frequency sequences but may be cost-beneficial.	Yes
102	Revise ATWS EOP to provide RPV level correction based on power	Revise EOP 1b "RPV Control – ATWS" to include an RPV Fuel Zone Level correction factor to account for reactor power level. (See also Item 103)	Oyster Creek PRA Review (Section F.5)	R – Potentially cost-beneficial. This has been implemented at other plants.	Yes
103	Modify fuel zone logic to provide RPV level correction based on	Modify instrumentation to account for reactor power (See also Item 102)	Oyster Creek PRA Review (Section F.5)	F – More costly than Item 102 with similar benefit. See Item 102 for disposition.	No
	power	· · · · · ·		(Note 102 found not to be cost beneficial.)	

-

Environmental Report
Appendix F Severe Accident Mitigation Alternatives
NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
104	Improve loss of circulating water response	Develop a loss of circulating water abnormal operating procedure or revise the loss of condenser vacuum procedure to include guidance to allow condensate and feedwater to be adequately protected by swapping necessary cooling of TBCCW to SW. This includes more rapid swapping to service water.	Oyster Creek PRA Review (Section F.5)	R – Potentially cost-beneficial.	Yes
		(See also Item 105)	•		
105	Improve loss of circulating water response	The plant could be modified to provide an auto-swap from circulating water to service water.	Oyster Creek PRA Review (Section F.5)	F – More costly than Item 104 with similar benefit. See Item 104 for disposition.	No (See SAMA 104)
		(See also Item 104)			
106	Improve direction for cooldown in Loss of RBCCW	Revise ABN-19 to include guidance to implement a $<90^{\circ}$ F/hr cooldown as soon as possible following a loss of RBCCW.	Oyster Creek PRA Review (Section F.5)	R – Potentially cost-beneficial.	Yes
107	Reduce potential for loss of CST following loss of instrument air	Modify the spill valve air supply to be fitted with air accumulators.	Oyster Creek PRA Review (Section F.5)	R – Potentially cost-beneficial	Yes .
108	Reduce fuel zone level instrument error band	Relocate reference leg instrument penetration closer to TAF and recalibrate.	Oyster Creek PRA Review (Section F.5)	R – Unlikely to be cost-beneficial but retained for further analysis.	Yes
109	Portable DC battery charger to preserve IC and EMRV operability along with adequate instrumentation	Provide small, engine-driven battery chargers capable of supplying 125V DC buses	Oyster Creek PRA Review (Section F.5)	R – Potentially cost-beneficial as the system would provide a success path for long term SBOs independent of currently installed AC power.	Yes
110	Delete high drywell pressure signal from SDC isolation	The purpose of this insight is to identify the desirability of removing the SDC interlock on high drywell pressure to increase the flexibility of SDC system use.	Oyster Creek PRA Review (Section F.5)	R – This has been implemented at other plants. See also Item 89.	Yes

Page F-136

Environmental Report Appendix F Severe Accident Mitigation Alternatives

C

.

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
111	Provide alternate drywell spray injection source	 The possible alternatives may include: ESW cross tie SW cross tie Diesel Fire pump cross tie 	Oyster Creek PRA Review (Section F.5)	R – Unlikely to be cost-beneficial but retained for further analysis.	Yes
112	Intake structure	The purpose of this insight is to identify that there are potential safety beneficial effects associated with a pro-active plan to ensure high reliability of the cooling water intake structure and its supply to support raw water systems into the plant.	Oyster Creek PRA Review (Section F.5)	R – Unlikely to be cost-beneficial but retained for further analysis.	Yes
113	Use of drywell sprays in SAMs	The primary alternative is to provide an evaluation that establishes a radiation level that can assure drywell spray initiation prior to RPV breach.	Oyster Creek PRA Review (Section F.5)	D – Already implemented at OC. This direction is already included in the SAMG's. Operators are directed to initiate Drywell Sprays at 20,000 R in containment. This equates to the 20% full damage. Individual fuel pins may be failing, but there is very little of any fuel melt. So this is long before RPV breach.	No
114	CT fan cooler bolts	Ensure all bolts on the Forked River combustion turbine fin-fan coolers are installed and torqued properly.	Oyster Creek IPEEE [F-22]	D – These fans were evaluated and extra bolts have been added. (LAR 88242.20)	No
115	CT Battery Spacers	Consider the addition of battery spacers in the CT battery compartments.	Oyster Creek IPEEE [F-22]	F – CT Battery was reviewed in more detail and additional battery spacers were determined to represent a negligible benefit (RAI-2 7/26/2000) (LAR 88242.20)	No
116	Improve Housekeeping	Review current housekeeping policy/procedures and walk-down plant to review housekeeping and controls for transient combustibles	Oyster Creek IPEEE [F-22]	D – Page 7-1 of IPEEE [F-22] indicates good housekeeping was confirmed.	No
117	CO2 system anchorage	Consider upgrading the high pressure CO2 system in the turbine building. These cylinders could potentially become missiles.	Oyster Creek IPEEE [F-22]	D – Previously re-evaluated by Oyster Creek and determined not necessary (LAR 88242.22)	No

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
118	Turbine generator hydrogen seal oil support	Consider additional support of a small oil filter on the Turbine generator hydrogen seal oil unit. The unit is supported by a vertical stanchion but has no lateral support.	Oyster Creek IPEEE [F-22]	D – Previously re-evaluated by Oyster Creek and determined not necessary (LAR 88242.23)	No
119	Demin trailer anchorage	Review the basis for the Arrowhead demineralizer trailer. During the IPEEE walkdowns, anchorage chain was not attached to the embedded eyehook.	Oyster Creek IPEEE [F-22]	D – Procedure 320, Rev 29, Figure 320-3 provides a checklist for the GSS to verify when the Arrowhead Demin trailers are reinstalled after the trailer anchorage chain has been removed, that the trailer holddown chains are reinstalled, due to IPEEE recommendation to prevent potential missile hazard. (LAR 88242.24)	No
120	High pressure generator purge CO2 rack anchorage	Consider anchoring the high pressure generator purge CO2 rack outside the turbine building. This rack can become a missile.	Oyster Creek IPEEE [F-22]	D – CO2 bottle rack at the south side of the turbine building designed to seismic anti-falldown criteria, installation of anchor bolts and bonding of rackbase to concrete pad performed to minimize seismic risk, as identified in the OC IPEEE recommendations. (LAR 88242.25.)	No
121	Replacement of fire protection drop- weight actuated deluge valves	Consider replacement of fire protection drop-weight actuated deluge valves. Following a seismic event these valves could spuriously actuate and cause flow diversion of fire water and/or spurious spray of critical equipment.	Oyster Creek IPEEE [F-22]	D – Completed per Job Order 502857, LAR 88242.26.	No
122	Fire brigade and operator training	Consider training fire brigade and operators on dominant fire scenarios.	Oyster Creek IPEEE [F-22]	D – Completed by assignment of ETTS 34893 (LAR 88242.27).	No

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
123	Replace CS and CSS relays	The following relays had chatter HCLPF <0.3 g and should be considered for replacement: PNL-ER18A-2HFA51A, PNL-ER8A- 2HFA51A, PNL-ER8B-2HFA51A.	Oyster Creek IPEEE [F-22]	D - Already addressed. All Core Spray GE HFA relays are 12HFA151A and Seismic Qualification of GE 12HFA121A relay exceeds the requirement of IPEEE. These are qualified to 1.27g. As such, OC does not require any replacement of GE HFA relays in Core Spray System. Containment spray is no longer an automatic system. It will be manually started at some point into the event (10 min. or so). Therefore, it only has to be operable "after" the event and relay chatter is not a concern after an event.	No
124	Block wall 53 Reinforcement	Block wall 53 has a HCLPF of 0.27g and should be considered for reinforcement. This block wall can impact 125 VDC.	Oyster Creek IPEEE [F-22]	R – Potentially cost-beneficial.	Yes
125	Reduce fire impact in dominant fire areas	A fire in the cable spreading room and 480 VAC "A" Switchgear room may have a number of adverse impacts. Modifying circuits or installing fire barriers can reduce the impacts of postulated fires.	Oyster Creek IPEEE [F-22]	R –Potentially cost-beneficial.	Yes
126	Not Used				
127	Operator training	Increased training on the systems and operator actions assessed as important in the PRA.	Oyster Creek IPE [F-15]	R – Potentially cost-beneficial.	Yes
128	IC Fouling	Programs instituted to reduce blockage and fouling of the isolation condensers	Oyster Creek IPE [F-15]	R – Potentially cost-beneficial.	Yes
129	Internal Flooding Procedure Enhancements	Improve procedures for responding to internal flooding events	Oyster Creek IPE [F-15]	R – Potentially cost-beneficial.	Yes

Oyster Creek Generating Station License Renewal Application

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
130	Protect Combustion Turbines	Increase CT building integrity to withstand high winds. Consider specifications similar to safety related requirements.	PRA Model Importance Review (Section F.5.1)	R – Potentially cost-beneficial.	Yes
131	Decrease Grid Impact	Perform periodic evaluations of grid stability assuming a spurious OC trip. Intent is to minimize a loss of offsite power event following a spurious OC trip. This requires coordination with grid managers.	PRA Model Importance Review (Section F.5.1)	D – Per PJM Nuclear Communications Protocol ⁽²⁾ , First Contingency analysis is performed automatically approximately once per minute. Cases where operating security limits are exceeded are corrected within 30 minutes.	No
132	Reduce probability of Multi-CT Operation	When both CTs are in operation, alignment for Oyster Creek LOOP response takes additional time due to need for CTs to coast down prior to switching. This SAMA would eliminate procedural guidance to shutdown CTs, if initially running,	PRA Model Importance Review (Section F.5.1)	R – Potentially cost-beneficial.	Yes
133	Enhance Hotwell makeup	Enhance hotwell makeup from CST to match CST makeup from fire water.	OC System Manager Review	R – Potentially cost-beneficial.	Yes
134	Upgrade Fire Pump House structural integrity	Upgrade fire pump house building integrity so that fire system would be capable of withstanding a severe weather event.	OC System Manager Review	R – Potentially cost-beneficial.	Yes
135	Increase structural integrity of IC makeup piping	The water supply to makeup to the Iso Condensers is neither safety related nor seismic. Upgrade of the Condensate Transfer System supply to the ICs would possibly increase their long term availability.	OC System Manager Review	C – The Oyster Creek IPEEE analysis included IC performance during seismic events. Using the EPRI hazard curves, the IC contributed 4.97% to the overall CDF of 3.6E-6/yr. If the IC could be made perfect, it would reduce contribution by a value of 1.79E-7/yr (3.6E-6*4.87%). Considering such a modification is expected to cost at least \$5,000,000, this option is considered not cost- beneficial.	No

Environmental Report Appendix F Severe Accident Mitigation Alternatives

NO.	SAMA TITLE	SAMA DESCRIPTION	SOURCE	PHASE I DISPOSITION	RETAINED FOR PHASE II ANALYSIS?
136	Provide alternate power to condensate transfer pumps	Presently, both Condensate Transfer Pumps are powered from USS 1B2 via MCC 1B32. Also both are tripped and not loaded onto the EDG on LOOP. Operator must go to intake to reset UV device to allow use of pumps. Redundant power to the pumps would increase the availability of the system, and auto load onto the EDGs would make them available quickly and with no operator action during LOOP.	OC System Manager Review	R – Potentially cost-beneficial.	Yes
137	Create a crib house	Currently, some equipment related to the intake structure is exposed to the elements. Creating an expanded crib house may improve equipment reliability.	OC System Manager Review	F – No specific reliability problems associated with environmental exposure of OC equipment have been identified. Such a structure is expected to cost \$500,000. Since no quantifiable benefit exists, this item is not considered cost-beneficial.	No
138	Protect transformers	The main and startup transformers are located approximately 15' apart. There is a concern that a failure of one could impact the other.	OC System Manager Review	R – Potentially cost-beneficial.	Yes

.

Oyster Creek Generating Station License Renewal Application ï

Notes to Table F-15:

Legend

- Applicability to the Plant (N/A): If a proposed SAMA does not apply to the Oyster Creek design, it is
 not retained. For example, inclusion of an automatic alternate refill system for an Isolation Condenser
 System would not require further analysis for a plant that does not have an Isolation Condenser
 System.
- Cost (C): If a SAMA requires extensive changes that are known to exceed any possible benefit, they
 are screened without developing an estimated cost of implementation. For example, the cost of
 installing an additional, buried offsite power source over a path of fifty miles is known to exceed any
 potential benefit and would be immediately disqualified. A screening value of \$4,462,000 is used
 when compared to a judged improvement cost (See section F.4).
- Already Implemented at Oyster Creek (D): If an improvement has already been implemented at Oyster Creek, it is screened from further consideration.
- Cost Exceed Benefit (F): If the cost obviously exceeds the benefit or if the benefit is negligible, the SAMA is screened from further consideration.
- Addressed by a Similar Item (I): If a SAMA is included within another SAMA, it is screened if the other item completely subsumes it.

Those retained (R) for further evaluation, are identified with a "Yes" in the last column.

Notes:

- ⁽¹⁾ The Oyster Creek procedures were evaluated as part of the HRA and the crew interviews. During this process it was concluded that the procedures and training were consistent with requirements and goals established by INPO. No significant general discrepancies or issues were identified related to the procedures. If specific issues or discrepancies with a specific procedure was identified, then it is discussed along with the appropriate SAMA. Otherwise, general procedure review and enhancement is not considered necessary.
- ⁽²⁾ "PJM Control Center Requirements, Attachment B, Nuclear Plant Communications Protocol," Revision 08, 1/1/2005.

F.6 Phase II SAMA Analysis

The Phase I SAMA screening process of 136⁽¹⁾ candidate plant changes, modifications, or procedure/training changes in Table F-15 has resulted in a reduced list of 37 SAMA candidates. This reduced SAMA list is provided in the Phase II summary disposition table, Table F-16. Table F-16 includes the basis for the dispositioning of each of the 37 SAMA candidates in Phase II using a more detailed analysis that is documented in the subsections of F.6. Seven SAMAs result in a positive net value based on detailed, realistic cost benefit analysis.

Some SAMA candidates are determined to have a negligible impact on the CDF (i.e., <1E-9/yr, which represents approximately 0.01% of the baseline CDF). The averted cost risk associated with such small CDF changes is less than \$1,000. For such candidates, detailed implemented cost estimates are not judged warranted.

For each of the remaining SAMA candidates that survived from Phase I that could not be eliminated based on screening cost, PRA/application insights, or negligible PRA impacts, a more detailed conceptual design is prepared along with a more detailed estimated cost. This information is then used to evaluate the effect of the candidates' changes upon the plant safety model.

The risks associated with the continued operation of the Oyster Creek plant are calculated and then converted into a present value dollar (\$) cost. This is referred to in the analysis as a cost-risk.

These cost-risks are then compared with the cost of implementing a plant modification, procedure change, or training related change. The estimated cost of every Phase II SAMA was not obtained from plant staff so the PRA staff has estimated the approximate cost in these cases. These estimates where noted are considered a "best-estimate" and are considered to be an "order-of-magnitude" estimate only. Comparison of costs from other available SAMA analyses is made as available.

The cost-risk based evaluation method used to determine the desirability of implementing the SAMA is defined by the following equation:

Net Value = (baseline cost-risk of site operation (MMACR) – cost-risk of site operation with SAMA implemented) – cost of implementation

If the net value of the SAMA is negative, the cost of implementation is larger than the benefit associated with the SAMA and the SAMA is not considered beneficial. The baseline cost-risk of plant operation is derived using the methodology presented in Section F.4. The cost-risk of plant operation with the SAMA implemented is determined in the same manner with the exception that the PRA results reflect the application of the SAMA to the plant (the baseline input is replaced by the results of a PRA sensitivity with the SAMA change in effect).

Table F-16 and subsections of F.6 below describe the analysis that is used to determine how the unscreened SAMA candidates in Table F-15 are assessed.

Each of the subsections of F.6 provide the following information:

⁽¹⁾ There is no SAMA 90 or 126.

- A description of the proposed SAMA
- The method for modeling the SAMA in the PRA
- Two tables summarizing the results
 - The first table in each subsection of F.6 (see blank table below) summarizes the results for the PRA baseline and the PRA case with the individual SAMA implemented. The calculational results shown in the table are as follows:
 - (1) The PRA frequencies of each radionuclide release category plus the "total" release frequency (which is also equal to the CDF). (Rows 1 and 2)
 - (2) The MACCS2 results for these radionuclide release frequencies for the plant configuration with the SAMA implemented. These results are provided in terms of Dose Risk (Person Rem per year) in Row 3 and the Offsite Economic Cost Risk (OECR) (\$ per year) in Row 4.

						1	Release	e Catego	iry			
Row	Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
1	Baseline Freq. (per yr.)	-										
2	SAMA Freq. (per yr.)											
3	SAMA Dose-Risk (Person Rem/yr.)											
4	SAMA OECR (\$/yr.)											

Example Blank Table

SAMA XX PRA and MACCS Results By Release Category

The second table (see blank table below) uses the present value total base cost-risk⁽¹⁾ (Column 1) and the calculated total present value cost-risk⁽¹⁾ associated with the plant if the SAMA is implemented (Column 2). The difference of these two values is the "Averted Cost-Risk". Using this "Averted Cost-Risk" (Column 3) minus the "Cost of Implementation" (Column 4) yields the "Net Value" (Column 5) which reflects whether the SAMA is cost beneficial, i.e., if the dollar value is positive.

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

SAMA Number XX Net Value							
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk ⁽¹⁾ for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value			

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

• 1.

SAMA ID NUMBER	SAMA TITLE	SAMA DESCRIPTION	SOURCE	ESTIMATED COST & AVERTED COST-RISK	COMMENT	PHASE II DISPOSITION ⁽⁵⁾
7	Enhance Alternate Injection Reliability	The capability exists at some BWRs to provide flow from the RHRSW and Fire Protection systems to the RHR system; however, the reliability of the cross-tie could potentially be improved by including the cross-tie valves in the maintenance program so that the operability of the valves is monitored and tested.	Monticello Application for License Renewal [F-13]	Modification: \$500,000 estimated by System Manager. This estimate is used for Oyster Creek. Averted cost-risk: \$174,000	For Oyster Creek, this represents a potential modification to enable alignment of service water or ESW to Core Spray or Feedwater. The competing risk is that the raw water could clog the FW or CS spargers or the associated valves.	Determined to be not cost beneficial
10	Passive Overpressure Relief	This SAMA would reduce the risk of catastrophic failure of the containment. The current Torus Hard Pipe Vent includes a rupture disk beyond an isolation valve; however, an alternate path to the Torus Hard Pipe Vent could be made in the wetwell using a rupture disk that would fail at about 60 psid. Alternatively, the containment vent valves could be changed so that they "fail open" on loss of support. Given this change, the vent path would be open on loss of support with the exception of the rupture disk. To prevent premature opening of the vent path during scenarios with loss of vent valve support, the strength of the rupture disk could be increased so that it is closer to the EOP vent pressure.	Monticello Application for License Renewal [F-13]	Modification: \$1,000,000 estimated for Oyster Creek. ⁽³⁾ Averted cost-risk: \$788,000	For Oyster Creek, this represents a potential modification to install a passive containment vent arrangement in the existing hard pipe vent. Competing risks exist for containment isolation failure and loss of ECCS torus suction.	Determined to be not cost beneficial

Page F-146

SAMA ID NUMBER	SAMA TITLE	SAMA DESCRIPTION	SOURCE	ESTIMATED COST & AVERTED COST-RISK	COMMENT	PHASE II DISPOSITION ⁽⁵⁾
18	Improved Ability To Cool The Residual Heat Removal Heat Exchangers.	This SAMA would reduce the probability of a loss of decay heat removal by implementing procedure and hardware modifications to allow manual alignment of the fire protection system or by installing a component cooling water cross-tie. A portable diesel-driven pump is under consideration to provide cooling water to a LPCI heat exchanger. This was discussed in the EPU correspondence as the tentative plan for dealing with the seismic outlier of Dresden Island Lock & Dam, i.e., loss of UHS, by Fall 2003.	Dresden Application for License Renewal [F-7]	Modification: \$265,000 estimated for Dresden. This estimate is used for Oyster Creek. Averted cost-risk: \$8,000	For Oyster Creek, this represents a potential modification to enable alignment of service water or fire protection to containment spray heat exchanger shells.	Determined to be not cost beneficial
						•.

			0001-1001	COMMENT	DISPOSITION
Re-open MSIVs	SAMA would allow regaining the main condenser as a heat sink by re- opening the MSIVs. There are two important aspects of the MSIV closure response: For non-ATWS conditions, the ability to rapidly respond to MSIV closure and restore the main condenser as a heat sink is not explicitly directed. For ATWS conditions, Dresden EOPs direct MSIV low level closure bypass in order to retain the main condenser as a heat sink; however, this assumes the MSIVs have not yet closed.	Dresden Application for License Renewal (F-7)	Modification: \$400,000 estimated by System manager Averted cost-risk: \$4,000	For Oyster Creek, this represents modification of the steam lines drains to allow improved MSIV operation.	Determined to be not cost beneficial
	For both cases, explicit procedural direction to re-open the MSIVs could be included.				
Diversify The Explosive Valve Operation	An alternate means of opening a pathway to the RPV for SBLC injection would improve the success probability for reactor shutdown.	Dresden Application for License Renewal [F-7]	Modification: Not estimated for Dresden. \$150,000 estimated for Oyster Creek. ⁽³⁾ Averted cost-risk: \$42,000	For Oyster Creek, this represents a potential modification to enable manual bypass of explosive valves (explosive valve in a bypass line).	Determined to be not cost beneficial
	Diversify The Explosive Valve Operation	 main condenser as a heat sink by reopening the MSIVs. There are two important aspects of the MSIV closure response: For non-ATWS conditions, the ability to rapidly respond to MSIV closure and restore the main condenser as a heat sink is not explicitly directed. For ATWS conditions, Dresden EOPs direct MSIV low level closure bypass in order to retain the main condenser as a heat sink; however, this assumes the MSIVs have not yet closed. For both cases, explicit procedural direction to re-open the MSIVs could be included. Diversify The Explosive Valve Operation 	 main condenser as a heat sink by reopening the MSIVs. There are two important aspects of the MSIV closure response: For non-ATWS conditions, the ability to rapidly respond to MSIV closure and restore the main condenser as a heat sink is not explicitly directed. For ATWS conditions, Dresden EOPs direct MSIV low level closure bypass in order to retain the main condenser as a heat sink; however, this assumes the MSIVs have not yet closed. For both cases, explicit procedural direction to re-open the MSIVs could be included. Diversify The Explosive Valve Operation An alternate means of opening a pathway to the RPV for SBLC license probability for reactor shutdown. 	 main condenser as a heat sink by reopening the MSIVs. There are two important aspects of the MSIV closure response: For non-ATWS conditions, the ability to rapidly respond to MSIV closure and restore the main condenser as a heat sink is not explicitly directed. For ATWS conditions, Dresden EOPs direct MSIV low level closure bypass in order to retain the main condenser as a heat sink; however, this assumes the MSIVs have not yet closed. Diversify The Explosive Valve Operation Diversify The Conduction of the RPV for SBLC injection would improve the success probability for reactor shutdown. 	 main condenser as a heat sink by re- opening the MSIVs. There are two important aspects of the MSIV Closure response: For non-ATWS conditions, the ability to rapidly respond to MSIV closure and restore the main condenser as a heat sink is not explicitly directed. For ATWS conditions, Dresden EOPs direct MSIV low level closure bypass in order to retain the main condenser as a heat sink; however, this assumes the MSIVs have not yet closed. Diversify The Explosive Valve Operation Diversify The Explosive Valve Operation Diversify The Explosive Valve Diversify The Explosite Valve Diversify The

Page F-148

Oyster Creek Generating Station License Renewal Application

SAMA ID NUMBER	SAMA TITLE	SAMA DESCRIPTION	SOURCE	ESTIMATED COST & AVERTED COST-RISK	COMMENT	PHASE II DISPOSITION ⁽⁵⁾
25	Bypass Low Pressure Permissive	LPCI and CS injection valves require a permissive signal from the same 2 pressure sensors in order to open. The instruments are currently specified as diverse. However, because this is a "pinch point" for all CS and LPCI injection, it is judged prudent to consider a plant modification to allow a bypass switch (1/division) to insert the permissive if the sensors fail to perform their function. A few other BWRs currently have this capability (e.g., Perry).	Dresden Application for License Renewal [F-7]	Modification: Not estimated for Dresden. \$50,000 estimated for Oyster Creek. ⁽³⁾ Averted cost-risk: \$4,000	For Oyster Creek, this represents a potential modification or procedure to enable quick bypassing of low pressure permissive for core spray.	Determined to be not cost beneficial
67	Safety Related Condensate Storage Tank	This SAMA will improve availability of CST following a Seismic event.	PBAPS Application for License Renewal [F-6]	Modification: \$1,000,000 per CST for Peach Bottom. This estimate is used for the one Oyster Creek CST tank. Averted cost-risk: \$65,000	For Oyster Creek, this represents a potential modification to enable CST to survive a greater spectrum of earthquake challenges.	Determined to be not cost beneficial
84	Manually Operate Containment Vent Valves	Provide capability to vent primary containment without support systems with procedure/training	Nine Mile Point 1 Application for License Renewal [F-11]	Modification: Not estimated for Nine Mile 1. \$150,000 estimated for Oyster Creek. ⁽³⁾ Averted cost-risk: \$80,000	For Oyster Creek, this represents a potential modification to enable manual operation of all containment vent valves. This would require local controls for the AOV vent valves.	Determined to be not cost beneficial

Oyster Creek Generating Station License Renewal Application

SAMA ID NUMBER	SAMA TITLE	SAMA DESCRIPTION	SOURCE	ESTIMATED COST & AVERTED COST-RISK	COMMENT	PHASE II DISPOSITION ⁽⁵⁾
88	Containment Vent	 The primary alternative identified is that the vent be opened and closed to control containment pressure approximately 10 psig below EOP Figure J. The vent procedure could be modified to explicitly include this restriction, plus add to the operating crew training cycle specific techniques to be used to maintain a vent control band. Another alternative is to include mechanical stops on the large vent valves to reduce the flow area from the vent, thus minimizing the discharge of steam flow rate for containment venting. 	Oyster Creek PRA Review (Section F.5)	Procedure: \$50,000‡ Averted cost-risk: \$0	This represents a potential procedure change to specify a control band for containment venting. Alternately, containment vent valves could be modified. Vent valves are already restricted in movement to 30 ⁰ maximum opening.	Determined to be not cost beneficial
89	Improve Procedure For Aligning SDC With High DW Pressure	Perform a Safety Evaluation that allows Operating Procedure 305 to be implemented "as-is" with the elimination of the requirement for operators to invoke 50.54(x).	Oyster Creek PRA Review (Section F.5)	Procedure: \$50,000‡ Averted cost-risk: Negligible (not calculated)	For Oyster Creek, this represents a procedure change to allow operators to bypass the SDC isolational signal and provide additional time to align SDC (i.e., improves crew response and is reflected in the PRA by a reduced Human Error Probability (HEP).	Determined to be not cost beneficial
91	Allow 4160 VAC Bus IC And ID Crosstie	Perform a Safety Evaluation that allows procedure 337 to be modified to allow operators to cross-tie buses 1C and 1D under emergency conditions which require operation of critical equipment.	Oyster Creek PRA Review (Section F.5)	Procedure and Hardware: \$90,000 Averted cost-risk: \$118,000	Competing risks such as human errors associated with the new cross-tie were not included.	Candidate for implementation based on assessment as cost beneficial

Environmental Report Appendix F Severe Accident Mitigation Alternatives

Page F-150

SAMA ID NUMBER	SAMA TITLE	SAMA DESCRIPTION	SOURCE	ESTIMATED COST & AVERTED COST-RISK	COMMENT	PHASE II DISPOSITION ⁽⁵⁾
92	Allow Operators To Maximize CRD Flow	Modify EOP 1, Support Procedure 3 to eliminate the 150 gpm flow limitation and replace with a caution to monitor the system for pump runout when system flow is greater than 150 gpm.	Oyster Creek PRA Review (Section F.5)	Procedure, Test, Analysis: \$100,000‡ Averted cost-risk: \$36,000	For Oyster Creek, this represents the potential for CRD flow to mitigate transients and a larger spectrum of LOCA sizes.	Determined to be not cost beneficial
94	Increase Success Probability For Fire Protection Alignment	Modify EOPs 1a and 1b to provide a cue or note to operators that fire protection system alignment takes longer to establish than other potential sources of RPV injection.	Oyster Creek PRA Review (Section F.5)	Procedure: \$50,000‡ Averted cost-risk: \$0	For Oyster Creek, this represents an earlier to cue to operators to align fire protection such that the HEP is decreased.	Determined to be not cost beneficial
95	Add Procedural Clarification Related To 5 Psid CSS Alarm	Modify the 5 psid CSS alarm response procedure (B-5-A, B-5-B) and procedure 310 to include a caution that CSS should not be secured if being utilized for accident mitigation.	Oyster Creek System Manager Review	Procedure: \$50,000‡ Averted cost-risk: Negligible (not calculated)	Operators indicated they would not secure a containment spray train based solely on the differential pressure alarm, and therefore, no penalty can be realistically assigned. Therefore no penalty is currently applied in the PRA.	Determined to be not cost beneficial
99	Provide an alternate method for IC shell level determination	The IC shells could be modified to include a permanent, passive local shell level indication such as available at Dresden. This, combined with adequate procedures and training, would allow IC operation should AC and DC power be unavailable	Oyster Creek PRA Review (Section F.5)	Procedure and Hardware: \$150,000 Averted cost-risk: \$674,000	This involves development of a means for local indication of IC level as well as training on control of IC with no AC or DC power available.	Candidate for implementation based on assessment as cost beneficial
100	Connect SBO transformer to both AC divisions.	Currently the SBO transformer, which is powered from the combustion turbines, is connected only to the "B" switchgear. Connecting the transformer to the "A" bus will add redundancy.	Oyster Creek System Manager Review	Procedure and Hardware: \$500,000 Averted cost-risk: \$146,000	Modification of the circuit to allow the combustion turbines to also supply the "A" bus directly would be beneficial. This would provide a benefit similar to SAMA 91 except that equipment such as feedwater pumps that are power from Bus A would also be potentially available.	Determined to be not cost beneficial

Oyster Creek Generating Station License Renewal Application

Page F-151

SAMA ID NUMBER	SAMA TITLE	SAMA DESCRIPTION	SOURCE	ESTIMATED COST & AVERTED COST-RISK	COMMENT	PHASE II DISPOSITION ⁽⁵⁾
101	Provide A Procedure For Determining RPV Level Using Fuel Zone Level Indicators A/C With SLC Operating	Additional guidance should be evaluated for operators to consider temporarily securing SLC pumps, as necessary, to record RPV level. This approach must balance SLC pump start frequency requirements as well as RPV level trends against the downsides of RPV flooding.	Oyster Creek System Manager Review	Procedure: \$50,000‡ Averted cost-risk: \$0	No significant benefit calculated with the PRA model.	Determined to be not cost beneficial
102	Revise ATWS EOP To Provide RPV Level Correction Based On Power	Revise EOP 1b "RPV Control – ATWS" to include an RPV Fuel Zone Level correction factor to account for reactor power level.	Oyster Creek System Manager Review	Procedure: \$50,000‡ Averted cost-risk: \$0	No significant benefit calculated with the PRA model.	Determined to be not cost beneficial
104	Improve Loss Of Circulating Water Response	Develop a loss of circulating water abnormal operating procedure or revise the loss of condenser vacuum procedure to include guidance to allow condensate and feedwater to be adequately protected by swapping necessary cooling of TBCCW to SW. This includes more rapid swapping to service water.	Oyster Creek PRA Review (Section F.5)	Modification: \$250,000 includes both procedural changes and hardware modifications to allow the timely transition to SW. Averted cost-risk: \$44,000	None.	Determined to be not cost beneficial
106	Improve Direction For Cooldown In Loss Of RBCCW	Revise ABN-19 to include guidance to implement a <90°F/hr cooldown as soon as possible following a loss of RBCCW to supplement protection of recirc seals by reducing RPV pressure.	Oyster Creek System Manager Review	Procedure: \$50,000‡ Averted cost-risk: \$34,000	Vendor test data was reviewed to assess the probability that recirculation pump seals may leak.	Determined to be not cost beneficial
107	Reduce potential for loss of CST inventory following loss of instrument air	Modify the spill valves so that they fail close on loss of instrument air. Modify the spill valve air supply to be fitted with air accumulators.	Oyster Creek PRA Review (Section F.5)	Modification: \$150,000 ⁽³⁾ Averted cost-risk: \$0	Negligible CDF benefit calculated.	Determined to be not cost beneficial

Page F-152

SAMA ID NUMBER	SAMA TITLE	SAMA DESCRIPTION	SOURCE	ESTIMATED COST & AVERTED COST-RISK	COMMENT	PHASE II DISPOSITION ⁽⁵⁾
108	Reduce Fuel Zone Level Instrument Error	Relocate reference leg instrument penetration closer to TAF and recalibrate.	Oyster Creek System Manager	Modification: \$500,000 ⁽³⁾	Negligible CDF benefit calculated.	Determined to be not cost beneficial
	Band		Review	Averted cost-risk: Not calculated		
109	Portable DC Battery Charger To Preserve IC And EMRV Operability Along With Adequate Instrumentation	Provide portable battery chargers capable of supplying 125V DC buses	Oyster Creek PRA Review (Section F.5)	Modification: \$75,000 estimated in Monticello SAMA evaluation. Averted cost-risk: \$674,000	For Oyster Creek, DC power is critical to the operation of the isolation condenser and other mitigation systems. It therefore represents a benefit in station blackout related sequences and other similar sequences.	Candidate for implementation based on assessment as cost beneficial
110	Delete High Drywell Pressure Signal From SDC Isolation	The purpose of this insight is to identify the desirability of removing the SDC interlock on high drywell pressure to increase the flexibility of SDC system use.	Oyster Creek System Manager Review	Modification: \$75,000 ⁽³⁾ Averted cost-risk: Negligible	See item 89, similar benefit as a proposed procedural change.	Determined to be not cost beneficial
111	Provide Alternate Drywell Spray Injection Source	The possible alternatives may include: • ESW cross tie • SW cross tie	Oyster Creek PRA Review (Section F.5)	Modification: \$500,000 Averted cost-risk:	A potential competing risk is that the raw water might clog the containment spray nozzles.	Determined to be not cost beneficial
		 Diesel Fire pump cross tie 		Negligible		
112	Intake Structure	The purpose of this insight is to identify that there are potential safety beneficial effects associated with a	Oyster Creek PRA Review (Section F.5)	Modification: \$1,000,000 ⁽²⁾	Minimal benefit.	Determined to be not cost beneficial
		pro-active plan to ensure high reliability of the cooling water intake structure and its supply to support raw water systems into the plant.	(1.1.1.1.)	Averted cost-risk: \$8,000		
124	Block Wall 53 Reinforcement	Block wall 53 has a HCLPF of 0.27g and should be considered for reinforcement. This block wall can	Oyster Creek IPEEE [F-22]	Modification: \$150,000 ⁽³⁾	Mentioned in IPEEE submittal to NRC.	Determined to be not cost beneficial
		impact 125 VDC.		Averted cost-risk: \$84,000		

SAMA ID NUMBER	SAMA TITLE	SAMA DESCRIPTION	SOURCE	ESTIMATED COST & AVERTED COST-RISK	COMMENT	PHASE II DISPOSITION ⁽⁵⁾
125	Reduce fire impact in dominant fire areas	A fire in the cable spreading room and 480 VAC "A" Switchgear room may have a number of adverse impacts. Modifying circuits or installing fire barriers may reduce the impacts of postulated fires.	Oyster Creek IPEEE [F-22]	Modification: \$100,000 ⁽³⁾ Averted cost-risk: \$333,000	Mentioned in IPEEE submittal to NRC. Mentioned as a significant contributor on page 1–6 of IPEEE submittal to NRC.	Candidate for implementation based on assessment as cost beneficial
127	Operator Training	Increased training on the PRA systems and operator actions determined as important in the PRA.	Oyster Creek IPE [F-15]	Training: \$50,000‡ Averted cost-risk: Not calculated	Mentioned by NRC in IPE SER.	Candidate for implementation based on assessment as cost beneficial
128	IC Fouling	Programs instituted to reduce blockage and fouling of the isolation condensers.	Oyster Creek IPE [F-15]	Program: \$200,000 ⁽³⁾ Averted cost-risk: Negligible	Mentioned by NRC in IPEEE SER.	Determined to be not cost beneficial
129	Internal Flooding Procedure Enhancements	Improve procedures for responding to internal flooding events.	Oyster Creek IPE [F-15]	Procedure: \$100,000 ⁽⁴⁾ Averted cost-risk: \$56,000	Mentioned by NRC in IPE SER.	Determined to be not cost beneficial
130	Protect Combustion Turbines	Increase CT building integrity to withstand high winds. Consider specifications similar to safety related requirements.	PRA Model Importance Review (Section F.5.1)	Modification: \$600,000 ⁽³⁾ Averted cost-risk: \$747,000	For Oyster Creek, this represents expanding the severe weather design requirements for the Combustion Turbines (CTs) and the SBO transformers to accommodate higher wind levels. This change allows the CTs to be available as an AC power source for a larger spectrum of events.	Candidate for implementation based on assessment as cost beneficial

Page F-154

SAMA ID NUMBER	SAMA TITLE	SAMA DESCRIPTION	SOURCE	ESTIMATED COST & AVERTED COST-RISK	COMMENT	PHASE II DISPOSITION ⁽⁵⁾
132	Reduce Probability of Multi-CT Operation	When both CTs are in operation, alignment for Oyster Creek LOOP response takes additional time due to need for CTs to coast down prior to switching. This SAMA would eliminate procedural guidance to shutdown CTs, if initially running,	PRA Model Importance Review (Section F.5.1)	Procedure: \$50,000‡ Averted cost-risk: \$46,000	An alternative SAMA to provide this capability by obtaining First Energy (operator of the CTs) agreement to always maintain one CT in standby status is considered cost prohibitive and is considered adequately represented by the procedure change.	Determined to be not cost beneficial
133	Increase Hotwell Makeup Capability	Increase hotwell makeup flowrate to allow condensate/feedwater to be beneficial over a wide spectrum of LOCA conditions	System Manager Comment	Modification: \$250,000 Averted cost-risk: \$72,000		Determined to be not cost beneficial
134	Upgrade Fire Pump House structural integrity	Upgrade fire pump house building integrity so that fire system would be capable of withstanding a severe weather event.	OC System Manager Review	Modification: \$150,000 Averted cost-risk: \$438,000		Candidate for implementation based on assessment as cost beneficial
136	Provide alternate power to condensate transfer pumps	Presently, both Condensate Transfer Pumps are powered from USS 1B2 via MCC 1B32. Also both are tripped and not loaded onto the EDG on LOOP. Operator must go to intake to reset UV device to allow use of pumps. Redundant power to the pumps would increase the availability of the system, and auto load onto the EDGs would make them available quickly and with no operator action during LOOP.	OC System Manager Review	Modification: \$100,000 Averted cost-risk: \$0		Determined to be not cost beneficial
138	Protect transformers	The main and startup transformers are located approximately 15' apart. There is a concern that a failure of one could impact the other.	OC System Manager Review	Modification: \$780,000 Averted cost-risk: \$446,000		Determined to be not cost beneficial

Oyster Creek Generating Station License Renewal Application

Page F-155

Notes to Table F-16:

‡ Cost of procedure change is estimated to be \$50,000 and includes:

- Procedure Change
- Training
- Verification
- Roll-Out
- Minor Calculations, If Needed
- ⁽¹⁾ Assumes all fire risk could be eliminated by this SAMA.
- ⁽²⁾ Based on continuing more aggressive program over 20 years for treatment to prevent intake structure problems of:
 - Clogging by floating vegetation
 - Mussels and Asiatic clams
 - Silting
- ⁽³⁾ Engineering judgment by the PRA team.
- ⁽⁴⁾ Internal flood improvements in procedure, training, and possible control room indication hardware is anticipated to cost in excess of \$100,000.
- ⁽⁵⁾ The Phase II determination of cost benefit is documented in the subsections of F.6.

F.6.1 SAMA 7: ENHANCE ALTERNATE INJECTION RELIABILITY

Currently, Oyster Creek has only one alternate source of RPV injection credited in the PRA model, Fire Protection Injection via core spray. Implementation of another alternate supply would provide a benefit in terms of additional redundancy for RPV water level control. Some other plants have the ability to align service water or emergency service water to the RPV for injection. At Oyster Creek, both service water and emergency service water piping currently exist in the reactor building. Providing a hard-piped cross-connection between emergency service water and core spray would provide a second alternate low pressure injection source⁽¹⁾.

In order to determine the potential benefit of such a plant modification, the PRA model was modified assuming a cross-tie between ESW and core spray was available. A failure probability of 1E-2 was assumed to represent operator action and additional equipment operation that could prevent the modification from functioning.

The OC-LEV2.caf fault tree model was saved as OC-SAMA7.caf and edited. The CS (Core Spray) node was modified by placing ESW gate logic under gates CS1FP and CS2FP. This allows the core spray function to be operable if core spray, fire water, or ESW is available, provided the core spray injection pathway operates. The ESW gates (CCG01MDD, CCG02MED) were "ORed" with a new basic event (1E-2) to represent the failure probability of the equipment and operator action associated with the new modification. In order to reduce the suction strainer failures that impact core spray, the ESW logic was "ANDed" into the suction strainer failure of the core spray injection function. The same process was not used for internal floods that impact core spray because it was assumed that the internal floods would fail the ESW alignment equipment and/or operator action.

The baseline CDF is 1.05E-5 per year and the model re-quantified with the proposed modification is 1.02E-5 per year. This is a reduction of 3.1E-7 per year. This is judged to be a conservative estimate of the improvement because both SW and ESW are "dirty" water systems from a salt water source. There are potential significant clogging issues associated with the Core Spray spargers that could compromise the benefit to be achieved from such cross ties. Development of cross-tie to SW or ESW may be feasible.

The results from this case indicate a 2.9 percent reduction in CDF (CDF_{new} =1.02E-5 per year). A further breakdown of this information is provided below according to release category.

⁽¹⁾ Likewise, some other plants have the ability to align service water directly to the condenser hotwell. This has the potential to eliminate the impact of the limited CST inventory in LOCA scenarios. However, this modification would be completely reliant on the present condensate and feedwater system for RPV injection which in turn is completely reliant on the offsite AC power. In addition, the potential for clogging of the FW injection path due to the debris from the ESW and SW may compromise this pathway. Therefore, this additional option was not pursued.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

	S	AMA 7	PRA and	I MACC	S Resul	ts By R	elease	Catego	У			
			Release Category									
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC	
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	. 1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08	
SAMA Freq. (per yr.)	1.02E-05	2.63E-06	3.34E-06	1.95E-07	9.55E-07	1.65E-06	1.39E-09	5.03E-07	7.30E-07	1.75E-07	3.14E-08	
SAMA Dose-Risk (Person Rem/yr.)	3.47E+01	6.56E-02	1.34E+01	2.89E-02	5.53E+00	6.92E+00	4.90E-03	3.99E+00	3.06E+00	1.31E+00	3.89E-01	
SAMA OECR (\$/yr.)	1.13E+05	2.60E+01	3.94E+04	2.36E+01	1.82E+04	2.09E+04	1.34E+01	1.90E+04	7.96E+03	6.59E+03	1.14E+03	

The System Manager's estimate of the cost for this modification is \$500,000.

This information was used as input to the present value cost benefit calculation. The results of this calculation are provided in the following table:

SAMA Number 7 Net Value

Base Case: Cost-Risk for Oyster Creek (site) ^{(1), (2)}	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value
\$4,462,000	\$4,288,000	\$174,000	\$500,000	-\$326,000

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

⁽²⁾ Includes a factor of two increase to account for external events.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.2 SAMA 10: PASSIVE OVERPRESSURE RELIEF

Containment venting requires instrument air and CIP-3 supplied control power as well as local operator action outside the Control Room and in the yard. The instrument air valves are fitted with air accumulators and CIP-3 receives power from diverse AC and DC sources. Therefore, loss of support is a low probability situation. However, operator action is required and reduction in the contribution could be achieved if a passive primary containment overpressure protection device is installed. Such a device, i.e., rupture disk, would eliminate the operator action. In order for this device to be useful, the vent pathway valves would have to be initially open, fail open, and remain open upon a high drywell pressure signal. It should be noted that this represents a substantial change to the design basis of this system. Associated with this significant design basis change, the rupture disk could also increase the potential for containment isolation failure, i.e., a competing risk. Also, the device would not be useful for low pressure, combustible gas venting scenarios.

The maximum benefit associated with the plant modification is assessed here by neglecting the competing risks. The OC-LEV2.caf fault tree model was saved as OC-SAMA10.caf and edited. This potential modification was modeled by deleting the following logic from the containment venting portion of the model (OV Node):

- OHEOV1 Operator Action
- OH-TORUSCLG Operator Action
- OHEOV1-COND Operator Action
- VENT-SUPPORT Gate with AC and DC support nodes

The baseline CDF is 1.05x10-5 per year and the model re-quantified with the proposed modification is 8.87x10-6 per yr. This is a reduction of 1.6x10-6 per yr. As noted, this is the maximum benefit associated with the change determined by neglecting the competing risks.

However, the plant modification could cause at least two competing risks or adverse consequences. One competing risk is the increase in the probability of a containment isolation failure. A normally open set of valves would be required to isolate the containment as necessary. This would likely require operator action. As such, the original operator action to open the vent would be replaced by an operator action to close the primary containment as necessary for containment isolation.

The second competing risk is that the use of rupture disks would result in a rapid containment blowdown which would likely compromise ECCS suction from the torus due to low NPSH. This adverse impact has also not been explicitly accounted for in the modeling of this SAMA but is considered qualitatively in assessing the benefit.

The results from this case indicate a 15.5 percent reduction in CDF (CDFnew=8.87E-6 per year). A further breakdown of this information is provided below according to release category.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

	SAMA 10 PRA and MACCS Results By Release Category											
			Release Category									
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	_M/I	M/L	H/E	H/I	H/L	BOC	
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08	
SAMA Freq. (per yr.)	8.87E-06	2.71E-06	3.37E-06	1.96E-07	9.99E-07	1.32E-07	1.67E-09	5.48E-07	6.78E-07	2.10E-07	3.23E-08	
SAMA Dose-Risk (Person Rem/yr.)	2.92E+01	6.76E-02	1.35E+01	2.90E-02	5.79E+00	5.54E-01	5.90E-03	4.34E+00	2.84E+00	1.58E+00	4.01E-01	
SAMA OECR (\$/yr.)	9.77E+04	2.68E+01	3.98E+04	2.37E+01	1.91E+04	1.68E+03	1.61E+01	2.06E+04	7.39E+03	7.91E+03	1.17E+03	

The cost of implementation for this SAMA is estimated to be \$1,000,000 based on the need for considerable analysis relating to primary containment integrity (i.e., rupture disks would become an extension of containment) as well as extensive modification of the primary containment vent pathway. Continued maintenance and training is also significant. This is assumed to include equipment procurement, training, and procedure updates. Licensing costs are also likely to be significant and are included in the estimate.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

	SAMA Number 10 Net Value										
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value							
\$4,462,000	\$3,674,000	\$788,000	\$1,000,000	-\$212,000							

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

In addition, the adverse impacts on RPV makeup due to NPSH issues and failure of containment isolation combine to make a strong case for not including this as a viable modification. Therefore, while the competing risks are not explicitly quantified they support the above determination that the modification should not be performed.

F.6.3 SAMA 18: IMPROVED ABILITY TO COOL THE CONTAINMENT SPRAY SYSTEM HEAT EXCHANGERS

SAMA 18 represents a potential modification to enable alignment of service water or fire protection to containment spray heat exchanger shells.

The OC-LEV2.caf fault tree model was saved as OC-SAMA18.caf and edited. To model this proposed modification, nodes FP (Fire Protection) and SW (Service Water) were added under the AND gates for emergency service water (Gates CCG01MDD, CCG02MBD). This logic would now require failure of service water and fire water in addition to emergency service water pumps, for failure of the containment spray heat exchanger heat sink.

The results from this case indicate a 0.5 percent reduction in CDF (CDF_{new} = 1.04E-5 per year). A further breakdown of this information is provided below according to release category.

			Release Category								
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.04E-05	2.70E-06	3.35E-06	1.96E-07	9.96E-07	1.65E-06	1.67E-09	5.46E-07	7.82E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.59E+01	6.75E-02	1.35E+01	2.90E-02	5.77E+00	6.92E+00	5.90E-03	4.33E+00	3.28E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	1.18E+05	2.67E+01	3.96E+04	2.37E+01	1.90E+04	2.09E+04	1.61E+01	2.06E+04	8.52E+03	7.91E+03	1.17E+03

SAMA 18 PRA and MACCS Results By Release Category

Dresden [F-7] estimated the cost of a similar modification to be \$265,000. This cost value is judged a reasonable estimate for this OC SAMA.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

SAMA Number 18 Net Value										
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value						
\$4,462,000	\$4,454,000	\$8,000	\$265,000	-\$257,000						

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

A sensitivity analysis is also performed, similar to that above, except that only the service water cross-tie is credited. The difference is a change in CDF of less than 1E-8/yr and demonstrates a very small benefit.

As an additional sensitivity, the model used for SAMA 18 was further edited to include fire water and service water as direct heat sinks for the SDC heat exchangers. The revision involved "ANDing" gates FP (Fire Protection) and SW (Service Water) along with RB (RBCCW) under the SD (SDC) gate. This model was saved as OC-SAMA18A.caf. When this model was requantified the resulting delta CDF was 1E-9/yr when compared to the 1.040E-5/yr value for the original SAMA 18 calculation, the difference is found to be insignificant. This shows that the primary benefit would be related to expanding the heat sinks for containment spray. This occurs because containment spray as a heat sink is useful in most scenarios, including all wherein SDC would also be beneficial. By contrast, SDC is not effective in high pressure scenarios or scenarios involving LOCAs.

F.6.4 SAMA 20: RE-OPEN MSIVS TO RESTORE THE MAIN CONDENSER AS A HEAT SINK

The main condenser represents one of the ultimate heat sink available to remove heat from the RPV and containment for non-LOCA conditions. There is currently no EOP direction to reopen the MSIVs and restore the main condenser as a heat sink for non-ATWS conditions. There are non-accident procedures (system procedures) that provide the required guidance and the crews are trained on how to perform the line up (reopen the MSIVs).

The enhancement that could be considered is to provide clear direction on reopening the MSIVs for cases when the event can be clearly identified as a spurious MSIV closure and the main condenser is otherwise available. Operators have indicated to the PRA team that current EOPs are interpreted to provide guidance to use the main heat sink wherever possible. However, at Oyster Creek, reestablishing the main heat sink can be difficult because the main steam lines can not easily be vented to equalize pressure across the MSIVs. This would likely lead to significant pressure perturbation when the MSIVs are opened. The pressure spikes would then likely cause reclosure. Providing a configuration which allows for easy steam line venting would require a modification to replace steam line drains and thus eliminate the need for the currently installed spectacle flanges.

In order to quantify the benefit of this improvement, the OC-LEV2.caf fault tree model was saved as OC-SAMA20.caf and edited. To model this proposed modification, a basic event was ANDed with the MSIV closure (%CMSIV) initiator. This basic event was set equal to 0.1 and represents the reopening of a spuriously closed steam line to allow the main heat sink to function. Based on the above information, the benefit from an enhanced procedure is modeled with a human error probability (HEP) of 0.1. Using a lower HEP (e.g., 0.01) is judged to potentially overestimate the benefit of the SAMA.

The results from this case indicate a 0.4 percent reduction in CDF (CDF_{new} = 1.05E-5 per year). The delta CDF is 3.8E-8/yr. A further breakdown of this information is provided below according to release category.

			Release Category								
Calculation Description	Total	Intact	L-LL/E, L-LL/i	L-LL/L	M/E	M/I	M/L	H/E	НЛ	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.05E-05	2.70E-06	3.37E-06	1.95E-07	9.94E-07	1.64E-06	1.67E-09	5.47E-07	7.84E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.59E+01	6.76E-02	1.36E+01	2.89E-02	5.75E+00	6.87E+00	5.90E-03	4.34E+00	3.28E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	1.18E+05	2.68E+01	3.98E+04	2.36E+01	1.90E+04	2.08E+04	1.61E+01	2.06E+04	8.54E+03	7.91E+03	1.17E+03

SAMA 20	PRA and	MACCS	Results	By Re	elease	Category

System managers estimate the cost of this modification to be \$400,000. Steam line drains inside the primary containment must be refitted with leak-tight isolation valves capable of remote operation.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

	SAMA Number 20 Net Value										
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value							
\$4,462,000	\$4,458,000	\$4,000	\$400,000	-\$396,000							

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.5 SAMA 23: DIVERSIFY THE EXPLOSIVE VALVE OPERATION

SAMA 23 represents a potential modification to enable manual bypass of explosive valves (manually operated valve in a bypass line).

The OC-LEV2.caf fault tree model was saved as OC-SAMA23.caf and edited. To model this proposed modification, a basic event, SAMA23BE, was added under the AND gate for the squib valves, BIG02MHC. This basic event was set to 1E-2 to reflect estimated operator reliability under such a configuration.

The results from this case indicate a 0.7 percent reduction in CDF (CDF_{new}= 1.04E-5 per year), A further breakdown of this information is provided below according to release category.

			Release Category								
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	н/і	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.04E-05	2.71E-06	3.38E-06	1.96E-07	9.32E-07	1.66E-06	1.67E-09	5.45E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.56E+01	6.76E-02	1.36E+01	2.90E-02	5.40E+00	6.95E+00	5.90E-03	4.33E+00	3.29E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	1.17E+05	2.68E+01	3.99E+04	2.37E+01	1.78E+04	2.10E+04	1.61E+01	2.06E+04	8.57E+03	7.91E+03	1.17E+03

SAMA 23 PRA and MACCS Results By Release Category

This SAMA is expected to involve installation of an explosive valve bypass line. This is a significant plant modification expected to cost at least \$150,000. System manager estimates it would cost \$150,000 for an additional manual valve (\$500,000 for MOV w/CR controls). None of these items would be considered cost beneficial.

Because the valving must be highly leak-tight to avoid unintentionally introducing boron to the RPV, a \$150,000 estimate is considered very optimistic.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

SAMA Number 23 Net Value										
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value						
\$4,462,000	\$4,420,000	\$42,000	\$150,000	-\$108,000						

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.6 SAMA 25: BYPASS LOW PRESSURE PERMISSIVE

SAMA 25 represents a potential modification or procedure to enable quick bypassing of low pressure permissive for core spray.

The OC-LEV2.caf fault tree model was saved as OC-SAMA25.caf and edited. To model this proposed procedure change, an AND gate was added under the gates for core spray injection valves (CSG00MEF, CSG00MEK). Under the new AND gate is logic for the permissive as well as a new basic event that represents operator action to bypass the permissive. The new basic event, SAMA25BE, was set to 1E-2.

The results from this case indicate a 0.3 percent reduction in CDF (CDF_{new}= 1.05E-5 per year). A further breakdown of this information is provided below according to release category.

			Release Category								
Calculation Description	Total_	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.05E-05	2.69E-06	3.38E-06	1.96E-07	9.93E-07	1.65E-06	1.65E-09	5.44E-07	7.82E-07	2.08E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.59E+01	6.74E-02	1.36E+01	2.90E-02	5.75E+00	6.95E+00	5.82E-03	4.31E+00	3.27E+00	1.56E+00	4.01E-01
SAMA OECR (\$/yr.)	1.18E+05	2.67E+01	3.98E+04	2.37E+01	1.90E+04	2.10E+04	1.59E+01	2.05E+04	8.52E+03	7.80E+03	1.17E+03

SAMA 25 PRA and MACCS Results By Release Category

The cost of implementation for this SAMA was estimated to be \$50,000.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

	SAMA Number 25 Net Value										
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value							
\$4,462,000	\$4,458,000	\$4,000	\$50,000	-\$46,000							

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.7 SAMA 67: SAFETY RELATED CONDENSATE STORAGE TANK

SAMA 67 represents a potential modification to enable the CST to survive a larger portion of the seismic spectrum. The modification to strengthen the seismic capability of the CST is judged only to impact the seismic risk contribution. Therefore, the fire and internal events risk contributions are assumed to remain unchanged.

The current Oyster Creek PRA model does not include seismic initiating events. However, the IPEEE evaluation [F-22] built a seismic model that can be used to estimate the potential benefit of this proposed modification. Seismic CDF is 3.63E-6/yr and no containment event tree was developed for use with seismic events.

In the IPEEE, the seismic induced failure of the condensate storage tank was modeled using top event SX. The following table shows the failure rate under various conditions modeled in the seismic PRA.

Model Identifier	Condition	Failure Rate (EPRI NP-6395-D Hazard Curve)	Failure Rate of Containment Spray Components (Safety Related) For Comparison
SX1	CST Failure given earthquake between 0.007g and 0.26g	4.91E-3	4.74E-5
SX2	CST Failure given earthquake between 0.26g and 0.46g	0.522	4.43E-2
SX3	CST Failure given earthquake between 0.46g and 0.62g	0.833	0.296
SX4	CST Failure given earthquake between 0.62g and 0.82g	0.935	0.648

The Fussell-Vesely (FV) importance measure for the SX Top event is 0.31 which means that the seismic induced failure of the CSTs occurs in approximately 31% of seismic core damage sequences. Given the fairly high seismic failure rate for CSTs, it is judged reasonable to assume that designing the CSTs to standards equal to safety related components would reduce CST failure sequences by a factor of 5. Such a change would reduce seismic CDF from 3.63E-6/yr to 2.73E-6/yr (3.63E-6*((1-0.31)+(0.31/5))). The results from this case indicate a 24.8 percent reduction in seismic CDF (CDF_{new}= 2.73E-6 per year).

The IPEEE indicates that most seismic CST failure sequences involve high RPV pressure conditions. As such, these sequences are assumed to apply only to Class1A and that the relative contribution to Level 2 endstates is proportional to those derived using the baseline Level 1 model. Applying this relationship yields the following results regarding the impact of the proposed modification.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

	SAMA 67 PRA and MACCS Results By Release Category										
	-		Release Category								
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	Н/І	H/L	BOC
Baseline Freq. (per yr.)	3.63E-06	2.73E-06	5.83E-07	1.41E-07	1.23E-07	0.00E+00	0.00E+00	4.84E-08	3.99E-09	0.00E+00	0.00E+00
SAMA Freq. (per yr.)	2.73E-06	2.06E-06	4.39E-07	1.06E-07	9.28E-08	0.00E+00	0.00 <u>E+00</u>	3.64E-08	3.00E-09	0.00E+00	0.00E+00
SAMA Dose-Risk (Person Rem/yr.)	2.67E+00	5.14E-02	1.76E+00	1.57E-02	5.37E-01	0.00E+00	0.00E+00	2.88E-01	1.26E-02	0.00E+00E	0.00E+00
OECR (\$/yr.)	8.39E+03	2.04E+01	5.18E+03	1.29E+01	1.77E+03	0.00E+00	0.00E+00	1.37E+03	3.27E+01	0.00E+00	0.00E+00

The cost of this SAMA was estimated in the Peach Bottom SAMA evaluation [F-6] and was estimated to be \$1,000,000 per tank. Because Oyster Creek has one CST, the cost of implementation for this SAMA is \$1,000,000.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

SAMA Number 67 Net Value										
Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value							
\$197,000	\$65,000	\$1,000,000	-\$935,000							
	Cost-Risk for Oyster Creek With SAMA Changes \$197,000	SAMA Number 67 Ne Cost-Risk for Oyster Creek With SAMA Averted Cost- Changes Risk \$197,000 \$65,000	SAMA Number 67 Net ValueCost-Risk for Oyster CreekWith SAMAAverted Cost- Cost of Changes\$197,000\$65,000\$1,000,000							

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

⁽²⁾ This includes only the seismic contribution to risk as that is the only portion of risk considered impacted by this SAMA.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.8 SAMA 84: MANUALLY OPERATE CONTAINMENT VENT VALVES

SAMA 84 represents a potential modification to enable manual operation of all containment vent valves. This would require local controls for vent valves.

The manual operation of the containment isolation AOVs requires local access within the Reactor Building. Adverse environmental conditions within the Reactor Building due to high radiation, high temperatures, or scenario dependent issues such as flooding or fire could compromise the benefit associated with the SAMA.

For the cost benefit evaluation the following assumptions are made:

- Only venting prior to core damage is credited as feasible. (No Level 2 credit is assumed.)
- Adverse Reactor Building environments due to high temperature, flooding or fire is not included. This overestimates the benefit for this SAMA.

The OC-LEV2.caf fault tree model was saved as OC-SAMA84.caf and edited. To model this proposed modification, a new gate, SAMA84, was added directly under the OV, Primary Containment venting, gate. The new gate was constructed as an AND gate and a new basic event was added to represent operators manually operating containment venting locally. This basic event was named OH-OV-SAMA84 and set equal to 1E-2 per demand. All containment venting basic events related to support system interaction were then moved under the SAMA84 gate to be "ANDed" with the new basic event. This logic makes the current equipment redundant to a new means to open the containment venting pathway.

The results from this case indicate a 1.7 percent reduction in CDF (CDF_{new} = 1.03E-5 per year). A further breakdown of this information is provided below according to release category.

<u>. </u>		<u> </u>			_				<u> </u>			
			Release Category									
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L_	H/E	<u>H/I</u>	H/L	BOC	
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08	
SAMA Freq. (per yr.)	1.03E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.49E-06	1.67E-09	5.48E-07	7.74E-07	2.10E-07	3.23E-08	
SAMA Dose-Risk (Person Rem/yr.)	3.53E+01	6.76E-02	1.36E+01	2.90E-02	5.79E+00	6.26E+00	5.90E-03	4.34E+00	3.25E+00	1.58E+00	4.01E-01	
SAMA OECR (\$/yr.)	1.16E+05	2.68E+01	3.99E+04	2.37E+01	1.91E+04	1.89E+04	1.61E+01	2.06E+04	8.44E+03	7.91E+03	1.17E+03	

SAMA 84 PRA and MACCS Results By Release Category

The cost to install handwheels or other local devices on the two torus air operated containment isolation valves is estimated to be \$100,000, plus \$50,000 for required procedure changes.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

Environmental Report Appendix F Severe Accident Mitigation Alternatives

SAMA Number 84 Net Value					
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value	
\$4,462,000	\$4,382,000	\$80,000	\$150,000	-\$70,000	

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.9 SAMA 88: CONTAINMENT VENT

SAMA 88 represents a potential procedure change to specify a control band for containment venting. Alternatively, containment vent valves could be modified. Vent valves are already restricted in movement to 30⁰ maximum opening. Further modification is not judged warranted.

Adding more specific direction to EOPs to provide operators with a defined pressure control band is judged to provide a reduction in operator error rate. Specifically, the failure probability for uncontrolled venting leading to loss of ECCS suction can be reduced by a factor of 10, if a specific control band is established. The OC-LEV2.caf fault tree model was saved as OC-SAMA88.caf and edited. This proposed procedure change was modeled by reducing basic event OHEOV3, "Operator Fails To Control Venting Evolution," from 3.8E-2 per demand to 3.8E-3 per demand.

The results from this case indicate a 0.1 percent reduction in CDF (CDF_{new} = 1.05E-5 per year). A further breakdown of this information is provided below according to release category.

		Release Category									
Calculation Description	Total	Intact	L-LL/E, L-LL/I	 L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.64E-06	1.67E-09	5.48E-07	7.85E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.60E+01	6.76E-02	1.36E+01	2.90E-02	5.79E+00	6.90E+00	5.90E-03	4.34E+00	3.29E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	1.18E+05	2.68E+01	3.99E+04	2.37E+01	1.91E+04	2.09E+04	1.61E+01	2.06E+04	8.56E+03	7.91E+03	1.17E+03

SAMA 88 PRA and MACCS	Results By	Release	Category
-----------------------	------------	---------	----------

The cost of implementation for this SAMA is estimated to be \$50,000 because it involves procedure changes only.

This information was used as input to the cost benefit calculation. As can be seen, there are negligible changes in the CDF and the release category frequencies. This leads to a negligible change in averted cost risk. The results of this calculation are provided in the following table:

SAMA Number 88 Net Value						
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value		
\$4,462,000	\$4,462,000	\$0	\$50,000	-\$50,000		

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.
Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

1. 11.

F.6.10 SAMA 89: IMPROVE PROCEDURE FOR ALIGNING SDC GIVEN HIGH DW PRESSURE

SAMA 89 represents the performance of a Safety Evaluation that would allow Operating Procedure 305 to be implemented "as-is" with the elimination of the requirement for operators to invoke 50.54(x).

The OC-LEV2.caf fault tree model was saved as OC-SAMA89.caf and edited. This action is currently quantified with 3 hours available for the action. This time is driven by the time to reach the high drywell pressure limit. If operators are allowed to bypass this SDC isolation signal, the alignment of SDC would be required prior to the primary containment pressure limit (PCPL). This is reached at approximately 19 hours. Requantifying the HEP for SDC with 19 hours instead of 3 hours available would reduce the failure probability from 1.6E-3 per demand to 4.1E-4 per demand. Thus, to model this proposed procedure change or modification, the value for basic event OHESD1, "Operator Fails To Align SDC System," was reduced from 1.6E-3 per demand to 4.1E-4 per demand.

The results from this case indicate a very small reduction in CDF (<1E-10/yr). This is due to the dominance of dependent operator error in the failure of all decay heat modes, which would not be addressed by this proposed improvement. Specifically, operator action OH-TORUSCLG, "Operator fails to align for Torus Cooling" would still apply as a common dependent diagnosis failure mode of both torus cooling and SDC. Therefore, the resulting change in CDF is negligible.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.11 SAMA 91: ALLOW 4160 VAC BUS IC AND ID CROSSTIE

This SAMA represents procedure/training changes and the performance of a Safety Evaluation that would allow System Procedure 337 to be modified to allow operators to cross-tie emergency AC buses 1C and 1D under emergency conditions which require operation of critical equipment.⁽¹⁾

The OC-LEV2.caf fault tree model was saved as OC-SAMA91.caf and edited. The current model includes one division of core spray and containment spray under the ECCS-HDWR-SBO gate. This gate represents the equipment powered from the combustion turbine following its alignment. Currently, the CT can be aligned to only one AC division via the SBO transformer. Since no cross-tie capability exists, only equipment from one division is credited in the PRA. In order to credit an improvement that would allow bus cross-tie alignment, the ECCS-HDWR-SBO gate was modified. Core spray and containment spray gates were added for the divisions that would be potentially available should the proposed cross-tie be implemented. Opposite divisions were ANDed with the equipment available directly from the SBO transformer (i.e., equipment credited in the base model). A new basic event, SAMA91-OP-ACTION, was added to represent operator actions necessary to align the proposed cross-tie. This basic event is ORed with the alternate core spray and containment spray trains and is set to 0.1. Because of the reluctance to cross tie emergency divisions, the HEP of 0.1 is considered appropriately realistic.

For non-LOOP cases, the improvement would also allow for a benefit. For these cases the EC and ED node logic was modified to allow the cross-tie to be aligned when the respective nonsafety related bus supply is unavailable (i.e., Bus 1A, Bus 1B). This was done by adding a new OR gate (SAMA91-EC) under gate ECG00MDB for the EC (Bus 1C Node). Bus 1D basic events were then added under this new OR gate, along with the SAMA91-OP-ACTION basic event, to require availability of bus 1D to support bus 1C, as necessary. Similar changes were made under the ED (Bus 1D) node.

Note that no competing risks have been included. Any issues that would present operational difficulties are expected to be identified as part of plant staff input and will be captured as costs.

The results from this case indicate a 2.6 percent reduction in CDF (CDF_{new} = 1.02E-5 per year. A further breakdown of this information is provided below according to release category.

⁽¹⁾ There is an existing procedure to allow the cross-tie but it is only allowed for planned shutdown conditions.

	54	WA 91	PRA and		o Resu	ILS DY I	Release	e Calleg	ory		
			Release Category								
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.02E-05	2.66E-06	3.22E-06	1.95E-07	9.74E-07	1.64E-06	1.67E-09	5.36E-07	7.64E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.50E+01	6.65E-02	1.30E+01	2.89E-02	5.64E+00	6.88E+00	5.90E-03	4.25E+00	3.20E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	1.15E+05	2.64E+01	3.80E+04	2.36E+01	1.86E+04	2.08E+04	1.61E+01	2.02E+04	8.32E+03	7.91E+03	1.17E+03

SAMA 91 PRA and MACCS Results By Release Category

The Safety Evaluation is estimated to cost approximately \$40,000. The procedure change is expected to cost an additional \$50,000 for a total of \$90,000.

The competing risk associated with this proposed SAMA relates to the connection of a faulted bus to the only AC power supply, i.e., the combustion turbine. Based on input from the system manager, adequate circuit protection exists to prevent propagation of potential faults and therefore for operators to perform the cross-tie action under emergency conditions. Therefore, it is judged that no modifications would be required although a more formal review by electrical design is required as part of the safety evaluation process. It is possible that modifications could be required

are provided in the following table: SAMA Number 91 Net Value

This information was used as input to the cost benefit calculation. The results of this calculation

Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value
\$4,462,000	\$4,344,000	\$118,000	\$90,000	\$28,000

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is less than the averted cost-risk for this SAMA, the net value is positive and this enhancement is cost beneficial based on the SAMA methodology.

F.6.12 SAMA 92: ALLOW OPERATORS TO MAXIMIZE CRD FLOW

SAMA 92 involves a procedure change to modify EOP 1, Support Procedure 3 to eliminate the 150 gpm flow limitation and replace with a caution to monitor the system for pump runout when system flow is greater than 150 gpm.

Oyster Creek remains one of the few BWRs that has retained the CRD bypass pathway as an injection method directly to the RPV. This flowpath has the potential to pass increased flow. This could be a benefit for Oyster Creek in the assessment of the risk profile if the action to align the pathway is taken early in an event and the flow is allowed to increase above currently specified levels.

The OC-LEV2.caf fault tree model was saved as OC-SAMA92.caf and edited. The current model does not take credit for CRD providing adequate high pressure makeup, primarily due to operator guidance that limits CRD flow to protect the system. However, if CRD is allowed to supply additional flow under emergency conditions, there is some likelihood that CRD alone could provide enough flow to prevent core damage. This potential capability is modeled by changing the FWT gate in the feedwater node to an AND gate. The CRD node (CD) was then added to this gate to allow CRD to be redundant to feedwater in terms of high pressure injection. LOCA events were also "ORed" in this logic so that CRD would not be allowed to be successful under LOCA conditions.

To confirm the likelihood of CRD successfully providing the level of benefit quantified, a deterministic thermal hydraulic analysis was performed to characterize the performance. MAAP run OC58a modeled a loss of feedwater, coupled with MSIV closure event. CRD injection to the vessel was assumed to be 60 gpm for the first 5 minutes and 220 gpm thereafter. This assumption may be optimistic in assessing the potential benefit associated with the change. The core was uncovered but the hottest core node remained below approximately 1200°F and core damage did not occur. Also, the PRA quantification did not credit the benefit of additional CRD injection during small LOCA events including seal LOCAs. Additional CRD injection would allow a greater spectrum of break sizes to be mitigated. This conservatism is judged to offset the potential to overestimate the value of CRD in providing redundant high pressure injection capability associated with an operator action assumed at 5 min.

The results from this case indicate an 2 percent reduction in CDF (CDF_{new} = 1.03E-5 per year). A further breakdown of this information is provided below according to release category.

	JP		FRA and	I MACC	o nesu	ILS DY I	release	catego	ory			
		Release Category										
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC	
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08	
SAMA Freq. (per yr.)	1.03E-05	2.56E-06	3.35E-06	1.88E-07	9.76E-07	1.66E-06	1.67E-09	5.45E-07	7.85E-07	2.10E-07	3.23E-08	
SAMA Dose-Risk (Person Rem/yr.)	3.58E+01	6.41E-02	1.35E+01	2.79E-02	5.65E+00	6.96E+00	5.90E-03	4.32E+00	3.29E+00	1.58E+00	4.01E-01	
SAMA OECR (\$/yr.)	1.17E+05	2.54E+01	3.95E+04	2.28E+01	1.86E+04	2.11E+04	1.61E+01	2.05E+04	8.56E+03	7.91E+03	1.17E+03	

The cost of implementation for this SAMA is estimated to be as follows:

- \$50,000 for procedure changes
- Test to ensure that the two pumps could provide greater than 220 gpm without low pressure suction trip or failures. (Estimated \$50,000)

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value
\$4,462,000	\$4,426,000	\$36,000	\$100,000	-\$64,000

SAMA Number 92 Net Value

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is more than the averted cost-risk for this SAMA, the net value is -\$64,000 and this enhancement is not cost beneficial based on the SAMA methodology.

F.6.13 SAMA 94: INCREASE SUCCESS PROBABILITY FOR FIRE PROTECTION ALIGNMENT

The fire protection system at Oyster Creek provides an alternate RPV injection source that can be aligned by the crew through local manual actions given sufficient time and access to equipment. SAMA 94 is a procedure and training change to modify EOPs 1a and 1b to provide a cue for crew action to align fire protection for RPV injection with sufficient time available. This could also be a note to operators that fire protection system alignment takes longer to establish than other potential sources of RPV injection.

The HRA includes this action as a number of basic events based on plant conditions. This SAMA would provide operators with an earlier cue for fire water alignment and would reduce error rate accordingly. The base basic event values are shown in the table below. The HRA calculation was reviewed and revised basic event values were determined by evaluating the impact if the action cue were to occur 5 minutes earlier. The last column of the table below shows these values. These values were modified in the OC-SAMA94.caf fault tree, which was copied directly from the OC-LEV2.caf fault tree model

Cases	Designator	Description	Base Failure Probability	Failure Probability 5 minutes Added to Cognitive Time- Window
A	OH-FPS-FW-IC	FPS injection for non-ATWS cases without FW or IC	7.3E-2	6.0E-2
В	OH-L2-DFPALIGN	FPS injection for non-ATWS cases without FW or IC M/U	7.3E-2	6.0E-2
С	OH-FPS-SORV	FPS injection for non-ATWS cases with SORV	1.0	0.08
D	OH-FPS-SBO	FPS injection for non-ATWS cases with SBO	0.15	0.1

The results from this case indicate a 0.2 percent reduction in CDF (CDF_{new} = 1.05E-5 per year). A further breakdown of this information is provided below according to release category.

	54	IVIA 94	PKA and		5 Resu	пс Бу	Releas	e categ	ory			
Calculation Description			Release Category									
	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	́ м/I	M/L	H/E	H/I	H/L	BOC	
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08	
SAMA Freq. (per yr.)	1.05E-05	2.70E-06	3.38E-06	1.96E-07	9.95E-07	1.65E-06	1.67E-09	5.47E-07	7.86E-07	2.10E-07	, 3.05E-08 ,	
SAMA Dose-Risk (Person Rem/yr.)	3.60E+01	6.74E-02	1.36E+01	2.90E-02	5.76E+00	6.95E+00	5.90E-03	4.34E+00	3.29E+00	1.58E+00	3.79E-01	
SAMA OECR (\$/yr.)	1.18E+05	2.67E+01	3.99E+04	2.37E+01	1.90E+04	2.10E+04	1.61E+01	2.06E+04	8.57E+03	7.91E+03	1.11E+03	

SAMA 94 PRA and MACCS Results By Release Category

The cost of implementation for this SAMA is estimated to be \$50,000 since it is limited to procedure changes.

This information was used as input to the cost benefit calculation. As can be seen, there are negligible changes in the CDF and the release category frequencies. This leads to a negligible change in averted cost risk. The results of this calculation are provided in the following table:

SAMA Number 94 Net Value									
Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value						
\$4,462,000	\$0	\$50,000	-\$50,000						
	Cost-Risk for Oyster Creek With SAMA Changes \$4,462,000	Cost-Risk for Oyster CreekWith SAMAAverted Cost- Changes\$4,462,000\$0	Cost-Risk for Oyster CreekAverted Cost- Cost of Implementation\$4,462,000\$0\$50,000\$0						

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.14 SAMA 95: ADD PROCEDURAL CLARIFICATION RELATED TO 5 PSID CSS ALARM

SAMA 95 is a procedure and training change to modify the 5 psid CSS alarm response procedure (B-5-A, B-5-B) and procedure 310 to include a caution that CSS should not be secured if being utilized for accident mitigation.

The Containment Spray tube to shell differential pressure alarm response could potentially cause operators to inadvertently secure an operating containment spray train based on the concern that there is a problem with tube integrity. However, based on operator interviews, this alarm can initiate due to normal system fouling and other operational conditions. Operators indicated that they were aware of the conditions and indicated that they would not secure a containment spray train based solely on the differential pressure alarm, no penalty was applied in the PRA model.

Based on the operating crew interviews and their current training, no penalty in the PRA for the associated error of commission is included. Therefore no change in CDF is calculated for this SAMA.

The cost of the change is relatively small (i.e., \$50,000 for a procedure change) but no material benefit is calculated. Therefore, this change is considered not cost beneficial.

F.6.15 SAMA 99: PROVIDE AN ALTERNATE METHOD FOR IC SHELL WATER LEVEL DETERMINATION

SAMA 99 represents a potential addition to the procedures and operator training program to provide a specific Job Performance Measure (JPM) for operation of the Isolation Condensers (ICs) with no support systems available (e.g., during a long-term SBO when DC power is exhausted). This also includes staging of materials for the local reading of the IC shell level.

Currently, IC shell level cannot be directly determined without support systems. Correctly determining IC shell level is important in accurately controlling the system. With IC shell level available locally, and RPV level available at the Yarway instruments, operators can maintain adequate control of the RPV for long-term SBO scenarios Operators and System Managers have indicated that IC shell level can be locally measured with some fairly simple improvements.

The OC-LEV2.caf fault tree model was saved as OC-SAMA99.caf and edited. To model this proposed procedure change and training enhancements, the failure rate for basic event OH-IC-SBO was reduced by a factor of 0.1. This basic event models the operators successfully operating the ICs locally when DC power is unavailable. It is believed that improved training on this scenario could improve operator reliability. A factor of ten (10) is judged slightly optimistic and may not be achievable.

The results from this case indicate an 15.6 percent reduction in CDF (CDF_{new}=8.85E-6 per year) if the assumed improvement in crew response could be achieved. A further breakdown of this information is provided below according to release category.

					F	Release	Catego	ry			
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	НЛ	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	8.85E-06	2.60E-06	2.41E-06	7.40E-08	9.86E-07	1.46E-06	1.67E-09	5.42E-07	5.53E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.02E+01	6.50E-02	9.70E+00	1.10E-02	5.71E+00	6.15E+00	5.90E-03	4.29E+00	2.32E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	1.01E+05	2.57E+01	2.85E+04	8.96E+00	1.88E+04	1.86E+04	1.61E+01	2.04E+04	6.03E+03	7.91E+03	1.17E+03

SAMA 99 PRA and MACCS Results By Release Category

The cost of implementation for this SAMA is estimated to be \$150,000. The cost of implementation includes procedure changes, training, and modification to install local level instrumentation that can function without support systems.

Note that operators have indicated that a Tygon tube based apparatus could potentially be prestaged to allow IC shell level detection. It is unclear if this is a viable method but it could potentially represent a less costly option.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

Environmental Report Appendix F Severe Accident Mitigation Alternatives

SAMA Number 99 Net Value									
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value					
\$4,462,000	\$3,788,000	\$674,000	\$150,000	\$524,000					

(1) Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is less than the averted cost-risk for this SAMA, the net value is \$524,000. This enhancement is cost beneficial based on the SAMA methodology.

F.6.16 SAMA 100: CONNECT SBO TRANSFORMER TO BOTH AC DIVISIONS.

Presently, the combustion turbine supplies only the "B" bus directly via the SBO transformer. Modification of the circuit to allow the combustion turbines to also supply the "A" bus directly would be beneficial. This would provide a benefit similar to SAMA 91 except that equipment such as feedwater pumps that are powered from Bus A would also be potentially available.

This modeling change to address this option was accomplished by making the same changes as noted in SAMA 91 as well as adding new basic events to represent the condensate/feedwater system as well as additional decay heat removal paths. Specifically, under gate ECCS-HDWR-SBO 2 basic events were added: SAMA139-FW-INJ (1E-2) to represent additional feedwater system availability and SAMA139-DHR-COND (0.1) to represent realignment of additional heat removal paths such as the main condenser and containment venting. This is judged optimistic toward supporting this SAMA because the base model takes little credit for these success paths even though Bus B is currently available from the CTs.

The results from this case indicate a 3.7 percent reduction in CDF (CDF_{new}=1.01E-5 per year). A further breakdown of this information is provided below according to release category.

								_				
	Release Category											
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I_	M/L	H/E	Н/1	H/L	BOC	
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08	
SAMA Freq. (per yr.)	1.01E-05	2.64E-06	3.16E-06	1.95E-07	9.63E-07	1.64E-06	1.67E-09	5.63E-07	7.54E-07	2.10E-07	3.23E-08	
SAMA Dose-Risk (Person Rem/yr.)	3.46E+01	6.60E-02	1.27E+01	2.89E-02	5.58E+00	6.87E+00	5.90E-03	4.21E+00	3.16E+00	1.58E+00	4.01E-01	
SAMA OECR (\$/yr.)	1.14E+05	2.62E+01	3.73E+04	2.36E+01	1.84E+04	2.08E+04	1.61E+01	2.00E+04	8.22E+03	7.91E+03	1.17E+03	

SAMA 100 PRA and MACUS Results BV Release Categor	SAMA 100 PRA	and MACCS	Results By	v Release	Category
---	--------------	-----------	-------------------	-----------	----------

System managers have estimated the cost of the modification to be \$500,000.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

SAMA Number 100 Net Value										
Base Case: Cost-Risk ^(!) for Oyster Creek (site) ⁽²⁾	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value						
\$4,462,000	\$4,316,000	\$146,000	\$500,000	-\$354,000						

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

⁽²⁾ Damage due to high winds is an external event. External event contributions attributable to other sources may be omitted. External event contributions from seismic and fire are removed from consideration, such that the cost risk multiplier used is 1.0 rather than 2.0.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology. However, note that a significant portion of this benefit can also be achieved by implementation of SAMA 91, the 4160 VAC cross-tie option.

F.6.17 SAMA 101: PROVIDE A PROCEDURE FOR DETERMINING RPV LEVEL USING FUEL ZONE LEVEL INDICATORS A AND C WITH SLC OPERATING

Additional guidance should be evaluated for operators to consider temporarily securing SLC pumps, as necessary, to record RPV level. This approach must balance SLC pump start frequency requirements as well as RPV level trends against the downsides of RPV flooding.

Two trains of Oyster Creek fuel zone level instruments utilize SLC system piping for the variable leg tap. This causes a situation where these trains are inaccurate when the SLC system is running. In ATWS scenarios, and all SAMG conditions where SLC is expected to be running, level indication evaluation provides an additional challenge for operators. Improved procedures, such as potentially securing SLC flow or providing a correction curve could reduce the operator error rate for the ATWS task involving lowering RPV level to control power. It is judged that a factor of three reduction in error rate is an attainable goal.

Case	Designator	Description	Base Failure Probability	Failure Probability with improved instrumentation procedure
A	OH-LVL-ERLY	RPV level control MSIVs closed, Early Initiation of Level Control (6 min.)	0.12	0.04
В	OH-LVL-LATE	RPV level control MSIVs closed, Late Initiation of Level Control (20 min.)	4.8E-02 ⁽¹⁾	4.8E-2 ⁽²⁾
C	OH-LVL-TT	RPV level control Main condenser available, Initiation of Level Control (40 min.)	9.0E-04	3.0E-4

(1) Conditional Failure probability.

(2) Conditional Failure probability is not adjusted for SAMA since benefit captured in OH-LVL-ERLY

The probability of these basic events was modified in model OC_SAMA101.caf, which was developed directly from OC-LEV2.caf.

The results from this case indicate a 0.2 percent reduction in CDF (CDF_{new} =1.05E-5 per year). A further breakdown of this information is provided below according to release category.

There is also a benefit to be gained by allowing a more suitable SAG branch to be selected given level can be determined versus the SAG leg that is defaulted to if level is not available. This additional benefit has not been quantified.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

SAMA 101 PRA and MACCS Results By Release Category											
-	•		Release Category								
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.05E-05	2.70E-06	3.38E-06	1.95E-07	9.87E-07	1.66E-06	1.67E-09	5.47E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.60E+01	6.75E-02	1.36E+01	2.89E-02	5.72E+00	6.95E+00	5.90E-03	4.34E+00	3.29E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	1.18E+05	2.67E+01	3.99E+04	2.37E+01	1.89E+04	2.10E+04	1.61E+01	2.06E+04	8.57E+03	7.91E+03	1.17E+03

The cost of implementation for this SAMA is estimated to be \$50,000 since it is limited to procedure changes.

This information was used as input to the cost benefit calculation. As can be seen, there are negligible changes in the CDF and the release category frequencies. This leads to a negligible change in averted cost risk. The results of this calculation are provided in the following table:

SAMA Number 101 Net Value										
Base Case: Cost-Risk ¹¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value						
\$4,462,000	\$4,462,000	\$0	\$50,000	-\$50,000						

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, and this enhancement is not cost beneficial based on the SAMA methodology.

F.6.18 SAMA 102: REVISE ATWS EOP TO PROVIDE RPV LEVEL CORRECTION BASED ON POWER

Revise EOP 1b "RPV Control – ATWS" to include an RPV Fuel Zone Level correction factor to account for reactor power level. Oyster Creek currently does not correct fuel zone level according to power. This type of correction has been implemented at other plants such as Nine Mile Point Unit 1, to account for RPV level being indicated lower than actual in ATWS events. This could cause operators to not lower water level low enough to adequately reduce power.

This is judged to have the same level of impact as SAMA 101, above.

The results from this case indicate a 0.2 percent reduction in CDF (CDF_{new} = 1.05E-5 per year). A further breakdown of this information is provided below according to release category.

-			Release Category									
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/i	M/L	H/E	H/I	H/L	BOC	
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08	
SAMA Freq. (per yr.)	1.05E-05	2.70E-06	3.38E-06	1.95E-07	9.87E-07	1.66E-06	1.67E-09	5.47E-07	7.86E-07	2.10E-07	3.23E-08	
SAMA Dose-Risk (Person Rem/yr.)	3.60E+01	6.75E-02	1.36E+01	2.89E-02	5.72E+00	6.95E+00	5.90E-03	4.34E+00	3.29E+00	1.58E+00	4.01E-01	
SAMA OECR (\$/yr.)	1.18E+05	2.67E+01	3.99E+04	2.37E+01	1.89E+04	2.10E+04	1.61E+01	2.06E+04	8.57E+03	7.91E+03	1.17E+03	

SAMA 102 PRA and MACCS Results By Release Category

The cost of implementation for this SAMA is estimated to be \$50,000 associated with procedure changes. There would also be significant analysis/modeling and training costs of approximately \$50,000.

This information was used as input to the cost benefit calculation. As can be seen, there are negligible changes in the CDF and the release category frequencies. This leads to a negligible change in averted cost risk. The results of this calculation are provided in the following table:

	SAMA Number 102 Net Value										
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value							
\$4,462,000	\$4,462,000	\$0	\$100,000	-\$100,000							
		· · · ·									

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.19 SAMA 104: IMPROVE LOSS OF CIRCULATING WATER RESPONSE

SAMA 104 is to develop a loss of circulating water abnormal operating procedure or revise the loss of condenser vacuum procedure to include guidance to allow condensate and feedwater to be adequately protected. This could include more rapid swapping to service water and/or the direction to temporarily secure condensate and feedwater while the swap occurs.

Currently, circulating water (CW) provides the normal heat sink for the TBCCW system. In turn, TBCCW provides cooling to the condensate and feedwater pumps. Without cooling, condensate pumps may fail within a matter of a few minutes. Oyster Creek has the capability to align the service water system as a backup to the circulating water system for TBCCW cooling. However, this alignment takes enough time that the PRA group judged it would be difficult to credit with regard to feedwater availability. As such, in the base PRA model, feedwater is completely dependent on circulating water. This SAMA involves creating a procedure that allows for a reliable means of implementing the TBCCW heat sink swap from circulating water to service water.

To model this potential improvement, the SW gate was added under the CP-COOLING gate in the CP fault tree. The logic was established so that SW was "ANDed" with CW. No operator actions were included which is slightly optimistic in supporting the proposed change. The OC_SAMA101.caf fault tree, which was developed directly from OC-LEV2.caf was used to model this SAMA.

			Release Category									
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC	
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08	
SAMA Freq. (per yr.)	1.02E-05	2.47E-06	3.33E-06	1.84E-07	9.77E-07	1.66E-06	1.67E-09	5.43E-07	7.85E-07	2.10E-07	3.23E-08	
SAMA Dose-Risk (Person Rem/yr.)	3.57E+01	6.17E-02	1.34E+01	2.72E-02	5.66E+00	6.95E+00	5.90E-03	4.31E+00	3.29E+00	1.58E+00	4.01E-01	
SAMA OECR (\$/yr.)	1.17E+05	2.45E+01	3.93E+04	2.23E+01	1.87E+04	2.10E+04	1.61E+01	2.05E+04	8.56E+03	7.91E+03	1.17E+03	

The results from this case indicate a 3.1 percent reduction in CDF (CDF_{new}= 1.02E-5 per year). A further breakdown of this information is provided below according to release category.

SAMA 104 PRA and MACCS Results By Release Category

The swapping action currently requires a number of operations to be implemented outside the control room. This includes:

- 1. Close V-3-58 in the Turbine Bldg. basement.
- 2. Open V-3-59 in the Turbine Bldg. basement.
- 3. Close V-3-76 and V-3-77 in the Turbine Bldg. basement.
- 4. Throttle V-3-76 to a position not fully closed in the Turbine Bldg. basement.
- 5. Open V-3-74 in the Turbine Bldg. basement.

In order to assure the actions are completed in sufficient time to protect the feedwater system, it is currently judged that hardware modifications will be needed in addition to procedural changes. These hardware changes would most likely involve conversion of local manual valves to remotely operated valves with controls in the control room. Therefore, the cost of implementation for this SAMA is estimated to be \$250,000 (hardware and procedure costs).

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

SAMA Number 104 Net Value										
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value						
\$4,462,000	\$4,418,000	\$44,000	\$250,000	-\$206,000						

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.20 SAMA 106: IMPROVE DIRECTION FOR COOLDOWN IN LOSS OF RBCCW

SAMA 106 is to revise ABN-19 to include guidance to implement a <90°F/hr cooldown as soon as possible following a loss of RBCCW to supplement protection of recirculation pump seals by reducing RPV pressure.

RBCCW provides cooling to the recirculation pump seals and its unavailability presents a challenge to the recirculation pump seal integrity. This challenge can be reduced by lowering RPV pressure. The strategy would be to depressurize to 500 to 700 psi immediately and then subsequently reduce pressure further as inventory makeup and cooldown requirements allow. Guidance to implement this strategy upon loss of RBCCW, including SBO cases, will reduce the probability of a seal LOCA. Based on a review of vendor test data which shows a lower failure rate at lower RPV pressures, a seal failure probability reduction of 10% is used as the best estimate achievable.

The OC_SAMA106.caf fault tree, which was developed directly from OC-LEV2.caf, was used to model this SAMA. The SLSEALLOCA basic event was lowered 10% from 5.0E-2 to 4.5E-2 per demand. The basic event was also added under gate SL1 to allow the improvement in non-SBO cases.

The results from this case indicate a 0.7 percent reduction in CDF (CDF _{new} = 1.04E-5 per year)
A further breakdown of this information is provided below according to release category.

			Release Category								
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	_н/і	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.04E-05	2.69E-06	3.34E-06	1.96E-07	9.88E-07	1.66E-06	1.67E-09	5.42E-07	7.83E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.58E+01	6.73E-02	1.34E+01	2.90E-02	5.72E+00	6.95E+00	5.90E-03	4.30E+00	3.28E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	1.17E+05	2.67E+01	3.95E+04	2.37E+01	1.89E+04	2.10E+04	1.61E+01	2.04E+04	8.54E+03	7.91E+03	1.17E+03

SAMA 106 PRA and MACCS Results By Release Category

The cost of implementation for this SAMA is estimated to be \$50,000 because it is limited to procedure changes.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

. 1

	SAMA Number 106 Net Value										
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value							
\$4,462,000	\$4,428,000	\$34,000	\$50,000	-\$16,000							
				· • *							

(1) Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, the net value is negative and this enhancement is not cost beneficial based on the SAMA methodology.

. . . .

.

F.6.21 SAMA 107: REDUCE POTENTIAL FOR LOSS OF CST INVENTORY FOLLOWING LOSS OF INSTRUMENT AIR

SAMA 107 is to modify the spill valve air supply to be fitted with air accumulators. Currently, the hotwell makeup valves fail open given loss of instrument air. In order to preserve CST inventory, operators must manually close the spill valves. Addition of an air accumulator for this function would improve reliability.

The OC_SAMA107.caf fault tree, which was developed directly from OC-LEV2.caf, was used to model this SAMA. The OH-DRAINCST basic event was lowered from 1.0E-1 to 1.0E-3 per demand. This conservatively captures the reliability of the new accumulators as well as the operator action that would still be necessary for longer term loss of instrument air scenarios.

The results from this case indicate a 0.1 percent reduction in CDF (CDF_{new}= 1.05E-5 per year). A further breakdown of this information is provided below according to release category.

			Release Category								
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	вос
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.05E-05	2.70E-06	3.38E-06	1.96E-07	9.99E-07	1.64E-06	1.67E-09	5.48E-07	7.85E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.60E+01	6.76E-02	1.36E+01	2.90E-02	5.79E+00	6.91E+00	5.90E-03	4.34E+00	3.29E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	1.18E+05	2.68E+01	3.99E+04	2.37E+01	1.91E+04	2.09E+04	1.61E+01	2.06E+04	8.56E+03	7.91E+03	1.17E+03

SAMA 107 PRA and MACCS Results By Release Category

The cost of implementation for this SAMA is estimated to be \$150,000 for installation of air accumulators.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

	S.	AMA Number 107 Ne	et Value	
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value
\$4,462,000	\$4,462,000	\$0	\$150,000	-\$150,000

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, the net value is negative and this enhancement is not cost beneficial based on the SAMA methodology.

F.6.22 SAMA 108: REDUCE FUEL ZONE LEVEL INSTRUMENT ERROR BAND

SAMA 108 is to relocate reference leg instrument penetration closer to TAF and recalibrate. Channels A and B have a range of -144" to 180" and Channels C and D have a range of -150" to 180". Channels A and B have an error band of +20" to -40" and Channels C and D have a no error band specified in the available documents. This error band (i.e., -5 feet) can increase the likelihood that operators lower water level too low during ATWS mitigation.

The potential for operators to lower water level too low in an ATWS is modeled in the basic events shown in the table, below. The HEPs for these actions were reviewed and the table, below, also shows the values applicable if the SAMA is implemented. For this evaluation, the cause based cognitive error and the execution error were assumed zero, should the proposal be implemented. This is optimistic with respect to supporting the modification.

Case	Designator	Description	Base Failure Probability	Failure Probability if Fuel Zone Error Band is Reduced
A	OH-AT-LVL-COND	Operator controls level with condensate to avoid inadequate core cooling.	2.1E-2	1.3E-2
В	OH-AT-LVL-FPS	Operator controls level with FPS or CS to avoid inadequate core cooling.	0.15	0.14

The fuel zone water level instruments also play a role in other operator actions. These primarily include blowdown and transition to SAGs. For blowdown, the main impact on the PRA model relates to allowing low pressure injection success. Once RPV level drops below 61", EOPs include direction to lower RPV pressure as necessary to allow low pressure systems to inject. Further guidance is provided to blowdown at 0" (TAF) if any alternate system is running. If no systems are available, blowdown is directed at

-20". A large error band can impact the actual RPV level wherein these actions occur however, because operators are directed to lower RPV pressure starting at 61", there is little significance for cases with low pressure injection systems available and no additional model changes were made.

With no systems capable of injection, the blowdown will not play a significant role in core protection since no makeup water is available. Also, since water level would, even with a large error band, be significantly above BAF, there is little impact on high pressure core melt type scenarios. No model changes were required for this scenario.

The transition to SAGs occurs when water level drops below –20". A large error band could delay this transition but the SAGs do not provide additional mitigation actions except containment flooding. Containment flooding is not credited to prevent core damage and would be primarily aimed at mitigating releases. Since the direction would occur well above BAF, even with a large instrument error, severe accident mitigation alternatives are not impacted and no model changes are necessary.

The results from this case indicate a very small benefit, which is on the order of 1.3E-9/per year.

The cost of implementation for this SAMA is expected to be on the order of \$500,000 as significant modification of instrument piping and instrumentation would be necessary.

Considering costs and benefits, this item is not considered cost-beneficial.

F.6.23 SAMA 109: PORTABLE DC BATTERY CHARGER TO PRESERVE IC AND EMRV OPERABILITY ALONG WITH ADEQUATE INSTRUMENTATION

SAMA 109 is to provide portable battery chargers capable of supplying 125V DC buses. This would provide a significant benefit in station blackout and similar sequences where battery capacity determines the time window for operator response. The longer the time window for AC power recovery, the higher the success probability.

Loss of offsite power (LOOP) and station blackout (SBO) scenarios are significant contributors to most nuclear plant PRAs, including Oyster Creek. One of the most significant determining factors to risk in such scenarios is the amount of time available for AC power recovery. Onsite batteries provide DC power for approximately 3 to 8 hours of useful capacity, depending on the electrical division relied upon. Extending this time is a significant contributor to risk reduction, particularly for LOOP events caused by severe weather. A means of providing battery charging, independent of installed capability, provides extended DC capability and allows for mitigation of a much wider spectrum of LOOP/SBO events. The alignment of a relatively small, self contained, engine-driven charging system would provide this benefit.

Several plants, including Monticello, Dresden, Susquehanna, and Nine Mile Point Unit 1, have previously identified the potential benefit of a small engine-driven charger that could be aligned to support the DC system, if necessary. The system would be a small, fairly off-the-shelf generator that operates on diesel or gasoline fuel. Development of a location suitable for operation and a means of connecting to the safety related batteries, via clamps or other terminations, would be the issues relating to currently installed equipment.

For the types of reasons discussed above, a number of industry SAMAs relate to DC power. The industry SAMAs tend to relate to more reliable or more capable DC systems. It was noted that the portable charger would, more feasibly, provide a similar benefit to many of the industry SAMAs such as providing additional batteries or alternative power sources such as fuel cells. Other industry SAMAs involved additional diesel generators or other sources of AC Power. Such systems would address LOOP/SBO risk but considering the cost of such systems, the currently installed combustion turbines, and the lower cost of mitigating LOOP/SBO risk using a portable engine-driven charger, these were not considered further.

A number of industry SAMAs have benefits which are judged to be offset or subsumed by implementation of an effective portable DC battery charger. Recognizing the feasibility of a small, simple engine-powered charger, these SAMAs were subsumed into the engine-driven charger SAMA, SAMA 109.

The OC-SAMA109.caf fault tree, which was developed directly from OC-EV2.caf, was used to model this SAMA.

The station blackout model includes an operator action, OH-IC-SBO that involves operators using plant equipment after DC batteries were depleted. Logic wherein this basic event applies requires a situation where one Division of the ICs can be effective in the long term (i.e., no seal LOCA, no stuck open EMRVs, etc.). The loss of the IC heat removal capability is judged significant and this pathway is not credited for this proposed SAMA.

The portable charger can also assist in the additional mitigation of SBO-LOCA situations (i.e., maintain EMRVs and instrumentation for fire protection water injection to RPV as a success

Environmental Report Appendix F Severe Accident Mitigation Alternatives

path). The proposed SAMA can provide extended DC support to mitigate non-LOCA loss of AC cases. In such cases, the IC is capable of removing decay heat over the long term. Thus, a basic event has been created to model the portable charger. This basic event is linked in the model so that it is ANDed with basic event OH-IC-SBO. It is assumed to benefit only non-LOCA loss of AC scenarios. The new basic event, CHGR-SAMA109 was set equal to 0.1 and represents the portable charger equipment as well as the operator actions necessary to align it.

The results from this case indicate a 15.6 percent reduction in CDF (CDF_{new}= 8.85E-6 per year). A further breakdown of this information is provided below according to release category.

<u> </u>			Release Category										
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC		
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08		
SAMA Freq. (per yr.)	8.85E-06	2.60E-06	2.41E-06	7.40E-08	9.86E-07	1.46E-06	1.67E-09	5.42E-07	5.53E-07	2.10E-07	3.23E-08		
SAMA Dose-Risk (Person Rem/yr.)	3.02E+01	6.50E-02	9.70E+00	1.10E-02	5.71E+00	6.15E+00	5.90E-03	4.29E+00	2.32E+00	1.58E+00	4.01E-01		
SAMA OECR (\$/yr.)	1.01E+05	2.57E+01	2.85E+04	8.96E+00	1.88E+04	1.86E+04	1.61E+01	2.04E+04	6.03E+03	7.91E+03	1.17E+03		

SAMA 109 PRA and MACCS Results By Release Category

The cost of this SAMA was estimated in the Monticello SAMA evaluation [F-13] to be \$75,000. This estimate, which is assumed to include necessary procedure changes, may be unrealistically low but is judged reasonable for Oyster Creek for initial consideration of the SAMA for further investigation.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

SAMA Number 109 Net Value									
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value					
\$4,462,000	\$3,788,000	\$674,000	\$75,000	\$599,000					

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is less than the averted cost-risk for this SAMA, the net value is \$599,000 and this enhancement is cost beneficial based on the SAMA methodology.

F.6.24 SAMA 110: DELETE HIGH DRYWELL PRESSURE SIGNAL FROM SDC ISOLATION

The purpose of this insight is to identify the desirability of removing the SDC interlock on high drywell pressure to increase the flexibility of SDC system use.

The model used for SAMA 89 is considered applicable for this proposal.

The cost of implementation for this SAMA is estimated to be \$75,000.

The results from this case indicate a very small reduction in CDF (<1E-10/yr) such that costbenefit considerations do not support the modification.

F.6.25 SAMA 111: PROVIDE ALTERNATE DRYWELL SPRAY INJECTION SOURCE

SAMA 111 considers possible alternatives for alternate sources of drywell spray supply, which may include:

- ESW cross tie
- SW cross tie
- Diesel Fire pump cross tie

The competing risk is that the raw water might clog the containment spray nozzles or a radionuclide release pathway to the environment may be opened.

The OC_SAMA111.caf fault tree, which was developed directly from OC-LEV2.caf was used to model this SAMA. To model this proposal, the fire protection node, FP, was "ANDed" under the gates for each set of containment spray pumps (Gates CCG01MAG and CCG02MED). This allows fire protection water to be redundant to the containment spray pumps.

The system manager has estimated that the cost for this improvement is \$500,000.

Drywell sprays have a minimal impact on the CDF risk metric. This impact is manifested in mitigating vapor suppression failures.

The Level 2 is significantly impacted by drywell sprays if available because it provides an effective containment boundary protection and release mitigator. However, failures of containment spray are dominated by injection valve power failures that are not compensated for by the SAMA.

The results from this case indicate a very small reduction in CDF (3.6E-10/yr). This is due partially to dominance by operator action associated with EOP directed actions and the drywell spray initiation curve. When compared to four (4) containment spray pump reliability or four (4) containment spray pumps plus an additional pump, operator reliability is limiting. Therefore, this SAMA is not considered cost-beneficial.

Therefore, based on the competing risk and the lack of a cost beneficial assessment. This change is not considered further.

F.6.26 SAMA 112: INTAKE STRUCTURE

SAMA 112 addresses the insight that there are potential safety beneficial effects associated with a pro-active plan to ensure high reliability of the cooling water intake structure and its supply to support raw water systems into the plant.

This proposal was modeled by reducing the loss of intake structure initiating event (LOIS) from 5.12E-3/yr to 1E-3/yr, a factor of approximately five (5).

The results from this case indicate a 0.8 percent reduction in CDF (CDF_{new} =1.04E-5 per year. A further breakdown of this information is provided below according to release category.

			Release Category									
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	н/і	H/L	BOC	
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08	
SAMA Freq. (per yr.)	1.04E-05	2.65E-06	3.37E-06	1.93E-07	9.94E-07	1.65E-06	1.67E-09	5.47E-07	7.86E-07	2.10E-07	3.23E-08	
SAMA Dose-Risk (Person Rem/yr.)	3.59E+01	6.63E-02	1.35E+01	2.86E-02	5.76E+00	6.94E+00	5.90E-03	4.33E+00	3.29E+00	1.58E+00	4.01E-01	
SAMA OECR (\$/yr.)	1.18E+05	2.63E+01	3.97E+04	2.34E+01	1.90E+04	2.10E+04	1.61E+01	2.06E+04	8.56E+03	7.91E+03	1.17E+03	

SAMA 112 PRA and MACCS Results By Release Category

The cost of initiating and administering this SAMA is judged to be \$1,000,000. This estimate includes program initiatives such as intake canal surveillance, active programs to combat mussel intrusion, "grassing", and other debris effects as well as trending of data by a system manager.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value					
\$4,462,000	\$4,454,000	\$8,000	\$1,000,000	-\$992,000					

SAMA Number 112 Net Value

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.27 SAMA 124: REINFORCEMENT BLOCK WALL 53

Block Wall 53 has a HCLPF estimated in the Oyster Creek IPEEE of 0.27g. Failure of this block wall can cause loss of 125 VDC. This alternative considers reinforcement of Block Wall 53. The following risk assessment for this SAMA item conservatively assumes for the purpose of this analysis that the reinforced wall after SAMA implementation is not susceptible to seismic-induced failure (i.e., the probability of seismic-induced failure of the reinforced wall is 0.0 for all seismic events).

F.6.27.1 <u>Two Approaches</u>

The updated seismic PRA referenced in the NRC SER on IPEEE [F-36] has a risk profile dominated by large seismic induced failures of the Turbine Building. This failure mode was added after submittal of the original IPEEE in 1993.

Because of the large uncertainty associated with the seismic analysis and because of potential "masking" effects related to assuming the entire Turbine Building fails in the updated seismic PRA referenced in the SER, two approaches are used here to assess the potential averted cost risk and net value of reinforcing the block wall. These two approaches are:

Approach 1: Use the latest seismic PRA results submitted as part of IPEEE RAIs and referenced in the NRC SER.

Approach 2: Use insights from the original IPEEE and the estimated impacts of the block wall on CDF to provide an additional perspective on the net value.

F.6.27.2 Approach 1

In the original IPEEE assessment, Block Wall 53 was a significant contributor (i.e., it was included in the third highest seismic accident sequence). However, in the revised model it is much less significant and does not appear in the Top 10 sequences. As can be seen in Table F-2 and F-3, the block wall does not show up in the Top 10 Seismic contributors and has a Fussell-Vesely of less than 0.034. A conservative estimate of the maximum benefit possible for block wall improvement would be significantly less than 1.6E-7/yr [4.7E-6*0.034)]. This represents a small residual risk and this SAMA is not evaluated further.

More significant seismic failures include Turbine Building failure, Reactor Building failure, and switchgear room cooling fan failure. Significantly improving the seismic capability of the Turbine Building and Reactor Building is judged to require expenditure beyond the maximum averted cost. Recovery of the switchgear room cooling fans is not credited in the seismic model. Mitigation by opening doors and using portable fans is currently proceduralized and no further improvement has been identified.

F.6.27.3 Approach 2

Base Seismic CDF and Release Risk Profile

The current Oyster Creek PRA model does not include seismic initiating events. However, the Oyster Creek IPEEE evaluation [F-22] includes a Level 1 seismic model that can be used to estimate the potential benefit of this proposed modification. The base seismic CDF calculated

by the Oyster Creek seismic IPEEE analysis is 3.63E-6/yr. In the interaction with the NRC on the IPEEE submittal, changes to the seismic analysis added catastrophic failure modes associated with the Reactor Building and Turbine Building failures which added approximately 2E-6/yr to the seismic CDF. A total revised seismic CDF of 4.7E-6/yr was quoted in the RAI responses and the NRC SER. The block wall impact on this incremental change is considered negligible. Therefore, for the Approach #2 SAMA evaluation, the original seismic CDF of 3.6E-6/yr is used as the "base" case for the sole purpose of calculating the change in risk when the block wall is reinforced. Based on review of the top 20 dominant seismic sequences (representing approximately 50% of the seismic CDF), as documented in the Oyster Creek IPEEE submittal report, the breakdown of the base seismic CDF as a function of core damage accident type is as follows:

- Class IA(Late): 15%
- Class IB(Early): 80%
- Class IIIB: 5%

This has removed the seismic induced catastrophic failure of the Turbine Building and Reactor Building. This is considered appropriate for the delta risk assessment of the block wall.

The Oyster Creek seismic IPEEE analysis does not include a Level 2 analysis; however, a reasonable approximation of release frequency distribution can be made, as follows:

- Use the above seismic CDF accident class distributions for the entire seismic CDF.
- Apply the release category probabilities as a function of accident class obtained from the Oyster Creek internal events PRA, except for one modification. Seismic IB scenarios involve switchyard structural failures that are assumed not recoverable within the PRA mission time. As the internal events Class IBE (Station Blackout) credits AC power recovery (which is inappropriate for Class IB seismic scenarios), the internal events Class ID release distribution is applied to the seismic Class IBE scenarios. The internal events Class ID scenarios reasonably simulate seismic Class IBE scenarios in that recovery of injection in the internal events Level 2 for Class ID scenarios is negligible.
- Adjust release category timings to reflect potential inability to evacuate by making the category times shorter by one category for each release state (i.e., H/I is added to H/E, H/L becomes new H/I, etc.). This accounts for the negative impacts on offsite mitigation efforts (e.g., evacuation) caused by seismic effects on the surrounding infrastructures (e.g., roads, bridges).

Using this approach, the release frequency as a function of accident class for the Oyster Creek base seismic risk profile is as follows:

Environmental Report Appendix F Severe Accident Mitigation Alternatives

	Oyster Creek Seismic Base Release Profile Frequencies (/yr)										
Accident Class	CDF	Intact	L-LL/E, L-LL/I	L-LL/L	- M/E	M/I	M/L	H/E	нл	H/L	вос
IA (Late)	5.45E-7	1.07E-08	3.57E-07	6.91E-08	0.00E+00	1.64E-08	0.00E+00	0.00E+00	9.10E-08	0.00E+00	0.00E+00
ID	2.90E-6	1.77E-06	9.95E-08	1.24E-08	9.73E-07	0.00E+00	0.00E+00	4.95E-08	0.00E+00	0.00E+00	0.00E+00
IIIB	1.82E-7	1.26E-07	8.75E-10	6.59E-11	6.65E-09	4.42E-09	1.36E-10	9.67E-09	1.68E-08	1.75E-08	0.00E+00
Totals	3.63E-6	1.90E-06	4.57E-07	8.16E-08	9.79E-07	2.09E-08	1.36E-10	5.92E-08	1.08E-07	1.75E-08	0.00E+00

Seismic CDF and Release Risk Profile for SAMA #124

Based on review of the Oyster Creek seismic IPEEE results, sequences with seismic-induced failure of Block Wall 53 represent approximately 15% of the base seismic CDF. Therefore, reinforcement of Block Wall 53 will result in reducing the base seismic CDF by approximately 15% to 3.09E-6/yr (e.g., approximately 5.4E-7/yr). This reduction is apportioned to each of the three seismic accident classes using the same ratios as the base seismic results (i.e., 15%, 80% and 15%). The resulting release frequency as a function of accident class for this SAMA item is as follows:

Release Profile Frequencies (/yr) for SAMA #124

Accident Class	CDF	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	вос
IA (Late)	4.63E-7	9.11E-09	3.03E-07	5.87E-08	0.00E+00	1.40E-08	0.00E+00	0.00E+00	7.73E-08	0.00E+00	0.00E+00
ID	2.47E-6	1.50E-06	8.47E-08	1.05E-08	8.29E-07	0.00E+00	0.00E+00	4.21E-08	0.00E+00	0.00E+00	0.00E+00
IIIB	1.54E-7	1.06E-07	7.40E-10	5.58E-11	5.62E-09	3.74E-09	1.15E-10	8.18E-09	1.42E-08	1.48E-08	0.00E+00
Totals:	3.09E-6	1.62E-06	3.89E-07	6.93E-08	8.34E-07	1.77E-08	1.15E-10	5.03E-08	9.15E-08	1.48E-08	0.00E+00

Cost-Benefit Calculation for SAMA #124

Using the above seismic risk profiles, and the dose and economic information presented earlier in this report, the economic cost risk for the base seismic risk profile and the SAMA #124 risk profiles are summarized below:

Oyster Creek Seismic Base OECR Results

Risk Metric	CDF	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Freq. (/yr)	3.63E-6	1.90E-06	4.57E-07	8.16E-08	9.79E-07	2.09E-08	1.36E-10	5.92E-08	1.08E-07	1.75E-08	0.00E+00
Dose-Risk (person rem/yr)	8.71E+00	4.76E-02	1.84E+00	1.21E-02	5.67E+00	8.76E-02	4.80E-04	4.69E-01	4.52E-01	1.31E-01	0.00E+00
OECR (\$/yr)	2.85E+04	1.89E+01	5.40E+03	9.87E+00	1.87E+04	2.65E+02	1.31E+00	2.23E+03	1.17E+03	6.58E+02	0.00E+00

SAMA #124 OECR Results

Risk Metric	CDF_	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/1	M/L	H/E	H/I	H/L	BOC
Freq. (/yr)	3.09E-6	1.62E-06	3.89E-07	6.93E-08	8.34E-07	1.77E-08	1.15E-10	5.03E-08	9.15E-08	1.48E-08	0.00E+00
Dose-Risk (person rem/yr)	7.41E+00	4.05E-02	1.56E+00	1.03E-02	4.83E+00	7.44E-02	4.06E-04	3.99E-01	3.83E-01	1.11E-01	0.00E+00
OECR (\$/yr)	2.42E+04	1.61E+01	4.59E+03	8.39E+00	1.59E+04	2.25E+02	1.11E+00	1.90E+03	9.98E+02	5.57E+02	0.00E+00

The cost of implementation for this SAMA is estimated to be \$150,000.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

		SAMA #124 Net V	alue	1. 1. A.
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site) ⁽²⁾	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value
\$559,000	\$475,000	\$84,000	\$150,000	-\$66,000

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

⁽²⁾ This includes only the seismic contribution to risk as that is the only portion of risk considered impacted by this SAMA.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.27.4 Summary

Both approaches outlined above demonstrate that the Block Wall 53 reinforcement reduces seismic risk, but the net value is determined to be not cost beneficial. The remainder of the SAMA analysis retains Approach 2 estimates of the net value for use in comparison tables and sensitivity analysis.

. .

F.6.28 SAMA 125: REDUCE FIRE IMPACT IN HIGHER RISK FIRE AREAS

Based upon the IPEEE results for Oyster Creek, two fire areas are identified as potentially dominant contributors to the fire induced risk profile. These two areas are:

- The cable spreading room
- The 480V AC "A" switchgear compartment

The following information is noted pertaining to the cable spreading room:

- The cable spreading room contains the two RPS M/G sets. Both M/G sets have grease-lubricated bearings and have a 'radiant' energy shield above them. As such, they do not represent a significant fire threat.
- There are a number of electrical cabinets within the CSR.
- The remainder of the CSR is judged relatively benign with respect to fires. The cable trays are provided with an 'in-tray' suppression system. Therefore, if any one tray is the starting point for a fire, there is an opportunity for it to be suppressed before another tray is damaged.
- There are a few specific conduits that are provided with radiant energy shield boards.

The following information is noted pertaining to the 480V AC "A" switchgear room:

- Two important Vital 480 VAC MCCs or their cable are in this room.
- There are liquid filled transformers in this room which create a potential fire hazard.

The current Oyster Creek internal events PRA does not include fire initiating events. The IPEEE evaluation, while conservative, can be used to provide some understanding of the potential for risk reduction. In order to quantify this potential, the fire impacts for the two areas (cited as dominant in the IPEEE) are incorporated into the updated internal events PRA for the purposes of SAMA evaluation only. The additional modeling was augmented by insights developed from preliminary analysis performed as part of preparation for a formal Fire PRA Update. The IPEEE information as well as the additional insights are discussed below.

The following initiating events and their associated initiating event frequencies are added to the SAMA PRA model:

- %FIRE41 Fire in Cable Spreading Area, General Area (2.22E-5/yr)
- %FIRE42 Fire in Cable Spreading Area, Panel DC-E Area (8.0E-4/yr)
- %FIRE43 Fire in Cable Spreading Area, Suppressed (1.03E-2/yr)
- %FIRE6A1 Fire in 480 VAC "A" Area, General Area (7.72E-5/yr)

- %FIRE6A2 Fire in 480 VAC "A" Area, USS 1A2 (1.47E-3/yr)
- %FIRE6A3 Fire in 480 VAC "A" Area, Hallway, Suppressed (2.19E-3/yr)
- %FIRE6A3B Fire in 480 VAC "A" Relay Cabinet, Suppressed (4.4E-4/yr)

These initiators for both dominant areas are added to the updated internal events model to provide an integrated picture of overall plant risk. Also, it should be noted that these initiating event frequencies are modified from the values reported in the IPEEE. The modifications resulted from the incorporation of updated generic fire frequency values from EPRI 1003111. Partitioning of the updated frequency values resulted in the altering of the fire frequency assigned to each electrical cabinet in the 'A' Switchgear Room. In addition, a recent walkdown associated with the Fire PRA Update effort determined that some fixed fire sources cannot physically result in fires which spread beyond their immediate location. The following list shows the fire initiating events whose frequencies are modified along with the corresponding values used in the IPEEE:

- %FIRE41 Fire in Cable Spreading Area, General Area (IPEEE: 1.23E-4/yr) the IPEEE value was revised to the 2.22E-05/yr value noted above based on an updated walkdown and analysis using EPRI 1003111.
- %FIRE6A1 Fire in 480 VAC "A" Area, General Area (IPEEE: 2.09E-4/yr) the IPEEE value was based the on assumption that any fire originating in the switchgear room was capable of causing area-wide damage if the suppression system failed. The modified treatment for this case included only the Load Center and its associated transformer. The modified fire frequency multiplied by failure probability of the automatic fire suppression system resulted in the 7.72E-05/yr value noted above.
- %FIRE6A2 Fire in 480 VAC "A" Area, USS 1A2 (IPEEE: 1.34E-3/yr) the IPEEE value was based on an assumed partition factor of 1/3. The updated treatment applies a more rigorous development and resulted in a minor change in fire frequency.
- %FIRE6A3 Fire in 480 VAC "A" Area, Hallway, Suppressed (IPEEE: 2.63E-3/yr) – the IPEEE value was based on an assumed partition factor of 2/3. Fire case 6A3 was broken into two sub-cases due to the insight that the relay cabinets are distinct fire locations. The updated treatment and the split of this case into two sub-cases (i.e., %FIRE6A3, %FIRE6A3B) resulted in a reduction in the fire frequency.

All fire initiators are added to the following gates in order to invoke initiating event logic in the PRA logic model:

- TRAN-MULT-EMRV "TRANSIENT MULTI-ERV INITIATORS"
- TRAN-NON-RT "TRANS INITS OTHER THAN RTM OR RT"
- GTR-NONISO "NON-ISOLATION TRANSIENT EVENT"

• IE-GEN-TRANS – "RPV TRANSIENT INITIATORS"

Table F-17 shows the systemic impact of each initiating event.

After quantifying the model modified to incorporate fires, the baseline Offsite Economic Cost Risk (OECR) is as follows:

PRA Results Incorporating Dominant Fire Contributors By	Release	Category
---	---------	----------

		Release Category									
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.) (Fire Incl.)	3.16E-05	5.77E-06	1.51E-05	2.49E-06	1.17E-06	2.59E-06	1.68E-09	5.98E-07	3.66E-06	2.11E-07	3.31E-08
SAMA Dose-Risk (Person Rem/yr.)	1.01E+02	1.44E-01	6.07E+01	3.69E-01	6.77E+00	1.09E+01	5.93E-03	4.74E+00	1.53E+01	1.58E+00	4.10E-01
OECR (\$/yr.)	3.05E+05	5.72E+01	_1.78E+05	3.01E+02	2.23E+04	3.29E+04	1.62E+01	2.25E+04	3.99E+04	7.93E+03	1.20E+03

These results for the modified base PRA reflect incorporation of the dominant fire risk contributors and show that the total release frequency increases by a factor of 3.0. The Dose Risk (person rem/yr) increases by a factor of 2.8. The MACCS2 calculated OECR increases by a factor of 2.6.

A difference in this probabilistic assessment from the IPEEE analysis is due to a newly quantified failure mode wherein a fire in 480VAC "A" switchgear room not only fails bus 1A2 but also 1B2 because the bus cross-tie breaker is in the "A" area and likely would not prevent a short from propagating to bus 1B2. The results are also impacted by the event sequence, system model, and data updates discussed in Section F.2.1.

After reviewing the cutsets from the revised model, it is apparent that a number of cutsets could be mitigated by other SAMAs. In particular, a number of cutsets are related to AC and DC power. SAMA 109 deals with AC and DC power issues, and is cost-beneficial independent of fire scenarios. Therefore, the fire modified model was further modified to incorporate SAMA 109. The results of this quantification are shown in the table noted SAMA 125A, below.

		Release Category									
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I_	H/L	BOC
Baseline Freq. (per yr.)	3.16E-05	5.77E-06	1.51E-05	2.49E-06	1.17E-06	2.59E-06	1.68E-09	5.98E-07	3.66E-06	2.11E-07	3.31E-08
SAMA Freq. (per yr.)	1.47E-05	5.36E-06	4.11E-06	4.29E-07	1.16E-06	1.92E-06	1.67E-09	5.91E-07	8.71E-07	2.10E-07	3.31E-08
SAMA Dose-Risk (Person Rem/yr.)	4.18E+01	1.34E-01	1.65E+01	6.35E-02	6.72E+00	8.06E+00	5.90E-03	4.69E+00	3.65E+00	1.58E+00	4.10E-01
SAMA OECR (\$/yr.)	1.36E+05	5.31E+01	4.85E+04	5.19E+01	2.22E+04	2.44E+04	1.61E+01	2.23E+04	9.49E+03	7.90E+03	1.20E+03

SAMA 125A PRA and MACCS Results By Release Category (SAMA 109 Implemented)

The cost of initiating and administering SAMA 109 has been determined to be cost-beneficial based on analysis with the internal events only in Section F.6.23, non-fire risk reduction. Further risk reduction would require consideration of additional options. The most obvious additional option would be to add a circuit breaker to bus 1B2 to protect the bus from cross-tie cable shorts initiated by fires in the 480 VAC "A" switchgear room. This plant modification would reduce basic event "FIRE-SHORT" from 0.2 to approximately 3E-4 (circuit breaker fails to open on demand). The model developed for case SAMA 125A was modified to incorporate the new cross-tie breaker on Bus 1B2. The SAMA 125B case, below, includes the benefit of such an improvement.

SAMA 125B PRA and MACCS Results By Release Category											
		Release Category									
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Freq. After SAMA 125A ⁽¹⁾ is Implemented (per yr.) (Fire, C/B	1.47E-05	5.36E-06	4.11E-06	4.29E-07	1.16E-06	1.92E-06	1.67E-09	5.91E-07	8.71E-07	2.10E-07	3.31E-08
SAMA Incl.) ⁽²⁾ SAMA 125B Freq. (per yr.)	1.24E-05	4.68E-06	3.06E-06	2.19E-07	1.13E-06	1.88E-06	1.67E-09	5.80E-07	.6.38E-07	2.10E-07	3.31E-08
SAMA Dose-Risk (Person Rem/yr.)	3.62E+01	1.17E-01	1.23E+01	3.24E-02	6.54E+00	7.90E+00	5.90E-03	4.60E+00	2.67E+00	1.58E+00	4.10E-01
SAMA OECR (\$/yr.)	1.20E+05	4.64E+01	3.61E+04	2.65E+01	2.16E+04	2.39E+04	1.61E+01	2.19E+04	6.95E+03	7.90E+03	1.20E+03

⁽¹⁾ Same as SAMA 109 is implemented.

⁽²⁾ Circuit breaker added to the 480V AC switchgear to preclude propagation of shorts induced by fire.

The cost of SAMA 125B is estimated to be \$100,000. The result of the net value calculation for this option is provided in the following table:

SAMA Number 125B Net Value									
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (125A)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value					
\$2,624,000	\$2,291,000	\$333,000	\$100,000	\$233,000					

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Cutsets resulting from this quantification were reviewed and it was found that loss of IC cutsets dominate the residual fire risk reflected in the Case 125B results. These cutsets occur from random IC failures as well as seal LOCAs and stuck open relief valves. A potential plant modification is possible to allow credit for depressurization and Core Spray as a backup to the Isolation Condenser. Such a modification would require the relocation of the EMRV related cables, circuitry, and components (relays) in this room to a different plant location. In addition, other modifications would be required to ensure that at least one train of Core Spray remains
Environmental Report Appendix F Severe Accident Mitigation Alternatives

unaffected by the postulated fire event. The extensive changes that would be needed would represent a significant plant modification. In addition, the potential adverse impact to adjoining areas may require fire wrapping as a means of risk mitigation and to maintain compliance with the existing NRC Regulations related to Fire Protection. A detailed scoping and estimate for such a modification was not prepared, but based on the number of components affected, an estimated cost in excess of \$600,000 is anticipated. Also, even if RPV injection could be provided, containment heat removal must also be addressed. This would mean protecting containment spray cabling or providing the manual containment venting capability outlined in SAMA 84 (\$150,000). A conservative estimate for the cost of further risk reduction is therefore \$750,000 (\$600,000 + \$150,000). In order to explore the potential for risk-reduction in this area, the model developed for the SAMA 125B case was further modified to essentially eliminate fire risk due to these dominant contributors. SAMA 125C represents the case where SAMA 109 and SAMA 125B are implemented and an additional means of eliminating all fire risk due to these dominant fire risk contributors is implemented.

SAMA 125C PRA and MACCS Results By Release Category

		Release Category									
Calculation Description	Total	Intact	L-LL/E, L-LL/I	_L-LL/L	M/E	_M/I	M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.) (Fire, C/B SAMA, SAMA 109 Incl.)	1.24E-05	4.68E-06	3.06E-06	2.19E-07	1.13E-06	1.88E-06	1.67E-09	5.80E-07	6.38E-07	2.10E-07	3.31E-08
SAMA Freq. (per yr.)	8.85E-06	2.60E-06	2.41E-06	7.40E-08	9.86E-07	1.46E-06	1.67E-09	5.42E-07	5.53E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.02E+01	6.50E-02	9.69E+00	1.10E-02	5.71E+00	6.13E+00	5.90E-03	4.30E+00	2.32E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	1.01E+05	2.58E+01	2.84E+04	8.95E+00	1.88E+04	1.85E+04	1.61E+01	2.04E+04	6.03E+03	7.90E+03	1.17E+03

The results of this calculation show the maximum benefit that can be achieved if risk from these fires is completely eliminated. This is summarized in the following table:

Base Case: Cost-Risk ⁽¹⁾ for	Cost-Risk for Oyster Creek			_					
Oyster Creek (125B)	With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value					
\$2,291,000	\$1,894,000	\$397,000	\$750,000	-\$353,000					

SAMA Number 125C Net Value

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Therefore, it has been determined that implementation of SAMA 109 along with installation of a circuit breaker on the 480 VAC Bus 1B2 cross-tie supply are the cost-beneficial approaches to fire risk reduction. As such, the additional circuit breaker for Bus 1B2 is assigned as SAMA 125B. Its net value is defined by case 125B, above.

Fire Initiator(s)	Fire Impact	Compartment	Model Changes
	125 VDC Division B	CSR	Initiator added directly under "DB" gate
	Service Water	CSR	Initiator added directly under "SW" gate
	Circulating Water	CSR	Initiator added directly under "CW" gate
	RPS Actuation-Drywell	CSR	Initiator added directly under "DP" gate
	Pressure		
	RPS Actuation-Reactor	CSR	Initiator added directly under "PR" gate. Recirc
	Pressure		pump trip logic related to Isolation Condenser
			modified slightly so that fire induced loss of reacto
6FIRE41			pressure actuation of recirc pump trip does not
			directly fail ICs without opportunity for manual trip.
	RPS Actuation-Reactor	CSR	Initiator added directly under "RL" gate
	l evel	0011	
	MSIV Isolation	CSR	Initiator added directly under "MEG01MEC" gate
			(Failure Of Automatic Actuation).
	Condensate Pumps	CSR	Initiator added directly under "CP" gate
	Operator ATWS	CSR	Initiator added directly "ORed" with OH-LVL-ERLY
	Actions		OH-LVL-LATE, OH-LVL-TT basic events.
	Control Rod Drive	CSR	Initiator added directly under "CP" gate
	(RPV Injection)		
	Containment Spray	CSR	Initiator added directly under "CC" gate
	Core Spray	CSR	Initiator added directly under "CS" gate
	Containment Venting	CSR	Initiator added directly under "OV" gate
		000	
	Automatic IC Initiation	CSR	Initiator added directly under "RPAL-FIRE" gate
		000	
	Isolation Condenser	CSR	Initiator added directly under ICGUIMDA gate
	A laster Condenser	000	(Isolation Condenser Train A Failed)
	Isolation Condenser	CSR	Fire fails main CR IC control circuit. Operators
	D ·		LINE AT THE ALL AND A LODIE AND A LODIE AND A LODIE AT THE ALL AND A
- ·		000	(Long Term DC Failure Affects IC B)
	Offsite Power	USR *	Initiator added directly under "EAB", "EBB" gates
	EDG A	USR	initiator added directly under "EC" gate

(

.

.

Fire Initiator(s)	Fire Impact	Compartment	Model Changes
%FIRE41	ADS	CSR	Initiator added directly under "ADG022" gate (ADS
(cont'd)			Support System Failure)
%FIRE42	125 VDC Division B	CSR	Initiator added directly under "DB" gate
	RPS Actuation-Reactor	CSR	Initiator added directly under "PR" gate. Recirc
	Pressure		pump trip logic related to Isolation Condenser
%FIRE43			modified slightly so that fire induced loss of reactor
			pressure actuation of recirc pump trip does not
			directly fail ICs without opportunity for manual trip.
	RPS Actuation-Reactor Level	CSR	Initiator added directly under "RL" gate
	Control Rod Drive (RPV Injection)	CSR	Initiator added directly under "CP" gate
	125 VDC Division B	480V AC "A"	Initiator added directly under "XBGCHA" gate
	(Charging Only)		(Supply From Battery Charger A M-G Set Fails) and "XBGCHB" gate (Supply From Battery Charger B M- G Set Fails.
	Service Water	480V AC "A"	Initiator added directly under "SW" gate
	Circulating Water	480V AC "A"	Initiator added directly under "CW" gate
%FIRE6A1	RPS Actuation-Drywell Pressure	480V AC "A"	Initiator added directly under "DP" gate
	RPS Actuation-Reactor Level	480V AC "A"	Initiator added directly under "RL" gate
	Control Rod Drive (RPV Injection)	480V AC "A"	Initiator added directly under "CP" gate
	Containment Spray	480V AC "A"	Initiator added directly under "CC" gate
	Core Spray	480V AC "A"	Initiator added directly under "CS" gate
	Containment Vent	480V AC "A"	Initiator added directly under "OV" gate
	Isolation Condenser	480V AC "A"	Initiator added directly under "ICG01MDA" gate
	"A"		(Isolation Condenser Train A Failed)
	Isolation Condenser "B"	480V AC "A"	Fire fails main IC control circuit. Operators using 480 VAC control modeled by adding basic event "FIRE-IC-BE" and logic under "ICG075" gate (Long Term DC Failure Affects IC B)

Environmental Report Appendix F Severe Accident Mitigation Alternatives

Table F-17. Summary of Fire Impacts Added to Base Model

Fire Initiator(s)	Fire Impact	Compartment	Model Changes
%FIRE6A1	Shutdown Cooling	480V AC "A"	Initiator added directly under "SD" gate
%FIRE6A1 (cont'd)	Onsite AC Power Distribution	480V AC "A 480V AC "A"	Initiator added directly under SD gate Initiator added directly under "SD gate Initiator added directly under "EH" gate (480 VAC Bus 1A2 Fails). Initiators are also added under "EK" gate (480 VAC Bus 1B2 Fails) and are ANDed with new basic event "FIRE-SHORT" (Recoverable Fire Induced Short). FIRE-SHORT is a newly identified failure mode wherein the cable for the bus cross-tie is located in fire area and can propagate a short to the alternate division. This short is recoverable via operating procedures. A value of 0.2 is used for the new basic event which represents operator action. Operator action requires operators to cut the cross-
	ADS	480V AC "A"	supply breaker. Initiator added directly under "ADG022" gate (ADS
	Circulating Water	480\/ AC "A"	Initiator added directly under "DP" gate
	RPS Actuation-Drywell Pressure	480V AC "A"	Initiator added directly under "RL" gate
%FIRE6A2	RPS Actuation-Reactor	480V AC "A"	Initiator added directly under "RL" gate
	Control Rod Drive (RPV Injection)	480V AC "A"	Initiator added directly under "CP" gate
	Containment Vent	480V AC "A"	Initiator added directly under "OV" gate
	Isolation Condenser "B"	480V AC "A"	Fire fails main IC control circuit. Operators using 480 VAC control modeled by adding basic event "FIRE-IC-BE" and logic under "ICG075" gate (Long Term DC Failure Affects IC B)
	Shutdown Cooling	480V AC "A"	Initiator added directly under "SD" gate
	-		
		· ·	
			· · · · · · · · · · ·

Table F-17. Summary of Fire Impacts Added to Base Model

Fire Initiator(s)	Fire Impact	Compartment	Model Changes
%FIRE6A2	Onsite AC Power	480V AC "A"	Initiator added directly under "EH" gate (480 VAC
(cont'd)	Distribution		Bus 1A2 Fails). Initiators are also added under "EK"
			gate (480 VAC Bus 1B2 Fails) and are ANDed with
			new basic event "FIRE-SHORT" (Recoverable Fire
			failure mode wherein the cable for the bug group tio
			is located in fire area and can propagate a short to
			the alternate division. This short is recoverable via
			operating procedures. A value of 0.2 is used for the
			new basic event which represents operator action.
			Operator action requires operators to cut the cross-
			tie cable, re-insulate the cable, and re-close the
			supply breaker.
	Circulating Water	480V AC "A"	Initiator added directly under "DP" gate
	RPS Actuation-Drywell	480V AC "A"	Initiator added directly under "RL" gate
	Pressure		
	RPS Actuation-Reactor	480V AC "A"	Initiator added directly under "RL" gate
	Level		
%FIRE6A3	Control Rod Drive	480V AC "A"	Initiator added directly under "CP" gate
	(RPV Injection)		
	Containment Sprav	480V AC "A"	Initiator added directly under "CCG02MCA" gate
	(1 Division)		(Containment Spray And ESW System Loop 1
			Failed)
	Containment Vent	480V AC "A"	Initiator added directly under "OV" gate
	Isolation Condenser	480V AC "A"	Initiator added directly under "ICG01MDA" gate
	"A"		(Isolation Condenser Train A Failed)
	Shutdown Cooling	480V AC "A"	Initiator added directly under "SD" gate
	ADS	480V AC "A"	Initiator added directly under "ADG022" gate (ADS
			Support System Failure)
%FIRE6A13B	Core Spray	480V AC "A"	Initiator added directly under "CS" gate

Table F-17. Summary of Fire Impacts Added to Base Model

Environmental Report
Appendix F Severe Accident Mitigation Alternatives

F.6.29 NOT USED

F.6.30 SAMA 127: OPERATOR TRAINING

On-going training on the PRA importance of systems and operator actions is judged to provide an "across-the-board" reduction in operator error probability. Also, training is important to maintain current PRA assessed operator reliability values.

Based on a review of model importance values, providing operators with training on PRA results, including external event insights, is deemed obviously cost-beneficial. It is also clearly cost-beneficial to continue to use PRA importance ranking to assist in prioritizing operator training activities such as simulator exercises.

F.6.31 SAMA 128: IC FOULING

Programs instituted to reduce blockage and fouling of the shell side of the isolation condensers were identified as potentially beneficial in the original IPE analysis.

The PRA model includes two basic events for IC fouling. Basic event HX014NE1AP represents plugging or fouling of IC A and basic event HX014NE1BP represents plugging or fouling of IC B. Model OC-SAMA128.caf, created from OC-LEV2.caf, was adjusted by reducing the IC plugging fouling basic events by an order of magnitude to reflect a significant improvement in reliability. The results from this case indicate a negligible reduction in CDF (i.e., 1E-10/yr). The negligible reduction in CDF results in a negligible cost-risk benefit (i.e., less than \$14,000 using Section F.6.34 for a guide value).

Administering a program such as this is expected to cost at least \$20,000 per year or in excess of \$200,000 present value based on standard amortization tables.

This proposal is clearly not cost beneficial.

F.6.32 SAMA 129: INTERNAL FLOODING PROCEDURE ENHANCEMENTS

SAMA 129 is to improve procedures for responding to internal flooding events.

Improved procedures and training could potentially reduce internal flood related risk; primarily by increasing the likelihood of isolating ruptures before risk significant equipment is affected. To simulate a potential benefit of rapid recovery because of procedures and training, internal flood initiating events were reduced by a factor of two. All initiators, except "Fire Protection Spray of Buses 1A, 1B," were reduced by a factor of two. The fire protection spray initiator was not reduced because it was assumed that damage could occur too quickly for isolation to be effective. A factor of two represents a significant improvement in operator capability that is likely to be achieved only after a considerable commitment to improved training and procedures. Also, it is noted that there is some potential for competing risk in that operator time and attention focused on internal flooding will, by definition, result in diverting operator training from other, potentially higher safety significant activities.

The results from this case indicate a 3.9 percent reduction in CDF (CDF_{new} =1.01E-5 per year). A further breakdown of this information is provided below according to release category.

		Release Category									
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	н/і	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.01E-05	2.42E-06	3.32E-06	1.82E-07	9.69E-07	1.64E-06	1.67E-09	5.42E-07	7.84E-07	2.10E-07	3.21E-08
SAMA Dose-Risk (Person Rem/yr.)	3.55E+01	6.05E-02	1.33E+01	2.70E-02	5.61E+00	6.90E+00	5.90E-03	4.30E+00	3.28E+00	1.58E+00	3.99E-01
SAMA OECR (\$/yr.)	1.17E+05	2.40E+01	3.91E+04	2.20E+01	1.85E+04	2.09E+04	1.61E+01	2.04E+04	8.54E+03	7.91E+03	1.16E+03

SAMA 129 PRA and MACCS Results By Release Category

The cost of implementation for this SAMA is estimated to be \$100,000 since a review of flooding rates, impacts, and operator intervention options is required in addition to procedure changes and training.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

SAMA Number 129 Net Value

Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value
\$4,462,000	\$4,406,000	\$56,000	\$100,000	-\$44,000

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3. DE 1

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, the net value is negative and this enhancement is not cost beneficial based on the SAMA methodology. Note also that competing risks associated with diluting the training curricula have not yet been quantified.

.

. **.**.

F.6.33 SAMA 130: PROTECT COMBUSTION TURBINES

SAMA 130 increases CT building integrity to withstand high winds. This considers specifications similar to safety related requirements.

The PRA model includes the probability that the CTs are damaged by high winds. This is treated as a value which is conditional on LOOP (4.62E-2/yr). Based on a review of the LOOP data in the Initiating Events Notebook, LOOP events were classified into four (4) categories:

- Plant Centered (56%)
- Grid Related (20%)
- Severe Weather (20%)
- Extreme Weather (4%)

The extreme weather case did not credit the CTs because the building design (i.e., 85 mph) limited the likelihood of survival. Figure 7, Page 5.1-5, of the OC IPEEE provides Tornado and Straight Wind Hazard Probability for the OC site. Based on the site specific wind hazard, if the CT building and SBO transformer structure were designed for a higher wind level, in the range of 115 mph, the conditional failure probability of being in the Extreme Weather "bin" could be reduced as follows:

- Plant Centered (56%)
- Grid Related (20%)
- Severe Weather (23.8%)
- Extreme Weather (0.2%)

This re-binning of LOOP initiating events basically expands the severe weather definition up to higher wind levels and allows the CTs to be available for a wider spectrum of events. This modeling change was accomplished by changing basic event LOOP-IE-SW probability from 0.2 to 0.238 per demand and basic event LOOP-IE-XW probability from 0.04 to 2E-3 per demand. This adjustment is made to all impacted gates except those under the FP (Fire Protection) gate. The fire pump house is also impacted by high winds but improvement is not applied in this particular SAMA.

The results from this case indicate a 30.1 percent reduction in CDF (CDF_{new} =7.33E-6 per year). A further breakdown of this information is provided below according to release category.

·	<u> </u>	WA 130	FRA an	U MAC	Jo Resi		Releas	e Caleg	JOLA		
			Release Category								
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	Н/1	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	- 1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	7.33E-06	2.13E-06	1.70E-06	1.95E-07	4.88E-07	1.64E-06	1.67E-09	3.13E-07	6.37E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	2.38E+01	5.33E-02	6.84E+00	2.88E-02	2.82E+00	6.90E+00	5.90E-03	2.49E+00	2.67E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	7.82E+04	2.11E+01	2.01E+04	2.36E+01	9.31E+03	2.09E+04	1.61E+01	1.18E+04	6.95E+03	7.91E+03	1.17E+03

The cost of implementation for this SAMA is judged to be \$600,000 since fairly extensive CT Building and SBO transformer structural improvements will be necessary.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

SAMA Number 130 Net Value

				· · _ ·
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site) ⁽²⁾	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value
\$2,231,000	\$1,484,000	\$747,000	\$600,000	\$147,000

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

(2) Damage due to high winds is an external event. External event contributions attributable to other sources may be omitted. External event contributions from seismic and fire are removed from consideration, such that the cost risk multiplier used is 1.0 rather than 2.0.

Given that the cost of implementation is less than the averted cost-risk for this SAMA, this enhancement is cost beneficial based on the SAMA methodology.

F.6.34 SAMA 132: REDUCE PROBABILITY OF MULTI-CT OPERATION

When the Combustion Turbines (CTs) are in operation, alignment for Oyster Creek LOOP response takes additional time due to the need for CTs to be stopped and to coast down first. This is due to uncertain procedural guidance in Procedure ABN-36 which directs operators to secure the CTs, if they were initially running.

Gates CT1 and CT2 in the OSP node model the likelihood that CT coast down is required. For 30 minute success criteria LOOP sequences, coast down causes CT failure because procedurally CTs require 40 minutes for alignment if they are initially operating. Because the CTs may spuriously trip due to overspeed caused by loss of load, this SAMA is modeled by "ANDing" an new basic event "SAMA132-BE" with the CT1 and CT2 gates. A value of 0.5 is used to represent the potential for spurious trip. If a spurious trip occurs, coastdown would be required before operators could restart. Otherwise, the current configuration would allow operators to immediately transfer loads.

The results from this case indicate a 1.24 percent reduction in CDF (CDF_{new} =1.04E-5 per year). A further breakdown of this information is provided below according to release category.

<u>. </u>					<u> </u>						
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E		M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.04E-05	2.68E-06	3.31E-06	1.96E-07	9.77E-07	1.66E-06	1.67E-09	5.38E-07	7.81E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.55E+01	6.71E-02	1.33E+01	2.90E-02	5.66E+00	6.95E+00	5.90E-03	4.26E+00	3.27E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	1.17E+05	2.66E+01	3.91E+04	2.37E+01	1.87E+04	2.10E+04	1.61E+01	2.03E+04	8.51E+03	7.91E+03	1.17E+03

SAMA 132 PRA and MACCS Results By Release Category

Two methods of achieving the reduction in probability that the CTs are in operation are as follows:

- Method A: Revise operating procedures to allow switching of the CTs to Oyster Creek while running.
- Method B: Achieve agreement with First Energy (operation of the CTs) to require at least 1 CT to be available in standby at all times.

Method A

The cost of implementation for this SAMA is judged to be \$50,000 to implement the procedure changes.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

	SAMA NUMBER 132 NET VALUE									
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value						
\$4,462,000	\$4,416,000	\$46,000	\$50,000	-\$4,000						

SAMA Number 132 Net Value

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

, . . .

Given that the cost of implementation of Method A is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

Method B

An alternative SAMA to provide a similar capability to Method "A" by obtaining First Energy (operator of the CTs) agreement to always maintain one CT in standby status is considered cost prohibitive and is considered adequately represented by the procedural modification in Method A.

F.6.35 SAMA 133: INCREASE HOTWELL MAKEUP CAPABILITY

The supply from the CST to the hotwell is currently via 10" or 4" pipe pathways. Two transfer pumps are available to augment the gravity feed and can supply 250 gpm each. The Fire Protection system can makeup to the CST at a rate of approximately 2000 gpm. A proposed SAMA would increase the hotwell makeup capacity so that it would transfer at least 2000 gpm from the CST to the hotwell. This additional flow from the CST to the hotwell, via the proposed SAMA, could allow feedwater to provide successful inventory control over a wider spectrum of LOCAs. Currently, the PRA does not credit feedwater for mitigation of below core LOCAs. The model can be adjusted to assume feedwater is able to mitigate any LOCA. This would be conservative toward supporting the proposed SAMA because, even with the additional flow, it is uncertain whether feedwater could mitigate large, below core LOCAs. This uncertainty arises because much of the inventory supplied by feedwater would flow out the break and not provide core cooling. In any event, for this sensitivity, it is assumed that the flow would be adequate to mitigate all LOCAs.

To model this sensitivity the gate "CP-LOCA-BTAF" is removed from the model. This gate is used to list those conditions (i.e., initiators) wherein feedwater is assumed to be insufficient, largely due to hotwell makeup concerns. The revised model was saved as OC-SAMA133.CAF and requantified. CDF reduced 1%, from 1.05E-5/yr to 1.04E-5/yr.

					F	lelease	Categor	у			······
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.04E-05	2.69E-06	3.38E-06	1.96E-07	9.91E-07	1.65E-06	1.50E-09	5.22E-07	7.55E-07	1.89E-07	3.14E-08
SAMA Dose-Risk (Person Rem/yr.)	3.54E+01	6.73E-02	1.36E+01	2.90E-02	5.74E+00	6.92E+00	5.28E-03	4.14E+00	3.16E+00	1.42E+00	3.89E-01
SAMA OECR (\$/yr.)	1.16E+05	2.67E+01	3.99E+04	2.37E+01	1.89E+04	2.09E+04	1.44E+01	1.97E+04	8.23E+03	7.09E+03	1.14E+03

SAMA 133 PRA and MACCS Results By Release Category

This modification is estimated to cost \$250,000 (3/8/2005 email from Pupek to Burns).

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

Base Case: Cost-Risk for Oyster Creek ⁽²⁾	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value
\$4,462,000	\$4,390,000	\$72,000	\$250,000	-\$178,000

SAMA Number 133 Net Value

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

⁽²⁾ Includes a factor of two increase to account for external events.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.36 SAMA 134: UPGRADE FIRE PUMP HOUSE STRUCTURAL INTEGRITY

SAMA 134 increases fire pump building integrity to withstand high winds. This considers specifications similar to safety related requirements.

The PRA model includes the probability that the fire pumps are damaged by high winds. This is treated as a value which is conditional on LOOP (4.62E-2/yr). Based on a review of the LOOP data in the Initiating Events Notebook, LOOP events were classified into four (4) categories:

- Plant Centered (56%)
- Grid Related (20%)
- Severe Weather (20%)
- Extreme Weather (4%)

The extreme weather case did not credit the fire pumps as the building design (i.e., 85 mph) limited the likelihood of survival. Figure 7, Page 5.1-5, of the OC IPEEE provides Tornado and Straight Wind Hazard Probability for the Oyster Creek site. Based on the site specific wind hazard, if the fire pump building were designed for a higher wind level, in the range of 115 mph, the extreme weather conditional failure probability could be reduced as follows:

- Plant Centered (56%)
- Grid Related (20%)
- Severe Weather (23.8%)
- Extreme Weather (0.2%)

This basically expands the severe weather definition up to higher wind levels and allows the fire pumps to be available for a wider spectrum of events. This modeling change was accomplished by changing basic event LOOP-IE-SW probability from 0.2 to 0.238 per demand and basic event LOOP-IE-XW probability from 0.04 to 2E-3 per demand. This adjustment is applied only under the FP (Fire protection) gate as this SAMA relates only to the fire pump house.

The results from this case indicate a 15.7 percent reduction in CDF (CDF_{new}=8.84E-6 per year). A further breakdown of this information is provided below according to release category.

	SA	MA 134	PRA an	d MACO	S Resu	ults By	Releas	e Categ	lory		•
					F	Release	Catego	ry			
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	Н/I	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07 .	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	8.84E-06	2.38E-06	2.65E-06	1.95E-07	5.29E-07	1.72E-06	1.67E-09	3.33E-07	8.15E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	2.91E+01	5.95E-02	1.07E+01	2.88E-02	3.06E+00	7.21E+00	5.90E-03	2.64E+00	3.41E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	9.38E+04	2.36E+01	3.13E+04	2.36E+01	1.01E+04	2.18E+04	1.61E+01	1.25E+04	8.88E+03	7.91E+03	1.17E+03

System managers estimate that this modification would cost \$150,000.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

SAMA Number 134 Net Value									
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek ⁽²⁾	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value					
\$2,231,000	\$1,793,000	\$438,000	\$150,000	\$288,000					

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

⁽²⁾ Damage due to high winds is an external event. External event contributions attributable to other sources may be omitted. External event contributions from seismic and fire are removed from consideration, such that the cost risk multiplier used is 1.0 rather than 2.0.

Given that the cost of implementation is not greater than the averted cost-risk for this SAMA, this enhancement is cost beneficial based on the SAMA methodology.

Note that Oyster Creek has the capability and procedural guidance to align a fire pump truck to provide additional fire pump redundancy. The truck is under the control of the Forked River Fire Department. Due to uncertainty regarding its availability, particularly in high wind events, its benefit has not been explicitly quantified in the PRA.

.

F.6.37 SAMA 136: PROVIDE ALTERNATE POWER TO CONDENSATE TRANSFER PUMPS

Presently, both Condensate Transfer Pumps are powered from USS 1B2 via MCC 1B32. Also, both pumps are tripped and not loaded onto the EDG following a LOOP. The operator must go to the intake to reset UV device to allow use of pumps. Redundant power to the pumps would increase the availability of the system, and auto load onto the EDGs would make them available quickly and with no operator action during LOOP.

This modeling change to address this option was accomplished by adding the AC power supplies (Gates EL and EI) under the individual pump gates in the condensate transfer tree (Gates CTG00MDC and CTG00MEC). The failure of Gate EL was removed as a single point failure under gate CTG010.

The results from this case indicate a 0.2 percent reduction in CDF (CDF_{new} =1.05x10⁻⁵ per year). A further breakdown of this information is provided below according to release category.

									<u> </u>		
					R	lelease	Catego	У			
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.05E-05	2.70E-06	3.37E-06	1.96E-07	9.96E-07	1.66E-06	1.67E-09	5.46E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.60E+01	6.76E-02	1.35E+01	2.90E-02	5.76E+00	6.95E+00	5.90E-03	4.33E+00	3.29E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	1.18E+05	2.68E+01	3.98E+04	2.37E+01	1.90E+04	2.10E+04	1.61E+01	2.06E+04	8.56E+03	7.91E+03	1.17E+03

SAMA 136 PRA and MACCS Results By Release Category

The cost of implementation for this SAMA is judged to be \$100,000.

This information was used as input to the cost benefit calculation. As can be seen, there are negligible changes in the CDF and the release category frequencies. This leads to a negligible change in averted cost risk. The results of this calculation are provided in the following table:

	SAMA Number 136 Net Value										
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value							
\$4,462,000	\$4,462,000	\$0	\$100,000	-\$100,000							

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.38 SAMA 138: PROTECT TRANSFORMERS

The main and startup transformers are located approximately 15' apart. The Oyster Creek PSA development and quantification has assessed the current transformer configuration and characterizes the potential for common failures using available generic data which has been Bayesian updated with Oyster Creek experience. Nevertheless, there is a postulated failure mode that an explosive failure of one transformer could impact the other. Because this event has never happened at Oyster Creek, it is speculated for this SAMA evaluation that there could be an impact on the order of 1E-2/yr to the plant-centered LOOP frequency based on assuming one explosive transformer failure per year in the nuclear industry. The base PRA model does not include the impact of this speculated hazard. Therefore, the SAMA cost benefit calculation must be performed by increasing the CDF and dose risk associated with this postulated hazard. Then, the benefit to be achieved will be the difference between the cost-risk with no additional protection for the hazard and the current base risk level which assumes the postulated hazard risk is near zero.

The modeling change to address this option is conservatively approximated by adding 1E-2/yr to the %LOOP initiating event frequency (%LOOP increased from 4.62E-2/yr to 5.62E-2/yr).

The results from this case indicate an 8.7 percent increase in CDF (CDF_{new}=1.14E-5 per year) if the hazard exists and no protection is provided. A further breakdown of this information is provided below according to release category.

					F	Release	Catego	У			,
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.14E-05	2.87E-06	3.87E-06	1.96E-07	1.14E-06	1.66E-06	1.67E-09	6.13E-07	8.32E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.957E+01	7.18E-02	1.56E+01	2.91E-02	6.62E+00	6.97E+00	5.90E-03	4.86E+00	3.49E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	1.299E+05	2.85E+01	4.56E+04	2.38E+01	2.18E+04	2.11E+04	1.61E+01	2.31E+04	9.07E+03	7.91E+03	1.17E+03

SAMA 138 PRA and MACCS Results By Release Category

Oyster Creek System Managers have reviewed this SAMA. Building a protective wall between the transformers is not feasible because the structure would need to be quite substantial and would interfere with normal access to equipment. The only technically feasible option would be to excavate a bus duct and "pull" the associated cables to protect the offsite supply circuitry. This has been estimated to cost \$780,000.

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

	SAMA Number 136 Net Value										
Base Case:	Cost-Risk for										
Oyster Creek	With SAMA	Averted Cost-	Cost of								
(site)	Changes	Risk	Implementation	Net Value							
\$4,462,000 ⁽²⁾	\$4,908,000 ⁽²⁾	\$446,000 ⁽²⁾	\$780,000	-\$334,000							

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

(2) The base PRA model does not include the impact of this postulated hazard. Therefore, the SAMA cost benefit calculation must be performed by increasing the CDF and dose risk associated with this postulated hazard. Then, the benefit to be achieved will be the difference between: (1) the cost-risk with no additional protection for the hazard; and, (2) the current base risk level which assumes the postulated hazard risk is near zero (equivalent to the maximum benefit achieved by the SAMA).

Given that the cost of implementation is greater than the averted cost-risk for this SAMA, this enhancement is not cost beneficial based on the SAMA methodology.

F.6.39 COMBINED IMPACT OF SAMAS

This section is purely for planning purposes, i.e., as input into the decision-making process. Once a SAMA is decided upon and implemented, then the PRA would be re-evaluated with the SAMA included. Following this re-baselining, the remaining individual SAMAs could be assessed with regard to their residual net value. This section provides estimates of the impact on the net value due to implementing combinations of SAMAs. These impact estimates provide needed input to decision-makers in their selection of possible plant or procedure changes.

While it is important to examine the impact of implementation for each individual SAMA, some combinations of SAMAs may act synergistically to yield a combined risk reduction greater than the sum of individual components. However, it is also important to note that implementation of cost-beneficial SAMAs may reduce the benefit of more marginal SAMAs by eliminating sequences that apply to the lower significant SAMAs.

The following sub-sections document the review of the impact of combinations of SAMAs.

Section F.6.39.1 addresses those SAMAs that are cost-beneficial on their own but may be non-cost-beneficial after the implementation of other, more beneficial, SAMAs.

Section F.6.39.2 addresses those SAMAs that are non-cost-beneficial on their own but may be cost-beneficial when implemented along with other SAMAs.

It is recognized that modeling and quantifying all possible combinations of SAMA would be a very resource intensive activity. Therefore, combinations of SAMAs for further review were developed based on a review of the Phase II single SAMA cost-benefit assessment as well as an overall consideration of the more significant aspects of the PRA.

F.6.39.1 <u>Review of Cost Beneficial SAMA That Are Reduced In Benefit By</u> Other SAMA

It is possible for an otherwise cost-beneficial item to be non-cost-beneficial when another more cost-beneficial item has been implemented. This section discusses the review of cost-beneficial SAMAs when assessed individually to determine if combinations of SAMAs would reduce the perceived benefit (i.e., net value).

The Phase II cost-beneficial items are shown in Table F-18. The results of these combination evaluations are discussed further in sub-section F.6.39.3.

The descriptions of the tabular columns in Table F-18 are as follows:

- Column 1 is the SAMA number from previous sections (See Table F-16).
- Column 2 is a brief description of the SAMA.
- Column 3 is the individual net value i.e., the present value of averted cost risk of implementing the SAMA minus the cost of implementation.
- Column 4 is an "item" identifier to designate the specific combination and order of the SAMA combination.

- Column 5 is the SAMA used in combination to assess the net benefit.
- Column 6 is the combination designator used in Section F.6.39.
- Column 7 is the marginal value of implementing the second SAMA.
- Column 8 is an assessment of whether the combination appears to be desirable to implement.

The following is a brief summary of the individual SAMAs that are evaluated in this section to assess the impacts of performing multiple SAMAs. All possible combinations are not modeled. Instead, model results and cutsets are reviewed to determine which SAMA combinations are most beneficial to quantitatively evaluate.

SAMA 91 – This involves improvements related to AC power by allowing crossties of the safety related buses. Related synergy is considered in combinations A1 and A2.

SAMA 99 – This SAMA involves scenarios with loss of AC power. Related synergy is considered in combinations A2 and A3.

SAMA 109 – This SAMA involves scenarios with loss of AC power. Related synergy is considered in combination A3.

SAMA 125 – This SAMA involves fire related accident sequences in areas with potentially dominant contributors to risk. The overlapping benefit associated with SAMA 109 is also evaluated in Section F.6.28. The SAMA 125B modification to install a circuit breaker to minimize the propagation of fire impacts has little or no impact on non-fire scenarios but does reduce the residual fire risk.

SAMA 127 – This SAMA relates to "across-the-board" operator training on PRA significant results. This SAMA is not envisioned to be non-cost-beneficial under any circumstances. It is considered cost-beneficial to continue to train the operators on the PRA results.

SAMA 130 – This SAMA involves AC power. Related synergy is considered in combination A4.

SAMA 134 – This SAMA involves scenarios with loss of AC power. Related synergy is considered in combination A4.

The combinations identified by an engineering review of the individual SAMAs and their potential for synergistic effects are identified in Table F.18 and are each discussed in the following text. The discussion of each combination includes:

- The calculated averted cost risk for the combination
- The net value comparison of the individual contributing SAMAs and the combination net value
- The assessment when the SAMAs are applied in reverse order

SAMA No.	Description	Individual Net Value (\$)	Item	Related	Combination	Marginal Value with Related SAMA Implemented (\$)	Does Combination Increase Net Value
04	Allow 4160 VAC		A	99	A1	\$472,000	No ⁽¹⁾
91	Bus IC And ID Crosstie	\$28,000	В	109	A2	\$547,000	No ⁽²⁾
	Provide an		С	91	A1	-\$24,000	· No
99	for IC Shell Level Determination	\$524,000	D	109	A3	-\$25,000	No
400	Portable DC Battery Charger to Preserve IC	¢500.000	E	91	A2	-\$24,000	No
109	Operability Along With Adequate Instrumentation	2299,000	F	99	A3	-\$100,000	No
125B	Reduce fire impact in dominant fire areas	\$233,000	G	109 ⁽³⁾	(3)	\$233,000	: Yes
127	Operator training		н	N/A ⁽⁴⁾	(4)	(4)	_(4)
130	Protect Combustion Turbines	\$147,000	1	134	A4	-\$132,000	No
134	Upgrade Fire Pump House Structural Integrity	\$288,000	J	130	A4	-\$273,000	No

⁽³⁾ The SAMA 125B is evaluated only in combination with SAMA 109.

Dependent on the sequence of implementation. Refer to Item E for the combination effectiveness.

⁽⁴⁾ Judged to be a prudent and therefore cost beneficial activity.

(2)

Table F-18

SAMA 91, 99, Combination: Combination A1

The following two SAMAs are investigated for synergies as Combination A1:

- SAMA 91 4160V AC Bus Cross-Tie
- SAMA 99 Local IC Operation, Shell Level Instrument

A model developed for SAMA 99 was modified by including those changes developed to model SAMA 91. The results of this model, when compared to the baseline, show the benefits of SAMA 91 and SAMA 99 implemented in combination. The following table shows these results:

Co	mbinatio	on A1:	SAMA C	ombina	ation 99	-91 Res	sults_by	/ Releas	se Categ	gory	
	_					Release	Catego	ry			
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.80E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	8.69E-06	2.57E-06	2.33E-06	7.40E-08	9.62E-07	1.46E-06	1.67E-09	5.31E-07	5.44E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	2.96E+01	6.42E-02	9.35E+00	1.09E-02	5.57E+00	6.14E+00	5.90E-03	4.21E+00	2.28E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	9.94E+04	2.55E+01	2.75E+04	8.95E+00	1.84E+04	1.86E+04	1.61E+01	2.00E+04	5.93E+03	7.91E+03	1.17E+03

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

		any and the set of and	or combination fiel va	
Base Case:	Cost-Risk for		Cost of	
Cost-Risk ⁽¹⁾ for	Oyster Creek		Implementation	
Oyster Creek	With SAMA	Averted Cost-	(SAMA 91 +	
(site)	Changes	Risk	SAMA 99)	Net Value
\$4,462,000	\$3,722,000	\$740,000	\$240,000	\$500,000

Combination A1: SAMA Number 99 and 91 Combination Net Value

(1) Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

The net value for SAMA 99 alone is \$524,000 (Section F.6.15). Therefore, implementation of SAMA 91, given implementation of SAMA 99, yields a reduction in net value of \$24,000 (i.e., \$500,000 - \$524,000). Thus, the total net value of the combination is reduced significantly from \$ 524,000, but is still positive. (See table below.)

SAMA	Description	Individual Net Value	Combination Net Value
99	Local IC Operation, Shell Level Instrument	\$524,000	
Combination 91 to 99	Combined 91 to 99	\$28,000	\$500,000
Marginal Value associated with adding 91 to 99	4160V AC Bus Cross-Tie	\$500,000 - \$524,000 = -\$24,000	

Comparison of Combination 91 and 99 Net Value with Individual Net Value Assessment

The incremental change in net value is negative when SAMA 91 is subsequently added to SAMA 99 to be implemented. Therefore, with SAMA 99 implemented, SAMA 91 would <u>not</u> be cost beneficial.

Reverse Sequence of Implementation for Combination A1

This combination can also be examined assuming that SAMA 91 is implemented first. In that case, it is found that:

The net value for SAMA 91 alone is \$28,000 (Section F.6.11). Therefore, implementation of SAMA 99, given implementation of SAMA 91, yields an additional benefit of \$472,000 (i.e., \$500,000 - \$28,000). Thus, the benefit of SAMA 99, is reduced from \$524,000 (Section F.6.15), but remains positive. (See table below.)

Comparison of Combination 91 and 109 Net Value with Individual Net Value Assessment					
SAMA	Description	Individual Net Value	Combination Net Value		
91	4160V AC Bus Cross-Tie	\$28,000			
Combination 99 to 91	Combined 99 to 91	\$524,000	\$500,000		
Marginal Value associated with adding 99 to 91	Local IC Operation, Shell Level Instrument	\$500,000 - \$28,000 = \$472,000			

The incremental change in net value is positive, however, the net value of the combination remains less than the maximum net value achieved by implementation of 99 alone.

Conclusion

The conclusion is that if SAMA 99 is to be implemented, SAMA 91 would become not cost beneficial to implement. For planning purposes, it is not justified to implement SAMA 91 first and then SAMA 99 even though each individual step could be shown to be cost beneficial.

SAMA 91, 109 Combination: Combination A2

The following two SAMAs are investigated for synergies as Combination A2:

- SAMA 109 Availability of Portable DC Battery Charger
- SAMA 91 4160V AC Bus Cross-Tie

Investigation of these two SAMAs is to identify if there are overlaps in the benefits that might arise by performing the two modifications that would eliminate one of the SAMAs as cost beneficial.

A model developed for SAMA 109 was modified by including those changes developed to model SAMA 91. The results of this model, when compared to the baseline, show the benefits of SAMA 91 and SAMA 109 implemented in combination. The following table shows these results:

										<u> </u>	
			Release Category								
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.80E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	8.69E-06	2.57E-06	2.33E-06	7.40E-08	9.62E-07	1.46E-06	1.67E-09	5.31E-07	5.44E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	2.96E+01	6.42E-02	9.35E+00	1.09E-02	5.57E+00	6.14E+00	5.90E-03	4.21E+00	2.28E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	9.94E+04	2.55E+01	2.75E+04	8.95E+00	1.84E+04	1.86E+04	1.61E+01	2.00E+04	5.93E+03	7.91E+03	1.17E+03

Combination A2: SAMA Combination 109-91 Results By Release Category

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

Combination A2. SAMA Number 91 and 109 Net Value				
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value
\$4,462,000	\$3,722,000	\$740,000	\$165,000	\$575,000

Combination A2: SAMA Number 91 and 109 Net Value

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

The net value for SAMA 109 alone is \$599,000 (Section F.6.23). Therefore, implementation of SAMA 91, given implementation of SAMA 109, yields a reduction in Net Value of \$24,000 (\$575,000 – \$599,000). Thus, there is no increase in net value calculated for implementation of SAMA 91 in combination with SAMA 109. In fact, the benefit of SAMA 91, is reduced significantly from \$28,000 (Section F.6.11) to -\$24,000, if SAMA 109 is also implemented. Thus, if SAMA 109 is implemented, SAMA 91 is no longer cost-beneficial.

See the table below that summarizes these results.

Comparison of Com	bination 91 and 109 Ne	t Value with Individual	Net Value Assessment
--------------------------	------------------------	-------------------------	----------------------

SAMA	Description	Individual Net Value	Combination Net Value
109	Portable DC Battery Charger	\$599,000	
Combination 91 to 109	Combined 91 to 109	-	\$575,000
Marginal Value associated with adding 91 to 109	4160V AC Cross-Tie	\$575,000 -\$2	- \$599,000 = 24,000

The incremental change in net value is negative when SAMA 91 is subsequently added to SAMA 109.

Reverse Sequence of Implementation for Combination A2

This combination can also be examined assuming that SAMA 91 is implemented first. In that case, it is found that:

The net value for SAMA 91 alone is \$28,000 (Section F.6.11). Therefore, implementation of SAMA 109, given implementation of SAMA 91, yields an additional benefit of \$547,000 (i.e., \$575,000 - \$28,000). Thus, the benefit of SAMA 109, is reduced from \$599,000 (Section F.6.23), but remains positive. (See table below.)

Comparison of Combination	109 and 91 Net Value	with Individual Net	Value Assessment
----------------------------------	----------------------	---------------------	------------------

SAMA	Description	Individual Net Value	Combination Net Value
91	4160V AC Bus Cross-Tie	\$28,000	••
Combination 109 to 91	Combined 109 to 91		\$575,000
Marginal Value associated with adding 99 to 91	Portable DC Battery Charger	\$575,000 - \$28,000 = \$547,000	

The incremental change in net value due to the order of implementation is positive, however, for planning purposes the net value of implementing the combination is <u>less than</u> the maximum net value achieved by implementation of SAMA 109 alone.

Conclusion

The conclusion is that SAMA 109 is cost beneficial and if implemented, then SAMA 91 is not cost beneficial.

SAMA 99, 109 Combination: Combination A3

The following two SAMAs are investigated for synergies as Combination A3:

- SAMA 109 Availability of Portable DC Battery Charger
- SAMA 99 Local IC Operation, Shell Level Instrument

Investigation of these two SAMAs is to identify if there are overlaps in the benefits that might arise by performing the two modifications that would eliminate one of the SAMAs as cost beneficial.

A model developed for SAMA 109 was modified by including those changes developed to model SAMA 99. The results of this model, when compared to the baseline, show the benefits of SAMA 99 and SAMA 109 implemented in combination. The following table shows these results:

Combination A3: SAMA Combination 109-99 Results By Release Category

			Release Category								
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	H/I	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.80E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	8.70E-06	2.59E-06	2.32E-06	6.23E-08	9.85E-07	1.45E-06	1.67E-09	5.41E-07	5.31E-07	2.10E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	2.97E+01	6.47E-02	9.34E+00	9.21E-03	5.70E+00	6.08E+00	5.90E-03	4.29E+00	2.23E+00	1.58E+00	4.01E-01
SAMA OECR (\$/yr.)	9.99E+04	2.57E+01	2.74E+04	7.53E+00	1.88E+04	1.84E+04	1.61E+01	2.04E+04	5.79E+03	7.91E+03	1.17E+03

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

Base Case:	Cost-Risk for			
Oyster Creek (site)	Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value
\$4,462,000	\$3,738,000	\$724,000	\$225,000	\$499,000

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

The net value for SAMA 109 alone is \$599,000 (Section F.6.23). Therefore, implementation of SAMA 99, given implementation of SAMA 109, yields a reduction in Net Value of \$100,000 (\$499,000 – \$599,000). Thus, the total net value of the combination is reduced significantly from \$599,000. This is a -\$100,000 incremental value. Thus, SAMA 99 becomes not costbeneficial if SAMA 109 is implemented.

See the table below that summarizes these results.

Comparison of Combination 99 and 109 Net Value with Individual Net Value Assessment

SAMA	Description	Individual Net Value	Combination Net Value
109	Portable DC Battery Charger	\$599,000	· · · ·
Combination 99 to 109	Combined 99 to 109	\$524,000	\$499,000
Marginal Value associated with adding 99 to 109	Local IC Operation, Shell Level Instrument	-	-100,000

The incremental change in net value is negative when SAMA 99 is subsequently added to SAMA 109 implementation.

Reverse Sequence of Implementation for Combination A3

This combination can also be examined assuming that SAMA 99 is implemented first. In that case, it is found that:

The net value for SAMA 99 alone is \$524,000 (Section F.6.15). Therefore, implementation of SAMA 109, given implementation of SAMA 99, yields a reduction in net value of \$25,000 (i.e., \$499,000 - \$524,000). Thus, the benefit of SAMA 109, is reduced significantly from \$599,000.

SAMA	Description	Individual Net Value	Combination Net Value
99	Local IC Operation, Shell Level Instrument	\$524,000	\$
Combination 99 to 109	Combined 109 to 99	\$599,000	\$499,000
Marginal Value associated with adding 109 to 99	Portable DC Battery Charger		-\$25,000

Comparison of Combination 109 and 99 Net Value with Individual Net Value Assessment

The incremental change of the net value is negative when SAMA 109 is subsequently added to SAMA 99 implementation.

Conclusion

The conclusion is that only one of these SAMAs is cost beneficial to implement. The highest individual net value is calculated for SAMA 109.

SAMA 130, 134 Combination: Combination A4

The following two SAMAs are investigated for synergies as Combination A4:

- SAMA 130 Protect Combustion Turbines
- SAMA 134 Upgrade Fire Pump House Structural Integrity

Investigation of these two SAMAs is to identify if there are overlaps in the benefits that might arise by performing the two modifications that would eliminate one of the SAMAs as cost beneficial.

A model developed for SAMA 130 was modified by including those changes developed to model SAMA 134. The results of this model, when compared to the baseline, show the benefits of SAMA 130 and SAMA 134 implemented in combination. The following table shows these results:

		_	L-LL/E,								
Rel. Cat.	CDF	Intact	L-LL/I	L-LL/L	M/E	<u></u> M/I	M/L	H/E	H/I	H/L	BOC
Baseline							-				
Freq.	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.80E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq.	7.26E-06	2.12E-06	1.66E-06	1.95E-07	4.75E-07	1.64E-06	1.67E-09	3.08E-07	6.34E-07	2.10E-07	3.23E-08
SAMA Dose-											
Risk	2.35E+01	5.30E-02	6.69E+00	2.88E-02	2.75E+00	6.90E+00	5.90E-03	2.44E+00	2.66E+00	1.58E+00	4.01E-01
SAMA OECR	7.72E+04	2.10E+01	1.96E+04	2.36E+01	9.07E+03	2.09E+04	1.61E+01	1.16E+04	6.91E+03	7.91E+03	1.17E+03

Combination A4: SAMA Combination 130-134 Results By Release Category

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

	Combination			
Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation	Net Value
\$2,231,000	\$1,466,000	\$765,000	\$750,000	\$15,000

Combination A4: SAMA Number 130 and 134 Net Value

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

The net value for SAMA 130 alone is \$147,000 (Section F.6.33). Therefore, implementation of SAMA 134, given implementation of SAMA 130, yields reduction in net value of \$132,000 (\$15,000 - \$147,000). Thus, there is no net benefit calculated for implementation of SAMA 134 in combination with SAMA 130.

See the table below that summarizes these results.

SAMA	Description	Individual Net Value	Combination Net Value
130	Protect Combustion Turbines	\$147,000	
Combination 130 with 134	Combined 134 to 130	\$288,000	\$15,000
Marginal Value associated with adding 134 to 130	Upgrade Fire Pump House Structural Integrity		-\$132,000

Comparison of Combination 130 and 134 Net Value with Individual Net Value Assessment

Reverse Sequence of Implementation for Combination A4

This combination can also be examined assuming that SAMA 134 is implemented first. In that case, it is found that the net value for SAMA 134 alone is \$288,000 (Section F.6.36). Therefore, implementation of SAMA 130, given implementation of SAMA 134, yields a reduction in net value of -\$273,000 (\$15,000 - \$288,000).

Comparison of Combination 134 and 130 Net Value with Individual Net Value Assessment

•	••	Individual	Combination
SAMA	Description	Net Value	Net Value
134	Upgrade Fire Pump House Structural Integrity	\$288,000	
Combination 134 with 130	Combined 130 to 134	\$147,000	\$15,000
Marginal Benefit associated with adding 130 to 134	Protect Combustion Turbines		-\$273,000

Conclusion

These two SAMAs address the same accident sequences (i.e., risk contributors); therefore, they are mutually exclusive in terms of the potential benefit to be derived. The SAMA with the highest net value of the pair is SAMA 134 – Upgrade the Fire Pump House Structural Integrity.

F.6.39.2 Synergies Among Non-Cost-Beneficial SAMAs

The impact of implementation for each individual Phase II SAMA is documented in Table F-16. However, some combinations of SAMAs may act synergistically to yield a combined risk reduction greater than the individual components.

A reasonable attempt at identifying such synergistic combinations of SAMAs for the purpose of evaluating the overall cost-benefit is a desirable step. It is judged that the most likely synergistic effect that will prove cost beneficial are combinations of those SAMAs that are already close to cost effective, i.e., have net values of between \$0 and -\$50,000. The first step in this assessment is to collect all the "marginally non-cost-beneficial" SAMAs. For this purpose, marginal SAMAs are those within \$50,000 of being cost neutral (i.e., Net Value > -\$50,000). This grouping resulted in the following eight SAMAs being selected for assessment in combination as a group of SAMAs.

SAMA No.	Description	Averted Cost-Risk (\$)	Cost (\$)	Net Value (\$)
25	Bypass Low Pressure Permissive	4,000	50,000	-46,000
88	Containment Vent		50,000	-50,000
89	Improve Procedure for Aligning SDC with High DW Pressure	-	50,000	-50,000
94	Increase Success Probability for Fire Protection Alignment		50,000	-50,000
101	Provide A Procedure For Determining RPV Level Using Fuel Zone Level Indicators A and C With SLC Operating		50,000	-50,000
102	Revise ATWS EOP to provide RPV Level Correction Based on Power		50,000	-50,000
106	Provide Direction for Cooldown in Loss of RBCCW	34,000	50,000	-16,000
132	Reduce Probability of Multi-CT Operation	46,000	50,000	-4,000

SAMA 95 is not included as it is not considered to have any measurable risk reduction benefit.

Combination B1

In order to assess this combination of SAMAs, a separate model was developed. The base model, OC-LEV2.caf, was adjusted to include the changes necessary to capture each of the "marginal" SAMAs listed above. The following table shows the results of this quantification.

	Collin	mation		ginal S		esuitsi	Jy Kele	ase Cal	egory		
					F	Release	Categor	У			
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I		H/E	НЛ	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.48E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.02E-05	2.64E-06	3.28E-06	1.95E-07	9.45E-07	1.65E-06	1.65E-09	5.29E-07	7.74E-07	2.07E-07	3.05E-08
SAMA Dose-Risk (Person Rem/yr.)	3.51E+01	6.61E-02	1.32E+01	2.89E-02	5.47E+00	6.95E+00	5.82E-03	4.19E+00	3.24E+00	1.56E+00	3.79E-1
SAMA OECR (\$/yr.)	1.15E+05	2.62E+1	3.87E+04	2.36E+01	1.80E+04	2.10E+04	1.59E+01	1.99E+04	8.44E+03	7.80E+03	1.11E+03

Combination B1: Marginal SAMA Results by Release Category

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation ⁽¹⁾	Net Value ⁽²⁾
\$4,462,000	\$4,348,000	\$114,000	\$400,000	-\$286,000

Combination B1 - MARGINAL SAMA Net Value

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

This represents the combined implementation of eight otherwise non-cost-beneficial SAMAs.

Combination B2

In order to further assess the potential synergies of otherwise non-cost-beneficial SAMAs, a separate model was developed to evaluate three particular marginal SAMAs implemented in combination. The base model, OC-LEV2.caf, was adjusted to include the changes necessary to the combination of SAMA 25,106, and 132.

SAMA No.	Description	Averted Cost-Risk (\$)	Cost (\$)	Net Value (\$)
25	Bypass low pressure permission	4,000	50,000	-46,000
106	Provide direction for cooldown in loss of RBCCW	34,000	50,000	-16,000
132	Reduce probability of Multi-CT operation	46,000	50,000	-4,000

The following table shows the results of this quantification.

(2) The net value is calculated based on a \$100,000 cost of implementation.

⁽¹⁾ The cost of implementation is based on the sum of all costs associated with the individual SAMAs. Dependent on the sequence of implementation. Refer to item D for the combination effectiveness.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

Cor	Combination B2: Marginal SAMA 25,106,132 Results By Release Category										
_					F	Release	Catego	ry			
Calculation Description	Total	Intact	L-LL/E, L-LL/I	L-LL/L	M/E	M/I	M/L	H/E	нл	H/L	BOC
Baseline Freq. (per yr.)	1.05E-05	2.71E-06	3.38E-06	1.96E-07	9.99E-07	1.66E-06	1.67E-09	5.80E-07	7.86E-07	2.10E-07	3.23E-08
SAMA Freq. (per yr.)	1.03E-05	2.66E-06	3.28E-06	1.96E-07	9.61E-07	1.65E-06	1.65E-09	5.29E-07	7.74E-07	2.08E-07	3.23E-08
SAMA Dose-Risk (Person Rem/yr.)	3.52E+01	6.65E-02	1.32E+01	2.90E-02	5.57E+00	6.95E+00	5.82E-03	4.20E+00	3.24E+00	1.56E+00	4.01E-01
SAMA OECR (\$/yr.)	1.16E+05	2.64E+01	3.87E+04	2.37E+01	1.84E+04	2.10E+04	1.59E+01	2.00E+04	8.44E+03	7.80E+03	1.17E+03

This information was used as input to the cost benefit calculation. The results of this calculation are provided in the following table:

Base Case: Cost-Risk ⁽¹⁾ for Oyster Creek (site)	Cost-Risk for Oyster Creek With SAMA Changes	Averted Cost- Risk	Cost of Implementation ⁽¹⁾	Net Value ⁽²⁾
\$4,462,000	\$4,378,000	\$84,000	\$150,000	-\$66,000

Combination B2: Marginal SAMA 25,106,132 SAMA Net Value

⁽¹⁾ Present Value Cost-Risk. The derivation of the present value cost-risk includes the OECR plus the other contributors to cost-risk described in Section F.3.

This represents the combined implementation of these three selected, but otherwise non-costbeneficial SAMAs.

⁽¹⁾ The cost of implementation is based on the sum of all costs associated with the individual SAMAs.

⁽²⁾ The net value is calculated based on a \$100,000 cost of implementation.

F.6.39.3 Summary of Combinations

There are individual SAMAs that are cost beneficial. When these cost beneficial SAMAs are combined with other cost beneficial SAMAs, there may be some loss in net benefit, i.e., shadowing effect. The following table summarizes the net value for the combinations investigated in Section F.6.39.1:

SAMA Combination	SAMAs Included	Averted Cost-Risk (\$)	Cost of Implementation (\$)	Net Value (\$)
A1	91, 99	740,000	240,000	500,000
A2	91, 109	740,000	165,000	575,000
A3	99, 109	724,000	225,000	499,000
A4	130, 134	765,000	750,000	15,000

Summary of Cost Beneficial SAMAs

While each of the Combinations A1 through A4 can be shown to be cost beneficial individually, this is not an optimum strategy. The <u>maximum</u> net value is achieved by implementing selected SAMAs. Then, the residual SAMAs will <u>not</u> be cost beneficial.

The conclusions from the analysis are as follows:

SAMA Combination	Optimum Action from Assessed Net Value
A1	Implement 99; Do not implement 91
A2	Implement 109; Do not implement 91
A3	Implement 109; Select 109 over 99
A4	Implement 134; Do not implement 130

The priority for SAMA implementation based on the individual maximum net value and the conclusions from the above assessed combinations is as follows: (1) 109; (2) 134; (3) 125B; and, (4) 127.

In addition to the assessment of SAMAs that are individually cost beneficial in Section F.6.39.1, the Section F.6.39.2 examined combinations of SAMAs that are not cost beneficial on an individual basis. The results for combinations of individual non-cost beneficial SAMAs evaluated in Section F.6.39.2 are presented in the following table.
Summary of SAMA Combinations				
SAMA Combination	SAMAs included	Averted Cost-Risk (\$)	Cost of Implementation (\$)	Net Value (\$)
B1	Eight SAMAs: 25, 88, 89, 94, 101, 102, 106, 132	114,000	400,000	-286,000
B2	Three SAMAs: 25, 106, 132	64,000	150,000	-66,000

Environmental Report Appendix F____Severe Accident Mitigation Alternatives

This summary table shows that the combinations of individual SAMAs, that were (1) found to be not cost beneficial, and (2) were judged to have the highest potential for a cost beneficial synergy, resulted in <u>not</u> being cost beneficial.

F.6.40 PHASE II SAMA ANALYSIS SUMMARY

The SAMA candidates which could not be eliminated from consideration by the Phase I baseline screening process or other PRA insights required the performance of a detailed analysis of the averted cost-risk and SAMA implementation costs. SAMA candidates are potentially justified only if the averted cost-risk resulting from the modification is greater than the cost of implementing the SAMA. Several of the SAMAs analyzed were found to be cost-beneficial as defined by the methodology used in this study. However, this evaluation should not necessarily be considered a definitive guide in determining the disposition of a plant modification that has been analyzed using other engineering methods. These results are intended to provide information about the relative estimated risk benefit associated with a plant change or modification compared with its cost of implementation and should be used as an aid in the decision-making process.

Table F-19 summarizes the results of the Phase II best estimate SAMA evaluation of individual SAMAs. Table F-19 provides the following information for each Phase II SAMA considered independently:

- The SAMA Number
- The Averted Cost-Risk
- The Cost of Implementation
- The Net Value
- The determination of whether the SAMA is cost beneficial based on this best estimate assessment

Phase II	Averted	Cost of		Cost
SAMA ID	Cost-Risk	Implementation	Net Value	Beneficial? ⁽⁵⁾
SAMA 7	\$174,000	\$500,000	-\$326,000	no
SAMA 10	\$788,000	\$1,000,000	-\$212,000	no
SAMA 18	\$8,000	\$265,000	-\$257,000	no
SAMA 20	\$4,000	\$400,000	-\$396,000	no
SAMA 23	\$42,000	\$150,000	-\$108,000	no
SAMA 25	\$4,000	\$50,000	-\$46,000	no
SAMA 67	\$65,000	\$1,000,000	-\$935,000	no
SAMA 84	\$80,000	\$150,000	-\$70,000	no
SAMA 88	\$0	\$50,000	-\$50,000	no
SAMA 89	(1)	\$50,000	(1)	no
SAMA 91	\$118,000	\$90,000	+\$28,000	yes
SAMA 92	\$36,000	\$100,000	-\$64,000	no
SAMA 94	\$0	\$50,000	-\$50,000	no
SAMA 95	(2)	\$50,000	(2)	no
SAMA 99	\$674,000	\$150,000	+\$524,000	yes
SAMA 100	\$146,000	\$500,000	-\$354,000	no
SAMA 101	\$0	\$50,000	-\$50,000	no
SAMA 102	\$0	\$100,000	-\$100,000	no
SAMA 104	\$44,000	\$250,000	-\$206,000	no
SAMA 106	\$34,000	\$50,000	-\$16,000	no
SAMA 107	\$0	\$150,000	-\$150,000	no
SAMA 108	(1)	~\$500,000 (est.)	(1)	no
SAMA 109	\$674,000	\$75,000	+\$599,000	yes
SAMA 110	(1)	~\$75,000	(1)	no
SAMA 111	(1)	\$500,000	(1)	no
SAMA 112	\$8,000	\$1,000,000	-\$992,000	no
SAMA 124	\$84,000	\$150,000	-\$66,000	no
SAMA 125B	\$333,000	\$100,000	+\$233,000	yes
SAMA 125C	\$397,000	\$750,000	-\$353,000	no
SAMA 127	(4)	(4)	(4)	yes
SAMA 128	\$20,000	\$200,000	-\$180,000	no
SAMA 129	\$56,000	\$100,000	-\$44,000	no
SAMA 130	\$747,000	\$600,000	+\$147,000	yes
SAMA 132	\$46,000	\$50,000	-\$4,000	no
SAMA 133	\$72,000	\$250,000	-\$178,000	no
SAMA 134	\$438,000	\$150,000	+\$288,000	yes
SAMA 136	\$0	\$100,000	-\$100,000	no
SAMA 138	\$446,000	\$780,000	-\$334,000	no

Table F-19. Summary of the Detailed Phase II SAMA Analyses

Notes to Table F-19:

- ⁽¹⁾ Based on the small reduction in CDF, the SAMA is considered not cost beneficial and no cost benefit calculation is performed.
- ⁽²⁾ No risk reduction benefit results; therefore, the SAMA is considered not cost beneficial.
- ⁽³⁾ Averted cost-risk is considered negligible; therefore, no cost benefit is calculated and the SAMA is not cost beneficial.
- ⁽⁴⁾ SAMA 127 recommends increased operator training on the importance of PRA identified key systems and operator actions and is deemed cost beneficial. SAMA 127 is considered one that is important to implement even though a specific net value is not identified.
- ⁽⁵⁾ There is a potential interaction between these SAMAs. As pointed out in Section F.6.39, it is found that certain of the cost beneficial SAMAs have "shadowing" effects on other SAMAs, such that, when they are implemented the other SAMAs become significantly less important.

F.7 Sensitivity Analysis

The decision regarding the cost-beneficial aspects of a candidate SAMA has traditionally been made on a best estimate basis. The previous section of Appendix F has described these best estimates for both cost-risk and implementation cost. However, in addition to this perspective, the decision-maker may also glean some insights from reasonable variations in key assumptions⁽¹⁾ used in the development of the cost-risk. This section examines two of the variables that represent key inputs to the cost-risk evaluation.

The following two sensitivities are investigated as to their impact on the overall SAMA evaluation for use as input to the decision-makers:

- Assume a real discount rate of 3 percent, instead of 7 percent used in the original base case present value analysis of the cost-risk analysis.
- Use the 95th percentile PRA results in place of the mean PRA results.

These two sensitivities both bias the net value high, that is, examine the potential to increase the net value of performing a SAMA. No sensitivities are presented here that decease the net value.

The Phase I SAMA list of Table F-15 was reviewed to determine if increases in averted costs associated with the sensitivities would impact the disposition of any SAMAs that were originally screened based on cost (i.e., Screening codes "C" and "F"). All other items from the Phase I screening were considered to remain screened because of: (1) competing risks; (2) not applicable to Oyster Creek; (3) already implemented at Oyster Creek; or (4) addressed by a similar SAMA. The investigation into the two types of sensitivities is documented in Table F.7-1. As a short cut to understanding and evaluating the sensitivities, it is noted that:

- (1) the use of an RDR of 3% results in an increase in averted cost of a factor of 1.4
- (2) the use of the 95% upper bound results in an increase in averted cost of approximately 2.5

Therefore, a screening can be performed using the factor of 2.5 increase to bound the maximum averted cost for each of the SAMAs. This value can then be compared with the individual SAMA costs to provide a conservative method of screening for <u>both</u> sensitivities. It is noted that Table F-15 is used in Section F.5 to describe the screening of SAMAs based on the MMACR. However, it is known from the calculations in Section F.6 that individual SAMAs have substantially less averted cost than the MMACR. Using this knowledge, in the sensitivity evaluation screening performed as part of Table F.7-1, the MMACR is not used, rather a conservative estimate of the specific SAMA impact on the averted cost is used. Table F.7-1 summarizes the results of this review. No items evaluated in Phase I for transfer to Phase II were changed based on the sensitivity screening in Table F.7-1.

⁽¹⁾ Section F.3.8 has provided parametric sensitivities with regard to MACCS2 inputs (such as population, evacuation time and speed, meteorology, release height).

F.7.1 REAL DISCOUNT RATE

A sensitivity study has been performed in order to identify how the conclusions of the SAMA analysis might change based on the value assigned to the real discount rate (RDR). The baseline, best estimate RDR of 7 percent has been changed to 3 percent and the modified maximum averted cost-risk was recalculated using the methodology outlined in Section F.4. The Phase I screening was re-examined as described above to identify any SAMA candidates that could no longer be screened based on the premise that their costs of implementation exceeded all possible benefit. In addition, the Phase II analysis was re-performed using the 3 percent RDR.

Implementation of the 3 percent RDR increased the averted costs by approximately 38 percent compared with the case where a 7 percent RDR was used.

The Phase II SAMAs were reevaluated based on the more conservative real discount rate (RDR) of 3 percent to calculate the net values for the SAMAs. Table F.7-2 provides a summary of the Phase II SAMA evaluations for the two different RDR assumptions. The determination of cost effectiveness changed for one Phase II SAMA (SAMA 132) when the 3 percent RDR was used in lieu of a 7 percent RDR.

SAMA 132 is a procedure change that would eliminate the direction to secure CTs prior to restarting them in LOOP scenarios.

These insights confirm the robust nature of the best estimate evaluation. The change in SAMA 132 is not viewed as significant compared to other insights from this study but is included for decision-maker use in evaluating uncertainty impacts on the cost-benefit calculation.

F.7.2 95TH PERCENTILE PRA RESULTS

The results of the SAMA analysis can be impacted by implementing conservative values from the PRA uncertainty distribution. If the best estimate failure probability values are consistently lower than the "actual" failure probabilities, the PRA model would underestimate plant risk and yield lower than "actual" averted cost-risk values for potential SAMAs. Re-assessing the cost benefit calculations using the high end of the failure probability distribution is a means of

equipment and operator actions included in the PRA model.

The 95th percentile core damage frequency (CDF) results are estimated for Oyster Creek for use in the reassessment. It is assumed that the factor by which the 95th percentile CDF results exceed the point estimate CDF is similar for many industry PRA models. While the degree of incorporation of plant specific data varies from plant to plant, the use of a similar generic database and the methods used to incorporate plant specific data are becoming more standardized. As a result, the characteristics of data uncertainties should be trending toward conformity.

The following is a summary of the point estimate CDF and 95th percentile CDFs for three SAMA submittals:

Plant	Point Estimate CDF	95 th Percentile CDF	Factor by Which the 95 th Percentile Results are Greater than the Point Estimates
V.C. Summer	5.59x10 ⁻⁵ /yr	1.32x10 ⁻⁴ /yr	2.36
Robinson	4.32x10 ⁻⁵ /yr	1.06x10 ⁻⁴ /yr	2.45
Brunswick	4.19x10 ⁻⁵ /yr	9.83x10 ⁻⁵ /yr	2.35

For the plants identified above, the 95th percentile CDF is between 2.35 and 2.45 times greater than the point estimate CDF. A factor of 2.5 is greater than the other industry examples and is judged acceptable for identifying the impact of data uncertainty on the Oyster Creek SAMAs.

PHASE I IMPACT

For Phase I screening, use of the 95th percentile CDF results will increase the modified maximum averted cost-risk and may prevent the screening of some of the higher cost modifications. However, the impact on the overall SAMA results due to the retention of the higher cost SAMAs for Phase II analysis is small. This is due to the fact that the benefit gleaned from the implementation of those SAMAs must be extremely large in order to be cost beneficial.

The impact of uncertainty in the PRA results on the Phase I SAMA analysis is examined as described above and reported in Table F.7-1.

As discussed above, the 95th percentile CDF results are assessed to be a factor of 2.5 greater than the point estimate CDF. For Oyster Creek, this corresponds to a CDF at the 95th percentile of 2.63E-5/yr. The dose-risk and offsite economic cost-risk are also increased by a factor of 2.5 to simulate the increase in the CDF resulting from the use of the 95th percentile CDF.

The Phase I SAMA list of Table F-15 has been re-examined using the revised modified maximum averted cost-risk to assess the impact of this set of assumptions. Table F.7-1 summarizes the results of this review⁽¹⁾. No items evaluated in Phase I for transfer to Phase II were changed based on the sensitivity screening documented in Table F.7-1.

PHASE II IMPACT

The 95th percentile results have been represented by increasing the base dose-risk and offsite economic cost-risk in proportion to the Level 1 results. The factor of 2.5 is also assumed to propagate through the results for the model runs performed for the Phase II detailed calculations. This means that the averted cost-risks for each case will be increased by the same factor.

Table F.7-3 provides a summary of the impact of using the 95th percentile CDF results in the detailed cost benefit calculations that have been performed as part of Phase II.

When the 95th percentile CDF results are used, seven of the Phase II SAMAs that were previously classified as "not cost beneficial", using a realistic assessment of risk, are determined to be cost beneficial. Table F.7-4 summarizes these seven SAMAs. However, the use of the 95th percentile PRA results is not considered to provide the most realistic assessment of the cost effectiveness of a SAMA. Nevertheless, this information is included for decision-maker use in evaluating the impact of uncertainties.

The \$750,000 cable rerouting based option for fire mitigation would be cost-beneficial under the 95th percentile sensitivity as it is structured. This option is discussed as case 125 C in Section F.6.28. With an averted cost of \$397,000 and an implementation cost of \$750,000, the option would become cost-beneficial if the averted cost were multiplied by 2.5 as per the 95th percentile case. This option would not be considered cost beneficial under the conditions that are applied to the 3% RDR sensitivity. This option is not highlighted further in this section because, as noted in Section F.6.28, the cost of rerouting cables has been conservatively estimated and it is not considered likely that this improvement would be ultimately cost-beneficial using a more detailed cost estimate.

- (1) The use of an RDR of 3% results in an increase in averted cost of a factor of 1.4
- (2) The use of the 95% upper bound results in an increase in averted cost of approximately 2.5

⁽¹⁾ The investigation into the two types of sensitivities is documented in Table F.7-1. As a short cut to understanding and evaluating the sensitivities, it is noted that:

Therefore, a screening can be performed using the factor of 2.5 increase to bound the maximum averted cost for each of the SAMAs. This value can then be compared with the individual SAMA costs to provide a conservative method of screening for <u>both</u> sensitivities.

Table F.7-1. Summary of Sensitivity Review of Phase I Screened SAMAReview of Items Screened Due to Cost (C) or Cost Exceed Benefit (F) for
RDR and 95th Upper Bound Sensitivities^{(1), (2), (3)}

NO.	SAMA TITLE	SAMA DESCRIPTION	PHASE I DISPOSITION	SCREENING REVIEW
2	Additional HP Injection System	An additional high pressure injection system would increase high pressure injection diversity and reduce the probability of requiring RPV depressurization early in an accident. An additional HP injection system would also impact the contribution of liner melt-through sequences in the Level 2 evaluation by reducing the frequency of high pressure core melt accident class. The benefit of this SAMA would be increased if the pump was 1) diesel powered, 2) could provide power to operate its own injection valves, and 3) be located in a flood safe zone.	F, I –Installation of another high pressure injection system is costly and is not offset by benefits. Benefits associated with an additional high pressure injection source are minimized by the Oyster Creek features of IC and CRD. IC is a passive high pressure inventory control method and the Oyster Creek CRD includes a dedicated bypass line that allows significant flow. SAMA improvement related to CRD is included in Item 92. Improving CRD flow would provide an additional high pressure injection system for scenarios wherein CRD is not currently credited. Cost of a self-powered, high pressure injection system, located in a separate fire and flood zone is expected to cost \$10,000,000. This is in excess of the maximum averted cost.	As a sensitivity, the base model was requantified after modifying logic to "AND" a new basic event with feedwater. This basic event is intended to represent a new high pressure injection system, with no support system requirements. The value was set equal to 5E-2. The resultant CDF was 7.34E-6/yr for a delta CDF of 3.15E-6/yr. This benefit (CDF reduction) is similar in magnitude to that of SAMA 130. SAMA 130 yields an averted cost of \$747,000. Using this averted cost as a surrogate to estimate the benefit of SAMA 2 and multiplying this by a factor of 2.5, to bound both the RDR and 95 th sensitivities, a value that is still far below the implementation cost is obtained (i.e., \$1,867,500 versus \$10,000,000). Therefore, this SAMA remains not cost beneficial despite the use of the conservatively biased sensitivity inputs.

Review of Items Screened Due to Cost (C) or Cost Exceed Benefit (F) for RDR and 95 th Upper Bound Sensitivities ^{(1), (2), (3)}					
NO.	SAMA TITLE	SAMA DESCRIPTION	PHASE I DISPOSITION	SCREENING REVIEW	
3	Enhance Depressurization and Injection Cues	RPV depressurization, while a reliable action, is an important contributor to plant risk. The cognitive portion of this action is specifically identified as an important contributor for another BWR. Potential means of improving the probability of identifying the need for depressurization include: adding a unique audible alarm and/or a highly visible alarm light to denote the need for depressurization. Installation of a large, graphical core display for water level is an additional enhancement.	F – Monticello estimated the cost of this modification to be about \$700,000. This is the result of combining the costs of performing the training/procedural changes and the required hardware changes. Procedural changes are generally on the order of \$50,000 to \$100,000 [F-20] and the hardware costs are estimated based on the \$600,000 cost of installing computer aided instrumentation in the main control room. This will not significantly reduce operator error rate as annunicators are currently in place and improvement potential is minimal.	Regardless of the assumptions used to assess the value of risk-reduction, this SAMA is not judged cost-beneficial because the potential for improvement over the current capabilities is negligible.	
6	Drywell Igniters or Passive Hydrogen Ignition System	This SAMA would provide a means to reduce the chance of hydrogen detonation.	F - Benefit is negligible because Oyster Creek containment operates with an inerted environment. Therefore, for inerted containments, such as the Oyster Creek Mark I containment, the NRC has previously concluded that igniters are not safety significant. The Calvert Cliffs application for license renewal [F-3] estimates the cost of a passive hydrogen ignition system to be \$760,000.	Regardless of the assumptions used to assess the value of risk-reduction, this SAMA is not judged cost-beneficial because the potential for improvement over the current capabilities is negligible.	
		· · · ·			

Review of Items Screened Due to Cost (C) or Cost Exceed Benefit (F) for RDR and 95th Upper Bound Sensitivities^{(1), (2), (3)}

NO.	SAMA TITLE	SAMA DESCRIPTION	PHASE I DISPOSITION	SCREENING REVIEW
8	Additional DFP for Fire Service Water System	An additional diesel fire pump would provide another source of water for RPV injection and containment spray. This could be achieved through the implementation of a procedure to direct the pressurization of the Fire Protection system using a fire truck.	 D – Oyster Creek currently has 1 electric and 2 diesel fire pumps. The electric pump is powered from normal AC power and uses a tank with limited volume. The two-diesel fire pumps are located outside the protected area in a standard metal sided building with concrete foundation. F – Addition of a third diesel fire pump is judged to have exceedingly small incremental benefit for RPV injection. This is because: OC has numerous injection sources Common-cause failure among the fire pumps dominates regardless if there are 2 or 3 pumps. The containment spray enhancement is treated under SAMA 111. 	As a sensitivity, the base model was requantified after modifying logic to "AND" a new basic event with the other fire pumps. This basic event is intended to represent a new diesel fire pump, with no support system requirements. The value was set equal to 5E-2. The resultant CDF was 1.05E-5/yr for a delta CDF of 1.91E- 8/yr. This benefit remains very small and clearly would yield a small averted cost. This SAMA is not cost-beneficial even if the benefit is multiplied by a factor of 2.5, or more.

	Review of Items Screened Due to Cost (C) or Cost Exceed Benefit (F) for RDR and 95 th Upper Bound Sensitivities ^{(1), (2), (3)}					
NO.	SAMA TITLE	SAMA DESCRIPTION	PHASE I DISPOSITION	SCREENING REVIEW		
9	Enhance, Test and Train on Alternate Boron Injection	Another BWR has the capability to use the RWCU and CRD systems to inject boron into the RPV; however, these alignments are not practiced. The RWCU alignment is not credited in the PRA model due to the length of time required for alignment. Changes to make these connections permanent and capable of being aligned from the MCR would improve their reliability. Additional training and practice of the alignments in the simulator and with mock-up test rigs would also improve alternate boron injection reliability.	 PHASE IDISPOSITION I - Oyster Creek has a reliable SLC system and the proceduralized capability for two alternate injection pathways. F - The cost of making the available options directly operable from the control room is expected to cost \$4,000,000. This includes making the proceduralized hose connections of the alternate systems into hard pipe connections. The benefit is minimal because the RPS is reliable and the existing SLC system provides an adequately reliable backup. 	As a sensitivity, the base model was requantified after modifying logic to "AND" a new basic event with the existing SLC hardware (I.e., Under Gate BIG00MEB). This basic event is intended to represent a new SLC train, with no support system requirements. The value was set equal to 5E-2. The resultant CDF was 1.04E-5/yr for a delta CDF of 7.87E-8/yr. This benefit remains small and clearly would yield a small averted cost. This SAMA remains not cost-beneficial even if the benefit is multiplied by a factor of 2.5 or more.		
		. ÷	ч	·		

Review of Items Screened Due to Cost (C) or Cost Exceed Benefit (F) for RDR and 95th Upper Bound Sensitivities^{(1), (2), (3)}

NO.	SAMA TITLE	SAMA DESCRIPTION	PHASE I DISPOSITION	SCREENING REVIEW
14	Post an Operator at the ASDS Panel Full Time	In the event that a fire in the Main Control Room requires evacuation to the ASDS panel, having a full time operator at the panel would allow for a more rapid transition to alternate reactor control. This is important for loss of injection cases where there is currently not enough time for the operators to evacuate the main control room and assume control at the ASDS panel (Class 1A).	C - The cost of implementation for this SAMA is based on an estimated base salary and the cost of benefits for 5 additional licensed operators. Five operators are justified considering that personnel are required to cover all shifts, 7 days a week and that 20 percent of operator time is spent in training. Assuming that an operator's salary and benefits cost \$100,000 per year and that the panel will be manned for the 20 year license renewal period, the cost of implementation would be \$10 million, not including raises. This cost is above the maximum averted cost for Oyster Creek.	The benefit of this SAMA is difficult to quantify because it intends to improve an already excellent operating capability. A complete reduction in Class IA events would produce a delta CDF of 2.46E-6/yr. This level of risk-reduction is less than that noted for SAMA 130. SAMA 130 yields an averted cost of \$747,000. Using this averted cost of \$747,000. Using this averted cost as a surrogate to estimate the benefit of SAMA 14 and multiplying this by a factor of 2.5, to bound both the RDR and 95 th sensitivities, a value that is still far below the implementation cost is obtained (i.e., \$1,867,500 versus \$10,000,000). Therefore, this SAMA
				use of the conservatively biased sensitivity inputs.
32	Use fuel cells instead of lead-acid batteries.	SAMA would extend DC power availability in an SBO.	I, F – Oyster Creek has diverse battery design presently. The system is already reliable. Evaluation of a portable DC charger is viewed as more beneficial. See Item 109. Also, note that the fuel cell option is new technology, never used in such a manner. It is judged expensive. A small, engine driven charger is considered a more cost-efficient and proven approach.	Due to competing risks and the availability of a more conventional option (i.e., SAMA 109), this SAMA is not considered cost-beneficial.

Review of Items Screened Due to Cost (C) or Cost Exceed Benefit (F) for RDR and 95th Upper Bound Sensitivities^{(1), (2), (3)}

NO.	SAMA TITLE	SAMA DESCRIPTION	PHASE I DISPOSITION	SCREENING REVIEW
44	Install an independent method of suppression pool cooling.	This SAMA would decrease the probability of loss of containment heat removal.	 F – IC provides an alternate method of DHR that eliminates heat discharge to the torus for non-LOCA scenarios. Development of another means beyond containment spray is viewed as limited benefit compared to a high cost for such a modification. An independent system is judged to cost \$5,000,000. This is in excess of the maximum averted cost. 	A complete reduction in Class II events would produce a delta CDF of 1.65E- 6/yr. This level of risk-reduction is less than that noted for SAMA 130. SAMA 130 yields an averted cost of \$747,000. Using this averted cost as a surrogate to estimate the benefit of SAMA 44 and multiplying this by a factor of 2.5, to bound both the RDR and 95 th sensitivities, a value that is still far below the implementation cost is obtained (i.e., \$1,867,500 versus \$5,000,000). Therefore, this SAMA remains not cost beneficial despite the use of the conservatively biased sensitivity inputs.
45	Install a filtered containment vent to remove decay heat.	This SAMA would provide an alternate decay heat removal method for non-ATWS events, with the released fission products being scrubbed. Option 1: Gravel Bed Filter Option 2: Multiple Venturi Scrubber	 F - Cost is high at > \$4M as assessed for Shoreham. The benefits in dose reduction are limited because of the Mark I shell failure mode and ATWS challenges that would fail containment. SAMA would not address core damage and does not address Noble gas release. This was not found cost- beneficial for Peach Bottom. Estimated to cost in excess of the maximum averted cost. 	Regardless of the assumptions used to assess the value of risk-reduction, this SAMA is not judged cost-beneficial because the potential for improvement over the current capabilities is small. Considering the high cost, the small variations in quantification characterization do not point to altering the conclusion for this SAMA.

Oyster Creek Generating Station License Renewal Application

Review of Items Screened Due to Cost (C) or Cost Exceed Benefit (F) for RDR and 95th Upper Bound Sensitivities^{(1), (2), (3)}

NO.	SAMA TITLE	SAMA DESCRIPTION	PHASE I DISPOSITION	SCREENING REVIEW
46	Install a containment vent large enough to remove ATWS decay heat.	Assuming that injection is available, this SAMA would provide alternate decay heat removal in an ATWS event.	F – Cost is high and benefits, in terms of dose reduction, are limited because of the small ATWS contribution to the risk profile. Containment vent size is sufficient to prevent containment failure as long as reactivity management tasks are completed as modeled in the PRA (i.e., RPV level control and SLC initiation). ATWS power levels without reactivity control would be in the range of 10% to 40% of full power. This requires a substantially larger containment vent than the current hard pipe vent. To achieve an operational "ATWS Vent" of hard pipe configuration and adequate size is estimated to cost in excess of \$2M. This is above the benefit to be achieved for elimination of the small ATWS contribution to risk at Oyster Creek.	Completely removing the ATWS contribution would lead to a delta CDF of 1.81E-7/yr. This level of benefit does not lead to any significant averted cost for this SAMA even if it could completely eliminate all ATWS risk. Therefore, the implementation cost far outweighs the small averted cost and the SAMA is not cost beneficial even for these conservatively biased assumptions.
48	Install a passive containment spray system.	This SAMA would provide redundant containment spray method without high cost.	F – High cost modification. Gravity feed system would provide limited benefit beyond that considered in Item 111 and would likely increase internal flooding risk.	Due to competing risks and the availability of a more conventional option (i.e., SAMA 111), this SAMA is not considered cost-beneficial.
49	Construct a building to be connected to primary/secondary containment that is maintained at a vacuum.	This SAMA would provide a method to depressurize containment and reduce fission product release.	C – This item is viewed as having a very large cost (> \$10 Million) and is well beyond the maximum averted cost for Oyster Creek.	Regardless of the assumptions used to assess the value of risk-reduction, this SAMA is not judged cost-beneficial because the potential for improvement over the current capabilities is small. Considering the high cost, variations in quantification assumptions do not point to altering the conclusion for this SAMA.

Review of Items Screened Due to Cost (C) or Cost Exceed Benefit (F) for RDR and 95th Upper Bound Sensitivities^{(1), (2), (3)}

NO.	SAMA TITLE	SAMA DESCRIPTION	PHASE I DISPOSITION	SCREENING REVIEW
51	Provide an additional diesel generator.	This SAMA would increase the reliability and availability of onsite emergency AC power sources.	C – Cost of an additional building and diesel is estimated at more than \$5M. This is greater than the maximum cost averted benefit.	The EDGs have a risk reduction worth (RRW) importance of 1.14. This suggests a potential delta CDF of 1.47E-6/yr (1.05E-5*(1.14-1)). This level of risk-reduction is less than that noted for SAMA 130. SAMA 130 yields an averted cost of \$747,000. Using this averted cost as a surrogate to estimate the benefit of SAMA 51 and multiplying this by a factor of 2.5, to bound both the RDR and 95 th sensitivities, a value that is still far below the implementation cost is remains not cost beneficial despite the use of the conservatively biased sensitivity inputs
62	Modify Reactor Water Cleanup (RWCU) for use as a decay heat proceduralize use.	This SAMA would provide an additional source of decay heat removal.	C – The RWCU system is currently proceduralized and used "as is" to provide decay heat removal over a portion of the spectrum of shutdowns. However, the RWCU system has very small heat removal capability and therefore, does not have the capability to provide a significant benefit. No options for significant capacity improvement have been identified that would cost less than \$4M.	A complete reduction in Class II events would produce a delta CDF of 1.65E- 6/yr. This level of risk-reduction is less than that noted for SAMA 130. SAMA 130 yields an averted cost of \$747,000. Using this averted cost as a surrogate to estimate the benefit of SAMA 62 and multiplying this by a factor of 2.5, to bound both the RDR and 95 th sensitivities, a value that is still far below the implementation cost is obtained (i.e., \$1,867,500 versus \$4,000,000). Therefore, this SAMA remains not cost beneficial despite the use of the conservatively biased sensitivity inputs.

Environmental Report Appendix F Severe Accident Mitigation Alternatives

Review of Items Screened Due to Cost (C) or Cost Exceed Benefit (F) for RDR and 95th Upper Bound Sensitivities^{(1), (2), (3)}

NO.	SAMA TITLE	SAMA DESCRIPTION	PHASE I DISPOSITION	SCREENING REVIEW
65	Suppression Pool Jockey Pump	This SAMA will improve prevention of core melt sequences by providing a small makeup pump to provide low pressure decay heat removal from the RPV using the suppression pool as a source of water.	F – Not viewed as a significant benefit. The small pump with suction from the suppression pool could provide water to the RPV. The flow rate may be adequate to supply MRDIR flow dictated in the SAMGs but is not considered sufficient for the prevention of core damage. Support systems for the pump will govern its availability to fulfill this role. No measurable risk decrease is judged achievable.	Regardless of the assumptions used to assess the value of risk-reduction, this SAMA is not judged cost-beneficial because no measurable improvement was identified. Considering the high cost, variations in quantification assumptions do not point to altering the conclusion for this SAMA.
68	Improved Vacuum Breakers (redundant valves in each line)	This SAMA reduces the probability of a stuck open vacuum breaker.	F - Oyster Creek has 14 single torus to drywell vacuum breakers arranged in 7 parallel lines, which can impact vapor suppression. Adding valves in series is highly expensive and reduces the success probability for the open on demand function. Benefit impacts only low frequency accident sequences. Added redundancy has only minor impact on the risk profile. Cost estimated by system manager to be \$2,000,000.	A complete reduction in Class III (i.e., LOCA) events would produce a delta CDF of 1.42E-6/yr. This level of risk- reduction is less than that noted for SAMA 130. SAMA 130 yields an averted cost of \$747,000. Using this averted cost as a surrogate to estimate the benefit of SAMA 68 and multiplying this by a factor of 2.5, to bound both the RDR and 95 th sensitivities, a value that is still below the implementation cost is obtained (i.e., \$1,867,500 versus \$2,000,000). Therefore, this SAMA remains not cost beneficial despite the use of the conservatively biased sensitivity inputs.
69	Improved MSIV Design	Replace MSIVs with improved design.	C – Replacing MSIVs is estimated by system manager to cost \$10 million which is beyond the maximum averted cost.	Regardless of the assumptions used to assess the value of risk-reduction, this SAMA is not judged cost-beneficial because the potential for improvement over the current capabilities is small. Considering the high cost, variations in quantification assumptions do not point to altering the conclusion for this SAMA.

	Review of Items Screened Due to Cost (C) or Cost Exceed Benefit (F) for RDR and 95 th Upper Bound Sensitivities ^{(1), (2), (3)}				
NO.	SAMA TITLE	SAMA DESCRIPTION	PHASE I DISPOSITION	SCREENING REVIEW	
70	Steam Driven Turbine Generator	This SAMA would provide a steam driven turbine generator which uses reactor steam and exhausts to the suppression pool. If large enough, it could provide power to additional equipment.	C – Adding such a system is judged to require a new building and therefore, involves a cost greater than \$10 million which is beyond the maximum averted cost.	Such as system would introduce competing risks such as high energy line breaks (HELB). While its benefits could be significant, the costs and competing risks are large enough that this SAMA cannot be recommended for further consideration.	
72	Dedicated RHR (bunkered) Power Supply	Install new electric distribution subsystem.	C – There may be some benefit for security or seismic related challenges but the cost of implementation far exceeds the maximum averted cost. A bunkered power supply is judged to require a new building and involve a cost greater than \$5 million. While the IC is a decay heat removal system in addition to an inventory control system, it is not an RHR system. The IC can operate independent of all electric support. A portable battery charger would allow operators to utilize the ICs during a long-term loss of all AC electrical subsystems with higher reliability. Therefore, one alternative is judged to reside with the portable charger included as Item 109.	Due to high costs and the availability of a more conventional option (i.e., SAMA 109), this SAMA is not considered cost-beneficial.	
77	Procedures for actions on loss of HVAC.	This SAMA would provide for improved credit to be taken for loss of HVAC sequences (improved affected electrical equipment reliability upon a loss of Control Building HVAC).	F – Oyster Creek has procedures for opening doors and installing portable fans as appropriate. No specific improvements have been identified.	Regardless of the assumptions used to assess the value of risk-reduction, this SAMA is not judged cost-beneficial because no measurable improvement was identified. Considering the limited benefit, variations in quantification assumptions do not point to altering the conclusion for this SAMA.	

Review of Items Screened Due to Cost (C) or Cost Exceed Benefit (F) for RDR and 95th Upper Bound Sensitivities^{(1), (2), (3)}

NO.	SAMA TITLE	SAMA DESCRIPTION	PHASE I DISPOSITION	SCREENING REVIEW
79	Use of CRD for alternate boron injection.	This SAMA provides an additional system to address ATWS with SLC failure or unavailability.	F – Alternate methods of boron injection already exist for Oyster Creek. Additional alternate systems would not provide a cost-beneficial option.	Completely removing the ATWS contribution would lead to a delta CDF of 1.81E-7/yr. This level of benefit does not lead to any reasonable level of cost-benefit for this SAMA even if it
			D Oyster Creek has a reliable SLC system and the proceduralized capability for two alternate injection pathways.	could completely eliminate all ATWS risk.
			C - The cost of making the available options directly operable from the control room is expected to cost \$4,000,000. This includes making the proceduralized hose connections of the alternate systems hard pipe connections. The benefit is minimal because the RPS is reliable and the existing SLC system provides adequately reliable as a backup.	
80	Improved drywell head bolts	Replace drywell head bolts with stronger material.	F - The Oyster Creek Drywell Head bolt failure mode is an insignificant contributor to containment failure at low temperatures (200 °F), but its contribution increases and becomes more significant as a function of temperature up to 800 °F. However, other important failure modes such as Mark I shell failure, penetrations, hatches, the pedestal, and RPV skirt at these temperatures are also via the Drywell. The presence of these other failure modes limits the benefit of the improved head bolts such that the benefit is judged to be outweighed by the cost of \$250K.	Regardless of the assumptions used to assess the value of risk-reduction, this SAMA is not judged cost-beneficial because the potential for improvement over the current capabilities is small. Considering the high cost, variations in quantification assumptions do not point to altering the conclusion for this SAMA.

Appendix F	
Severe Accident Mitigation Alternatives	Environmental Report

Review of Items Screened Due to Cost (C) or Cost Exceed Benefit (F) for RDR and 95th Upper Bound Sensitivities^{(1), (2), (3)}

NO.	SAMA TITLE	SAMA DESCRIPTION	PHASE I DISPOSITION	SCREENING REVIEW
103	Modify fuel zone logic to provide RPV level correction based on	Modify instrumentation to account for reactor power (See also Item 102)	F – More costly than Item 102 with similar benefit. See Item 102 for disposition.	SAMA 102 analysis resulted in a negligible benefit. Since the benefit is exceedingly small, variations in quantification assumptions do not point
	power		(Note 102 found not to be cost beneficial.)	SAMA.
105	Improve loss of circulating water response	The plant could be modified to provide an auto-swap from circulating water to service water. (See also Item 104)	F – More costly than Item 104 with similar benefit. See Item 104 for disposition.	SAMA 104 was not determined to be cost-beneficial under the RDR and 95 th percentile cases documented in Tables F.7-1 and F.7-2. With a higher cost and similar benefit, this SAMA cannot be considered cost-beneficial under an set of analysis assumptions.
115	CT Battery Spacers	Consider the addition of battery spacers in the CT battery compartments.	F – CT Battery was reviewed in more detail and additional battery spacers were determined to represent a negligible benefit (RAI-2 7/26/2000) (LAR 88242.20)	Regardless of the assumptions used to assess the value of risk-reduction, this SAMA is not judged cost-beneficial because no measurable improvement was identified. Considering the limited benefit, variations in quantification assumptions do not point to altering the conclusion for this SAMA.
		· · · ·		
				· ·

Oyster Creek Generating Station License Renewal Application

Review of Items Screened Due to Cost (C) or Cost Exceed Benefit (F) for RDR and 95th Upper Bound Sensitivities^{(1), (2), (3)}

NO.	SAMA TITLE	SAMA DESCRIPTION	PHASE I DISPOSITION	SCREENING REVIEW
135	Increase structural integrity of IC makeup piping	The water supply to makeup to the Iso Condensers is neither safety related nor seismic. Upgrade of the Condensate Transfer System supply to the ICs would possibly increase their long term availability.	C – The Oyster Creek IPEEE analysis included IC performance during seismic events. Using the EPRI hazard curves, the IC contributed 4.97% to the overall CDF of 3.6E-6/yr. If the IC could be made perfect, it would reduce contribution by a value of 1.79E-7/yr (3.6E-6*4.87%). Considering such a modification is expected to cost at least \$5,000,000, this option is considered not cost- beneficial.	The 1.79E-7/yr risk reduction discussed in the Phase I disposition is far less than that noted for SAMA 130. SAMA 130 yields an averted cost of \$747,000. Using this averted cost as a surrogate to estimate the benefit of SAMA 135 and multiplying this by a factor of 2.5, to bound both the RDR and 95 th sensitivities, a value that is still far below the implementation cost is obtained (i.e., \$1,867,500 versus \$5,000,000). Therefore, this SAMA remains not cost beneficial despite the use of the conservatively biased sensitivity inputs (i.e., \$1,867,500 versus \$5,000,000).
137	Create a crib house	Currently, some equipment related to the intake structure is exposed to the elements. Creating an expanded crib house may improve equipment reliability.	F – No specific reliability problems associated with environmental exposure of OC equipment have been identified. Such a structure is expected to cost \$500,000. Since no quantifiable benefit exists, this item is not considered cost-beneficial.	Regardless of the assumptions used to assess the value of risk-reduction, this SAMA is not judged cost-beneficial because no measurable improvement was identified. Considering the limited benefit, variations in quantification assumptions do not point to altering the conclusion for this SAMA.

Notes on Table F.7-1

- ⁽¹⁾ Table F.7-1 provides a Phase I re-review of those SAMAs that were screened in Section F.5 based on the best estimate evaluations of CDF and 7% RDR. The re-review focuses on SAMAs screened on Cost (C or F). The re-review includes an increase in the estimated averted cost for the SAMA compared with the estimated cost of implementation. It is noted that Table F-15 is used in Section F.5 to describe the screening of SAMAs based on the MMACR. However, it is known from the calculations in F.6 that individual SAMAs have substantially less averted cost then the MMACR. Using this knowledge in the sensitivity evaluation screening performed as part of Table F.7-1, the MMACR is not used, rather a conservative estimate of the specific SAMA impact on the averted cost is used.
- (2) All other items from the Phase I screening were considered to remain screened because of: (1) competing risks; (2) not applicable to Oyster Creek; (3) already implemented at Oyster Creek; or (4) addressed by a similar SAMA.
- ⁽³⁾ The impact of the sensitivities evaluated here is to increase the averted cost (i.e., benefit) for a given SAMA. Based on a review of the Phase II sensitivity quantifications summarized in Table F.7-2, it is determined that the averted cost is increased by a factor of 1.4 in cases when an RDR of 3% is used instead of 7%. Similarly, the impact of the 95th percentile sensitivity (Table F.7-3) is to increase the averted cost by a factor of 2.5. This knowledge is used in the reconsideration of Phase I SAMAs which are screened based on the consideration of averted cost (i.e., benefit). To bound both sensitivity cases (i.e., RDR and 95th percentile), an averted cost multiplier of 2.5 is used in this review of Phase I SAMAs. In many cases, the Phase I SAMAs are not evaluated to determine a specific averted cost. In these cases, a conservative estimate is applied to approximate the level of benefit provided by the SAMA. This is similar in technique to the averted cost value, determinations are made directly using the CDF impact. Because the CDF impact of these SAMA are generally small, making determinations based on CDF impact is deemed an acceptable approach.

SAMA ID	Cost of Implementation (\$)	7 % RDR Averted Cost- Risk (\$)	7 % RDR Net Value (\$)	3 % RDR Averted Cost- Risk (\$)	3 % RDR Net Value (\$)	Change in Cost Effectiveness to make the SAMA Cost Beneficial?
7	500,000	174,000	-326,000	240,000	-260,000	No
10	1,000,000	788,000	-212,000	1,088,000	88,000	No ⁽²⁾
18	265,000	8,000	-257,000	10,000	-255,000	No
20	400,000	4,000	-396,000	6,000	-394,000	No
23	150,000	42,000	-108,000	58,000	-92,000	No
25	50,000	4,000	-46,000	6,000	-44,000	No
67	1,000,000	65,000	-935,000	88,000	-912,000	No
84	150,000	80,000	-70,000	110,000	40,000	No
88	50,000	0	-50,000	0	-50,000	No
89	50,000	0	-50,000	0	-50,000	No
91	90,000	118,000	+28,000	162,000	+72,000	No ⁽¹⁾
92	100,000	36,000	-64,000	50,000	-50,000	No
94	50,000	0	-50,000	0	-50,000	No
95	50,000	0	-50,000	0	-50,000	No
99	150,000	674,000	+524,000	928,000	+778,000	No ⁽¹⁾
100	500,000	146,000	-354,000	204,000	-296,000	No
101	50,000	· 0	-50,000	0	-50,000	No
102	50,000	0	-50,000	0	-50,000	No
104	250,000	44,000	-206,000	60,000	-40,000	No
106	50,000	34,000	-16,000	46,000	-4,000	No
107	250,000	· 0	-250,000	0	-250,000	No
108	1,000,000	0	-1,000,000	0	-1,000,000	No
109	75,000	674,000	+599,000	928,000	+853,000	No ⁽¹⁾
110	75,000	0	-75,000	0	-75,000	No
111	500,000	0	-500,000	0	-500,000	No
112	1,000,000	8,000	-992,000	10,000	-990,000	No
124	150,000	84,000	-66,000	115,000	-35,000	No
125B	100,000	333,000	233,000	458,000	358,000	No ⁽¹⁾
125C	750,000	397,000	-353,000	540,000	-210,000	No
127	50,000	(3)	(3)	(3)	(3)	No ⁽³⁾
130	600,000	747,000	+147,000	1,032,000	+432,000	No
132	50,000	46,000	-4,000	64,000	+14,000	Yes
133	250,000	72,000	-178,000	10,000	-150,000	No
134	150,000	438,000	+288,000	606,000	+456,000	No ⁽¹⁾
136	100,000	0	-100,000	0	-100,000	No
138	780,000	446,000	-334,000	616,000	-164,000	No

Table F.7-2. Summary of SAMA Discount Sensitivity

に耳し

Notes to Table F.7-2:

- ⁽¹⁾ These SAMAs are considered cost beneficial after the baseline 7% RDR Phase II analyses; therefore, there is no change in cost benefit resulting from the sensitivity analysis.
- ⁽²⁾ The calculation with RDR = 3% shows a cost beneficial result but the cost-risk calculation does not account for the significant competing risks.
- (3) SAMA 127 recommends increased operator training on the importance of PRA identified key systems and operator actions. SAMA 127 is judged cost beneficial after the baseline 7% RDR Phase II analyses; therefore, there is no change in cost benefit resulting from the sensitivity analysis.

SAMA ID	Cost of Implementation (\$)	Base Averted Cost- Risk (\$)	Base Net Value (\$)	95% Averted Cost- Risk(\$)	95% Net Value(\$)	Change in Cost Effectiveness to make the SAMA Cost Beneficial?
7	500,000	174,000	-326,000	435,000	-65,000	No
10	1,000,000	788,000	-212,000	1,970,000	970,000	Yes
18	265,000	8,000	-257,000	20,000	-245,000	No
20	400,000	4,000	-396,000	10,000	-390,000	No
23	150,000	42,000	-108,000	105,000	-45,000	No
25	50,000	4,000	-46,000	10,000	-40,000	No
67	1,000,000	65,000	-935,000	162,500	-837,500	No
84	150,000	80,000	-70,000	200,000	50,000	Yes
88	50,000	0	-50,000	0	-50,000	No
89	50,000	0	-50,000	0	-50,000	No
91	90,000	118,000	28,000	295,000	205,000	No ⁽¹⁾
92	100,000	36,000	-64,000	90,000	-10,000	No
94	50,000	0	-50,000	0	-50,000	No
95	50,000	0	-50,000	0	-50,000	No
99	150,000	674,000	524,000	1,685,000	1,535,000	No ⁽¹⁾
100	500,000	146,000	-354,000	365,000	-135,000	No
101	50,000	0	-50,000	0	-50,000	No
102	50,000	0	-50,000	0	-50,000	No
104	250,000	44,000	-206,000	110,000	-140,000	No
106	50,000	34,000	-16,000	85,000	35,000	Yes
107	250,000	0	-250,000	0	-250,000	No
108	1,000,000	0	-1,000,000	0	-1,000,000	No
109	75,000	674,000	599,000	1,685,000	1,610,000	No ⁽¹⁾
110	75,000	0	-75,000	0	-75,000	No
111	500,000	0	-500,000	0	-500,000	No
112	1,000,000	8,000	-992,000	20,000	-980,000	No
124	150,000	84,000	-66,000	210,000	60,000	Yes
125B	100,000	333,000	233,000	832,500	732,500	No ⁽¹⁾
125C	750,000	397,000	-353,000	992,500	242,500	Yes
127	50,000	(2)	(2)	(2)	(2)	No ⁽²⁾
130	600,000	747,000	147,000	1,867,500	1,267,500	No ⁽¹⁾
132	50,000	46,000	-4,000	115,000	65,000	Yes
133	250,000	72,000	-178,000	180,000	-70,000	No
134	150,000	438,000	288,000	1,095,000	945,000	No ⁽¹⁾
136	100,000	0	-100,000	0	-100,000	No
138	780,000	446,000	-334,000	1,115,000	325,000	Yes

Table F.7-3. Summary of 95th Percentile Sensitivity Analysis

Notes to Table F.7-3:

- ⁽¹⁾ These SAMAs were considered cost beneficial after the baseline mean CDF Phase II analyses; therefore, there is no change in cost benefit resulting from the sensitivity analysis.
- (2) SAMA 127 recommends increased operator training as the importance of PRA identified key systems and operator actions and was deemed cost beneficial after the baseline 7% RDR Phase II analyses; therefore, there is no change in cost benefit resulting from the sensitivity analysis.

Table F	7-4
---------	-----

Summary of "New" Cost Beneficial SAMAs if CDF Increased to 95th Percentile

SAMA No.	Description	Discussion	Competing Risks Accounted for
10	This SAMA would reduce the risk of catastrophic failure of the containment. The current Torus Hard Pipe Vent includes a rupture disk beyond an isolation valve; however, an alternate path to the Torus Hard Pipe Vent could be made in the wetwell using a rupture disk that would fail at about 60 psid. Alternatively, the containment vent valves could be changed so that they "fail open" on loss of support. Given this change, the vent path would be open on loss of support with the exception of the rupture disk. To prevent premature opening of the vent path during scenarios with loss of vent valve support, the strength of the rupture disk could be increased so that it is closer to the EOP vent pressure.	This SAMA would introduces a few significant competing risk. One such competing risk is the potential to cause low NSPH for ECCS systems during intended or spurious actuation of the system. Also, containment would be bypassed during spurious system actuation.	Competing Risks could be significant but are <u>not</u> accounted for.
84	Provide capability to vent primary containment without support systems with procedure/training	The 95 th percentile sensitivity is considered an extreme case but the benefit of this modification becomes marginally cost- beneficial under these sensitivity case conditions.	No significant competing risks noted.
106	Revise ABN-19 to include guidance to implement a <90°F/hr cooldown as soon as possible following a loss of RBCCW to supplement protection of recirc seals by reducing RPV pressure.	The 95 th percentile sensitivity is considered an extreme case but the benefit of this modification becomes marginally cost- beneficial under these sensitivity case conditions.	No significant competing risks noted.

Table F.7-4

.

Summary of "New" Cost Beneficial SAMAs if CDF Increased to 95th Percentile

SAMA No.	Description	Discussion	Competing Risks Accounted for
124	Block wall 53 reinforcement	The 95 th percentile sensitivity is considered an extreme case. Also, the benefit is based on the IPEEE seismic analysis which was not performed with the intent of supporting detailed cost- benefit assessments. Also, the seismic analysis has not been updated since it was completed in 1996.	No significant competing risks noted.
125C	Cable re-routing in 480V AC "A" switchgear room	Using the 95 th percentile sensitivity assessment and the "low" cost of implementation results in a cost beneficial case.	Competing risks could be significant but are not accounted for.
132	When both CTs are in operation, alignment for Oyster Creek LOOP response takes additional time due to need for CTs to coast down prior to switching. This SAMA would eliminate procedural guidance to shutdown CTs, if initially running,	Under the extreme conditions of the 95 th percentile sensitivity assessment, this SAMA becomes cost-beneficial.	No significant competing risks noted.
138	The main and startup transformers are located approximately 15' apart. There is a concern that a failure of one could impact the other.	Under the extreme conditions of the 95 th percentile sensitivity assessment, this SAMA becomes cost-beneficial.	No significant competing risks noted.

.

Oyster Creek Generating Station License Renewal Application

F.8 Conclusions

F.8.1 OVERVIEW

The benefits of revising the operational strategies in place at Oyster Creek and/or implementing hardware modifications can be evaluated without the insight from a risk-based analysis. Use of the PRA in conjunction with cost benefit analysis methodologies has, however, provided an enhanced understanding of the effects of the proposed changes relative to the cost of implementation and projected impact on future population. The results of this study indicate that of the identified potential improvements that can be made at Oyster Creek, several are cost beneficial based on the methodology applied in this analysis and warrant further review for potential implementation.

The review of past license renewal submittals and the Oyster Creek PRA has resulted in the identification of 136 candidate SAMAs for consideration.

This group of 136 candidate SAMAs is screened for obvious cases where cost of implementation would be significantly greater than the cost-risk averted. This so called Phase I screening resulted in 37 candidate SAMAs transferred to Phase II for detailed analysis. These 37 candidate SAMAs are treated in Phase II using specific cost estimates for each of the items and explicit PRA modeling of the incorporation of the SAMA. Both internal and external events are considered in this PRA evaluation. The Phase II analysis results in seven SAMAs that are considered potentially cost beneficial. Section F.8.2 identifies these seven SAMAs. Section F.8.2 also identifies that three of these seven SAMAs are not cost beneficial when implemented in tandem with more cost beneficial SAMAs. Based on the results of the Oyster Creek SAMA analysis, Exelon concludes that several cost-beneficial options exist to reduce plant risk but that none are related to plant aging.

F.8.2 BEST ESTIMATE RESULTS

Table F.8-1

Of the 37 candidate SAMAs transferred into Phase II, there are seven (7) SAMAs that resulted in potential for a positive cost benefit if the identified SAMA is implemented and a best estimate analysis is performed. This list of potentially cost beneficial SAMAs is identified in Table F.8-1:

SAMA No.	Description	Best Estimate Net Value (20 Year Life)
91	Allow 4160V AC Bus IC and ID cross tie	\$28,000
99	Provide an alternate method for IC shell level determination	\$524,000
109	Portable DC battery charger to preserve IC and EMRV operability along with adequate instrumentation	\$599,000
125B	Reduce fire impact in dominant fire area of the 480V AC switchgear via a circuit breaker addition	\$233,000
127 ·	Increased training on the systems and operator actions determined to be important from the PRA.	Judgment
130	Protect combustion turbines	\$147,000
134	Upgrade fire pump house building integrity so that fire system would be capable of withstanding a severe weather event.	\$288,000

Cost Beneficial SAMAS When Considered	Separately
---------------------------------------	------------

The net values are considered optimistic based on the SAMA methodology because of the consideration that competing risks associated with diluting the training curricula and diverting management and engineering resources have not yet been quantified.

These seven SAMAs are identified as "Cost Beneficial".

SAMA 127 is considered one that is important to implement even though a specific net value is not identified.

Of the remaining six SAMAs that are potentially cost beneficial, there is a potential interaction between these SAMAs.

As pointed out in Section F.6.39, it is found that certain of the cost beneficial SAMAs have "shadowing" effects on other SAMAs such that when they are implemented the other SAMAs become significantly less important. For example, the SAMAs that are found not cost beneficial when SAMAs 109 and 134 are implemented are 91, 99, and 130.

The priority for SAMA implementation based solely on the maximum net value is:

Priority	SAMA No.	Description	Best Est. Net Value (20 yr. Life)
1	109	Portable DC Battery Charger to Preserve IC and EMRV Operability Along With Adequate Instrumentation	\$599,000
2	134	Upgrade Fire Pump House Structural Integrity	\$288,000
3	125B	480V AC switchgear circuit breaker addition ⁽¹⁾	\$233,000
_4	127	Operator Training	Judgement

Environmental Report Appendix F Severe Accident Mitigation Alternatives

(1) It is noted that SAMA 125 related to reduction in the fire induced CDF in the 480V AC switchgear room is found cost beneficial with or without SAMA 109 implementation. If SAMA 109 is not implemented, the more capital intensive change 125C should be considered.

An examination of SAMA combinations found no significant positive synergies among the individual SAMAs that alter the overall conclusions of the individual SAMA evaluations, i.e., no increase in net value when multiple SAMAs are implemented together.

F.8.3 SENSITIVITY ANALYSIS RESULTS

The list of SAMAs have also been assessed using different assumptions for two key inputs to examine the impact of uncertainties:

- The estimate of core damage frequency
- The real discount rate (RDR)

The results of these sensitivity cases provide yet another perspective on the results of the SAMA evaluation reflecting the uncertainty in these two input variables.

F.8.3.1 RDR Change: A Sensitivity Evaluation

The change in RDR from 7% to 3% causes one additional SAMA to be considered cost beneficial. Table F.8-2 summarizes this SAMA.

It is noted that the net value for the "new" candidate SAMA is not significant given the nature of the sensitivities and the conservatism involved in the overall assessment of these SAMA. Therefore, no significant insight is judged derived from these sensitivity analyses that affect the decisions.

These insights are not viewed as significant compared to other insights from this study but are included for decision-maker use in evaluating uncertainty impacts on the cost-benefit calculation.

		Net Value		
SAMA No.	SAMA DESCRIPTION	Best Est. (7% RDR)	3% RDR	
132	When both CTs are in operation, alignment for Oyster Creek LOOP response takes additional time due to need for CTs to coast down prior to switching. This SAMA would eliminate procedural guidance to shutdown CTs, if initially running,	-\$4,000	\$14,000	

Table F.8-2. Summary of Additional Cost Beneficial SAMAif RDR Changed to 3%

F.8.3.2 Risk Profile Changes: A Sensitivity Evaluation

If the CDF used in the risk analysis increased to the 95th percentile, then the cost-risk for the individual SAMAs will increase because of the additional perceived risk. Using this extreme assumption results in the addition of seven (7) SAMAs to the list of SAMAs that could be considered by decision-makers. Table F.8-3 summarizes this list of seven (7) SAMAs along with the net value calculated for the best estimate evaluation and the 95th percentile sensitivity evaluation.

However, the use of the 95th percentile PRA results is not considered to provide the most realistic assessment of the cost effectiveness of a SAMA. Nevertheless, this information is included for decision-maker use in evaluating the impact of uncertainties.

		Net Value	
SAMA No.	Description	Best Est.	95 th Percentile CDF \$970,000 ⁽¹⁾
10	This SAMA would reduce the risk of catastrophic failure of the containment. The current Torus Hard Pipe Vent includes a rupture disk beyond an isolation valve; however, an alternate path to the Torus Hard Pipe Vent could be made in the wetwell using a rupture disk that would fail at about 60 psid. Alternatively, the containment vent valves could be changed so that they "fail open" on loss of support. Given this change, the vent path would be open on loss of support with the exception of the rupture disk. To prevent premature opening of the vent path during scenarios with loss of vent valve support, the strength of the rupture disk could be increased so that it is closer to the EOP vent pressure.	-\$212,000	
84	Provide capability to vent primary containment without support systems with procedure/training	-\$70,000	\$50,000
106	Revise ABN-19 to include guidance to implement a <90°F/hr cooldown as soon as possible following a loss of RBCCW to supplement protection of recirc seals by reducing RPV pressure.	-\$16,000	\$35,000
124	Block wall 53 reinforcement	-\$66,000	\$60,000
125C	Cable re-routing in 480V AC "A" switchgear room	-\$353,000	\$242,000 ⁽¹⁾
132	When both CTs are in operation, alignment for Oyster Creek LOOP response takes additional time due to procedure for CTs to coast down prior to switching. This SAMA would change the procedure such that they can be switched to the SBO transformer under load, eliminating the need for the CTs to coast down, if running.	-\$4,000	\$65,000
138	The main and startup transformers are located approximately 15' apart. There is a concern that a failure of one could impact the other.	-\$334,000	\$325,000

Table F.8-3. Summary of Additional Cost Beneficial SAMA if CDF Increased to 95th Percentile

⁽¹⁾ Competing risks could be significant, but are <u>not</u> accounted for.

Page F-276

F.9 References

- [F-1] GE Nuclear Energy, "Technical Support Document for the ABWR," 25A5680, Rev. 1, November 1994.
- [F-2] U.S. Nuclear Regulatory Commission, "Regulatory Analysis Technical Evaluation Handbook," NUREG/BR-0184, 1997.
- [F-3] Calvert Cliffs Application for License Renewal, Attachment 2, Appendix F, "Severe Accident Mitigation Alternatives Analysis," April 1998.
- [F-4] Applicant's Environmental Report; Operating License Renewal Stage; H. B. Robinson Steam Electric Plant Unit No. 2, Appendix F Severe Accident Mitigation Alternatives, Letter, J. W. Moyer, CP&L, to United States Nuclear Regulatory Commission, June 14, 2002, Application for Renewal of Operating License. Available on U. S. Nuclear Regulatory Commission website at http://www.nrc.gov/reactors/operating/licensing/renewal/applications/robinson.html.
- [F-5] Edwin I. Hatch Nuclear Plant Application for License Renewal, Environmental Report, Appendix D, Attachment F, February 2000.
- [F-6] Peach Bottom Application for License Renewal, Appendix E, Environmental Report, Appendix G, "Severe Accident Mitigation Alternatives."
- [F-7] Applicant's Environmental Report; Operating License Renewal Stage; Dresden Nuclear Power Station Units 2 and 3, Section 4.20 Severe Accident Mitigation Alternatives (SAMA) and Appendix F SAMA Analysis, Letter, Benjamin, Exelon, to U. S. Nuclear Regulatory Commission, January 3, 2003, Application for Renewed Operating Licenses. Available on U. S. Nuclear Regulatory Commission website at http://www.nrc.gov/reactors/operating/licensing/renewal/applications/dresden-quad.html.
- [F-8] Applicant's Environmental Report; Operating License Renewal Stage; Quad Cities Nuclear Power Station Units 1 and 2, Section 4.20 Severe Accident Mitigation Alternatives (SAMA) and Appendix F SAMA Analysis, Letter, Benjamin, Exelon, to U. S. Nuclear Regulatory Commission, January 3, 2003, Application for Renewed Operating Licenses. Available on U. S. Nuclear Regulatory Commission website at http://www.nrc.gov/reactors/operating/licensing/renewal/applications/dresden-quad.html
- [F-9] ASME RA-S-2002, Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications, April 2002.
- [F-10] Applicant's Environmental Report; Operating License Renewal Stage; Browns Ferry Nuclear Power Plant Units 1,2 and 3, Appendix E, Section 4.20 Severe Accident Mitigation Alternatives (SAMA), December 2003. Available on U.S. Nuclear Regulatory Commission website at http://www.nrc.gov/reactors/operating/licensing/renewal/applications/browns-ferry/envbfn-2.pdf
- [F-11] Applicant's Environmental Report; Operating License Renewal Stage; Nine Mile Point Units 1 and 2, Appendix E, Section 4.16 Severe Accident Mitigation Alternatives

(SAMA), May 2004. Available on U.S. Nuclear Regulatory Commission website at http://www.nrc.gov/reactors/opertating/licensing/renewal/applications/nine-mile-pt/er-reprot.pdf

- [F-12] EPRI NP-6041, "A Methodology for Assessment of Nuclear Power Plant Seismic Margin," Revision 1, August 1991.
- [F-13] Applicant's Environmental Report; Operating License Renewal Stage; Monticello Nuclear Generating Plant, Appendix F SAMA Analysis, Draft version, November 2004.
- [F-14] Chanin, D. and Young, M., Code Manual for MACCS2: User's-Guide, NUREG/CR-6613, Volume 1, SAND 97-0594, May 1998.
- [F-15] Canavan, et.al., "Oyster Creek Individual Plant Examination (IPE)", August 1992.
- [F-16] NUREG/CR-6525, "SECPOP2000: Sector Population, Land Fraction, and Economic Estimation Program," U.S. Nuclear Regulatory Commission, Washington, D.C., Rev. 1, August 2003.
- [F-17] U.S. Department of Agriculture, "1997 Census of Agriculture," National Agricultural Statistics Service, 1998. http://www.nass.usda.gov/census/census97/volume1/vol1pubs.htm
- [F-18] U.S. Department of Agriculture, "Usual Planting and Harvesting Dates for U.S. Field Crops," National Agricultural Statistics Service, December 1997. http://usda.mannlib.cornell.edu/reports/nassr/field/planting/uph97.pdf
- [F-19] NUREG-1150, "Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants," U. S. Nuclear Regulatory Commission, Washington, D.C., June 1989.
- [F-20] Applicant's Environmental Report; Operating License Renewal Stage; Brunswick Steam Electric Plant, Appendix F SAMA Analysis, Draft version, November 2004.
- [F-21] NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Oconee Nuclear Station," Supplement 2, U.S. Nuclear Regulatory Commission, Washington, D.C., December 1999.
- [F-22] Canavan, et.al., "Oyster Creek Individual Plant Examination for External Events (IPEEE)", 12/1/95.
- [F-23] EPRI, "Fire Induced Vulnerability Evaluation (FIVE)," EPRI TR-100370, April 1992.
- [F-24] EPRI, "Probabilistic Seismic Hazard Evaluation at Nuclear Power Plant Sites in the Central and Eastern United States: Resolution of the Charlston Issue," NP-6395-D, 1989.
- [F-25] 2004B Oyster Creek PRA
- [F-26] USNRC, "Procedural and Submittal Guidance for the Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities," NUREG-1407, June 1991.

- [F-27] USNRC, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants - LWR Edition," NUREG-75/087, December 1975.
- [F-28] Integrated Plant Safety Assessment Systematic Evaluation Program, Oyster Creek Nuclear Generating Station, NUREG 0822, Supplement No. 1, USNRC, January 1983.
- [F-29] USNRC, "Safety Evaluation Report, Hartsville Nuclear Plants A1, A2, B1, B2," NUREG-0014.
- [F-30] EPRI Special Report, "Guidelines for Permanent BWR Hydrogen Water Chemistry Installations – 1987 Revision," EPRI NP-5283-SR-A, September 1987.
- [F-31] USNRC, Regulatory Guide 1.91, "Evaluations of Explosions Postulated to Occur on Transportation Routes Near Nuclear Power Plants," Revision 1, February 1978.
- [F-32] Stolz, J.F. (NRC) letter to Barton, J.J., (GPU Nuclear), "Issuance of Safety Evaluation Report Relating to the Full-Term Operating License for Oyster Creek Nuclear Generating Station."
- [F-33] USNRC, Regulatory Guide 1.78, "Assumptions for Evaluating the Habitability of a Nuclear Power Plant Control Room During a Postulated Hazardous Chemical Release," June 1974.
- [F-34] Dromerick, A.W., (NRC) to Barton, J.J., (GPU Nuclear), "Issuance of Amendment TAC No. M81848."
- [F-35] Dromerick, A.W, (NRC) to Barton, J.J., (GPU Nuclear), "Review of Oyster Creek Nuclear Generating Station Individual Plant Examination (IPE) Submittal (TAC No. M74443)," August 2, 1994.
- [F-36] Pastis, H.N., (NRC) to DeGregorio (Amergen Energy), "Review of Oyster Creek Nuclear Generating Station Individual Plant Examination of External Events (IPEEE) Submittal (TAC No. M83652)," February 8, 2001.
- [F-37] Chanin, D. and Young, M., Code Manual for MACCS2: User's Guide, NUREG/CR-6613, Vol. 1, SAND 97-0594, May 1998.
- [F-38] NUREG/CR-6525, "SECPOP2000: Sector Population, Land Fraction, and Economic Estimation Program," U.S. Nuclear Regulatory Commission, Washington, D.C., Rev. 1, August 2003.
- [F-39] U.S. Department of Agriculture, "1997 Census of Agriculture," National Agriculture Statistics Service, 1998. http://www.nass.usda.gov/census/census97/volume1/vol1pubs.htm
- [F-40] U.S. Department of Agriculture, "Usual Planting and Harvesting Dates for U.S. Field Crops," National Agriculture Statistics Service, December 1997. http://usda.mannlib.cornell.edu/reports/nassr/field/planting/uph97.pdf
- [F-41] NUREG-1150, "Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants," U.S. Nuclear Regulatory Commission, Washington, D.C., June 1989.
- [F-42] Evacuation Time Estimates for the Plume Exposure Pathway Emergency Planning Zone: Oyster Creek Nuclear Generating Station, Earth Tech, February 2003.
- [F-43] 2002 Census of Agriculture, New Jersey State and County Data, Volume 1, Geographic Area Series Part 30, AC-02-A-30, June 2004.
- [F-44] Eide, S.A., Gentillon, C.D., Wierman, T.E., and Rasmuson, D.M., <u>Evaluation of Loss of Offsite Power Events at Nuclear Power Plants:</u> 1986-2003, NUREG/CR-INEEL/EXT-04-02326, (DRAFT) October 2004.
- [F-45] Perspectives Gained From the Individual Plant Examination of External Events (IPEEE) Program, US NRC, NUREG-1742, April 2002.
- [F-46] Holzworth, G.C., Mixing Heights, Wind Speeds, and Potential for Urban Air Pollution Throughout the Contiguous United States, U.S. EPA AP-101, January 1972.

ADDENDUM FA

External Events Excerpts From NUREG-1437 Vol I

Oyster Creek Nuclear Generating Station

Severe accidents initiated by external phenomena such as tornadoes, floods, earthquakes, fires, and sabotage have not traditionally been discussed in guantitative terms in Final Environmental Statements (FESs). With the exception of sabotage, the NRC staff has, however, reviewed or performed detailed probabilistic assessments of external events for Zion Units 1 and 2, Indian Point Units 2 and 3, Limerick Units 1 and 2, Surry Unit 1, Peach Bottom Unit 2, and Millstone Unit 3. In most cases, the external event risks were determined to be comparable to internal event risks. However, for Zion and Limerick, the licensee's PRAs indicated that external events could be significant contributors to risk. For the Indian Point units, NRC staff evaluations also indicated that external events could significantly contribute to severe accident risk. The most recent NRC analysis of external events has been the NUREG-1150 external events assessment for Surry Unit 1 and Peach Bottom Unit 1. This analysis examined a broad range of external events and found that they could range from negligible to significant contributors to risk when compared with internal initiators. It should be noted, however, that in cases where external event risk was shown to be a significant contributor to the overall risk, the majority of the estimated risk arose from large beyond design basis earthquakes; but in all cases, the total risk (internal and external) is still small.

NRC's earthquake design standards have been conservatively developed to ensure protection of the public health and safety from earthquakes whose magnitudes are well above the most likely earthquake magnitude when considering the collective earthquake history for specific plant sites in the United States. Therefore, earthquakes exceeding NRC seismic design standards are extremely unlikely. However, in the unlikely event of such an earthquake, there would be substantial damage to older residential structures, commercial structures, and highhazard facilities such as dams whose seismic design standards are below nuclear seismic design standards. The societal impact due to the non-nuclear losses alone from an earthquake larger than the design basis of a nuclear plant, including property damage, injuries, and fatalities, would be major. The technology for assessing losses from such large earthquakes is a developing one, and there are several ongoing studies of this technology, including work at the United States Geological Survey. Presently there is no agreed-upon method for performing such assessments, although a recent report of the National Academy of Sciences suggests some broad guidelines CNAS 1989). The NRC has not developed a method for assessing the societal losses from large earthquakes such that the reactor contribution to accident consequences can be quantitatively compared with the non-nuclear losses. However, as supported by at least one study (Lee et al. 1979), the commission expects that the reactor accident contribution to the losses from large beyond design basis earthquakes would be small relative to the non-nuclear losses. While this in itself does not mean the reactor consequences from such an earthquake would be small, the Commission concludes that even with potentially high consequences from a

beyond design basis earthquake, the extremely low probability of such an earthquake yields a small risk from beyond design basis earthquakes at existing nuclear power plants.

With regard to sabotage, quantitative estimates of risk from sabotage are not made in external event analyses because such estimates are beyond the current state of the art for performing risk assessments. The commission has long used deterministic criteria to establish a set of regulatory requirements for the physical protection of nuclear power plants from the threat of sabotage. 10 CFR Part 73, "Physical Protection of Plants and Materials", delineates these regulatory requirements. In addition, as a result of the World Trade Center bombing, the Commission amended 10 CFR Part 73 to provide protection against malevolent use of vehicles, including land vehicle bombs. This amendment requires licenses to establish vehicle control measures, including vehicle barrier systems to protect against vehicular sabotage. The regulatory requirements under 10 CFR part 73 provide reasonable assurance that the risk from sabotage is small. Although the threat of sabotage are not reasonable assurance that the risk from sabotage is small. Although the threat of sabotage are not reasonably expected. Nonetheless, if such events were to occur, the commission would expect that resultant core damage and radiological releases would be no worse than those expected from internally initiated events.

Based on the above, the commission concludes that the risk from sabotage and beyond design basis earthquakes at existing nuclear power plants is small and additionally, that the risks from other external events, are adequately addressed by a generic consideration of internally initiated severe accidents.

The NRC is continuing to evaluate ways to reduce the risk from nuclear power plants from external events. For example, each licensee is performing an individual plant examination to look for plant vulnerabilities to internally and externally initiated events and considering potential improvements to reduce the frequency or consequences of such events.