

GPU Nuclear, Inc. Three Mile Island Nuclear Station Route 441 South Post Office Box 480 Middletown, PA 17057-0480 Tel 717-948-8461

July 22, 2005 E910-05-036

U.S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, DC 20555

Gentlemen,

Subject Saxton Nuclear Experimental Corporation (SNEC) Operating License No., DPR-4 Docket No. 50-146 FSS Report for SSGS Firing Aisle

The purpose of this letter is to submit for your review the attached FSS Report for SSGS Firing Aisle. One CD-ROM is included in this submission. The CD-ROM labeled: "FSS Report – SSGS Firing Aisle – Publicly Available" contains the following 5 files:

Document Title	Document Title File Name	
. Main Report	001 FSS Report – SSGS Firing Aisle.pdf	0.195
Appendix A (pages 1-6)	002 – Appendix A (1-6).pdf	7.84
Appendix A (attachments 1 to 14)	003 - Appendix A (attachments 1 to 14).pdf	45.6
Appendix B	004 - Appendix B.pdf	14.4
Appendix C	005 – Appendix C.pdf	7.41

If you have any questions on this information, please contact Mr. Art Paynter at (814) 635-4384.

Sincerely,

for G. A. Kuehn

- Program Director, SNEC
- cc: NRC Project Manager NRC Project Scientist, Region 1 Mr. Tim Bauer, ORISE Project Leader







Prepared by GPU Nuclear, Inc.

July 2005

# **Table Of Contents**

**Executive Summary** 

- 1.0 Purpose and Scope
- 2.0 Survey Area Description
- 3.0 Operating History
  - 3.1 Plant Operations
  - 3.2 Survey Area Remediation Status
- 4.0 Site Release Criteria
- 5.0 Final Status Survey Design / DQO Process
- 6.0 Final Status Survey Results
  - 6.1 Summary for Survey Unit SS13-1
  - 6.2 Summary for Survey Unit SS13-2
- 7.0 Data Assessment
  - 7.1 Assessment Criteria
  - 7.2 Summary of Overall Results
  - 7.3 Survey Variations
  - 7.4 Quality Control Measurements
- 8.0 Final Survey Conclusions
- 9.0 References
- 10.0 Appendices

# Executive Summary

This report presents the results and conclusions of the final status survey (FSS) of the Class 3 structural surfaces of the Saxton Nuclear Experimental Corporation (SNEC) facility designated as SS13. This FSS includes surveys of residual structural surfaces (e.g. concrete) of the firing aisle of the Saxton Steam Generating Station of the SNEC site and was conducted in the summer of 2003.

The FSS was performed in accordance with the SNEC License Termination Plan (LTP). The firing aisle survey area was divided into two survey units. Each unit consisted of relatively flat residual structural surfaces. Data was collected from each survey unit in accordance with the specific survey design data collection requirements. The following is a summary of the measurements performed:

1) Automated position sensitive large area detector surface contamination monitor (SCM) scans of about 15% of the surface area.

The SCM surveys were conducted by a contractor utilizing a large area position sensitive gas flow proportional counter. Portions of the survey units could not be surveyed with this equipment because of the large size of this detector and surface irregularity but coverage percentages were adequate.

The collected FSS survey data demonstrate that the 640 square meters of the SSGS firing aisle survey area meets the radiological release criteria for unrestricted use specified in 10CFR20.1402. Therefore GPU Nuclear, Inc. concludes that the area meets the NRC requirements and may be released for unrestricted use.

# 1.0 Purpose and Scope

This report presents the results and conclusions of the final status survey of the residual structural surfaces of the SSGS firing aisle consisting of two survey units designated SS13-1 and SS13-2 west of the SNEC facility. It provides the information required by 10CFR50.82(a)(11) and the SNEC license termination plan (LTP) to demonstrate that this area meets the radiological criteria for unrestricted use specified in 10CFR20.1402.

This report describes the radiological data collected in two survey units consisting of two Class 3 survey units of residual structural surface of the SSGS firing aisle. This report only addresses the FSS performed on this specific area . The format of this report follows the guidance contained in reference 9.2.

# 2.0 Survey Area Description

The SSGS firing aisle is Class 3 impacted structural surface located up to about 6 feet underground to the west of the SNEC facility. The survey unit encompasses about 640 square meters of concrete. Because the area was clearly delineated as floors and walls, the survey area was divided into two survey units. The two survey units are discussed below. The individual survey unit designations are derived from table 5-2 of the SNEC LTP (reference 9.3).

Survey unit SS13-1 is a Class 3 residual concrete surface of the SSGS firing aisle. It consists of the floor of the main firing aisle area – a surface about 6 feet below grade. The survey unit is approximately 560 square meters.

Survey unit SS13-2 is a Class 3 residual concrete surface of the SSGS firing aisle. It consists of the walls of the main firing aisle area extending from the floor slab about 6 feet below grade up to the boiler.pad at grade level. The survey unit is approximately 80 square meters.

# 3.0 Operating History

## 3.1 Plant Operation

The Saxton Nuclear Experimental Corporation (SNEC) facility included a pressurized water reactor (PWR), which was licensed to operate at 23.5 megawatts thermal (23.5 MWTh). The reactor, containment vessel and support buildings have all been removed. The facility is owned by the Saxton Nuclear Experimental Corporation and is licensed by GPU Nuclear, Inc. The SNEC facility is maintained under a Title 10 Part 50 license and associated Technical

Specifications. In 1972, the license was amended to possess but not operate the SNEC reactor.

The facility was built from 1960 to 1962 and operated from 1962 to 1972 primarily as a research and training reactor. Steam from the SNEC reactor was directed to the adjacent Saxton Steam Generating Station (SSGS) to generate electricity. Other shared systems also introduced SNEC activity into the SSGS and the main SNEC discharge entered the SSGS discharge tunnel. After shutdown in 1972, the SNEC facility was placed in a condition equivalent to the current SAFSTOR status. Since then, it has been maintained in a monitored condition. The fuel was removed in 1972 and shipped to a (now DOE) facility at Savannah River, SC, who is now the owner of the fuel. As a result of this, neither SNEC nor GPU Nuclear, Inc. has any further responsibility for the spent fuel from the SNEC facility. The building and structures that supported reactor operation were partially decontaminated by 1974. The SSGS was dismantled circa 1974.

In the late 1980s and through the 1990s, additional decontamination and disassembly of the containment vessel and support buildings and final equipment and large component removal was completed. Final decontamination and dismantlement of the reactor support structures and buildings was completed in 1992. Large component structures, pressurizer, steam generator, and reactor vessel were removed in late 1998. Containment vessel removal (to below grade) and backfill was completed in late 2003. Currently, decontamination, disassembly and demolition of the SNEC facility buildings and equipment has been completed and the facility is in the process of Final Status Survey for unrestricted release and license termination.

## 3.2 Survey Area Remediation Status

No known remediation occurred in the firing aisle.

# 4.0 Site Release Criteria

The site release criteria applied to the structural surface areas of the SSGS firing aisle correspond to the radiological dose criteria for unrestricted use per 10CFR20.1402. The dose criteria is met "if the residual radioactivity that is distinguishable from background radiation results in a Total Effective Dose Equivalent (TEDE) to an average member of the critical group that does not exceed 25 mrem/yr, including that from groundwater sources of drinking water, and that the residual radioactivity has been reduced to levels that are as low as reasonably achievable (ALARA)".

Levels of residual radioactivity that correspond to the allowable dose to meet the site or survey unit release criteria for structural surfaces were derived by analyses using a building re-use scenario. The dose modeling for this scenario is

explained in the SNEC LTP (reference 9.3). The derived concentration guideline levels (DCGL) shown in Table 5-1 of the SNEC LTP form the basis for satisfying the site release criteria.

Residual radioactivity sample results for the surfaces were used to calculate a surrogate Cs137 DCGL. The adjusted surrogate DCGL was developed using the methodology described in the SNEC LTP section 5.2.3.2.3 based on nuclide specific DCGLs from Table 5-1 of the LTP.

An adjustment was made to the surrogate Cs137 DCGL to address the de-listed radionuclides as described in the LTP section 6.2.2.3. SNEC has instituted an administrative limit of 75% of the DCGL for all measurement results. The de-listed radionuclides are conservatively accounted for in this 25% reduction since the de-listed radionuclides were only 4.7% of the dose contribution. These adjustment factors are discussed in section 6 of the SNEC LTP.

# 5.0 Final Status Survey Design and DQO

The SNEC calculation providing the design of the survey for these survey units is provided in Appendix A. Scans of the two Class 3 survey units covered 13% of SS13-1 and 28% of SS13-2. Scans were conducted using an automated position sensitive large area gas flow proportional counter ("Surface Contamination Monitor" - SCM).

No fixed point measurements were performed. Because of the manner in which the SCM measures continuously and collects position information as well, SCM scanning is equivalent to continuous, full coverage static measurements. Section 5.4.3 of the SNEC LTP provides for use of such positionally sensitive scanning in lieu of fixed point measurements when the scanning system has a detection limit a small fraction of the DCGL (e.g. 10%). MARSSIM section 6.7.1 requires that fixed point measurements be capable of detecting the DCGL. In addition, section 6.4.1 of MARSSIM briefly discusses the potential use of modern, positionally referenced survey instrumentation. The maximum MDC observed for a 100cm<sup>2</sup> area in the SCM scanning was less than 50% of the DCGL. Although the LTP recommends lower detection limits for use of the SCM as fixed point measurements, the use of the SCM results for direct measurements is acceptable because the detection limits meets the MARSSIM requirements. Therefore, no static measurements are required.

The survey design uses a surrogate Cs137/gross beta effective DCGL developed from radionuclide mix analyses from samples collected before the Final Status Survey in the vicinity of the survey unit. The mix was based on radionuclide mix data (including the hard-to-detects listed in Table 5-1 of the LTP) primarily from the SSGS basement footprint area (attachment 2 of appendix A).

Cs137, Co-60, Am241, and Pu239 were positively detected in one or more of these samples and are accounted for in the adjusted surrogate DCGL. Additional sample results obtained later were used to modify the mix after the survey. The following table (Table 1) presents the Data Quality Objectives (DQO) and other relevant information from the survey design package.

DQO/Design Parameter	SS13-1, SS12-2	
SNEC Design Calc. #	E900-03-019	
MARSSIM Classification	3	
Survey Unit Area (m²)	560, 80	
Statistical Test	N/A**	
Type 1 decision error (α)	N/A	
Type 2 decision error (β)	N/A	
LBGR (cpm)	N/A	
Estimated σ (dpm/100cm²)	N/A	
Relative Shift ( $\Delta/\sigma$ )	N/A	
Number of static points	N/A	
DCGLw* (Cs137 dpm/100cm <sup>2</sup> )	13571	
75%Admin Limit* (Cs137 dpm/100cm²)	10178	
DCGLw (Cs137 cpm)	N/A	
Action Level (cpm)	N/A	
Scan MDC (dpm/100cm <sup>2</sup> )	6547	
SNEC Survey Request #	SR84	
Scan Survey Instrument	SCM	

Table 1 – DQO/Design

\* this table presents final design DCGL and action level values from appendix C

\*\*because the SCM performs continuous scans with positional information that are equivalent to full coverage fixed point surveys, some MARSSIM design parameters are not applicable (e.g. LBGR, number of static points, etc.). The SCM produces results directly in dpm/100cm<sup>2</sup> so cpm based factors are not used.

# 6.0 Final Status Survey Results

The following sections provide the survey summary results for each survey unit as required by the respective design. Summary data was taken from reference 9.8 and 9.9 which are filed in the SNEC history files.

## 6.1 Survey Unit SS13-1

## 6.1.1 Scan survey

Scan measurements were made in SS13-1 using the automated SCM system with a design MDCscan of 6547 dpm/100cm<sup>2</sup> (section 2.1.10 on page 3 of appendix A). Actual scan MDC was 3622 dpm/100cm<sup>2</sup> (reference 9.9). The adjusted surrogate gross beta DCGLw for this survey unit for the SCM scans was 13571 dpm/100cm<sup>2</sup> and the 75% administrative limit was 10178 dpm/100cm<sup>2</sup> (table 6 of appendix C).

Of the 560 square meters of this survey unit, portions were inaccessible to the SCM scanning for various reasons, particularly uneven surfaces not amenable to large probe automated scanning. Since this is a Class 3 area, scanning was not attempted on all of the surface. Of the 560 square meters, 74.4 were actually scanned. Therefore about 13 percent of the survey unit was scanned which is consistent with coverage requirements for Class 3 survey units.

All SCM surveys indicated activity less than the 75% administrative limit for a minimum 1 square meter grid averaging. One square meter averages are applied to the SCM data since this is the minimum size of an area for emc testing per the SNEC LTP. No follow-up 43-68 scans were required.

## 6.1.2 Fixed point measurements

This survey unit was scanned using an automated position sensitive proportional counter. This survey unit did not receive fixed point direct static measurements. As discussed in Section 5.0, the SCM is equivalent to continuous static measurements of the entire surface scanned.

## 6.2 Survey Unit SS13-2

## 6.2.1 Scan survey

Scan measurements were made in SS13-2 using the automated SCM system with a design MDCscan of 6547 dpm/100cm<sup>2</sup> (section 2.1.10 on page 3 of appendix A). Actual scan MDC was at most 4304 dpm/100cm<sup>2</sup> (reference 9.9). The adjusted surrogate gross beta DCGLw for this survey unit for the SCM scans was 13571 dpm/100cm<sup>2</sup> and the 75% administrative limit was 10178 dpm/100cm<sup>2</sup> (table 6 in appendix C).

Of the 80 square meters of this survey unit, portions were inaccessible to the SCM scanning for various reasons, particularly uneven surfaces not amenable to large probe automated scanning. Since this is a Class 3 area, scanning was not attempted on all of the surface. Of the 80 square meters, 22 were actually scanned. Therefore about 28 percent of the survey unit was scanned which is consistent with coverage requirements for Class 3 survey units.

All SCM surveys indicated activity less than the DCGLw for a minimum 1 square meter grid averaging. One square meter averages are applied to the SCM data since this is the minimum size of an area for emc testing per the SNEC LTP. No follow-up 43-68 scans were required.

## 6.2.2 Fixed point measurements

This survey unit was scanned using an automated position sensitive proportional counter. This survey unit did not receive fixed point direct static measurements. As discussed in Section 5.0, the SCM is equivalent to continuous static measurements of the entire surface scanned.

# 7.0 Data Assessment

## 7.1 Assessment Criteria

The final status survey data has been reviewed to verify authenticity, appropriate documentation, guality, and technical acceptability. The review criteria for data acceptability are:

- 1) The instruments used to collect the data were capable of detecting the radiation of the radionuclide of interest at or below the investigation levels.
- 2) The calibration of the instruments used to collect the data was current and radioactive sources used for calibration were traceable to recognized standards or calibration organizations.
- 3) Instrument response was checked before and, when required, after instrument use each day data was collected.
- 4) Survey team personnel were properly trained in the applicable survey techniques and training was documented.
- 5) The MDCs and the assumptions used to develop them were appropriate for the instruments and the survey methods used to collect the data.
- 6) The survey methods used to collect the data were appropriate for the media and types of radiation being measured.
- 7) Special instrument methods used to collect data were applied as warranted by survey conditions, and were documented in accordance with an approved site Survey Request procedure.
- 8) The custody of samples that were sent for off-site analysis were tracked from the point of collection until final results were provided.

9) The final status survey data consists of qualified measurement results representative of current facility status and were collected in accordance with the applicable survey design package.

If a discrepancy existed where one or more criteria were not met, the discrepancy was reviewed and corrective action taken (as appropriate) in accordance with site procedures.

The statistical test does not need to be performed for this final status survey since the data clearly show that the survey unit meets the release criteria because all measurements in the survey units are less than or equal to the DCGLw.

## 7.2 Summary of Overall Results

SS13-1 had no alarm points during scan surveys of approximately 13% of the surface. Scan MDCs were adequate. Fixed point measurements were not required consistent with the SNEC LTP and MARSSIM for automated position sensitive survey equipment. Scan fraction and elimination of fixed point measurements meets LTP and MARSSIM requirements.

SS13-2 had no alarm points during scan surveys of approximately 28% of the surface. Scan MDCs were adequate. Fixed point measurements were not required consistent with the SNEC LTP and MARSSIM for automated position sensitive survey equipment. Scan fraction and elimination of fixed point measurements meets LTP and MARSSIM requirements.

## 7.3 Survey Variations (Design, survey request, LTP)

7.3.1 Portions of the survey units could not be scanned using the SCM automated detector system. However, this was considered in the design that expected scanning of accessible areas.

## 7.4 QC comparisons

## 7.4.1 Scan surveys

Areas were rescanned as QC duplicates. The QC rescans did not identify any activity above alarm points and so are in agreement with the primary scans and support the same conclusion that the survey unit passes. QC scans were conducted on  $6.6 \text{ m}^2$  of the survey area, which represents about 6.9 percent of the 96 square meters originally scanned. This exceeds the minimum 5% required.

## 7.4.2 Fixed Point measurements

Since no fixed point measurements were required due to the unique nature of SCM scanning, no specific fixed point QC measurements were made.

# 8.0 Final Survey Conclusions

The Structural Surfaces of the SSGS firing aisle survey units SS13-1, SS13-2 final status survey was performed in accordance with the SNEC LTP, site procedures, design calculations, and Survey Request requirements. FSS data was collected to meet and/or exceed the quantity specified or required for each survey unit design. The survey data for each survey unit meets the following conditions:

- 1) The average residual radioactivity on the surfaces is less than the derived surrogate DCGLw in all of the survey units.
- All measurements were less than the DCGLw in units SS13-1 and SS13-2.

These conditions satisfy the release criteria established in the SNEC LTP and the radiological criteria for unrestricted use given in 10CFR20.1402. Therefore it is concluded that the SNEC Structural Surface Areas of the SSGS firing aisle designated SS13 are suitable for unrestricted release.

# 9.0 <u>References</u>

- 9.1 SNEC Facility Site area grid map Drawing number SNECRM-020
- 9.2 SNEC procedure E900-ADM-4500.60 "Final Status Survey Report"
- 9.3 SNEC License Termination Plan
- 9.4 NUREG 1575 "Multi-Agency Radiation Survey and Site Investigation Manual" (MARSSIM), revision 1 August 2000
- 9.5 COMPASS computer program, Version 1.0.0, Oak Ridge Institute for Science and Education
- 9.6 SNEC procedure E900-IMP-4500.59, "Final Site Survey Planning and DQA"
- 9.7 SNEC procedure E900-IMP-4520.04, "Survey Methodology to Support SNEC License Termination"
- 9.8 SNEC Survey Request (SR) # SR084
- 9.9 Shonka Research Associates, Inc. "Final Report for SCM Survey of Saxton Nuclear Experimental Corporation", March 3, 2005

# 10.0 Appendices

Appendix A - SNEC Calculation E900-03-019 – "Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design" (14 pages plus numerous attachments)

Appendix B - SNEC Calculation E900-03-019 – "Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design" (14 pages plus numerous attachments) Revision 1

Appendix C – DCGL Calculation Logic – SSGS Footprint

Appendix A

.

Survey Design

.

•

FirstEnergy Sh					 :т		
		ULATION DESC			. (		
Calculation Number		Revision Number		Effective Date		Page Numb	er
E900-03-019		0	-	8/14/03	,	1 a	of 14
Subject	<u> </u>			0/17/00	I		
Shonka SSGS Footprint & CV	Steam Pipe Tu	unnel (SSGS Side)	FS	S Survey Design			
Question 1 - Is this calculation defi	ned as "In QA Sco	ope"? Refer to definition	on 3	.5. Yes 🛛 No			
Question 2 - Is this calculation defined	ned as a *Design	Calculation"? Refer to	o de	finitions 3.2 and 3.3.	Yes 🛛	No 🗌	]
Question 3 - Does the calculation h	ave the potential	to affect an SSC as de	escr	ibed in the USAR?	Yes 🗌	No 🛛	
NOTES: If a "Yes" answer is obtained f Assurance Plan. If a "Yes" answer calculation as the Technical Reviewer. calculation. Calculations that do not have	or Question 1, the c is obtained for Que If a "YES" answer i re the potential to af	alculation must meet the estion 2, the Calculation s obtained for Question 3 fect SSC's may be imple	requ n Or 3, Si men	Jirements of the SNEC iginator's Immediate s NEC Management app ted by the TR.	Facility D supervisor roval is re	ecommission should not quired to imp	ning Quality review the plement the
	DESC	<b>RIPTION OF RE</b>	VIS	SION		i	
	·						
	APPF	ROVAL SIGNAT	ŲR	ES cred		·	
Calculation Originator	P. Donnachi	1 A Amarka		A	Date	8/14/	03
Technical Reviewer	R. Holmes/	atholus		V	Date	8/14	1/03
Additional Review			<u> </u>		Date		
Additional Review	۲ ۱				Date		
SNEC Management Approval	A. Paynter/	LH+W			Date	8/11	4/03

.

FirstEnergy	SNEC CALCULATION SHEET	
Calculation Number	Revision Number	Page Number

## Revision Number

0

#### Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

#### 1.0 PURPOSE

- 1.1 The purpose of this calculation is to provide the survey design guidance to be followed for conducting final status surveys (FSS) in the Saxton Steam Generation Station (SSGS) footprint and the adjacent CV Steam Pipe Tunnel (805' elev.). The SSGS footprint consists of the "Firing Aisle" (806' elev.), SSGS Basement Area (790' elev.) and Seat Chamber 1 & 2 Roof areas (~803' elev.). The CV Steam Pipe Tunnel extends off the northeast corner of the SSGS footprint.
- 1.2 Shonka Research Associates (SRA) will conduct scan surveys using procedures reviewed and approved by SNEC. These procedures are attached as Appendices.

### 2.0 SUMMARY OF RESULTS

- The following information will be used to conduct the applicable FSS for this survey design: 2.1
  - The SSGS Footprint area is divided into eleven (11) survey units, i.e. six (6) Class 2.1.1 1, two (2) Class 2 and three (3) Class 3 survey units.
  - 2.1.2 The SSGS Survey Unit (SU) Numbers are as follows (See Attachments 7 & 8 for survey unit locations):

SU Number	Area Description	Classification	Area (m <sup>2</sup> ) <sup>1</sup> .
SS13-1	Firing Aisle Floor (806')	3	560
SS13-2	Firing Aisle Walls	3	80
SS14-1	Basement Floor (790') <sup>2.</sup>	1	75
SS14-2	Basement Floor (790') <sup>2.</sup>	1	75
SS14-3	Basement Floor (790') <sup>2.</sup>	1	88
SS14-4	Basement Floor (790') <sup>2.</sup>	1	77
SS14-5	Basement Floor (790') <sup>2.</sup>	1	56
SS15	Basement Wall (East End)	1	100
SS16	Basement Walls Up to 2 meters	2	240
SS17	Basement Walls > 2 meters	3	350
SS18	Seal Chamber 1 & 2 Roofs	2	32

Note 1: Area and linear dimensions are approximations.

Note 2: Basement floors will include walls of trenches where possible.

2.1.3 The CV Steam Pipe Tunnel (SSGS Side) consists of three parts: floor, walls and ceiling. Since characterization information in this tunnel is limited and radioactive steam passed through it, the entire area has been classified as Class 1. This area is not described in the current Revision 2 of the SNEC LTP. However, this area will be included in Table 5-2 under the SSGS section in the next LTP revision. The CV Steam Pipe Tunnel is divided into three (3) Class 1 survey units.

FirstEnergy	SNEC CALCULATION SHEET	
Calculation Number	Revision Number	Page Number

0

Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

2.1.4 The Survey Unit Numbers for these CV Steam Pipe Tunnel (SSGS Side) are as follows:

SU Number	Area Description	Classification	Area (m <sup>2</sup> )
SS22-1	CV Steam Pipe Tunnel floor	1	20
SS22-2	CV Steam Pipe Tunnel walls	1	45
SS22-3	CV Steam Pipe Tunnel ceiling	1	15

- 2.1.5 The number of static measurement points will be developed, as applicable, after SRA completes their survey and results are reviewed by the FSS group.
- 2.1.6 The minimum scan coverage for Class 1 areas will be 100%, Class 2 areas, 50% and for Class 3 areas, 10-50%.
- 2.1.7 Scan speed will be set in accordance with SRA procedures and the SNEC MDC<sub>scan</sub> value calculated for structure surfaces.
- 2.1.8 The SSGS Footprint and the adjacent CV Steam Pipe Tunnel have different <u>surface DCGL</u> values. For this design the following DCGL values apply:

SSGS Footprint – <u>13,095 dpm/100 cm<sup>2</sup></u>

CV Steam Pipe Tunnel – <u>7628 dpm/100 cm<sup>2</sup></u>

These values are the 75% administrative limits for the surrogate Cs-137 values calculated in Attachments 3 & 5.

2.1.9 As a guideline for elevated measurement (hot spot) determination a surface area <u>DCGL<sub>emc</sub></u> will use an apriori Cs-137 surface area factor for a 1-m<sup>2</sup> area equal to 11. These values are calculated to be:

SSGS Footprint - <u>144,045 dpm/100 cm<sup>2</sup></u>

CV Steam Pipe Tunnel - 83,908 dpm/100 cm<sup>2</sup>

Note: If an elevated measurement (hot spot) is detected a dimensional analysis will be made of the hot spot and the appropriate area factor will be applied from SNEC LTP Table 5-15a.

2.1.10 The <u>MDC<sub>scan</sub></u> values for this design that SRA must achieve are:

SSGS Footprint - 6547 dpm/100 cm<sup>2</sup>

CV Steam Pipe Tunnel – <u>3814 dpm/100 cm<sup>2</sup></u>

- 2.1.11 Areas greater than the DCGL<sub>w</sub> must be identified, documented, marked, and bounded to include an area estimate.
- 2.1.12 Class 1 areas with surface deformations that cannot be surveyed by Shonka will be identified by marking or painting around the suspect area's perimeter.

SNEC CA	ALCULATION SHEET		
Calculation Number	Revision Number	Page Number	

0

Page 4 of \_14\_

Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

- 2.1.13 Remediation is indicated when any area exceeds 3 x the DCGL<sub>w</sub> for any scan measurement or when the value for any area of ~1 square meter is greater than the DCGL<sub>emc</sub>. Note: If additional remediation is performed the survey unit design is void.
- 2.1.14 Gas flow proportional counter (GFPC) will be used IAW SRA procedures.

#### 3.0 <u>REFERENCES</u>

- 3.1 SNEC Facility License Termination Plan.
- 3.2 Procedure E900-IMP-4500.59, "Final Site Survey Planning and DQA".
- 3.3 SNEC procedure E900-IMP-4520.04, "Survey Methodology to Support SNEC License Termination".
- 3.4 SNEC procedure E900-IMP-4520.06, "Survey Unit Inspection in Support of FSS Design".
- 3.5 NUREG-1575, "Multi-Agency Radiation Survey and Site Investigation Manual", August 2000.
- 3.6 SRA Procedures See Appendix Section 6.0.
- 3.7 SNEC Calculation E900-03-012, "Effective DCGL Worksheet Verification."

#### 4.0 ASSUMPTIONS AND BASIC DATA

- 4.1 SRA procedures to be used to perform scan surveys.
- 4.2 SNEC LTP section 2.2.4.1.5 and Figure 2-25 provide a description of the SSGS Footprint.
- 4.3 Attachment 6 provides figure of the CV Steam Pipe Tunnel (SSGS Side).
- 4.4 Remediation History

The Saxton Steam Generating Station (SSGS) Footprint consists of multiple levels. The upper level, "Firing Aisle" (~806' El), contained little or no contaminated surfaces. However, several drain lines contained levels of Cs-137 that was discernable above typical background values. The majority of this piping was removed during the remediation process. Any impacted piping that is to be left behind will be sampled and surveyed in accordance with SNEC site procedures.

The lower level, SSGS Basement Area (~790'), was surveyed and sampled in stages because of elevated ground water levels, which would have normally resided to a depth several feet above the floor (~790'). Water was pumped from region to region at this elevation to allow the completion of the characterization process on the walls and floor sections of the basement area. Results from surveys and sampling in this region show somewhat contaminated surfaces exist on the floor and in the sump areas at this lower elevation. Tie lines (piping) between sumps were also contaminated and were cut out. Surface drain lines and miscellaneous piping that were impacted and accessible were removed. Other piping in this region that showed elevated levels of residual contamination and will be treated in accordance with SNEC site procedures.

FirstEnergy	SNEC CALCU	LATION SHEET	
Calculation Number		Revision Number	Page Number
E900-03-019		0	Page 5 of _14

#### Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

Characterization results for the SSGS area are presented in the SNEC LTP, Tables 2-3a through 2-3d and 2-29. This is a complex structure both physically and radiologically. Table 5-2 provides the survey classifications that result from the complete characterization data for this area.

The west end of the CV Steam Pipe Tunnel exited the southwest side of the pipe tunnel that surrounds the CV. The CV Steam Pipe Tunnel then connected to the SSGS. The tunnel is known to have had trace amounts of surface contamination from leaking steam pipes. All piping has been removed from this tunnel. It is presently sealed at its end with a metal and/or concrete block wall. Since this area was potentially surface contaminated and since it was not physically isolated from the SSGS, it poses some questions as to just how well SSGS cleanup was accomplished prior to demolition. In 2001 surface scans and loose contamination surveys were performed in 2001. Results from these surveys indicated <1000 dpm/100 cm<sup>2</sup> beta-gamma and <15 dpm/100 cm<sup>2</sup> alpha for removable surface contamination, surface scans <100 ncpm (RM-14) and <0.1 mr/hr general area. On 8/14/03 paint chips were taken from the tunnel wall. An evaluation of these chips determined that there was no surface activity between the paint layer and the bare wall. This paint was determined to have been part of the original structure and not used to cover up contamination. Gamma scans (ref. gamma log numbers 5-14471 and 1-14472) performed on the paint chips indicated no radionuclides above minimum detectable activity (MDA). Therefore, there was no reason to remove paint prior to FSS.

- 4.5 This survey determines the effective DCGL<sub>w</sub> value for Cs-137 using the spreadsheet mix in Attachments 3 & 5. A 25% reduction to the effective DCGL<sub>w</sub> was performed to address de-listed radionuclides. The SNEC facility has instituted an administrative limit of 75% for the allowable dose for all measurement results. The de-listed radionuclide dose is accounted for within the 75% administrative limit.
- 4.6 Radionuclide mixes used to determine effective DCGL<sub>w</sub> were taken from Attachments 2 & 4.
- 4.7 The MDC<sub>scan</sub> calculation is determined based on LTP section 5.5.2.5. The calculation simply reduces the applicable DCGL<sub>w</sub> by 50%.
- 4.8 Special measurements including gamma-ray spectroscopy are not included in this survey design.
- 4.9 Static and other survey measurements may be conducted as applicable after review of the SRA survey is completed. This design will be revised to incorporate these surveys as determined by the FSS group.
- 4.10 The survey design checklist is listed in Attachment 1.

#### 5.0 CALCULATIONS

SSGS Footprint

- The required DCGLw =  $17,461 \times 0.75 = 13,095 \text{ dpm}/100 \text{ cm}^2$ .
- The MDC<sub>scan</sub> =  $13,095 \times 0.5 = 6547 \text{ dpm}/100 \text{ cm}^2$ .
- DCGL<sub>emc</sub> for 1  $m^2$  = 13,095 X AF of 11 = 144,045 dpm/100 cm<sup>2</sup>.

## SNEC CALCULATION SHEET

Calculation Number

E900-03-019

Revision Number

0

Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

CV Steam Pipe Tunnel

- The required DCGLw =  $10,170 \times 0.75 = 7628 \text{ dpm}/100 \text{ cm}^2$ .
- The MDC<sub>scan</sub> =  $7628 \times 0.5 = 3814 \text{ dpm}/100 \text{ cm}^2$ .
- DCGL<sub>emc</sub> for  $1 \text{ m}^2 = 7628 \text{ X AF}$  of  $11 = 83,908 \text{ dpm}/100 \text{ cm}^2$ .

### 6.0 APPENDICES

- 6.1 Attachment 1, Survey Design Checklist.
- 6.2 Attachment 2, Sample Results for SSGS Footprint
- 6.3 Attachment 3, SSGS Footprint Effective Area DCGL<sub>w</sub> for Cs-137 (dpm/100 cm<sup>2</sup>)
- 6.4 Attachment 4, Sample Results for CV Pipe Tunnel (SSGS Side)
- 6.5 Attachment 5, CV Tunnel (SSGS Side) Effective Area DCGL for Cs-137 (dpm/100 cm<sup>2</sup>)
- 6.6 Attachment 6, CV Steam Pipe Tunnel (SSGS Side) Figure
- 6.7 Attachment 7, SSGS Footprint Firing Aisle & Top of Seal Chambers
- 6.8 Attachment 8, SSGS Footprint Basement (790')
- 6.9 Attachment 9, SRA SCM Procedure 001, Rev 6, Confirmation and Calibration of the Incremental Encoder.
- 6.10 Attachment 10, SRA SCM Procedure 005, Rev 6, Requirements for Completion of the Survey Using the SCM.
- 6.11 Attachment 11, SRA SCM Procedure 006, Rev 4, Performance of a Position Calibration on a PSPC.
- 6.12 Attachment 12, SRA SCM Procedure 007, Rev 7, Source Response Check and Performance Based Check of any PSPC Detector Configuration Installed on the SCM.
- 6.13 Attachment 13, SRA SCM Procedure 008, Rev 3, Conduct of Operations for Surveys Using the SCM/SIMS:
- 6.14 Attachment 14, SRA SCM Procedure 011, Rev 1, Survey Naming Convention when Using the SCM.

# FirstEnergy

#### SNEC CALCULATION SHEET

Calculation Number E900-03-019 Page Number

Page 7 of \_14\_

Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

# Attachment 1

Revision Number

0

## **Survey Design Checklist**

Calcula	alculation No. Location Code: See attached design for location codes.			
ITEM	REVIEW F	ocus	Status (Circle One)	Reviewer Initials & Date
1	Has a survey design calculation number been description p	assigned and is a survey design summary rovided?	Yes N/A	108/14/03
2	Are drawings/diagrams adequate for the subject the subject to heading	ect area (drawings should have compass s)?	Yes N/A	N
3	Are boundaries properly identified and is the su	urvey area classification clearly indicated?	Yes, N/A	
4	Has the survey area(s) been properly divid	led into survey units IAW EXHIBIT 10	Yes, WA	
5	Are physical characteristics of the area	Nocation or system documented?	Yes N/A	
6	Is a remediation effectivenes	ss discussion included?	Yes N/A	
7	Have characterization survey and/or sampling comparable to applicat	g results been converted to units that are ole DCGL values?	Yes N/A	
8	Is survey and/or sampling data that was used for	determining survey unit variance included?	Yes, NA	
9	Is a description of the background reference ar sampling results included along with	eas (or materials) and their survey and/or a justification for their selection?	Yes, N/A	
10	Are applicable survey and/or sampling data that	was used to determine variability included?	Yes NA	
11	Will the condition of the survey area have an i probable impact been cons	mpact on the survey design, and has the sidered in the design?	Yes, N/A	
12	Has any special area characteristic including previously noted during characterization) been design	any additional residual radioactivity (not identified along with its impact on survey ?	Yes N/A	
13	Are all necessary supporting calculations and/o	or site procedures referenced or included?	Yes, N/A	
14	Has an effective DCGLw been ide	entified for the survey unit(s)?	Yes, N/A	
15	Was the appropriate DCGL <sub>EMC</sub> included	I in the survey design calculation?	(res) N/A	
16	Has the statistical tests that will be used t	o evaluate the data been identified?	Yes	
17	Has an elevated measurement comparis	on been performed (Class 1 Area)?	Yes N/A	
18	Has the decision error levels been identified and	are the necessary justifications provided?	Yes, NA	
19	Has scan instrumentation been identified along	with the assigned scanning methodology?	Yes, NA	
20	Has the scan rate been identified, and is the M	IDCscan adequate for the survey design?	(Yes)N/A	
21	Are special measurements e.g., in-situ gamma-ra and is the survey methodology, and	ay spectroscopy required under this design, evaluation methods described?	Yes, NA	
22	Is survey instrumentation calibration data include	ed and are detection sensitivities adequate?	(Yes,) N/A	
23	Have the assigned sample and/or measurement lo or CAD drawing of the survey area(s	ocations been clearly identified on a diagram s) along with their coordinates?	Yes, N/A	
24	Are investigation levels and administrative limits clearly indic	adequate, and are any associated actions cated?	Yes N/A	
25	For sample analysis, have the required	d MDA values been determined.?	Yes, NA	
26	Has any special sampling methodology been ider	tified other than provided in Reference 6.3?	Yes N/A	HD 15/10
VOTE: a	copy of this completed form or equivalent, shall be	included within the survey design calculation.	$\leq$	J

# FirstEnergy

## SNEC CALCULATION SHEET

Calculation Number E900-03-019 Revision Number

0

Page 8 of \_14\_

Page Number

Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

## Attachment 2 Sample Results for SSGS Footprint

	T 1/2 (d)	T 1/2 (d)	T 1/2 (d)	T 1/2 (d)	T 1/2 (d)	T 1/2 (d)
	157861.05	1925.23275	11019.5925	32050.6875	8813847.75	10446.15
	Am-241	Co-60	Cs-137	Pu-238	Pu-239	Sr-90
	Am-241	Co-60	Cs-137	Pu-238	Pu-239	Sr-90
	0.0995	0.0327	1.3931	0.0014	0.0060	0.0277
	0.0875	1.9646	78.9405	0.0292	0.0400	
	0.0199	0.0328	0.2508	0.0068	0.0050	0.0185
	0.0199	0.0328_	0.3065	0.0015	0.0050	0.0167
	0.0090	0.0262	0.4365	0.0019	0.0060	0.0278
	0.1294	0.1329_	6.2384	0.0068	0.0120	0.0185
	0.1990	0.2459_	91.0626	0.1952	0.2000	0.0556
	0.0398	0.1330	5.1214	0.0146	0.0160	0.0186
	0.0697	1.0260	72.0571	0.2932	0.1700	
	0.0040	0.0510	2.4127	0.0039	0.0030	0.0094
	0.0139	0.3941	150.4871	0.0029	0.0040	0.0189
	0.0889	0.3847	84.0773	0.0647	0.0381	0.1473
	0.7064	1.6667	37.5482	0.3240	0.3300	0.1702
	0.0528	0.2091	4.1717	0.0098	0.0040	0.0474
	0.2890	1.5060	627.5376	0.0452	0.1450	0.0474
	0.1356	0.1077	11.0809	0.0030	0.0030	0.0858
	0.0478	0.0308	0.2580	0.0482	0.0490	0.0572_
	0.1097	3.1170	2999.1594	0.0690	0.0800	0.0382
	0.0670	0.3719	111.1883	0.1442	0.0875	0.1386
	0.1320	0.0569	3.7134	0.1158	0.0386	0.0168
Mean⇒	1.16E-01	5.76E-01	2.14E+02	6.91E-02	6.21E-02	5.34E-02
% of Total⇒	0.054%	0.268%	99.593%	0.032%	0.029%	0.025%
Median⇒	7.86E-02	1.71E-01	8.66E+00	2.19E-02	2.70E-02	3.30E-02
Sigma⇒	1.56E-01	8.47E-01	6.70E+02	9.80E-02	8.68E-02	4.96E-02
2 Sigma + Mean⇒	4.27E-01	2.27E+00	1.55E+03	2.65E-01	2.36E-01	1.53E-01

	Location/Description
	SSGS Footprint AV-134, 0'-3', Well #2
	Sedment Phase - SSGS East Sump @ 25', AV183, Well #1
	SSGS Footprint AT-139 @ 6
	SSGS Footprint AT-139, 9'-12', Well #4
	SSGS Footprint AW-132 @ 21', Well #3
	SSGS Footprint West Turbine Sump Area AV-134 (Pumped)
	SSGS Footprint East Turbine Sump Area AV-133 (Pumped)
~	SSGS Footprint Callection Tank Area AW-132 (Pumped)
	SSGS Footprint, Well # 7 Pumped Sediment
	SSGS North Sump
	SSGS SE Sump, AU-133, SR-0003
	SSGS South East Sump Sediment AV-133
	SSGS Mezzanne, East, SR-0004
	SSGS North Sump Penetration - 4" Pipe
	SSGS, East, Disk # 1
	SSGS Footprint, East, SR-0004, NW Sump
SS	GS Footprint, Center Section, Core Bare # 2, Disk # 1, Building Structure
	SSGS 790' E., East - Debris From Pump Stand Small Pipe
	SSGS 4" Cross Over Line - Sump to Sump - 790" E.
550	S Footprint Sample # 5, Canarete Floar Care - SR-56, Building Structure

SNEC CALCULATION SHEET		

Calculation Number	Revision Number
E900-03-019	0

Page Number

Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

Attachment 3 SSGS Footprint Effective Area DCGL for Cs-137 (dpm/100 cm<sup>2</sup>)

Effective DCGL Calculator for Cs-137 (dpm/100 cm^				1^2)	Gross Act	wity DCGLW	Gross Activity A	dministrative Limit	
						17498	dpm/100 cm^2	13124	dpm/100 cm^2
		_							
	25.0	mremly TEDE Limit							
					-	\$1.50 PAL CS-13	7. Limit 37.84528	Martin Cs-137 Adm	inistrative Limit
	SAMPLE NO(s)⇒	SSGS Footprint				17461	dpm/100 cm^2	13095	dpm/100 cm^2
						WSNEC AL ST	75%	ļ	
						2. OILO AL 12	1078	l	
									I
	Isotone	Sample Input (pCi/g,		Individual Limits	Allowed dpm/100	memory TEDE	Beta dpm/100 cm^2	Alpha dpm/100 cm^2	
	Am 241	A 275.01	0.027%	27	4.91	4.45		4.81	Am-241
'	AU1-241	4.276-01	0.021 %	Li	4.01	4.45		4.01	7.511-241
2	C-14		0.000%	3,700,000	0.00	0.00	0.00	NA	C-14
3	Co-60	2.27E+00	0.146%	7,100	25.57	0.09	25.57	N/A	Co-60
4	CS-137 (1) (1)	1841.55E+03 7	*** <b>99.784%</b>	28,000	17460.65 🕸	243 15.59 MA	17460.6 🐲	NA	Cs-137
5	Eu-152		0.000%	13,000	0.00	0.00	0.00	NA	Eu-152
6	H-3		0.000%	120,000,000	0.00	0.00	Not Detectable	NA	H-3
7	NI-63		0.000%	1,800,000	0.00	0.00	Not Detectable	N/A	NI-63
8	Pu-238	2.65E-01	0.017%	30	2.99	2.49	NA	2.99	Pu-238
9	Pu-239	2.36E-01	0.015%	28	2.66	2.37	NA	2.66	Pu-239
10	Pu-241		0.000%	880	0.00	0.00	Not Detectable	NA	Pu-241
11	Sr-90	1.52E-01	0.010%	8,700	1.71	0.00	1.71	NA	Sr-90
			100.000%		17498	25.0	17488	10	
					Maximum Permissible dpm/100 cm <sup>*</sup> 2				-

Hast Derey	SNEC CALCULATION SHEET	
Calculation Number	Revision Number	Page Number

0

Page 10 of \_14\_\_

Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

# Exhibit 4 Sample Results for CV Pipe Tunnel (SSGS Side)

1	SNEC SAMPLE RESULTS				
I	LAB or LAB No.				
1	BWXT 0102059-01	CV Tunnel Sedment Composite OL 1			
1	SNEC Sample No	359			
1	CV Tunnel				
I	Other Identifier				
1					
	CV Yard Soli				
1	Analysis Date=>	redruary 14, 2001			
	Isotope	pCVg (soilids) or pCVI (if water) or pCI (if smears)			
1	Am-241	< 0.18			
2	<u>C-14</u>	< 9.34			
3	<u> </u>	<b></b>			
4	<u>Cm-244</u>	< 0.18			
-	Co-60	1.26			
5	<u>Cs-134</u>	< 0.19			
7	<u>Cs-137</u>	1250			
8	<u>Eu-152</u>	< 0.13			
3	Eu-154	< 0.09			
10	Eu-155	< 0.67			
11	Fe-55				
12	H-3	< 5.4			
13	ND-94	< 0.03			
14	NI-59	<u> </u>			
15	NI-63	< 4.U2			
16	Pu-238	< 0.55			
17	Pu-239	<0.22			
18	Pu-240	<ul> <li>&lt; U.22</li> <li>&lt; 44.60</li> </ul>			
13	Pu+241	< 44,03 < 0.02			
20	PU-242	<ul> <li>&lt; 0.22</li> <li>&lt; 1.02</li> </ul>			
21	5D-123	\$ 1.V3			
22					
23	11-234	<u> </u>			
29	<u> </u>				
20	11-238	1 46			
2	0-230				
	Other Isotopes	and the facilities of a Cill life waters of a Cill (if smears)			
	On-site Analysis for Cs-137	porg (sounds) or your (in water) or you (in survey)			
	On-site Analysis for Co-60				
	On-site Analysis for H-3				
	I-129	< 5.02			
	Gross Alpha	17.1			
	Gross Beta				
	K-40				
	Ra-226				
	Th-232				
	Cm-242	< 0.19			
	Th-228				
	Np-237	< 0.24			
	Ce-144	< 1.33			

FirstEnergy	
-------------	--

## SNEC CALCULATION SHEET

Calculation Number E900-03-019 Revision Number

Page Number

Subject

.

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

# Exhibit 5 CV Tunnel (SSGS Side) Effective Area DCGL for Cs-137 (dpm/100 cm<sup>2</sup>)

	Effective DCGL Calculator for Cs-137 (dpm/100 cm				ո^2)	Gross Acth	NY DCGLW	Gross Activity	dministrative Limit
					-	10705	dpm/100 cm^2	8029	dpm/100 cm^2
	25.0	mrem/y TEDE Limit							
'					_	新和田边的CS-13	7, Limit Ethiopie	22.2 Cs-137 Adm	inistrative Limit 2344
	SAMPLE NO(s)⇒	CV Steam Tunnel (SS	GS Side)			10170	dpm/100 cm^2	7628	dpm/100 cm^2
		· · · · · ·			_			-	
						SNEC AL	75%		
		Sample Input InCi/a		Individual Limits	Allowed dom/100		Beta dom/100	Alpha dom/100	
	Isotope	uCi, etc.)	% of Total	(dpm/100 cm^2)	cm <sup>4</sup> 2	mrem/y TEDE	cm^2	cm^2	
1	Am-241		0.000%	27	0.00	0.00	N/A	0.00	Am-241
		0.045.00	0.74.00		<b>7</b> 00		<b>T</b> ~		
Z	C-14	9,342+00	0.710%	3,700,000	75.99	0.00	15.99	N/A	G-14
3	Co-60	1.26E+00	0.096%	7,100	10.25	0.04	10.25	N/A	CO-60
4	Cs-137.3	94.1.26E+03 @P	济洋95.004%	28,000	#10170.13	100 Sec.	(2610170.1 (b)	NA	CS-137 SUREN LAT
5	Eu-152	1	0.000%	13,000	0.00	0.00	0.00	N/A	Eu-152
6	H-3		0.000%	120,000,000	0.00	0.00	Not Detectable	N/A	H-3
7	NI-63		0.000%	1,800,000	0.00	0.00	Not Detectable	N/A	Ni-63
8	Pu-238	5.50E-01	0.042%	30	4.47	3.73	N/A	4.47	Pu-238
9	Pu-239	2.20E-01	0.017%	28	1.79	1.60	N/A	1.79	Pu-239
10	Pu-241	4.47E+01	3.397%	880	363.60	10.33	Not Detectable	N/A	Pu-241
11	Sr-90	9.67E+00	0.735%	8,700	78.68	0.23	78.68	NA	Sr-90
			100.000%		10705	25.0	10335	6	
		•		•	Maximum				•
					Permissible dpm/100 cm^2				

BratEnergy	SNEC CALCULATION SHEET	
Calculation Number E900-03-019	Revision Number	Page Number Page 12 of 14
Subject Shonka SSGS Footprint	& CV Steam Pipe Tunnel (SSGS Side) FSS Surv	/ey Design

•

Exhibit 6 CV Steam Pipe Tunnel (SSGS side)



SNEC CALCULATION SHEET					
Calculation Number Page Number Page Number					
E900-03-019	Page 13 of _14				
Subject Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design					

Attachment 7 SSGS Footprint Firing Aisle & Top of Seal Chambers



SSGS FIRING AISLE & SEAL CHAMBER TOPS PLAN EL. 806'-0'

SNEC CALCULATION SHEET				
Calculation Number	Revision Number	Page Number		
E900-03-019	0	Page 14 of _14		
Subject				

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

.

Attachment 8 SSGS Footprint Basement (790')



Control Copy #\_\_\_\_\_

1



Shonka Research Associates, Inc. 4939 Lower Roswell Road, Suite 106 Marietta GA 30068 770-509-7606

# **Surface Contamination Monitor**

SCM Procedure 001, Rev6

Confirmation and Calibration of the Incremental Encoder

# SCM PROCEDURE 001, REV6DATE: 9/7/01PAGE 2 OF 14TITLE: CONFIRMATION AND CALIBRATION OF THE INCREMENTAL ENCODER

•

		REVIEWED BY:	D. DEBORD	BRIEF SUMMARY OF	
ALVISION	A011101((0)	REVIEWER(S)	DATE	CHANGES	
006	M. Marcial		9/7/01	Added details on how to name the survey name that is also the SCM filename.	

 Table A 1. Revision Table

QA REVIEW BY: D. SHONKA	DATE:				
Ditrah B. Strante	9/7/01				
EFFECTIVE DATE: 9/7/01					

.

.

# 1. Purpose

This procedure establishes the methods for calibration and verification of the incremental encoder included on the SCM.

# 2. Scope and Limitations

This procedure applies to version 2.0 or later of the process software. Any SCM used to conduct a rolling survey must have completed a valid encoder confirmation. Perform a new encoder confirmation if any of the following occur.

- 1. Maintenance on the encoder
- 2. Disassembly/re-assembly of the cart
- 3. Adding a new computer, software, or encoder to the cart.
- 4. 24 months since last confirmation
- 5. Operator notices anomalies in the reported strip length

Perform a calibration whenever the mean of an encoder confirmation exceeds 1% error.

# 3. Definitions and Acronyms

ITEM	DESCRIPTION	
SCM	The Surface Contamination Monitor is a mobile platform containing detectors, support electronics, and data logger used for conducting radiological surveys.	
Incremental Encoder	Electronic device used to measure rotation.	
Target Survey Speed	Maximum survey speed determined to support required MDA	
MDA	Minimum Detectable Activity	

Table 1. Definitions and Acronyms.

# 4. General Information

The incremental encoder provides a method of determining the distance traveled by the SCM. The encoder turns and generates TTL level pulses at regular intervals. A calibration factor in pulses per inch allows the SCM to determine distance by number of pulses. This calibration factor could be determined by dividing the pulses per rotation by the circumference of the wheel. To reduce the impact of measurement error this procedure determines the calibration factor by rolling the cart a known distance and dividing by the pulses received by the counter card in the SCM to get a pulse/in factor.

The user must be cautious to operate the SCM in straight lines parallel to the measuring tape. Failure to do so can result in distance errors of more than 1%.

# 5. Materials, Equipment, and Supplies

ITEM	SPECIFICATION
SCM	Model 3
SCM Process Software	Version 2.0 or later
Tape Measure	30 ft. 10 m. or longer
Таре	Tape must be suitable for securing tape measure to floor surface such as electrical tape.

Table 2. Materials, Ed	uipment, and	Supplies.
------------------------	--------------	-----------

# 6. Responsibilities

#### 6.1. Operator

- 6.1.1. Reads and becomes familiar with this procedure before performing calibration.
- 6.1.2. Has successfully completed SCM I training.
- 6.1.3. Performs measurements in accordance to this procedure.

# 7. Procedure

NOTE: Any means that is suitable for securing the tape measure to the floor may be substituted for electrical tape.

## 7.1. Confirmation of encoder for use in US mode

- 7.1.1. Secure the tape measure to the floor with a piece of electrical tape at the zero inch mark.
- 7.1.2. Extend the tape measure and secure it to the floor at a distance not less than 30 feet with a second piece of electrical tape.
- 7.1.3. Record the distance in inches on the "Incremental Encoder Calibration Verification Data Sheet for Use in Inch Mode" provided in Appendix A.
- 7.1.4. If the SCM is powered off, turn on the system and launch the process software.

- 7.1.5. If the target survey speed is less than 2 in/sec, set the motor controller to 2 in/sec, else set the motor controller to the target survey speed.
- 7.1.6. Enter a new survey name. See SCM Procedure 011.
- 7.1.7. Position the SCM at either piece of electrical tape.
- 7.1.8. Initiate the measurement by pressing the <Enter> key.
- 7.1.9. Roll the cart forward until and line up with the opposite piece of electrical tape.

NOTE: The cart must be kept traveling in a straight line. The operator may use the tape measure and a fixed point on the frame to guide the cart. In addition, take care when aligning the cart to the tape to avoid parallax error.

- 7.1.10. Complete the measurement by pressing the <Enter> key.
- 7.1.11. Record the reported strip length in inches on the "Incremental Encoder Calibration Verification Data Sheet for Use in Inch Mode" provided in Appendix A.
- 7.1.12. Follow the software prompts and repeat steps 7.1.7-7.1.11 two additional times.
- 7.1.13. Proceed to Section 8.1 and perform acceptance criteria calculations.

#### 7.2. Confirmation of encoder for use in metric mode

- 7.2.1. Secure the tape measure to the floor with a piece of electrical tape at the zero meter mark.
- 7.2.2. Extend the tape measure and secure it to the floor at a distance of 10 meters or more with a second piece of electrical tape.
- 7.2.3. Record the distance in meters in the "Actual Distance" blank on the "Incremental Encoder Calibration Verification Data Sheet for Use in Metric Mode" provided in Appendix B.
- 7.2.4. If the SCM is powered off, turn on the system and launch the process software.
- 7.2.5. If the target survey speed is less than 2 in/sec, set the motor controller to 2 in/sec, else set the motor controller to the target survey speed.
- 7.2.6. Enter a new survey name. See SCM Procedure 011, "Survey Naming Convention when Using the SCM".
- 7.2.7. Position the SCM at either piece of electrical tape.
- 7.2.8. Initiate the measurement by pressing the <Enter> key.

7.2.9. Roll the cart forward and line up with the opposite piece of electrical tape.

NOTE: The cart must be kept traveling in a straight line. The operator may use the tape measure and a fixed point on the frame to guide the cart. In addition, take care when aligning the cart to the tape to avoid parallax error.

- 7.2.10. Complete the measurement by pressing the <Enter> key.
- 7.2.11. Record the reported strip lengths in inches in the Strip Distance Table on the form "Metric Mode Incremental Encoder Calibration Verification Form" provided in Appendix B.
- 7.2.12. Follow the software prompts and repeat steps 7.2.7-7.2.11 two additional times.
- 7.2.13. Proceed to Section 8.2 and perform acceptance criteria calculations.

#### 7.3. Encoder Calibration

This section uses the "Encoder Calibration Data Sheet" provided in Appendix C.

- 7.3.1. Perform confirmation measurements outlined in 7.1 or 7.2 depending on mode of operation.
- 7.3.2. Record the mean of the three confirmation measurements in the "Distance<sub>old</sub>- blank.
- 7.3.3. Record the old encoder calibration constant (found on line 7 of the FM.DEF file) in the "Constant<sub>old</sub>" blank.
- 7.3.4. Record the target distance in the "Distance<sub>Target</sub>" blank. For US inde the target distance will be the actual distance traveled. Use Equation 4 to calculate the target distance for Metric mode.
- 7.3.5. Calculate the new encoder constant using Equation 1.

Equation 1. Calculation for encoder constant.  $CONSTANT_{New} = \frac{CONSTANT_{old} * DISTANCE_{old}}{DISTANCE_{Turgel}}$ 

- 7.3.6. Record the new encoder constant in the "Constant<sub>New</sub>" blank.
- 7.3.7. Update Line 7 of FM.DEF with the new encoder constant.
- 7.3.8. Perform encoder confirmation in steps 7.1 or 7.2 depending on mode of operation.

#### 8. **Acceptance Criteria**

#### 8.1. Acceptance Criteria for US mode

- 8.1.1. Calculate the mean of the three measurements and ensure that it is within 1% of the actual distance traveled by the SCM.
- 8.1.2. Calculate the percent deviation from the mean for each of the three measurements using equation 2 and ensure that the deviation for each measurement is below 3%.

#### Equation 2. Calculation for percent deviation from the mean.



- 8.1.3. Record the mean and percent deviation from the mean for each measurement on the "Incremental Encoder Calibration Verification Data Sheet for Use in Inch Mode" provided in Appendix A.
- 8.1.4. If the deviation from the mean is larger than 3% for any measurement, repeat the confirmation test or troubleshoot encoder system.
- 8.1.5. If the mean of the three measurements differs from the actual distance by more than 1%, proceed to 7.3 and perform calibration.

#### 8.2. Acceptance Criteria for Metric mode

8.2.1. Convert the Actual Distance in meters to Target Distance in inches using Equation 4. Equation 3 provides the derivation.

Equation 3. Target distance in inches derivation.  $TargetDistance_{inch} = ActualDistance_{meter} \times \frac{100_{cm/meter}}{5_{cm/puel}} \times 2_{inch/puel}$ 

## Equation 4. Calculation of target distance in inches.

 $TargetDistance_{inch} = ActualDistance_{meter} \times 40_{inch / meter}$ 

- 8.2.2. Record target distance on the form "Incremental Encoder Calibration Verification Data Sheet for Use in Metric Mode" provided in Appendix B.
- 8.2.3. Record the mean and percent deviation from the mean for each measurement on the "Incremental Encoder Calibration Verification Data Sheet for Use in Metric Mode" provided in Appendix B.
- 8.2.4. Calculate the mean of the three measurements and ensure that it is within 1% of the target distance.

#### Equation 5. Calculation for percent deviation from the mean for metric mode.

Deviation <sub>∞</sub> =	Mean <sub>inch</sub> – Measurement <sub>inch</sub>
	Mean <sub>inch</sub>

- 8.2.5. Calculate the percent deviation from the mean for each of the three measurements using Equation 5 and ensure that the deviation for each measurement is below 3%.
- 8.2.6. If the deviation from the mean is larger than 3% for any measurement, repeat the confirmation test or troubleshoot encoder.
- 8.2.7. If the mean of the three measurements differs from the target distance by more than 1%, proceed to 7.3 and perform calibration.

# 9. References

9.1. N/A

# 10. Required Records

- 10.1. Incremental Encoder Calibration Verification Form
- 10.2. SCM Procedure 011, "Survey Naming Convention when Using the SCM"

# 11. Appendices

- 11.1. Appendix A: Incremental Encoder Calibration Verification Data Sheet for Use in Inch Mode
- 11.2. Appendix B: Incremental Encoder Calibration Verification Data Sheet for Use in Metric Mode

.

11.3. Appendix C: Encoder Calibration Data Sheet
# Appendix A

**Incremental Encoder Calibration Verification Data Sheet** 

for Use in Inch Mode

4

#### Inch Mode **Incremental Encoder Calibration** Verification Form

\_\_IN/SEC

DATE: \_\_\_\_\_ SCM SERIALNUMBER: \_\_\_\_\_

SCM SPEED: 

ACTUAL DISTANCE:\_\_\_\_\_ \_\_\_וא

Note: Perform this test at the intended survey speed, unless the survey speed is less than 2 in/sec. If survey speed is less than 2 in/sec then perform test at 2 In/sec.

Table 3. Strip lengths.

MEASUREMENT	DISTANCE (INCHES)	DEVIATION FROM MEAN (%)
1		
2		
3		
MEAN		xxxxxxx

MEAN VARIANC	E FROM ACTU	AL DISTA	NCE:	24		
						,
INITIALS	MEAN VARIA	ANCE FRO	M ACTUAL DIS	TANCE LESS THAN	1%	
INITIALS	DEVIATION	FROM ME. ENTS	AN FOR EACH N	IEASUREMENT WI	THIN 3% OF THE	ACTUAL
INITIALS	PASSED					
INITIALS	FAILED	WHY:				

PERFORMED BY:	DATE:
REVIEWED BY:	DATE:

4

# Appendix B

#### Incremental Encoder Calibration Verification Data Sheet

for Use in Metric Mode

•••

#### Metric Mode Incremental Encoder Calibration Verification Form

DATE: \_\_\_\_\_\_ SCM SERIALNUMBER: \_\_\_\_\_

SCM SPEED: \_\_\_\_\_IN/SEC ACTUAL DISTANCE: \_\_\_\_\_METERS

TARGET DISTANCE: \_\_\_\_ INCHES

Note: Perform this test at the intended survey speed, unless the survey speed is less than 2 in/sec. If survey speed is less than 2 in/sec then perform test at 2 in/sec.

Table 4. Strip lengths.

MEASUREMENT DISTANCE (INCHES)		DEVIATION FROM MEAN (%)		
1				
2				
3				
MEAN		xxxxxxxx		

#### MEAN VARIANCE FROM ACTUAL DISTANCE: \_\_\_\_\_ %

INITIALS	MEAN VARIANCE FROM ACTUAL DISTANCE LESS THAN 1%					
INITIALS	DEVIATION FROM MEAN FOR EACH MEASUREMENT WITHIN 3% OF THE ACTUAL MEASUREMENTS					
INITIALS	PASSED					
INITIALS	FAILED	WHY:				
		_				
PERFORMED BY:				<u> </u>	DATE:	

REVIEWED BY: \_\_\_\_\_ DATE: \_\_\_\_

٠

:

# Appendix C

**Encoder Calibration Data Sheet** 

	Enco	der Calibration Form	
		der Galbrauon i onn	
DATE:	. <u> </u>	SCM SERIALNUMBER:	
SCM SPEED:	IN/SEC	ACTUAL DISTANCE:	INCH
Note: Perform the less than 2 at 2 in/sec.	s test at the inte in/sec. If surve	ended survey speed, unless by speed is less than 2 in/se	the survey speed is othen perform test
DISTANCE₀∟ (MEAN OF 3 DISTA!	ICE MEASUREMEN	rs):	інсн
CONSTANT out (LINE 7 OF FM.DEF)	:		PULSE/INCH
DISTANCE <sub>TARGET</sub> (US – ACTUAL DIST	ANCE   METRIC - TA	ARGET DISTANCE):	ІНСН
	Constan	$t_{New} = \frac{Constant_{Old} * Distance_{Ol}}{TargetDistance}$	<u>'d</u>
CONSTANT <sub>NEW</sub> :	•/a		
NITIALS LIN	E 7 OF FM.DEF UPD	ATED WITH CONSTANT <sub>NEW</sub>	
NITIALS PER	FORM ENCODER C	ONFIRMATION	
NITIALS PAS	SED		
INITIALS FAI	LED WHY:		
<u> </u>			
PERFORMED BY:		DATE: _	

SCM PROCEDURE 001, REV6 DATE: 9/7/01 PAGE 14 OF 14 TITLE: CONFIRMATION החל CALIBRATION OF THE INCREMENTAL ENCODER

Control Copy #\_\_\_\_\_



•

i

Shonka Research Associates, Inc. 4939 Lower Roswell Road, Suite 106 Marietta GA 30068 770-509-7606

# **Surface Contamination Monitor**

SCM Procedure 005, Rev6

Requirements for Completion of a Survey Using the SCM

REVISION	AUTHOR(S)	REVIEWER(S)	DATE	CHANGES	
005	M. Marcial		9/7.01	Updated responsibility section, general typos, made references to response and daily checks uniform, added reference to SCM Procedure 006 and 011.	
006	J. Kelley	D. DeBord	7/17/03	Added text that references the MDCs set for by the client to sections 4.1 and 7.4.5	

Table	A 1.	Revision	Table

QA REVIEW BY: D. SHONKA	DATE:			
Delnah Stimber	7/17/03			
EFFECTIVE DATE: 7/17/03				

.

•

# 1. Purpose

This procedure details the requirements for completion of a survey using the SCM.

## 2. Scope and Limitations

This procedure applies to version 2.0 or later of the SCM process software.

# 3. Definitions and Acronyms

ITEM	Table 1. Definitions and Acronyms.   DESCRIPTION
SCM	The Surface Contamination Monitor is a mobile platform containing detectors, support electronics, and data logger used for conducting radiological surveys.
SIMS	Survey Information Management System – SIMS is flexible and comprehensive interfacing software for the SRA SCM. SIMS processes the SCM instrument data with a sophisticated data parser, integrated spreadsheet, and powerful special functions such as spatial data filters. SIMS provides the most flexible reporting system available for printing survey records or complete stand- alone survey reports. SEMS contains all the tools needed to meaningfully communicate between the SCM and the data analysis team.
PSPC	Position Sensitive Proportional Counter – This is a radiation detector that is capable of establishing where along the detector a pulse is sensed (the system is described in NUREG/CR-6450). The detectors are similar in efficiency to other counters, but have backgrounds associated with small area detectors (5cm x 5cm). This results in improved sensitivity, due to low background, and specific identification of the location of the radioactivity. The PSPCs may be fabricated in any length.
SRC	Source Response Check – Determines if the system is operating the same from day-to-day.
PBC	Performance Based Check – Determines the system efficiency and performance.

# 4. General Information

#### 4.1. Rolling Mode

Check the wheel encoder upon arrival on site per "SCM Procedure 001". Check the PSPC per "SCM Procedure 007".

The Project Manager establishes the survey speed based on the isotopes of concern and the desired sensitivities set forth by the client. The SCM system is capable of concurrent alpha, beta and gamma surveys.

An SCM survey uses the concept of survey strips. SIMS reassembles the strips to provide complete documentation of a survey without requiring any manual transfer of data. The operator makes a crude sketch of the area and indicates the direction and start point of each strip. Record the filename of the survey on the sketch and, if available, note a reference coordinate for one of the corners of the survey area. The surface does not need to be pre-gridded. Mark the surface into survey lanes using a chalk line or other markings. The wheel encoder enables tracking of distance down each lane. Markings on the detector housing allow the operator to align the detector to the lane. Each lane is twice as wide as the detector. Typical survey lanes are about 12 feet wide.

Start the SCM software if it is not already active and enter the survey parameters:

- Survey Name (Filename),
- Room ID, and
- Equipment ID.

Use the speed indicator on the computer display to adjusted to the proper survey speed. After establishing the speed, disengaged the motor and position the SCM with the front of the first PSPC at least 10 cm before the start of the first survey lane. Start the motor and begin logging data as the leading edge of the first PSPC enters the survey lane by pressing the <Record> button. The motor maintains a constant speed, while the operator guides the cart down the lane unless using the fly-by-wire or autonomous carts. Upon reaching the end of the lane, press the <Stop> button on the SCM screen and optionally disengaged the motor. Position the cart to record the next lane. Repeat this process until completing the survey.

Change the filename and optionally the Room ID to prepare the instrument for the next survey area. The display provides information during the survey process, such as, survey name, strip number, distance traveled in strip, target speed and current speed, alarm set points, and detector data. Two different display types for the detector data exist in the SCM process software. For a pixilated image of the flux from the floor with color corresponding to intensity, select the visualization screen. For a more traditional feel, select the bar graph screen that has rows corresponding to roughly 4inch bins across the detector. The system also provides visual and audible alarms to the user to indicate problems with operating parameters such as speed. The SCM logs data to the disk drive from any combination of the detectors while the <Record> key is active. This permits reassembly of the data in the SIMS application.

#### 4.2. Corner Mode

Use the corner detector operated in a data-logging mode to survey areas not accessible with the SCM attached to the motor driven cart. The output of corner mode is compatible with SIMS. The corner detector is a PSPC operated in a similar fashion to the SCM rolling survey, but with a fixed time interval for each detector placement and data acquisition. The Project Manager establishes the time interval to provide a sensitivity that is consistent with that established for the rolling mode.

Measure out 10 cm strips along the surface being measured. Start the SCM software if it is not already active and enter the survey parameters: Survey Name (Filename), Room ID, and Equipment ID. Position the detector between the first set of marks and press <Record> button in the SCM process software. At the end of the preset time interval, the system stops recording. Move the detector into the next position, and record the next strip. Repeat this process until completing the survey.

# 5. Materials, Equipment, and Supplies

	materials, Eduburcud and oal	shuca		
ITEM	SPECIFICATION			
SCM	Model 3			
SCM Process Software	Version 2.0 or later			
PSPC	Typical lengths include 0.9 and 1.8 meter			
Tape Measure	30 ft, 10 m, or longer			
Chalk Line 30 ft, 10 m, or longer depending on survey lane length				
Check Source Alpha, beta or gamma as appropriate				

# Table 2. Materials, Equipment, and Supplies.

# 6. Responsibilities

#### 6.1. Project Manager

- 6.1.1. Reads and becomes familiar with this procedure.
- 6.1.2. Ensures all surveys are performed according to this procedure.

- 6.1.3. Establishes the rolling mode speed and detector height.
- 6.1.4. Establishes the corner mode count time and detector height.

#### 6.2. Operator

- 6.2.1. Reads and becomes familiar with this procedure before performing calibration.
- 6.2.2. Performs all surveys according to this procedure.
- 6.2.3. Operates the SCM during the survey.
- 6.2.4. Guides and monitors the SCM's speed throughout the surveys.
- 6.2.5. Has successfully completed SCM I training.

### 7. Procedure

#### 7.1. SCM Preparation

- 7.1.1. Remove the protective cover from the detector housing.
- 7.1.2. Set the detector housing to the proper height for the survey. Perform alpha surveys with the detector set at 1/4" above the surface or as directed by the Project Manager. Beta surveys may vary from 1/4" to 3/4" depending on the isotope. Verify the setting with the Project Manager.
- 7.1.3. Set the high voltage control on the electronics module to "Alpha" for alpha surveys and "Beta" for beta surveys.
- 7.1.4. Power on the GM Rate Meter, if conducting a concurrent GM survey.
- 7.1.5. Purge the detector and insure that P-10 gas flow is indicated on the outlet flow gauges.
- 7.1.6. If this is the initial project survey, perform steps 7.2; else proceed to step 7.3.

# 7.2. Confirmation of Operation (Performed at beginning of project and as required by referenced procedures)

- 7.2.1. Launch SCM process software.
- 7.2.2. Verify PSPC position response. In addition, if required, perform a position calibration in accordance with "SCM Procedure 006".

7.2.3. Perform encoder calibration per "SCM Procedure 001". Perform the encoder calibration at the beginning of each project, and after maintenance affecting the encoder wheel.

#### 7.3. Survey Setup

- 7.3.1. If this is the beginning of a shift, perform PSPC daily source response check (SRC) per "SCM Procedure 007". Perform the SRC at the beginning of each shift. Perform periodic performance based response checks (PBC) during the survey in accordance with "SCM Procedure 007".
- 7.3.2. Make a crude sketch of the survey area including distances, if a CAD drawing is not available.
- 7.3.3. Identify and mark survey lanes using a tape measure and chalk line or other markings.
- 7.3.4. Indicate strip locations and directions on sketch with arrows.
- 7.3.5. Record the filename of the survey on the sketch.
- 7.3.6. Identify SW corner on drawing and if available provide a reference coordinate.

#### 7.4. Rolling Survey Operations

7.4.1. When prompted, enter a survey name and record the name on the sketch. See "SCM Procedure 011" for survey naming conventions.

1

- 7.4.2. Confirm the PSPC detector in the "Supervisor/Select Detectors" screen.
- 7.4.3. Confirm the operation mode is set to "Encoder".
- 7.4.4. Return to the operations screen.
- 7.4.5. Set the survey speed in the "Operator/Alarm Set Points" screen. Survey speed for alpha surveys is normally 1"/sec. Beta survey speeds may vary from 2"/sec. to 6"/sec. Verify the speed for the survey with the Project Manager who will determine one that meets the survey MDCs.
- 7.4.6. Engage the motor and adjust the speed.
- 7.4.7. Disengage the motor.
- 7.4.8. Select the "Visualization" Screen.
- 7.4.9. Position the SCM with the front of the first PSPC at least 10 cm before the start of the first survey lane.
- 7.4.10. Start the motor and begin logging data as the leading edge of the first PSPC enters the survey lane by pressing the <Record> button.

7.4.11. Guide the SCM down the strip.

7.4.12. Upon reaching the end of the strip, disengage the motor.

#### NOTE:

#### Any deviation from the survey lane (strip path) will result in errors in the mapping of surface activity.

- 7.4.13. Press the <Stop> button on the operations screen.
- 7.4.14. Position the detector at the beginning of the next strip aligning the markings on the detector housing with the chalk lines on the floor. The detector housing is typically marked 10cm from each end.
- 7.4.15. Repeat steps 7.4.9 to 7.4.14 for all strips in the survey.
- 7.4.16. Perform performance based checks in accordance with "SCM Procedure 007".

#### 7.5. Corner Detector Operations

- 7.5.1. Use the Corner detectors to acquire data in areas that are normally not accessible to the SCM used with the motor driven cart.
- 7.5.2. Set up of the corner detectors for binning constants, high voltage settings, and baseline source response checks is the same as other PSPCs.
- 7.5.3. Confirm the operation mode is set to "Corner".
- 7.5.4. Set the timer for the time necessary to obtain count times consistent with the speed of the motor driven SCM for the same area. The timer should be set for a value equal to the width of the detector, typically 10 cm, divided by the travel speed. Verify the timer setting with the Project Manager.
- 7.5.5. If a survey name has not been provided, enter a survey name that reflects the area (consistent with the survey name used with the motor driven cart). The "SCM Procedure 011" details the naming of surveys.
- 7.5.6. Draw a sketch of the area, if a CAD drawing is not available.
- 7.5.7. Denote the location of each strip taken with the corner detector. including any overlaps with other strips.
- 7.5.8. Press the <Enter> key on the keyboard or press the remoted pendant <Record> button to acquire a strip. The count will complete at the end of the preset time.

7.5.9. Perform performance based checks in accordance with SCM Procedure 007.

# 8. Acceptance Criteria

None - Specific procedures provide acceptance criteria for calibration activities.

#### 9. References

- 9.1. SCM Procedure 001 "Confirmation and Calibration of the Incremental Encoder on Encoder Equipped Models of the SCM".
- 9.2. SCM Procedure 007 "Source Response Check and Performance based Checks of any PSPC Detector Configuration Installed on the SCM".
- 9.3. SCM Procedure 008 "Conduct of Operations for Surveys Using the SCM/SIMS". SCM Procedure 011 "Survey Naming Convention when Using the SCM".

# 10. Required Records

All data acquired during the survey is transferred to SIMS for processing. The "SCM Procedure 008" details the maintenance of all survey records.

# 11. Appendices

N/A

;

Control Copy #\_\_\_\_\_

. !



٠,

,

Shonka Research Associates, Inc. 4939 Lower Roswell Road, Suite 106 Marietta GA 30068 770-509-7606

# **Surface Contamination Monitor**

SCM Procedure 006, Rev4

Performance of a Position Calibration on a PSPC

··. ·

REVISION AUTHOR(S)		REVIEWED BY: D. DEBORD		BRIEF SUMMARY OF
REVISION A		REVIEWER(S)	DATE	CHANGES
()()4	M. Marcial	مي تيز جبتر ·	9/7/01	Added cover sheet and revision sheet.

#### Table A 1. Revision Table

# 

QA REVIEW BY: D. SHONKA	DATE:
Downh B Shunt	9/7/01
EFFECTIVE DAT	FE: 9/7/01

•

.

# 1. Purpose

This procedure details the requirements for performing a position calibration of a PSPC detector array.

# 2. Scope and Limitations

This procedure applies to version 2.0 or later of the Surface Contamination Monitor process software.

# 3. **Definitions and Acronyms**

ITEM	DESCRIPTION
SCM	The Surface Contamination Monitor is a mobile platform containing detectors, support electronics, and data logger used for conducting radiological surveys.
SIMS	Survey Information Management System – SIMS is flexible and comprehensive interfacing software for the SRA SCM. SIMS processes the SCM instrument data with a sophisticated data parser, integrated spreadsheet, and powerful special functions such as spatial data filters. SIMS provides the most flexible reporting system available for printing survey records or complete stand-alone survey reports. SIMS contains all the tools needed to meaningfully communicate between the SCM and the data analysis team.
PSPC	Position Sensitive Proportional Counter – This is a radiation detector that is capable of establishing where along the detector a pulse is sensed (the system is described in NUREG/CR-6450). The detectors are similar in efficiency to other counters, but have backgrounds associated with small area detectors (5cm x 5cm). This results in improved sensitivity, due to low background, and specific identification of the location of the radioactivity. The manufacturer of PSPCs makes them in any length.
Peak Edge	The channel that is halfway between the maximum and minimum of the peak on the side of the peak facing the nearest MHV connector.

#### Table 1. Definitions and Acronyms.

# 4. General Information

The design of the SCM acquisition system allows several detector configurations. To this end, the acquisition engine and software provides for adjustments to allow for the differences between the attributes of the different detector configurations. The most important of these adjustments is the position calibration.

. . 4

;

The position calibration allows the software to take the recorded information by the acquisition system and map it to a position on the detector.

# 5. Materials, Equipment, and Software

ITEM	SPECIFICATION
SCM	Model 3
SCM Process Software	Version 2.0 or later
PSPC	Typical lengths include ().9 and 1.8 meter
Check Source	Collimated alpha source or other source if collimated alpha is not available
STITCHER	Version 3.0 or later
VISUSPECT	Version 3.0 or later

#### Table 2. Materials, Equipment, and Software.

## 6. Responsibilities

#### 6.1. Operator

- 6.1.1. Reads and becomes familiar with this procedure before performing calibration.
- 6.1.2. Performs all measurements according to this procedure.
- 6.1.3. Has successfully completed SCM I and SCM II Training.

## 7. Procedure

#### 7.1. Perform Confirmation of Position Calibration

- 7.1.1. Connect a pre-amp module to each end of the detector array.
- 7.1.2. Place the source at the end of the intended active area of the array.
- 7.1.3. Press the <Acquire> button in the SCM process software to start a one-minute acquisition.
- 7.1.4. Verify that the peak occurs at the outer edges of the display screen.
- 7.1.5. If the peak does not occur at the outer edge of the display, perform steps 7.2.
- 7.1.6. Repeat steps 7.1.2 to 7.1.5 for the left end of the intended active area of the array.
- 7.1.7. Return to the operations screen.

#### 7.2. Set Binning Constants

- 7.2.1. Press the <Setup> button.
- 7.2.2. Press the <Supervisor> button.
- 7.2.3. Press the <Calibrations> button.
- 7.2.4. Press the <Detector Position> button.
- 7.2.5. Enter the position analyzer by pressing <Use Position Analyzer> button.
  - 7.2.5.1. Edit Detector Binning Constants using the following steps:
  - 7.2.5.2. Place a high-count rate, collimated alpha source at the far left end (as you are looking at the detector from the operator's position). When using a recount detector, place the source at the left end of the primary (rear) detector. Detector ends are normally marked with tape and are inboard of the MHV connectors. Typically, detector ends are 10 cm from the outside edge of the PSPC.
  - 7.2.5.3. Press the <B> (Binning Constants) button.
  - 7.2.5.4. Press the <L> button to start an acquisition. This function positions the cursor near the left peak.
  - 7.2.5.5. Use the left or right arrows as necessary to position the cursor at the peak edge.
  - 7.2.5.6. When the cursor is set, move the source to the right end of the detector. For a recount assembly, place the source under the left edge of the recount (front) detector.
  - 7.2.5.7. Press the <L> button again to set the left channel. This action causes the cursor to move to the right peak.
  - 7.2.5.8. Use the left or right arrows as necessary to position the cursor at the peak edge.
  - 7.2.5.9. Press the  $\langle R \rangle$  button to set the right channel.
  - 7.2.5.10. Press the <ESC> key to return to the position analyzer screen.
- 7.2.6. The computer will calculate the slope and intercept using the left and right channels identified by the peaks.
- 7.2.7. If the detector array contains more than 1 detector, perform step 7.3.

#### 7.3. Set Detector Endpoints using the Following Steps:

- 7.3.1. Press the <Acquire> button to start a one-minute acquisition.
- 7.3.2. Move a high-count rate, collomated alpha source to each end of each detector.

- 7.3.3. Record the peak edge of each peak.
- 7.3.4. Press the <Quit> button to exit the position analyzer.
- 7.3.5. Press the <Set Detector End Points> button to edit the detector endpoints.
- 7.3.6. Enter the endpoint for each detector.
- 7.3.7. Press the <Save> button.
- 7.3.8. Press the <Return to Operations> button.

## 8. Acceptance Criteria

End point verification indicates that the peak from the collimated source appears at the outer edges of the computer display screen.

# 9. Appendices

9.1. None

. .

. . :

Control Copy #\_\_\_\_\_



Shonka Research Associates, Inc. 4939 Lower Roswell Road, Suite 106 Marietta GA 30068 770-509-7606

# **Surface Contamination Monitor**

SCM Procedure 007, Rev7

Source Response Check and Performance Based Check of any PSPC Detector Configuration Installed on the SCM

# SCM PROCEDURE 007, REV7DATE: 7/17/03PAGE 2 OF 12TITLE: SOURCE RESPONSE CHECK AND PERFORMANCE BASED CHECK OF ANY PSPC DETECTORCONFIGURATION INSTALLED ON THE SCM

.

	REVISION		REVIEWED BY:	D. DEBORD	BRIEF SUMMARY OF
	REVISION	AUTHOR(3)	REVIEWER(S)	DATE	CHANGES
	006	M. Marcial		9/7/01	Added cover sheet, revision sheet, Project Manager responsibilities, made uniform the naming of checks and added reference SCM Procedure 011. Added sigma evaluation to acceptance criteria. Quality Control >> Performance Based
•	007	J. Kelley	D. DeBord	7.17 03	Added action upon failure to meet acceptance criteria. Section 8.1.2 and 8.2.1 include the changes. In step 7.1.10 the steps to repeat are 7.1.7 to 7.1.9 not 7.1.5 to 7.1.7. Formatting was added to section 8.

Table	Α	1.	Revision	Table

QA REVIEW BY: D. SHONKA	DATE:
Delhan & Stinkan	7/17/03
EFFECTIVE	DATE: 7/17/03

.

,

\*

# 1. Purpose

This procedure details the requirements for baseline source response checks (SRC), daily SRCs and Performance Based Checks (PBC) of any PSPC detector configuration installed on the SCM.

# 2. Scope and Limitations

This procedure applies to version 2.0 or later of the SCM process software.

# 3. Definitions and Acronyms

	Table 1. Definitions and Acronyms.
ITEM	DESCRIPTION
SCM	The Surface Contamination Monitor is a mobile platform containing detectors, support electronics, and data logger used for conducting radiological surveys.
SIMS	Survey Information Management System – SIMS is flexible and comprehensive interfacing software for the SRA SCM. SIMS processes the SCM instrument data with a sophisticated data parser, integrated spreadsheet, and powerful special functions such as spatial data filters. SIMS provides the most flexible reporting system available for printing survey records or complete stand- alone survey reports. SIMS contains all the tools needed to meaningfully communicate between the SCM and the data analysis team.
PSPC	Position Sensitive Proportional Counter – This is a radiation detector that is capable of establishing where along the detector a pulse is sensed (the system is described in NUREG/CR-6450). The detectors are similar in efficiency to other counters, but have backgrounds associated with small area detectors (5cm x 5cm). This results in improved sensitivity, due to low background, and specific identification of the location of the radioactivity. The PSPCs may be fabricated in any length.
SRC	Source Response Check – Determines if the system is operating the same from day-to-day.
PBC	Performance Based Check – Determines the system efficiency and performance.

# 4. General Information

Normal operation of the SCM with a PSPC requires daily SRCs to assure that the PSPC is performing within acceptable limits. Perform this procedure at the beginning and end of each shift for each detector in use. Compare the results to the results of the daily SRC to the baseline SRC for this project. Use the initial daily SRC for a project as the baseline SRC.

Any time a system parameter changes, take a new baseline SRC for comparison with proceeding days. Examples of altered parameters would be:

- 1. Change in high voltage.
- 2. Calibration source changed.

Perform Performance Based Checks (PBC) frequently through out the course of the survey. The PBCs establish the system performance during the survey and are the basis for the detector efficiency. Moreover, the PBCs affect the reported surface activity output by SIMS.

# 5. Materials, Equipment, and Supplies

ITEM	SPECIFICATION
SCM	Model 3
SCM Process Software	Version 2.0 or later
PSPC	Typical lengths include 0.9 and 1.8 meter
Check Source	NIST traceable source for PBCs used to establish efficiency. Use the same source for all comparisons between the baseline SRC and the daily SRC (need not be NIST traceable).

Table 2. Materials, Equipment, and Supplies.

# 6. Responsibilities

#### 6.1. Project Manager

- 6.1.1. Reads and becomes familiar with this procedure.
- 6.1.2. Evaluates SRCs that fail the acceptance criteria.

#### 6.2. Operator

- 6.2.1. Reads and becomes familiar with this procedure before performing calibration.
- 6.2.2. Performs all measurements are according to this procedure.
- 6.2.3. Has successfully completed SCM Level I training.

## 7. Procedure

#### 7.1. Source Response Check Measurement.

- 7.1.1. If this is a baseline SRC, use the form in Appendix A, "Baseline Source Response Check Form"; otherwise, use the form in Appendix B, "Daily Source Response Check Form". Use this procedure for all detectors regardless of configuration. Perform all source response checks with the detector and source stationary. If desired, use a source holder so that the placement of the source to the detector is repeatable.
- 7.1.2. Enter the Energy/Position analyzer by following these steps:
  - 7.1.2.1. Press the <Setup> button.
  - 7.1.2.2. Press the <Supervisor> button.
  - 7.1.2.3. Press the <Calibrations> button.
  - 7.1.2.4. Press the <Detector Position> button.
  - 7.1.2.5. Press the <Use Position Analyzer> button.
- 7.1.3. Make sure that there are no sources under the detector.
- 7.1.4. Start Acquisition by pressing the <Acquire> button.
- 7.1.5. When the 1-minute timed acquisition ends, integrate the entire spectrum and record the measured background for the entire spectrum.
- 7.1.6. Record the measured background on the appropriate form in the column labeled "Total Counts" and the row labeled "Background for Entire Array".
- 7.1.7. Place calibration source under the center of the detector or in contact with mylar or protective screen. When the SCM is setup for rolling mode, it is often quicker to place the source on the ground and roll the cart to position the source under the detector. When surveying in corner mode, it is often quicker to turn the PSPC over and place the source directly on the mylar or protective screen. In any case, assure that the source to detector geometry is the same as when the baseline SRC was taken.
- 7.1.8. Start Acquisition by pressing the <Acquire> button.
- 7.1.9. When the 1-minute count is complete, record the count with calibration source on the data table in the appropriate row for the given detector of the appropriate form in the column labeled "Total Counts".

7.1.10. Repeat Steps 7.1.7-7.1.9 for each detector in the PSPC array.

#### 7.2. Source Response Check Evaluation

7.2.1. For each detector, subtract the recorded background entered in the data table in the row labeled "Background for Entire Array" from the recorded "Total Counts" for each detector. Enter the result in the block "Total Background Subtracted Counts".

Note: If this procedure is being done to establish a baseline, it is now complete. If this is a comparison to baseline, proceed to step 7.2.2

- 7.2.2. Copy values in the column labeled "Total Background Subtracted Counts" from the baseline form for each detector onto the form "Daily Source Response Check Form" in the column labeled "Total Baseline Background Subtracted Counts" provided in Appendix B.
- 7.2.3. For each detector perform the calculation shown in Equation 1 and record the value in the block "Percent Difference from Baseline Measurement" on the form in Appendix B.

#### Equation 1. Calculation of percent difference from baseline.

Total Background Subtracted Counts – Total Baseline Background Subtracted Counts

Total Baseline Background Subtracted Counts

7.2.4. Compare these values with the acceptance criteria contained in Step 8.1.2. If the value is greater than the acceptance criteria, notify the Project Manager.

#### 7.3. Performance Based Check

Note: Perform the Performance Based Check (PBC) with the detectors operating in the mode in which the surveys bounded by the Performance Based Checks will be performed.

- 7.3.1. Perform periodic PBCs throughout the course of the survey. Perform PBCs at the beginning of the shift, at least once per 4 hours of surveying, and at the completion of each shift.
- 7.3.2. Perform all PBCs using the same source. The source used for efficiency determination is acceptable but not required to be used.
- 7.3.3. Obtain PBCs in the same performance manner as normal surveys, i.e. SCM speed and detector height, or timer setting and height for corner detectors.
- 7.3.4. Establish a survey file name for the Performance Based Checks. See SCM Procedure 011 for file naming conventions.

- 7.3.5. Place the source on the floor and perform a survey of the area, operating the SCM in accordance with SRA Procedure 005. For rolling surveys, center the source along the PSPC axis 1.0 m from the leading edge of the first detector before rolling the cart over the source. For corner surveys place source on detector mylar or protective screen.
- 7.3.6. For corner surveys, press the <Record> button and wait until acquisition is complete. For rolling surveys press record, then start motor. Continue strip until last detector is 1.0 m past the source.
- 7.3.7. Repeat the survey 3 times for each PBC.
- 7.3.8. Record the time, filename, strip numbers, and the source used in the logbook or survey form.
- 7.3.9. Evaluation of the PBCs for the duration of the survey occurs in the survey report issued upon completion of the survey.

# 8. Acceptance Criteria

#### 8.1. SRCs

- S.1.1. For baseline SRCs, there is no acceptance criteria.
- 8.1.2. Daily SRCs are acceptable if all "Percent Difference from Baseline Measurement" values are less than 20%. If a system fails to meet the acceptance criteria, all survey data taken since the last acceptable PBC or SRC will be rejected. Also, the system should be removed from service until the failure is resolved.

. 3

#### 8.2. PBCs

8.2.1. Use SIMS software to process the PBC data files. Establish a control chart indicating the mean and "2-sigma" and "3-sigma" values. Evaluate subsequent PBCs against the "2-sigma" and "3-sigma" criteria and for indications of adverse trends. If more than 1 of the 3 measurements obtained during a PBC is greater than the "2-sigma" or if any measurement is greater than "3-sigma", the PBC fails. Surveys bounded by a failed PBC are considered invalid. If a system fails to meet the acceptance criteria, all survey data taken since the last acceptable PBC or SRC will be rejected. Also, the system should be removed from service until the failure is resolved.

### 9. References

- 9.1. SCM Procedure 005 "Requirements for Completion of a Survey Using the SCM".
- 9.2. SCM Procedure 011 "Survey Naming Convention when using the SCM".

# 10. Required Records

None.

## 11. Appendices

11.1. Appendix A, Baseline Source Response Check Measurements Form

ì

11.2. Appendix B, Daily Source Response Check Measurements Form

# Appendix A

**Baseline Source Response Check Form** 

SCM PROCEDURE 007, REV7	DATE: 7/17/03		PAGE 10 OF 12
TITLE: SOURCE RESPONSE CHECK AND	PERFORMANCE BASED CHE	CK OF AN	Y PSPC DETECTOR
<b>CONFIGURATION INSTALLED ON THE SC</b>	:M	•	•

#### **Baseline Source Response Check Form**

SCM CONFIGURATION:	SCM SERIALNUMBER:	

HIGH VOLTAGE SETTING: \_\_\_\_\_

SOURCE SERIAL NUMBER OR ID: \_\_\_\_\_ ISOTOPE:\_\_\_\_\_

DETECTOR	SERIAL NUMBER	TOTAL COUNTS	TOTAL BACKGROUND SUBTRACTED COUNTS
BACKGROUND FOR ENTIRE ARRAY	N/A		N/A
DETECTOR #1			
DETECTOR #2			
DETECTOR #3			
DETECTOR #4			
DETECTOR #5			

#### ENTER N/A FOR ALL NON-EXISTING DETECTORS

PERFORMED BY: \_\_\_\_\_

|--|

1

REVIEWED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

SCM PROCEDURE 007, REV7DATE: 7/17/03PAGE 11 OF 12TITLE: SOURCE RESPONSE CHECK AND PERFORMANCE BASED CHECK OF ANY PSPC DETECTORCONFIGURATION INSTALLED ON THE SCM

. . . .

١

# Appendix **B**

**Daily Source Response Check Form** 

. !

#### **Daily Source Response Check Form**

DAILY SOURCE RESP	ONSE CHEC	K CONFIGU	RATION		
SCM CONFIGURATION: SCM SERIALNUMBER:					
HIGH VOLTAGE SETT	ING:				
SOURCE SERIAL NUM	BER OR ID:		ІЅОТОРІ	E:	
				_	
BASELINE SOURCE R	ESPONSE CF	IECK CONFI	IGURATION DAT	E:	
SCM CONFIGURATION	SCM CONFIGURATION: SCM SERIALNUMBER:				
HIGH VOLTAGE SETT	ING:				
SOURCE SERIAL NUM	BER OR ID:		ISOTOPE	: <u></u>	·······
•• • •	•			•	
DETECTOR	SERIAL NUMBER	TOTAL COUNTS	TOTAL BACKGROUND SUBTRACTED COUNTS	TOTAL BASELINE BACKGROUND SUBTRACTED	PERCENT DIFFERENCE FROM BASELINE
				000113	MCASUREMENT
BACKGROUND FOR ENTIRE ARRAY	N/A		N/A	N/A	N/A
DETECTOR #1					
DETECTOR #2					
DETECTOR #3					
DETECTOR #4					
DETECTOR #5					
	ENTER N/A	FOR ALL N	ION-EXISTING DE	TECTORS	
INITIALS NO ME	ASUREMEN	T VARIES M	ORE THAN 20% F	ROM BASELINE	
INITIALS PASSE	D				
INITIALS FAILEI	WHY:	<u> </u>	<u></u>		
PERFORMED BY:			. <u> </u>	DATE:	<u> </u>
REVIEWED BY: DATE:					<u> </u>

\_\_\_\_\_

Control Copy #\_\_\_\_\_

.

٠.

:

1



۰.

Shonka Research Associates, Inc. 4939 Lower Roswell Road, Suite 106 Marietta GA 30068 770-509-7606

# **Surface Contamination Monitor**

SCM Procedure 008, Rev3

Conduct of Operations for Surveys Using the SCM/SIMS

#### 

----

• :

•

REVISION	AUTHOR(S)	REVIEWED BY:	D. DEBORD	BRIEF SUMMARY OF
		REVIEWER(S)	DATE	CHANGES
003	M. Marcial	1.1	9/7/01	Updated survey documentation control form. added reference to SCM Procedure 011.

Table	A 1.	Revision	Table
-------	------	----------	-------

QA REVIEW BY: D. SHONKA	DATE:	
Dibrich B. Sturch	9/7/01	
EFFECTIVE DATE: 9/7/01		
······································		

٠

: **1** 1

### 1. Purpose

:

This procedure establishes guidance and requirements for processing, documenting, and archiving data in support of surveys conducted with the SCM/SIMS.

## 2. Scope and Limitations

This procedure applies to version 2.0 or later of the SCM process software.

This procedure applies to all surveys performed by SRA to fulfill contractual obligations to clients or for in-house use.

This procedure does not apply to the documentation for clients that require use of their own data handling procedures: however, the requirements contained herein may still be appropriate for such instances if they do not conflict with client requirements.

# 3. Definitions and Acronyms

Table 1. 3. Definitions and Acronyms.		
ITEM	DESCRIPTION	
SCM	The Surface Contamination Monitor is a mobile platform containing detectors, support electronics, and data logger used for conducting radiological surveys.	
SIMS	Survey Information Management System – SIMS is flexible and comprehensive interfacing software for the SRA SCM. SIMS processes the SCM instrument data with a sophisticated data parser, integrated spreadsheet, and powerful special functions such as spatial data filters. SIMS provides the most flexible reporting system available for printing survey records or complete stand-alone survey reports. SIMS contains all the tools needed to meaningfully communicate between the SCM and the data analysis team.	
Batch Processing	A data processing feature of SIMS that allows group processing of multiple survey block files. A group of files may be saved as a Batch Processing File so that the batch may be run again at a later date.	
SIMS Survey Directory	The DOS directory titled with the Project Name. This directory is used to store all elements of the survey. A detailed directory structure is identified in this procedure.	
# SCM PROCEDURE 008, REV3 DATE: 9/7/01 PAGE 4 OF 28 TITLE: CONDUCT OF OPERATIONS FOR SURVEYS USING THE SCM/SIMS

ITEM	DESCRIPTION
PSPC	Position Sensitive Proportional Counter – This is a radiation detector that is capable of establishing where along the detector a pulse is sensed (the system is described in NUREG/CR-6450). The detectors are similar in efficiency to other counters, but have backgrounds associated with small area detectors (5cm x 5cm). This results in improved sensitivity, due to low background, and specific identification of the location of the radioactivity. The PSPCs may be fabricated in any length.
Contact Sheet	A list of phone numbers and addresses.
Packing List	A detailed list of all items shipped or carried by survey team members in support of the survey.
Plan of the Day (POD)	A daily meeting attended by survey team members conducted prior to beginning any work. The meeting serves to assign tasks and inform members of any operations by team members or by other teams that may affect survey activities. A daily safety meeting should be conducted as part of the Plan of Day meeting.
Scope of Work	A detailed description of the contractual requirements for the survey.
OOS	Out-of-scope work
MSDS	Material Safety Data Sheets
QA	Quality Assurance (SRCs and PBCs)
CAD	Computer Aided Design
Master Drawing	A diagram, map, or other drawing of the survey areas.
Logbook	A daily record of survey activities maintained by the Survey Technician. The logbook contains any observations, problems, or obstacles encountered during the survey. If survey forms are not provided, it may be used to document survey sketches.
Survey Notebook	A notebook used to organize and provide quick access to logistical, procedural, and administrative survey documentation.
Survey Block	A survey is divided into sections called survey blocks. The size of the survey block is typically limited for convenience to 15 meters by 15 meters or 20 meters by 10 meters.
Survey Name	The name assigned to the individual survey blocks. The name should be a valid DOS file name of no more than 8 characters as it will be used to archive electronic files. See SCM Procedure 011 for file naming conventions.

٩

• •

ITEM	DESCRIPTION
Auto Generated Survey Records	Stylized survey records automatically generated by SIMS without operator intervention.
Auto Generated Survey Table Summary	Text file automatically generated by SIMS without operator intervention. This file typically has the Survey Name, highest 1(X) cm <sup>2</sup> area, number of meters, number of meters exceeding 1(X) cm <sup>2</sup> limit, highest microR/hr and PSPC efficiency.
Master Survey Table	A compilation of the Auto Generated Survey Table Summaries for each section of the survey.
Survey Report Volume	The Survey Report Volume (SRV) serves to catalog the Auto Generated Survey Records. The SRV will consist of one or more binders sectioned with dividers using the same structure as the sub- directories in the SIMS data directory. Substitution of CD presentation of the data instead of hard copy files in binders is a client option. The Master Survey Table should appear as the first page and an Auto Generated Survey Table Summary should be the first sheet for each survey section.
Verification	The act of reviewing, inspecting, testing, checking, auditing, or otherwise determining and documenting whether items, processes, services, or documents conform to specified requirements. With respect to computer code development, verification is the process of evaluating the products of a software development phase to provide assurance that they meet the requirements defined for them by the previous phase. As applied to completed computer codes, verification means to demonstrate the capability of the code to produce valid results for test problems encompassing the range of permitted usage defined by the code's documentation.

# 4. General Information

Performance of surveys requires designation of the following staff members:

- 1. Project Manager,
- 2. Survey Technicians,
- 3. Office Manager, and
- 4. Quality Assurance (QA) Reviewer.

The size of the survey dictates the number of Survey Technicians, but for small surveys the Project Manager may assume the responsibilities of the Survey Technician. Persons directly involved with the survey may not serve as Quality Assurance Reviewer.

The Project Manager is responsible for planning, organizing logistics, supervising survey performance, documenting the survey, and processing survey data. The Project Manager is responsible for choosing the methods and procedures needed to complete all

deliverable items for the survey, for performing the required tasks, and for documenting the process in a manner that reflects high professional standards.

Survey Technicians are responsible for operation and maintenance of the SCM during the course of the survey. They perform surveys in accordance with SRA and local site procedures. Survey Technicians must complete the SRA training courses required for operation of the SCM. In the event more than one individual is involved in the accumulation of survey data, each individual shall be considered a Survey Technician. For larger surveys the Project Manager may appoint a Survey Lead Technician. The Survey Lead Technician will assist the Project Manager in supervising and organizing survey activities.

The Office Manger assists the survey team by providing clerical and logistical support. The Office Manager is responsible for maintaining controlled copies of any documents provided to the client. The Office Manager approves all revisions to any deliverable documents. Additionally, the Office Manager maintains the survey archive upon completion of the final deliverables of the survey. The Office Manager may function at the survey site, the home office, or at a remote location.

The QA reviewer insures completion of all required elements of the survey; that the completed survey is in accordance with all applicable procedures; and addresses all contractual survey items. In addition, the QA reviewer performs a final check on deliverable documents to ensure that there are no grammatical, spelling, or punctuation type errors; that page numbering is correct; that all tables agree with Auto Generated Survey Records; that all cross-references are correct; etc. Survey documentation must be completed and ready for delivery (i.e. resolution of comments must be finished) before QA review can take place.

. 1

# 5. Materials, Equipment and Supplies

Table 2.	Materials, Equipment, and Supplies.
ITEM	SPECIFICATION
SCM	Model 3
SCM Process Software	Version 2.0 or later
PSPC	Typical lengths include 0.9 and 1.8 meter
SIMS Workstation	Capable of running the current version of SIMS
SIMS	Current Version
Removable Media	Zip Disk® or other removable disk media for use with the IOMEGA Zip Drive or compatiable drive.
File Compression Software	PKZIP® or WINzip (current version) data compression utilities. Software should be capable of creating self- extracting files.

ITEM	SPECIFICATION
Backup Hardware and Software	Seagate Backup (current version) - utility for transferring data to tape cartridges. Tape cartridges must be compatible with tape drive.
Binders	3-ring or other binders for securing loose paper.
Logbooks	Suitable for using in the field.

# 6. Responsibilities

### 6.1. Project Manager

- 6.1.1. Has completed SCM Level I and Level II training and SIMS Level I and Level II.
- 6.1.2. Reads and becomes familiar with this procedure.
- 6.1.3. Conducts planning of survey logistics and performance requirements.
- 6.1.4. Determines relevant procedures.
- 6.1.5. Coordinates survey logistics.
- 6.1.6. Assembles Survey Notebook.
- 6.1.7. Ensures that the survey is performed in accordance with SRA procedures.
- 6.1.8. Reads daily Survey Technician logs and compiles master log.
- 6.1.9. Distributes and collects daily QA documents.
- 6.1.10. Conducts daily Plan of Day meeting to each shift.
- 6.1.11. Maintains Survey Notebook in accordance with this procedure.
- 6.1.12. Collects, maintains, and processes survey data using SIMS. #
- 6.1.13. Transfers survey data and documents to Office Manager for storage upon completion of survey.

### 6.2. Survey Technician

- 6.2.1. Has completed SCM Level I training at a minimum.
- 6.2.2. Reads and becomes familiar with this procedure before conducting surveys.
- 6.2.3. Performs surveys in accordance with this procedure and procedures provided by the Project Manager.
- 6.2.4. Provides text and diagrams describing survey pattern for each survey block in accordance with this procedure.
- 6.2.5. Maintains daily logbook in accordance with this procedure.
- 6.2.6. Performs and documents daily QA checks.

`

#### 6.3. Office Manager

- 6.3.1. Transmits completed report and other deliverables to the client.
- 6.3.2. Maintains control of deliverable documents throughout the revision process.
- 6.3.3. Maintains the survey archive in accordance with this procedure.

#### 6.4. Quality Assurance Reviewer

- 6.4.1. Reads and becomes familiar with this procedure before reviewing survey documentation.
- 6.4.2. Reviews completed survey documentation to insure completion of all required elements, that the completed survey is in accordance with all applicable procedures, and addresses all contractual items.

## 7. Procedure

#### 7.1. Pre Deployment Preparation

- 7.1.1. Designate the Project Manager.
- 7.1.2. Choose a project name. SIMS uses this name to catalog documents in the SIMS directory structure. The project name should be a single word of no more than 8 characters.
- 7.1.3. The Project Manager creates a directory on the SIMS workstation using the Project Name.
  - 7.1.3.1. The Project Manager maintains control of the documents in these directories during the course of the survey; however, control transfers to the Office Manager upon completion of the survey.
  - 7.1.3.2. Any of the directories may include sub-directories to organize the stored data. For example, on large surveys a directory may contain multiple sub-directories for separate sections of the survey. The naming convention should aid in identification of the particular areas. For example, use directory names such as exterior, interior, bldg1, elev1, etc. If using a Survey Identification Code, then use that code as the directory name. Typically, the "\_QRaw" and "\_SRaw" directories do not have sub-directories. Create at a minimum the following sub-directories under the Project name directory as shown in Table 3. Any references this procedure makes to the directories in Table 3 includes the sub-directories created under them.

 SCM PROCEDURE 008, REV3
 DATE: 9/7/01
 PAGE 9 OF 28

 TITLE: CONDUCT OF OPERATIONS FOR SURVEYS USING THE SCM/SIMS

DIRECTORY NAME	USAGE	
_QRaw	Stores all SCM Source Response Check and Performance Based Check files transferred from the SCM and not processed by SIMS.	
_SRaw	Stores all SCM survey files transferred from the SCM and not processed by SIMS.	
CAD	Site drawings and maps.	
Admin	Time sheets, expense reports, etc.	
Correspondence	Any correspondence between SRA staff and client.	
Documents	Completed Auto Generated Survey Records (ASGR) and tables.	
Documents\Backup	This directory contains original AGSRs and tables before they were revised. Copy original AGSRs here before generating new or revised reports or records. The backup directories should be numbered sequentially.	
Data	Use this directory to store survey data.	
Pictures	This directory contains digital images of the site and survey process.	
Reports	This directory contains any reports or survey records issued internally or to a client. Reports may include status reports, final reports, executive summaries, survey records, etc. Each type of report should have its own directory. For example, all alpha reports could go into the alpha sub-directory.	

### 7.1.4. Develop the survey plan.

7.1.5. Compile a packing list to include both company and personnel items. Management and all survey team members should review the finitial draft. Management and each survey team member should receive a copy of the packing list prior to departure. Use the packing list in Appendix B, "Sample Packing List", as a guide.

1

- 7.1.6. Assemble a Survey Notebook as outlined in this section. The Survey Notebook shall contain at a minimum the following sections
  - 7.1.6.1. Contact Sheet The contact sheet provides an easily accessible list of phone numbers and addresses. Place the sheet on the cover or insert as the first page of the Survey Notebook. Appendix A. "Sample Contact Sheet", lists a sample contact sheet and should contain the following information at a minimum as shown in Table 4.

#### Table 4. Contact sheet information in Survey Notebook.

ITEM	
Client phone number and address.	
Emergency contact phone numbers for all team members.	
Hotel phone number and address. Room numbers should be added as they become available.	
Local internet access numbers.	
Site phone number and address.	
A contact number in the event that the notebook is found.	

- 7.1.6.2. Maps and directions.
- 7.1.6.3. Scope of Work.
- 7.1.6.4. Safety The safety section should at a minimum contain the following items as shown in Table 5.

#### Table 5. Safety Items in Survey Notebook.

ITEM
Site Safety Plan.
Applicable MSDS Sheets.
Medical – Includes items such as immunization records, respirator qualification, staff medicines, etc.
7.1.6.5 Procedures – All SRA and site procedures to be used during

- 7.1.6.5. Procedures All SRA and site procedures to be used during survey.
- 7.1.6.6. Source Certification Documentation.
- 7.1.6.7. Training Records.
- 7.1.6.8. Packing List.
- 7.1.6.9. Shipping The shipping section should at a minimum contain the following items as shown on Table 6.

#### Table 6. Shipping sheet information.

ITEM
Blank Commercial Invoice
Blank Shipper's Declaration for Dangerous Goods form
Client shipping labels
DOT Label with UN number
Federal Express Airbill
Federal Express Dangerous Goods Airbill
Instructions for shipping P-10
Insurance certificate
NON-FLAMMABLE GAS labels
SRA shipping labels

7.1.6.10. Parts and Expenses – Envelope for receipts.

- 7.1.6.11. Travel Reservations, flight information, and envelope for tickets.
- 7.1.6.12. Backup copies of all software to be used on site.
- 7.1.7. Ensure that all items on the packing list have been shipped or prepared for transport.

### 7.2. Deployment

- 7.2.1. Arrival and Initial Start-up
  - 7.2.1.1. Check in with site contact. Confirm requirements for security and disposition of check sources and P-10 cylinders.
  - 7.2.1.2. Conduct Safety Meeting.
  - 7.2.1.3. Conduct Plan of Day Meeting.
  - 7.2.1.4. The Project Manager should distribute logbooks, initial QA forms, and daily QA forms.
  - 7.2.1.5. Conduct a walk through inspection of the survey area to assess any needed adjustments to the survey plan.
  - 7.2.1.6. Identify a staging area, a secure storage area, and an area to set up data processing (SIMS).

- 7.2.1.7. Place all shipped and hand carried equipment into the designated staging area and conduct an inventory check using the Packing List.
- 7.2.1.8. The Project Manager assembles the SIMS workstation and tests SIMS while the Survey Technicians assemble and perform required QA checks on the SCM(s).
- 7.2.1.9. As each SCM completes QA checks, the Project Manager will collect and verify the generated QA documentation.
- 7.2.1.10. Create a directory titled "C:\FM5\Data\Transfer" in the SCM software directory of each SCM. If the directory already exists, delete its contents.
- 7.2.1.11. The Survey Team assures the SCM's is ready for field operations and assigns a survey area. The Project Manager ensures the Survey Technician(s) understand the survey naming convention and orientation.
- 7.2.2. Daily Startup
  - 7.2.2.1. Conduct Safety Meeting
  - 7.2.2.2. Conduct Plan of Day Meeting
  - 7.2.2.3. Distribute logbooks and daily QA forms.
  - 7.2.2.4. As each SCM completes daily QA checks, the Project Manager collects and verifies its QA documentation.
- 7.2.3. Daily Survey Activities
  - 7.2.3.1. Survey Technicians perform surveys in accordance with SRA Procedure 005. Direct any questions regarding procedures to the Project Manager.
  - 7.2.3.2. Survey Technicians record in the logbook the sketch of each survey block detailing the pattern used to conduct the survey. Use arrows to designate the start point, end point and direction of each survey strip. Place an asterisk in the southwest corner (or as designated by the Project Manager) of the survey block to identify the orientation of the survey block in SIMS. If the survey block is not oriented to the cardinal directions, provide another indication of orientation.
  - 7.2.3.3. Maintain the logbook with the following formats as shown in Table 7.

SCM PROCEDURE 008, REV3 DATE: 9/7/01 PAGE 13 OF 28 TITLE: CONDUCT OF OPERATIONS FOR SURVEYS USING THE SCM/SIMS

#### Table 7. Logbook formats.

IT	EM
•••	

Each day should begin on a new page.

The date should appear in the upper right corner of each page.

Each morning the Survey Technician should note P-10 Gas level, time on site, and action items from the Plan of Day meeting..

The name and start time of each survey block should be noted in the left margin.

If survey forms are not provided, use the logbook to record the survey sketch.

Note any obstacles, problems, or unique observations in the logbook as they occur.

Each recorded observation should include time of day.

7.2.3.4. The Project Manager transfers survey data files from each SCM to SIMS periodically throughout the day. Files should be transferred a minimum of twice a day. Every SCM should participate in each transfer session. The individual file transfers should occur between survey blocks so as not to impede survey efforts. Each transfer should be conducted as shown in Table 8.

Table 8. Transfering	data	from	the	SCM	to	removable	media*	•
----------------------	------	------	-----	-----	----	-----------	--------	---

STEP	DESCRIPTION
1	Label a floppy disk with each SCM serial number or ID.
2	Exit the SCM software.
3**	Using file compression software, create a transfer file that contains all of the Survey Header Files (*.svy) and Survey Data Files (*.0??) in the SCM directory.
4	Move the transfer file to the floppy disk.
5	Once the transfer file resides on the floppy disk, move all Survey Header Files and Survey Data Files to the "C:\FM5\Data\Transfer" directory.
6	Restart the SCM software and return control to the Survey Technician.

\*Repeat the steps in this table for each SCM.

\*\*The detector configuration files currently have a similar file extension as the Survey Data Files. DO NOT transfer or delete the detector configuration files!

STEP	DESCRIPTION
1	Using file compression software, extract the Survey Header Files and Survey Data Files from each floppy into the "Data" directory of the SIMS Survey Directory.
2	If a removable media has not been prepared, insert a blank removable media into the removable media drive and create a directory labeled 'Transfer'.
3	Copy the Survey Header Files and Survey Data Files from the "Data" directory of the SIMS Survey Directory into the "Transfer" directory of the removable media. This serves as a temporary archive of survey data.
4	Move the Survey Header Files and Survey Data Files from the "Data" directory of the SIMS Survey Directory into their respective sub directories. Source Response Checks and Performance Based Checks survey files go into the "_QRaw" directory. Survey files go into the "_SRaw" directory.
5	Erase the files from the removable media used to transfer SCM data to prepare them for the next file transfer.

### Table 9. Transfer of data from removable media to SIMS.

- 7.2.3.5. Print and review Master Survey Table for comparison with reports and survey records.
- 7.2.3.6. If time and resources permit, compare values in Auto Generated Survey Records with corresponding values on Master Survey Tables.

*NOTE:* All reports and survey records should be printed and reviewed before demobilization.

7.2.4. Daily Data Processing

7.2.4.1. Update Survey Report Volume.

• Verify Auto Generated Survey Table Summary (STS File) entries with values in the corresponding individual Auto Generated Survey Records (AGSRs).

**\$** .

- Place AGSRs into the proper sections of the Survey Report Volume.
- Place an updated copy of the Master Survey Table at the beginning of the Survey Report Volume.
- 7.2.4.2. Complete any outstanding data transfers.
- 7.2.4.3. Move completed Auto Generated Survey Records to the "Documents" directory.

- 7.2.4.4. Consolidate any tables created by Batch Processing into the Master Survey Table.
- 7.2.4.5. Process outstanding data files as described in Table 10.

STEP	DESCRIPTION
1	Draw the survey block on the Master Drawing if available.
2	Label the grid with the Survey Name and place an asterisk in the lower left corner of the survey block as viewed in SIMS if available. The lower left corner typically represents the southwest corner.
3	Using SIMS and the survey sketch stitch the survey.
4	Repeat steps 1 through 3 for all transferred survey files.
5*	Batch process Auto Generated Survey Records and tables for all recently stitched surveys. Apply appropriate background values to activity limits if backgrounds have been calculated.
6	Move completed Auto Generated Survey Records to the "Document" directory.
7	Consolidate any tables created by Batch Processing into the Master Survey Table.
8**	Print and review Master Survey Table.
9	If time and resources permit, print any unprinted Auto Generated Survey Records .
10	If time and resources permit, compare values in AGSRs with corresponding values on Master Survey Tables.
8==   9   10	Print and review Master Survey Table. If time and resources permit, print any unprinted Auto Generated Survey Red If time and resources permit, compare values in AGSRs with corresponding v Master Survey Tables. The SIMS Batch Processor writes the auto-generated tables to the directory in which t

#### Table 10. Steps to process data files.

Processing File is stored.

\*\*All reports and survey records should be printed and reviewed before demobilization.,

### 7.2.5. Revision of Auto Generated Survey Records

- 7.2.5.1. Create a backup sub-directory in the relevant "Document" directory.
- 7.2.5.2. Move current version of Auto Generated Survey Records into the backup directory. The backup directories should be numbered sequentially.
- 7.2.5.3. Follow steps 5 through 8 in Table 10 to regenerate records.

### 7.3. Post Deployment

7.3.1. Records

- 7.3.1.1. The Office Manager maintains all controlled copies of any final record, report or executive summary.
- 7.3.1.2. The Office Manager may revise any controlled copies. The Office Manager distributes any revised document to the survey team members for comments.
- 7.3.1.3. Upon completion of the final revision, the Office Manager presents the report and other deliverables to the QA Reviewer for verification.
- 7.3.1.4. After QA approval of the report, the Office Manager conveys the report and other deliverables to the client.
- 7.3.2. Survey Archive
  - 7.3.2.1. Upon completion of all reports, the Project Manager turns over all survey documentation and materials to the Office Manager.
  - 7.3.2.2. The Office Manager places all finalized material into the survey archive that includes at a minimum the items shown in Table 11.

Table 11.	<b>Materials</b>	turned over	and	archived.
-----------	------------------	-------------	-----	-----------

ITEM
Logbook(s)
SIMS Software
SIMS Survey Directory
Master Drawing and other site drawings
Contract paper work
Survey Notebook
Survey Report Volume (i.e. printouts of Auto Generated Survey Records)
Video Tape(s), if taped
Computer media containing survey data file backup
Copies of any other paper work provided to the client

7.3.2.3. The SIMS Survey Directory should be archived to backup tape.

- 7.3.2.4. Secure all of the items listed in Table 11, the backup tape of the SIMS Survey Directory, and any other documentation pertaining to the survey in a document storage box labeled with the Project Name and date.
- 7.3.2.5. After QA review, the box should be stored in accordance with office document archive procedures.
- 7.3.2.6. Place a sign out sheet in the box. Log any removal of any material from the box.

#### 7.4. Quality Assurance Review

- 7.4.1. As soon as is practical following the receipt of a survey for review, the Quality Assurance reviewer shall:
  - 7.4.1.1. Verify general grammar, spelling, punctuation, etc. for correctness.
  - 7.4.1.2. Verify that statements are clear and precise.
  - 7.4.1.3. Recalculate numerical problems to insure that no "calculator type" errors have occurred (this includes verification of spreadsheet cell formulas).
  - 7.4.1.4. Verify that all assumptions are clearly documented and are valid.
  - 7.4.1.5. Verify that data tables are correct, valid and that table entries are consistent with the data from the Auto Generated Survey Records.
  - 7.4.1.6. Verify that the survey documentation contains all of the information necessary for complete reconstruction at a later date.
  - 7.4.1.7. Verify that the SIMS Survey Directory matches what was archived on the tape backup.
- 7.4.2. Upon full completion of the QA review, hold a meeting with the Project Manager and Office Manager to discuss comments and resolve issues if necessary.
- 7.4.3. Upon receipt of a revised survey, the QA reviewer shall first ascertain the scope of the revisions (major or minor).
- 7.4.4. If only minor edits (those that do not affect results or conclusions) have been made, then QA review should consist of a read through of the documentation to insure that the changes made were appropriate and that no more are necessary.

- 7.4.5. If major changes have been made, then a full review as described in step 7.4.1 is required.
- 7.4.6. Once all issues have been resolved satisfactorily, complete and sign the Survey Documentation Control Sheet. (see Appendix C, "Survey Documentation Control Sheet").
- 7.4.7. Complete and sign the Survey QA Review Sheet. (see Appendix D, "Survey QA Review Sheet").
- 7.4.8. Return the survey documentation to the Office Manager.

# 8. Acceptance Criteria

Survey Documentation Control Sheet and Survey QA Review Sheet (with signatures) are complete.

All survey documentation has been archived.

All voided/superseded survey revisions are marked as such on their respective Survey Document Control Sheets.

# 9. References

9.1. SRA Procedure 005 "Requirements for Completion of a Survey Using the SCM"

# 10. Required Records

The following records shall be maintained for the life of the company as shown in Table 12. Record maintained upon completion the survey.

•

#### Table 12. Record maintained upon completion the survey.

ITEM
All completed survey reports regardless of revision status
Logbook
SIMS Software Version used in survey
SIMS Survey Directory
Site Drawings
Survey Notebook
Survey Report Volume
Video Tape or digital photos
Computer media containing survey data file backup

# 11. Appendices

- 11.1. Appendix A, "Sample Contact Sheet"
- 11.2. Appendix B, "Sample Packing List"
- 11.3. Appendix C, "Survey Documentation Control Sheet"
- 11.4. Appendix D, "Survey QA Review Sheet"

•

# Appendix A

Sample Contact Sheet



:

# SRA CONTACT SHEET

NAME	PHONE NUMBER
INTERNET ACCESS INFO	
National AOL Accesss Number	(800) 245-0113
Local AOL Accesss Number	(630) 435-1054
DON'S EMERGENCY CONTACTS	
Wife Cell	(404) 351-168()
Ноте	(77()) 781-9292
Cell	(41)4) 668-761)6
BOB'S EMERGENCY CONTACTS	·
Wife	(770) 578-8362
Cell	(678) 296-4815
CHARLIE'S EMERGENCY CONTACTS	
Wife	(352) 628-5707
Cell	(720) 841-5377
SITE INFO	
Marty Phalen (Job Site Contact) (Cell)	(815) 263-9(X)1
GRA INFO	
Shonka Research Associates. Inc.	(770) 509-7606

## HANFORD DEPLOYMENT

Hotel Address and Phone	Site Address and Phone	Client Address and Phone
Number:	Number:	Number:
Holiday Inn		1
205 Remmington Blvd.		
Boling Brook IL 6044()		
_		).
Phone: (5()9)943-14()()		

If this notebook is found please contact Shonka Research Associates at (888) 509-7606 .'

# **Appendix B**

Sample Packing List

.**≸** ₹

# **BONUS Packing List**

#### Don

Knit Cap Bag Brief Case Cold Weather Gear Hard Hat Hot Sauce Leatherman Organizer Hotel # w/Confirmation (N.E. Power Rate!) Car Confirmation # Map Safety Glasses Safety Shoes (Substantial Foot Wear) Shaving Kit

#### Joe

Knit Cap Bag Cold Weather Gear Hard Hat Safety Glasses Safety Shoes (Substantial Fixet Wear) Shaving Kit

### **SCM #1**

Cables, BNC, HVPA-DLG (2) Cables, DB37 (2) Cable, DB9, Encoder cable. Cables, Power, AC (2) Detector Mounting Brackets (2) Detector, Model 2 PSPC, 6' (2) Detector, Model 2 PSPC, 41 (2) Electronics (NIM, DLG, HVPA) Extension Cord (1) Flow Gauge, Inlet Flow Gauge, Outlet Frame, SCM, Motorized Lunch Box PC Das1402 CTR-5 MHV Cables (2) Motor Motor Controller P-10 bottles (1) Plug, gas, quick connect (3) Regulator Surge Suppresser, ISOBAR, 120db Filter Tubing, Tygon (3)

SCM #2 Cables, BNC, HVPA-DLG (2) Cables, DB37 (2) Cable, DB9, Encoder cable. Cables, Power, AC (2) Detector Mounting Brackets (2) Detector, Model 2 PSPC, 6' (2) Detector, Model 2 PSPC, 4' (2) Electronics (NIM, DLG, HVPA) Extension Cord (1)

#### Toolbox, Electronics (Gray) 37Pin Terminal Block Alligator Leads (3) Connector, MHV (2) Connector, BNC (2) Connector, BNC, T (1) Electrical Tape GLPT. Red Liquid Tape Heat Gun Heat Shrink NIM Extended Cables Pin extension leads U-Dore Scotch Tape Solder Tie-Wraps (small, med, large) Tweeker Wire Wire Strippers

## Toolbox, Mylar (Red)

Anode Wire Roll (1) Mylar Roll (3) Razzor Blades Scotch Tape Silver Solder Solder Extractor Soldering Iron Uher Tape Roll (3)

## Toolbox, SCM (Yellow)

:

Adapter, BNC Female to Banana Bottle Wrench Bungy Cords (3) Chalk, Powdered <u>\$</u> . Chalk, Sticks or Paint Sticks Chalk Line Channel Locks Crescent Wrench (2) Detector, Combustible Gas W/charger Dykes Exacto Knife Flash Light Hex Wrenches, ball ended (Metric) Hex Wrenches, ball ended (US) Measure Tape, 100" Pliers, Needle Nose Screw Driver, Philips (3). Screw Driver, Standard (2) Socket Set Source, Cs-137, 100 cm<sup>2</sup> Spare BNC (1) Spare DB37 (1) Tape, Scotch Teflon Tape Tie Wraps, Large (25) Tweeker

#### SCM PROCEDURE 008, REV3 DATE: 9/7/01 PAGE 24 OF 28 TITLE: CONDUCT OF OPERATIONS FOR SURVEYS USING THE SCM/SIMS

Flow Gauge, Inlet Flow Gauge, Outlet Frame, SCM, Motorized Lunch Box PC Das1402 CTR-5 MHV Cables (2) Motor Motor Controller P-10 bottles (1) Plug, gas. quick connect (3) Regulator Surge Suppresser, IS()BAR, 120db Filter Tubing, Tygon (3)

# GM

Probe ESP-II DB9-BNC Cable MHV Cable

## Camera

Cable, BNC, Remote to DLG (1) Carncorder Power supply and power cable Carncorder Remote Carncorder Tapes (28) Carncorder to Snappy Cable (Phono) Carncorder W/case Carncorder W/case Carncorder wide angle lens Mount Plate, Tripost Snappy

# SIMS

CABLE, LAP LINK Computer Mouse Keyboard Phone Cable Monitor (21") Mini Isobar

## **Test Equipment**

BNC cables (2) Scope, Hand Held, Fluke 105B Test Leads

# Misc.

Clip Board (2) Disk, 3.5" (1 box) Legal Pad Pencils (4) Pens (4) Batteries, C cell (6) Batteries, D cell (2)

## **Check Sources**

Soruce, Cs. 100cm^2 Cs. Certificate Source, Am-241

## Software and Data Files

Copy of New SCM version 4.x. Copy of Bonus SCM version Copy of Visuspect 3.x. Copy of Stucher 3.x.

## Documentation

Logbook (2) Marketing Folders (2) Procedures Manual Rad Worker II Respirator qual/fit test Survey Notebook Complete Set of Schematics

## **Spare Parts**

Cahle, Power, AC DAS1402 Keyboard Leeson Motor Board Mouse, BSI P-10 Bottles (2) Tubing (1 Box) Extension Cord (12 Guage)

\* Hard Drives Removed and hand carried.

. <del>\$</del>

;

# **Shipping Containers**

Frame & 2' Detector Electronics Tool Boxes P-10 (4) Detectors, 4' Don's Suitcase Luggable Box #1 Box #2 Box #3 Box #4 Box #5 Checked Carry-on ..

# Appendix C

**Survey Documentation Control Sheet** 

# SHONKA RESEARCH ASSOCIATES, INC.

# Survey Documentation Control Sheet

DESCRIPTION	VALUE
CLIENT	
PROJECT / TASK NUMBER	
CLIENT TRACKING NUMBER	

DESCRIPTION		EXAMPLE	VALUE
	SURVEY AREA CODE	A1(00)-B	
URVEN	SURVEY UNIT CODE	(XX)1	
15	SURVEY LOCATION ELEMENT	FZ(X)1	
	SURVEY CLASSIFICATION ELEMENT	1	
VEY	SURVEY REASON CODE	F01	
SUR TY	SURVEY MEDIA CODE	C(0)1	
	SURVEY DETECTOR ELEMENT	AB-(0)1-251-()	
SURVEY RECORD NUMBER OR SCM FILENAME		AB60401Z	:
SURVEY MAP FILENAME AND REFERENCE COORDINATES IN $(X, Y, Z)$ [METERS]		Floor1.DXF (29.5. 12.5. 0)	

PERFORMED BY:	DATE:
PERFORMED BY:	DATE:
REVIEWED BY:	DATE:

#### THIS SURVEY HAS BEEN VOIDED OR SUPERSEDED BY:

(SURVEY IDENTIFICATION CODE)

# Appendix D

Survey QA Review Sheet

# SHONKA RESEARCH ASSOCIATES, INC.

### **Survey QA Review Sheet**

# THE UNDERSIGNED HAS REVIEWED THIS SURVEY IN ACCORDANCE WITH THE METHOD(S) INDICATED BELOW.

	1. SURVEY REPORT		
A	Review to determine that the data tables are consistent with the Auto Generated Survey Records.		
в	Review report to ensure that backgrounds have been considered and applied.		
с	Review body of report and verify that general grammar, spelling, punctuation, etc. are correct		
D	Other:		
	2. DOCUMENTATION		
A	Review to determine that the survey documentation has been validated, meets all requirements for deliverable items, and that the documentation contains all necessary information for reconstruction at a later date.		
В	Review to verify that the tape backup is complete.		
С	Ensure that the Survey Archive has been performed.		
D	Other:		
	3. DELIVERABLE ITEMS		
A	Ensure that all deliverable items due the client have been completed.		
В	Ensure that all deliverable items are prepared for transmission to client.		
c	Other:		
	4. OTHER		
A			

REVIEWED BY: \_\_\_\_\_

:

\_ DATE: \_\_\_\_\_

Control Copy #\_\_\_\_

•

. .



Shonka Research Associates, Inc. 4939 Lower Roswell Road, Suite 106 Marietta GA 30068 770-509-7606

# **Surface Contamination Monitor**

----

SCM Procedure 011, Rev1

Survey Naming Convention when Using the SCM

Ξ

:

-

. **#** 

•

•		
	•	

Table A 1. Revision Table						
REVISION	REVIEWED BY: D. DEBORD		BRIEF SUMMARY OF			
	NE FIGION	A011101(3)	REVIEWER(S)	DATE	CHANGES	
001	M. Marcial		9/7/01	Initial write.		

Table A 1. Revision Table

QA REVIEW BY: D. SHONKA	DATE:
Delineh B. Runik	9/7/01
EFFECTIVE DAT	E: 9/7/01

# 1. Purpose

This procedure establishes the methods for naming surveys when using the SCM. The SCM saves data to a filename that is identical to the survey name entered by the SCM operator into the process software. Therefore, the survey name is currently limited to 8 alphanumerics.

# 2. Scope and Limitations

This procedure applies to any use of the SCM when logging data.

# 3. Definitions and Acronyms

ITEM	DESCRIPTION
SCM	The Surface Contamination Monitor is a mobile platform containing detectors, support electronics, and data logger used for conducting radiological surveys.
Survey Measurement Type Code	This code identifies the type of survey: alpha, beta, gamma, quality assurance, etc.
Survey Operating Mode Code	This code identifies the operating mode: rolling, corner or merged.
SCM ID Code	This code identifies the SCM serial number.
Survey Sequence Code	This code identifies the survey number. This number starts at 1 and increments throughout the survey for a given Survey Measurement Type Code, Survey Operating Mode Code, and SCM ID Code.
Survey Interrelated Code	This code identifies when a survey relates to another previous survey of the same survey block.
Survey Identification Code (SIC)	This code provides a naming convention for surveys.
SCM SIC Objects	The defined objects are: Survey Measurement Type Code. Survey Operating Mode Code, SCM ID Code, Survey Sequence Code, and the Survey Interrelated Code.
SCM SIC Fundamental Objects	The SIC is made up of elements and numbers. An element is an alphanumeric.
Fundamental Object Data Type	Each SCM SIC Fundamental Object has a data type defined as 1 alphanumeric or 1 digit.
Survey Strip	A continuous data set logged by the SCM.

### Table 1. Definitions and Acronyms.

ITEM	DESCRIPTION
Survey Stitch	A process of assembling survey strips into on file for data analysis.
Survey Block	A group of survey strips stitched into one spatial image.

# 4. General Information

The survey name holds values to help the SIMS data processor immediately identify the file. The survey name is made up of SCM Survey Identification Code (SIC) objects: Survey Measurement Type Code, Survey Operating Mode Code, SCM ID Code, Survey Sequence Code, and the Survey Interrelated Code.

# 5. Materials, Equipment, and Supplies

Tab	ole 2 . Material	s, Equipment, and Supplies.	
ITEM	:	SPECIFICATION	
SCM	Model 3		
SCM Process Software	Version 2.0	) or later	• •

## 6. Responsibilities

#### 6.1. Operator

- 6.1.1. Reads and becomes familiar with this procedure before performing an SCM survey.
   6.1.2. Have a set of the set of the
- 6.1.2. Has successfully completed SCM I training.

## 7. Procedure

### 7.1. Survey Naming Convention

The diagram in Appendix A. "SCM 8-Character SIC Diagram", shows the SCM SIC.

7.1.1. The first two characters designate the Survey Measurement Type and Purpose. Table 3 shows the allowed values.

.

SURVEY PURPOSE CODE	DESCRIPTION
R	Source Response Check
Р	Performance Based Check
С	Calibration Check
S	Survey
В	Background Survey
Z	Informational Survey
A	Alpha Survey
SURVEY MEASUREMENT TYPE CODE	DESCRIPTION
A	Alpha Survey
В	Beta Survey
G	Gamma Survey
Ν	Nuctron Survey
X	Alpha Beta and Gamma Survey
Y	Alpha and Beta Survey
W	Wheel Encoder Confirmation

Table	3.	Allowed	values	for the	Survey	Measurement	Type	and Purp	ose.

7.1.2. The third character designates as the Survey Operating Mode Code. Table 4 shows the allowed values. Use the merged code when combining the survey strips in a rolling survey with the survey strips of a corner survey.

SURVEY OPERATING MODE CODE	DESCRIPTION
R	Rolling or scanning survey.
С	Corner or static measurement survey.
М	A merged survey.

Table 4. Allowed values for the Survey Operating Mode Code.

7.1.3. The fourth character designates as the SCM ID Code. This code is the serial number of the SCM and will be a digit from zero thru 9. When merging survey data from 2 different SCMs, then enter this object as "Z".

SCM ID CODE DESCRIPTION		
0-9	SCM serial number.	
Z	Use this code when merging data from 2 different SCMs that where used on the same survey block.	

### Table 5. Allowed values for the SCM ID Code.

7.1.4. The fifth, sixth and seventh characters is designated as the Survey Sequence Code. This code is a sequentially incrementing number used for a given Survey Measurement Type Code, Survey Operating Mode Code, and SCM ID Code.

#### Table 6. Allowed values for the Survey Sequence Code.

SURVEY SEQUENCE CODE	DESCRIPTION	
(XX)-999	Sequential survey number.	

7.1.5. The eighth character designates the Survey Interrelated Code. Use this code when performing a repeat, investigation, or other survey of a previous survey.

iapie	7. Allowed Va	liues for t	ne scm i	D Code.
				the second s

SCM ID CODE	DESCRIPTION
A thru Y	A sequential character that increments for each repeated survey or related survey.
Z	Use the "Z" code as a placeholder so that the SCM file names are all 8-characters long.

## 8. References

8.1. N/A

## 9. Required Records

9.1. N/A

# 10. Appendices

10.1. Appendix A, "SCM 8-Character SIC Diagram"

٠

.

19.

# Appendix A

SCM 8-Character SIC Diagram

#### SCM PROCEDURE 011, REV1 DATE: 9/7/01 TITLE: SURVEY NAMING CONVENTION WHEN USING THE SCM

PAGE 8 OF 8

.

Figure 1. SCM 8-Character SIC.



Appendix B

Survey Design Revision 1

•

			(	DRIGIN	IAI
FirstEnergy SNE(	C ÇALCULATIO		HEET		
1	'CALCULATION DE	SCRIPTION			
Calculation Number	Revision Numbe	Effective Date	- F	age Number	
E900-03-019	1	10/	7/03	1 of	14
Subject					
Shonka SSGS Footprint & CV Ste	eam Pipe Tunnel (SSGS S	ide) FSS Survey D	esign		
Question 1 - Is this calculation defined a	as "In QA Scope"? Refer to de	finition 3.5. Yes 🛛	No 🔲		
Question 2 - Is this calculation defined a	as a "Design Calculation"? Re	fer to definitions 3.2 a	nd 3.3. Yes 🖾	No 🗖	
Question 3 - Does the calculation have	the potential to affect an SSC	as described in the U	SAR? Yes 🗌	No 🛛	
NOTES: If a "Yes" answer is obtained for Qu Assurance Plan. If a "Yes" answer is ob calculation as the Technical Reviewer. If a calculation. Calculations that do not have the	uestion 1, the calculation must me tained for Question 2, the Calc "YES" answer is obtained for Que e potential to affect SSC's may be	et the requirements of th ulation Originator's imm stion 3, SNEC Managen implemented by the TR.	e SNEC Facility Dec ediate supervisor s eent approval is requ	commissioning C should not revie uired to impleme	Quality (w) the ent the
	DESCRIPTION OF	REVISION		ŀ	
<ol> <li>Page 2, Section 2.1.2 – A that were surveyed by Sh</li> <li>Page 4 - Add new Refere work to be performed in t</li> <li>Page 14 – Add SS14-6 re</li> <li>Note: Revisions are not</li> </ol>	Add Survey Unit SS14-6 nonka. ence 3.8 – This new refer trenches and sumps in the eference to print. ted by change bars in rig	to include SSGS to rence provides add e SSGS basemer ht margin.	basement floor ditional informa it.	trench walk	5
	APPROVAL SIGN	IATURES ,		 : <u>;-</u> -	
Calculation Originator P.	APPROVAL SIGN	IATURES	Date	10/7/03	
Calculation Originator P. Technical Reviewer R.	APPROVAL SIGN Donnachie/ Holmes/	IATURES milie mes	Date Date	10/7/03 10/7/0	3
Calculation OriginatorP.Technical ReviewerR.Additional Review	APPROVAL SIGN Donnachie/ Holmes/	IATURES milie mes	Date Date Date	10/7/03	3
Calculation OriginatorP.Technical ReviewerR.Additional ReviewAdditional Review	APPROVAL SIGN Donnachie/	IATURES milie mes	Date Date Date Date Date	10/7/03 10/7/0	3

•

Fisterery	SNEC CALCULATION SHEET			
Calculation Number	Revision Number	Page Number		
E900-03-019	· 1	Page 2 of 14		

#### Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

### 1.0 PURPOSE

- 1.1 The purpose of this calculation is to provide the survey design guidance to be followed for conducting final status surveys (FSS) in the Saxton Steam Generation Station (SSGS) footprint and the adjacent CV Steam Pipe Tunnel (805' elev.). The SSGS footprint consists of the "Firing Aisle" (806' elev.), SSGS Basement Area (790' elev.) and Seal Chamber 1 & 2 Roof areas (~803' elev.). The CV Steam Pipe Tunnel extends off the northeast corner of the SSGS footprint.
- 1.2 Shonka Research Associates (SRA) will conduct scan surveys using procedures reviewed and approved by SNEC. These procedures are attached as Appendices.

### 2.0 SUMMARY OF RESULTS

- 2.1 The following information will be used to conduct the applicable FSS for this survey design:
  - 2.1.1 The SSGS Footprint area is divided into twelve (12) survey units, i.e. seven (7) Class 1, two (2) Class 2 and three (3) Class 3 survey units.
  - 2.1.2 The SSGS Survey Unit (SU) Numbers are as follows (See Attachments 7 & 8 for survey unit locations):

SU Number	Area Description	Classification	Area (m <sup>2</sup> ) <sup>1.</sup>
SS13-1	Firing Aisle Floor (806')	3	560
SS13-2	Firing Aisle Walls	3	80
SS14-1	Basement Floor (790') <sup>2</sup>	1	75
SS14-2	Basement Floor (790') <sup>2.</sup>	1	75
SS14-3	Basement Floor (790') <sup>2.</sup>	1	88
SS14-4	Basement Floor (790') <sup>2.</sup>	1	77
SS14-5	Basement Floor (790') <sup>2</sup>	1	56
SS14-6	Basement Trench Walls <sup>2.</sup>	1	~20
SS15	Basement Wall (East End)	1	100
SS16	Basement Walls Up to 2 meters	2	240
SS17	Basement Walls > 2 meters	3	350
SS18	Seal Chamber 1 & 2 Roofs	2	32

Note 1: Area and linear dimensions are approximations.

Note 2: Basement floors will include walls of trenches where possible. Reference 3.8 covers additional FSS work inside sumps and trenches.

2.1.3 The CV Steam Pipe Tunnel (SSGS Side) consists of three parts: floor, walls and ceiling. Since characterization information in this tunnel is limited and radioactive steam passed through it, the entire area has been classified as Class 1. This area is not described in the current Revision 2 of the SNEC LTP. However, this area will be included in Table 5-2 under the SSGS section in the next LTP revision. The CV Steam Pipe Tunnel is divided into three (3) Class 1 survey units.
FirstEnergy	SNEC CALCULATION SHEET	
Calculation Number	Revision Number	Page Number

E900-03-019

Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

2.1.4 The Survey Unit Numbers for these CV Steam Pipe Tunnel (SSGS Side) are as follows:

1

SU Number	Area Description	Classification	Area (m <sup>2</sup> )
SS22-1	CV Steam Pipe Tunnel floor	1	20
SS22-2	CV Steam Pipe Tunnel walls	1	45
SS22-3	CV Steam Pipe Tunnel ceiling	1	15

- 2.1.5 The number of static measurement points will be developed, as applicable, after SRA completes their survey and results are reviewed by the FSS group.
- 2.1.6 The minimum scan coverage for Class 1 areas will be 100%, Class 2 areas, 50% and for Class 3 areas, 10-50%.
- 2.1.7 Scan speed will be set in accordance with SRA procedures and the SNEC MDC<sub>scan</sub> value calculated for structure surfaces.
- 2.1.8 The SSGS Footprint and the adjacent CV Steam Pipe Tunnel have different <u>surface DCGL</u><sub>w</sub> values. For this design the following DCGL<sub>w</sub> values apply:

### SSGS Footprint - 13,095 dpm/100 cm<sup>2</sup>

### CV Steam Pipe Tunnel – 7628 dpm/100 cm<sup>2</sup>

These values are the 75% administrative limits for the surrogate Cs-137 values calculated in Attachments 3 & 5.

2.1.9 As a guideline for elevated measurement (hot spot) determination a surface area <u>DCGL<sub>emc</sub></u> will use an apriori Cs-137 surface area factor for a 1-m<sup>2</sup> area equal to 11. These values are calculated to be:

### SSGS Footprint - 144,045 dpm/100 cm<sup>2</sup>

### CV Steam Pipe Tunnel – <u>83,908 dpm/100 cm<sup>2</sup></u>

Note: If an elevated measurement (hot spot) is detected a dimensional analysis will be made of the hot spot and the appropriate area factor will be applied from SNEC LTP Table 5-15a.

2.1.10 The <u>MDC<sub>scan</sub></u> values for this design that SRA must achieve are:

### SSGS Footprint - <u>6547 dpm/100 cm<sup>2</sup></u>

### CV Steam Pipe Tunnel – <u>3814 dpm/100 cm<sup>2</sup></u>

- 2.1.11 Areas greater than the DCGL<sub>w</sub> must be identified, documented, marked, and bounded to include an area estimate.
- 2.1.12 Class 1 areas with surface deformations that cannot be surveyed by Shonka will be identified by marking or painting around the suspect area's perimeter.

FirstEnergy	SNEC CALCULATION SHEET	
Calculation Number	Revision Number	Page Number
<b>Baaaaaaaa</b>		

E900-03-019

Subject

### Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

- 2.1.13 Remediation is indicated when any area exceeds 3 x the DCGL<sub>w</sub> for any scan measurement or when the value for any area of ~1 square meter is greater than the DCGL<sub>emc</sub>. Note: If additional remediation is performed the survey unit design is void.
- 2.1.14 Gas flow proportional counter (GFPC) will be used IAW SRA procedures.

### 3.0 REFERENCES

- 3.1 SNEC Facility License Termination Plan.
- 3.2 Procedure E900-IMP-4500.59, "Final Site Survey Planning and DQA".
- 3.3 SNEC procedure E900-IMP-4520.04, "Survey Methodology to Support SNEC License Termination".
- 3.4 SNEC procedure E900-IMP-4520.06, "Survey Unit Inspection in Support of FSS Design".
- 3.5 NUREG-1575, "Multi-Agency Radiation Survey and Site Investigation Manual", August 2000.
- 3.6 SRA Procedures – See Appendix Section 6.0.
- SNEC Calculation E900-03-012, "Effective DCGL Worksheet Verification." 3.7
- SNEC Calculation E900-03-025, "SNEC Area Trench & Sump Survey Design." 3.8

### 4.0 ASSUMPTIONS AND BASIC DATA

- 4.1 SRA procedures to be used to perform scan surveys.
- 4.2 SNEC LTP section 2.2.4.1.5 and Figure 2-25 provide a description of the SSGS Footprint.
- 4.3 Attachment 6 provides figure of the CV Steam Pipe Tunnel (SSGS Side).
- 4.4 **Remediation History**

The Saxton Steam Generating Station (SSGS) Footprint consists of multiple levels. The upper level, "Firing Aisle" (~806' El), contained little or no contaminated surfaces. However, several drain lines contained levels of Cs-137 that was discernable above typical background values. The majority of this piping was removed during the remediation process. Any impacted piping that is to be left behind will be sampled and surveyed in accordance with SNEC site procedures.

The lower level, SSGS Basement Area (~790'), was surveyed and sampled in stages because of elevated ground water levels, which would have normally resided to a depth several feet above the floor (~790'). Water was pumped from region to region at this elevation to allow the completion of the characterization process on the walls and floor sections of the basement area. Results from surveys and sampling in this region show somewhat contaminated surfaces exist on the floor and in the sump areas at this lower elevation. Tie lines (piping) between sumps were also contaminated and were cut out. Surface drain lines and miscellaneous piping that were impacted and accessible were removed. Other piping in this region that showed elevated levels of residual contamination and will be treated in accordance with SNEC site procedures.

SNEC CALCULATION SHEET			
Calculation Number	Revision Number	Page Number	
E900-03-019	1	Page 5 of 14	

#### Subject

### Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

Characterization results for the SSGS area are presented in the SNEC LTP, Tables 2-3a through 2-3d and 2-29. This is a complex structure both physically and radiologically. Table 5-2 provides the survey classifications that result from the complete characterization data for this area.

The west end of the CV Steam Pipe Tunnel exited the southwest side of the pipe tunnel that surrounds the CV. The CV Steam Pipe Tunnel then connected to the SSGS. The tunnel is known to have had trace amounts of surface contamination from leaking steam pipes. All piping has been removed from this tunnel. It is presently sealed at its end with a metal and/or concrete block wall. Since this area was potentially surface contaminated and since it was not physically isolated from the SSGS, it poses some questions as to just how well SSGS cleanup was accomplished prior to demolition. In 2001 surface scans and loose contamination surveys were performed in 2001. Results from these surveys indicated <1000 dpm/100 cm<sup>2</sup> beta-gamma and <15 dpm/100 cm<sup>2</sup> alpha for removable surface contamination, surface scans <100 ncpm (RM-14) and <0.1 mr/hr general area. On 8/14/03 paint chips were taken from the tunnel wall. An evaluation of these chips determined that there was no surface activity between the paint layer and the bare wall. This paint was determined to have been part of the original structure and not used to cover up contamination. Gamma scans (ref. gamma log numbers 5-14471 and 1-14472) performed on the paint chips indicated no radionuclides above minimum detectable activity (MDA). Therefore, there was no reason to remove paint prior to FSS.

- 4.5 This survey determines the effective DCGL<sub>w</sub> value for Cs-137 using the spreadsheet mix in Attachments 3 & 5. A 25% reduction to the effective DCGL<sub>w</sub> was performed to address de-listed radionuclides. The SNEC facility has instituted an administrative limit of 75% for the allowable dose for all measurement results. The de-listed radionuclide dose is accounted for within the 75% administrative limit.
- 4.6 Radionuclide mixes used to determine effective DCGL<sub>w</sub> were taken from Attachments 2 & 4.
- 4.7 The MDC<sub>scan</sub> calculation is determined based on LTP section 5.5.2.5. The calculation simply reduces the applicable DCGL<sub>w</sub> by 50%.
- 4.8 Special measurements including gamma-ray spectroscopy are not included in this survey design.
- 4.9 Static and other survey measurements may be conducted as applicable after review of the SRA survey is completed. This design will be revised to incorporate these surveys as determined by the FSS group.
- 4.10 The survey design checklist is listed in Attachment 1.

### 5.0 CALCULATIONS

SSGS Footprint

- The required DCGLw = 17,461 x 0.75 = 13,095 dpm/100 cm<sup>2</sup>.
- The MDC<sub>scan</sub> =  $13,095 \times 0.5 = 6547 \text{ dpm}/100 \text{ cm}^2$ .
- DCGL<sub>emc</sub> for  $1 \text{ m}^2 = 13,095 \text{ X AF}$  of  $11 = 144,045 \text{ dpm}/100 \text{ cm}^2$ .

|--|

Calculation Number

E900-03-019

Revision Number

1

Page Number

Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

CV Steam Pipe Tunnel

- The required DCGLw = 10,170 x 0.75 = 7628 dpm/100 cm<sup>2</sup>.
- The MDC<sub>scan</sub> =  $7628 \times 0.5 = 3814 \text{ dpm}/100 \text{ cm}^2$ .
- DCGL<sub>emc</sub> for  $1 \text{ m}^2 = 7628 \text{ X AF}$  of  $11 = 83,908 \text{ dpm}/100 \text{ cm}^2$ .

### 6.0 APPENDICES

- 6.1 Attachment 1, Survey Design Checklist.
- 6.2 Attachment 2, Sample Results for SSGS Footprint
- 6.3 Attachment 3, SSGS Footprint Effective Area DCGL<sub>w</sub> for Cs-137 (dpm/100 cm<sup>2</sup>)
- 6.4 Attachment 4, Sample Results for CV Pipe Tunnel (SSGS Side)
- 6.5 Attachment 5, CV Tunnel (SSGS Side) Effective Area DCGL for Cs-137 (dpm/100 cm<sup>2</sup>)
- 6.6 Attachment 6, CV Steam Pipe Tunnel (SSGS Side) Figure
- 6.7 Attachment 7, SSGS Footprint Firing Aisle & Top of Seal Chambers
- 6.8 Attachment 8, SSGS Footprint Basement (790')
- 6.9 Attachment 9, SRA SCM Procedure 001, Rev 6, Confirmation and Calibration of the Incremental Encoder.
- 6.10 Attachment 10, SRA SCM Procedure 005, Rev 6, Requirements for Completion of the Survey Using the SCM.
- 6.11 Attachment 11, SRA SCM Procedure 006, Rev 4, Performance of a Position Calibration on a PSPC.
- 6.12 Attachment 12, SRA SCM Procedure 007, Rev 7, Source Response Check and Performance Based Check of any PSPC Detector Configuration Installed on the SCM.
- 6.13 Attachment 13, SRA SCM Procedure 008, Rev 3, Conduct of Operations for Surveys Using the SCM/SIMS:
- 6.14 Attachment 14, SRA SCM Procedure 011, Rev 1, Survey Naming Convention when Using the SCM.

. .

FirstEnergy

### SNEC CALCULATION SHEET

**Calculation Number** 

E900-03-019

Page Number

1

Page 7 of \_14\_

Subject

## Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

### Attachment 1

**Revision Number** 

## **Survey Design Checklist**

Calcula	ation No. 6900-03-019	Location Code: See attached design for l	ocation codes.	
ITEM	REVIEW F	ocus	Status (Circle One)	Reviewer Initials & Date
1	Has a survey design calculation number been description p	assigned and is a survey design summary rovided?	Yes N/A	1017/03
2	Are drawings/diagrams adequate for the subject heading	ect area (drawings should have compass s)?	Yes, N/A	Patt 10/7/03
3	Are boundaries properly identified and is the su	urvey area classification clearly indicated?	(es) N/A	AX 10/103
4	Has the survey area(s) been properly divid	led into survey units IAW EXHIBIT 10	Yes N/A	DH 10/1/03
5	Are physical characteristics of the area	Nocation or system documented?	Yes, N/A	ANH 10H/03
6	Is a remediation effectivenes	ss discussion included?	Yes N/A	PNA 10/7/03
7	Have characterization survey and/or sampling comparable to applicat	results been converted to units that are ble DCGL values?	Yes, N/A	204-10/03
8	Is survey and/or sampling data that was used for	determining survey unit variance included?	Yes, N/A	Att 10/2/07
9	Is a description of the background reference an sampling results included along with	reas (or materials) and their survey and/or a justification for their selection?	Yes, N/A	Det 10/-102
10	Are applicable survey and/or sampling data that	was used to determine variability included?	Yes, N/A	RX410/103
11	Will the condition of the survey area have an in probable impact been cons	mpact on the survey design, and has the sidered in the design?	Yes, N/A	REA 10/1/03
12	Has any special area characteristic including previously noted during characterization) been design	any additional residual radioactivity (not identified along with its impact on survey ?	Yes N/A	ANA 10/1/03
13	Are all necessary supporting calculations and/c	or site procedures referenced or included?	(Yes) N/A	QX410/7/03
14	Has an effective DCGLw been ide	ntified for the survey unit(s)?	(Yes,) N/A	PDA of 103
15	Was the appropriate $DCGL_{EMC}$ included	I in the survey design calculation?	Yes N/A	10/1/03
16	Has the statistical tests that will be used t	o evaluate the data been identified?	Yes, N/A	POA10/1/03
17	Has an elevated measurement comparis	on been performed (Class 1 Area)?	Yes, N/A	ANA 10/1/0
18	Has the decision error levels been identified and	are the necessary justifications provided?	Yes N/A	exy 10/1/03
19	Has scan instrumentation been identified along	with the assigned scanning methodology?	(Yes) N/A	Andriles
20	Has the scan rate been identified, and is the M	DCscan adequate for the survey design?	(Yes,) N/A	PA4 10/2/03
21	Are special measurements e.g., in-situ gamma-ra and is the survey methodology, and	ay spectroscopy required under this design, evaluation methods described?	Yes, N/A	Ag w/1/03
22	Is survey instrumentation calibration data include	ed and are detection sensitivities adequate?	Yes N/A	ALA 10 Hog
23	Have the assigned sample and/or measurement lo or CAD drawing of the survey area(s	ocations been clearly identified on a diagram s) along with their coordinates?	Yes N/A	Q440/7/03
24	Are investigation levels and administrative limits clearly indic	adequate, and are any associated actions cated?	Yes N/A	QQ419/1/03
25	For sample analysis, have the required	d MDA values been determined.?	Yes, N/A	PANO/1/03
26	Has any special sampling methodology been iden	tified other than provided in Reference 6.3?	Yes, N/A	204 10/1/03

NOTE: a copy of this completed form or equivalent, shall be included within the survey design calculation.

### FirstEnergy

## SNEC CALCULATION SHEET

**Calculation Number** 

E900-03-019

Revision Number
1

T 4/2 (4)

T 4 10 / 41

Page 8 of \_14\_

T 412 (4) T 412 (4)

Page Number

Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

## Attachment 2 Sample Results for SSGS Footprint

Location/Description	
SSGS Footprint AV-134, 0'-3', Well #2	
Sediment Phase - SSGS East Sump @ 25', AV183, W	el] #1
SSGS Footprint AT-139 @ 6"	
SSGS Footprint AT-139, 9-12', Well #4	
SSGS Footprint AW-132 @ 21', Well #3	
SSGS Footprint West Turbine Sump Area AV-134 (Pun	nped)
SSGS Footprint East Turbine Sump Area AV-133 (Pur	xped)
SSGS Footprint Collection Tank Area AW-132 (Pump	eđ)
SSGS Footprint, Well # 7 Pumped Sediment	
SSGS North Sump	
SSGS SE Sump, AU-133, SR-0003	
SSGS South East Sump Sediment AV-133	
SSGS Mezzanine, East, SR-0004	
SSGS North Sump Penetration - 4" Pipe	
SSGS, East, Disk # 1	
SSGS Footprint, East, SR-0004, NW Sump	
SSGS Footprint, Center Section, Core Bore # 2, Disk # 1, Build	ing Structure
SSGS 790" EL, East - Debris From Pump Stand Small	Pipe
SSGS 4" Cross Over Line - Sump to Sump - 790" E	il.
SSGS Footprint Sample # 5, Concrete Floor Core - SR-56, Buik	ing Structure

	1 112 (u)	1 112 (0)	1 112 (0)		1 1/2 (4)	
1	157861.05	1925.23275	11019.5925	32050.6875	8813847.75	10446.15
	Am-241	Co-60	Cs-137	Pu-238	Pu-239	Sr-90
	Am-241	Co-60	Cs-137	Pu-238	Pu-239	Sr-90
	0.0995	0.0327	1.3931	0.0014	0.0060	0.0277
	0.0875	1.9646	78,9405	0.0292	0.0400	
	0.0199	0.0328	0.2508	0.0068	0.0050	0.0185
	0.0199	0.0328	0.3065	0.0015	0.0050	0.0167
	0.0090	0.0262	0.4365	0.0019	0.0060	0.0278
	0.1294	0.1329	6.2384	0.0068	0.0120	0.0185
	0.1990	0.2459	91.0626	0.1952	0.2000	0.0556
	0.0398	0.1330	5.1214	0.0146	0.0160	0.0186
	0.0697	1.0260	72.0571	0.2932	0.1700	
	0.0040	0.0510	2.4127	0.0039	0.0030	0.0094
	0.0139	0.3941	150.4871	0.0029	0.0040	0.0189
	0.0889	0.3847	84.0773	0.0647	0.0381	0.1473
	0.7064	1.6667	37.5482	0.3240	0.3300	0.1702
	0.0528	0.2091	4.1717	0.0098	0.0040	0.0474
	0.2890	1.5060	627.5376	0.0452	0.1450	0.0474
	0.1356	0.1077	11.0809	0.0030	0.0030	0.0858
i	0.0478	0.0308	0.2580	0.0482	0.0490	0.0572
	0.1097	3.1170	2999.1594	0.0690	0.0800	0.0382
	0.0670	0.3719	111.1883	0.1442	0.0875	0.1386
	0.1320	0.0569	3.7134	0.1158	0.0386	0.0168
Mean⇒	1.16E-01	5.76E-01	2.14E+02	6.91E-02	6.21E-02	5.34E-02
% of Total⇒	0.054%	0.268%	99.593%	0.032%	0.029%	0.025%
Median=>	7.86E-02	1.71E-01	8.66E+00	2.19E-02	2.70E-02	3.30E-02
Sigma⇒	1.56E-01	8.47E-01	6.70E+02	9.80E-02	8.68E-02	4.96E-02
2 Sigma + Mean⇒	4.27E-01	2.27E+00	1.55E+03	2.65E-01	2.36E-01	1.53E-01

T 4/2 / 41 T 4/2 / 41

FirstEnergy	SNEC CALCULATION SHEET	
Calculation Number	Revision Number	Page Number

Calculation Number E900-03-019

1

Page 9 of \_14\_\_\_

Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

## Attachment 3 SSGS Footprint Effective Area DCGL for Cs-137 (dpm/100 cm<sup>2</sup>)

	Effective DCGL Calculator for Cs-137 (dpm/100 cm				<u>ייי</u> ו^2)	Gross Act	vity DCGLW	Gross Activity	dministrative Limit
					17498	dpm/100 cm^2	13124	dpm/100 cm^2	
1	25.0	mrem/y TEDE Limit							
		-			_	331517-Ca-13	Limit AND AND	表示:## Cs-137 Adm	inistrative Limit 3523
	SAMPLE NO(s)⇒	SSGS Footprint				17461	dpm/100 cm^2	13095	dpm/100 cm^2
						*SNEC ALX	75%		
	Isotope	Sample Input (pCl/g, uCl, etc.)	% of Total	Individual Limits (dpm/100 cm^2)	Allowed dpm/100 cm*2	mrem/y TEDE	Beta dpm/100 cm^2	Alpha dpm/100 cm^2	
1	Am-241	4.27E-01	0.027%	27	4.81	4.45	N/A	4.81	Am-241
2 3	C-14 Co-60	2.27E+00	0.000% 0.146%	3,700,000 7,100	0.00 25.57	0.00 0.09	0.00 25.57	N/A N/A	C-14 Co-60
4	Cs-137	3231,55E+03 10	3599.784%	Sec. 28,000	17460.65	4%=15.59 Tex	46917460.6 39	NA	Cs-137
5 6 7	Eu-152 H-3 Ni-63		0.000% 0.000% 0.000%	13,000 120,000,000 1,800,000	0.00 0.00 0.00	0.00 0.00 0.00	0.00 Not Detectable Not Detectable	N/A N/A N/A N/A N/A	Eu-152 H-3 Ni-63
8	Pu-238	2.65E-01	0.017%	30	2.99	2.49	N/A	2.99	Pu-238
9	Pu-239	2.36E-01	0.015%	28	2.66	2.37	N/A	2.66	Pu-239
10 11	Pu-241 Sr-90	1.52E-01	0.000% 0.010% 100.000%	880 8,700	0.00 1.71 17498	0.00 0.00 25.0	Not Detectable 1.71 17488	N/A N/A 10	Pu-241 Sr-90
					Maximum Permissible dpm/100 cm*2				

FirstEnergy	SNEC CALCULATION SHEET		
Calculation Number	Revision Number		Page Number
E900-03-019		1	Page 10 of _14

Subject

\_\_\_\_\_

## Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

## Exhibit 4 Sample Results for CV Pipe Tunnel (SSGS Side)

		SNEC SAMPLE RESULTS
	LAB or LAB No.	Location/Description
1	BWXT, 0102059-01	CV Tunnel Sediment Composite, OL1
	SNEC Sample No.	359
1	CV Tunnel	Comments:
	Other Identifier	
	CV Yard Soil	
	Analysis Date=>	February 14, 2001
1	Isotope	pCi/g (soilids) or pCi/l (if water) or pCi (if smears)
1	Am-241	< 0.18
2	C-14	< 9.34
3	Cm-243	
4	Cm-244	< 0.18
5	Co-60	1.26
6	Cs-134	< 0.19
7	Cs-137	1250
8	Eu-152	< 0.13
9	Eu-154	< 0.09
10	Eu-155	< 0.67
11	Fe-55	< 54.99
12	Н-3	< 9.4
13	Nb-94	< 0.03
14	Ni-59	< 43.81
15	Ni-63	< 4.02
16	Pu-238	< 0.55
17	Pu-239	<0.22
18	Pu-240	< 0.22
19	Pu-241	< 44.69
20	Pu-242	< 0.22
21	Sb-125	< 1.03
22	Sr-90	9.67
23	Tc-99	< 1.91
24	U-234	1.12
25	U-235	< 0.46
26	U-238	1.46
	Other Isotopes	pCl/g (soilids) or pCl/l (if water) or pCl (if smears)
	On-site Analysis for Cs-137	
	On-site Analysis for Co-60	***
	Un-site Analysis for H-S	
		47.4
	Gross Alpha	
	GIUSS Bela	
	Ra.226	
	Th-222	
	Cm-242	< 0.19
	Th-228	
	Np-237	< 0.24
	Ce-144	< 1.33

FirstEnergy

## SNEC CALCULATION SHEET

Calculation Number E900-03-019 **Revision Number** 

1

Page 11 of \_14\_

Page Number

Subject

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

## Exhibit 5 CV Tunnel (SSGS Side) Effective Area DCGL for Cs-137 (dpm/100 cm<sup>2</sup>)

	<b>Effective DC</b>	GL Calculator	for Cs-137	(dpm/100 cm	1^2)	Gross Act	thy DCGLW	Gross Activity	dministrative Limit		
						10705	dpm/100 cm^2	8029	dpm/100 cm^2		
		-									
25.0 mremly TEDE Limit											
						151010 . A Ce-13	,Limit Theres	TASE Co-137 Adm	inistrative Limit 的。		
	SAMPLE NO(s)⇒	CV Steam Tunnel (SS	GS Side)			10170	dpm/100 cm^2	7628	dpm/100 cm^2		
						*SNEC AL®	75%				
					1				1		
		Sample Input (pCl/g,		Individual Limits	Allowed dpm/100		Beta dpm/100	Alpha dpm/100			
	Isotope	uCi, etc.)	% of Total	(dpm/100 cm^2)	cm^2	mrem/y TEDE	cm^2	Cm^2			
1	Am-241		0.000%	27	0.00	0.00	N/A	0.00	Am-241		
,	C-14	9 345+00	0 710%	3 700 000	75 00	0.00	75 99	NVA	C-14		
3	Co-60	1.26E+00	0.096%	7,100	10.25	0.04	10.25	N⁄A	Co-60		
4	Cs-137 8025582	125E+03 46	194.95.004%	SE 535 28,000	sa10170.13 g	9.08 X	10170.1	N/A	Cs-137) 483500?		
5	Eu-152		0.000%	13,000	0.00	0.00	0.00	N/A	Eu-152		
6	H-3		0.000%	120,000,000	0.00	0.00	Not Detectable	N/A	Н-3		
7	NI-63		0.000%	1,800,000	0.00	0.00	Not Detectable	N/A	Ni-63		
8	Pu-238	5.50E-01	0.042%	30	4.47	3.73	N/A	4.47	Pu-238		
9	Pu-239	2.20E-01	0.017%	28	1.79	1.60	N/A	1.79	Pu-239		
10	Pu-241	4.47E+01	3.397%	880	363.60	10.33	Not Detectable	NA	Pu-241		
11	Sr-90	9.67E+00	0.735%	8,700	78.68	0.23	78.68	N/A	Sr-90		
			100.000%		10705	25.0	10335	6			
					Maximum Permissible dpm/100 cm^2				-		

<b>FirstEnergy</b>	NEC CALCULATION SHEET	
Calculation Number	Revision Number	Page Number
E900-03-019	1	Page 12 of _14
Subject		_!

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

Exhibit 6 CV Steam Pipe Tunnel (SSGS side)



FirstEnergy	SNEC CALCULATION SHEET	
Calculation Number	Revision Number	Page Number
E900-03-019	1	Page 13 of _14
Subject		

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

Attachment 7 SSGS Footprint Firing Aisle & Top of Seal Chambers



SSGS FIRING AISLE & SEAL CHAMBER TOPS PLAN EL. 806'-0"

SNEC CALCI	JLATION SHEET	
Calculation Number	Revision Number	Page Number
E900-03-019	1	Page 14 of _14
Subject		

Shonka SSGS Footprint & CV Steam Pipe Tunnel (SSGS Side) FSS Survey Design

Attachment 8 SSGS Footprint Basement (790')



Appendix C

. •

DCGL Calculation Logic

.

-

.

.

### DCGL Calculation Logic-SSGS Footprint

1. Survey Unit: Saxton Steam Generating Station (SSGS) Footprint

•

- II. Description: The purpose of this calculation is to determine a representative isotopic mix for the SSGS Footprint from available sample analyses. The effective surface area and volumetric DCGL<sub>w</sub>s are then determined from the mean percent of applicable samples.
- III. Data Selection Logic Tables: The radionuclide selection logic and subsequent DCGL calculations are provided in seven (7) tables. These tables were developed using Microsoft Excel. Table explanation is as follows.

Table 1: Data Listing – This table, which has been extracted from a larger database, provides a list of the most representative SSGS Footprint sample analyses. Results are from scoping, characterization, and pre/post remediation surveys. The samples consist of various sediments and concrete cores that were taken in support of the aforementioned surveys. As applicable, a sample number, sample location/description, radionuclide concentration, analysis date are provided for each sample. Positive nuclide concentrations are noted with yellow/shaded background fields while MDAs are noted in the gray shaded fields.

**Table 2**: Decayed Listing – This table provides the best overall representation of data selected and decayed from Table 1. In Table 1 half-life values (days) are listed above each respective nuclide column. Samples are decayed to the date noted above Table 1 (e.g. January 15, 2004). Positive results are denoted in a yellow background field while MDA values are in a gray background.

**Table 3**: Decayed Listing of Positive Nuclides & MDAs Removed– This table provides the decayed values of positive nuclides selected in Table 2. In addition MDA values have been removed from this table.

Table 4: Mean Percent of Total for Positive Nuclides – This table provides the calculation methodology for determining the relative fractions of the total activity contributed by each radionuclide. From this information the mean, sigma, and mean % of total are calculated. The mean % of total values is used to calculate the surface gross activity DCGL<sub>w</sub> per MARSSIM equation 4-4. See Table 6. Note that the Am-241 mean percent values were averaged using only samples 1 & 9. In addition, the mean percent value calculated from sample 9 for Co-60 and Pu-239 were not averaged throughout the spreadsheet, since this sample was the only one where these respective nuclides were positive. This results in higher "mean percent of total" values in the mix, which are conservative.

Table 5: Ratio to Cs-137 for Positive Nuclides – This table provides the calculation methodology for determining the surrogate ratio to Cs-137 for each radionuclide. From this information the mean, sigma, and mean % of total are calculated. The mean % of total values is used to calculate the volumetric DCGL<sub>w</sub> per MARSSIM equation I-14. See Table 7. Note that the Am-241 ratios were averaged using only samples 1 & 9. In addition, the ratio values calculated from sample 9 for Co-60 and Pu-239 were not averaged throughout the spreadsheet, since this sample was the only one where the respective nuclides were positive. This results in higher "mean percent of total" values in the mix, which are conservative.

Note: From Tables 4 and 5 only the "mean % of total" values are used as input to the "Effective DCGL Calculation Spreadsheet" as illustrated in Tables 6 and 7.

Table 6: Effective DCGL Calculator for Cs-137 (dpm/100 cm<sup>2</sup>) – This table provides the surface gross activity DCGL<sub>w</sub> calculation results from data derived from Table 4.

**Table 7:** Effective DCGL Calculator for Cs-137 (in pCi/g) – This table provides the surrogate volumetric modified Cs-137 DCGL<sub>w</sub> calculation results from data derived from Table 5.

IV. Summary – Since the SSGS Footprint is a concrete structure the release limit is primarily based on the surface area DCGL<sub>w</sub>. However, some SSGS Footprint concrete surfaces have volumetric contamination. Therefore, a volumetric DCGL<sub>w</sub> is also determined. Using the above data selection logic tables the calculated gross activity DCGL<sub>w</sub> for surface area is 13,615 dpm/100 cm<sup>2</sup>. The Cs-137 volumetric DCGL<sub>w</sub> is 6.56 pCi/g. These values would be reduced by 25% as part of SNEC's requirement to apply an administrative limit as discussed in the License Termination Plan (LTP).

.

					TABLE	1 - Data Listir	ig (pCi/g)								
														Decay Date	
														January 15, 2004	
	SNEC Sample No	Location/Description	H-3	Sr-90	Co-60	Cs-137	Am-241	Pu-238	Pu-239	Pu-241	C-14	Ni-63	Eu-152	Analysis Date	Elapsed Time
1	SX10GW00321	Sediment Phase - SSGS East Sump @ 25', AV183, Well #1			3	85	8.80E-02	0.03	0.04					April 25, 2000	1360
2	SX10SD00368	SSGS Footprint Collection Tank Area AW-132 (Pumped)		0.02	0.2	5.5	0.04	0.015	0.016	1.8				June 6, 2000	1318
3	SXCF1210	SSGS Footprint, Center Section, Core Bore # 2, Disk # 1	11.8	0.06	0.04	0.27	0.048	0.049	0.049	6.79	3.72	7.33	0.21	July 20, 2001	909
4	SXCF3531	SSGS Footprint Sample # 5, Concrete Floor Core - SR-56	2	0.0169	0.0584	3.73	0.132	0.116	0.0386	2.44	0.191	2.39	0.132	May 5, 2003	255
5	SXCF4323	SSGS Footprint SS14-1, AP-2-6	0.81	0.0256	0.0382	40.2	0.0154	0.0323	0.0241	1.56	0.147	2.5	0.197	November 18, 2003	58
6	SXCF4325	SSGS Footprint, AP-2-7, Sect 1, Slice 1	0.784	0.0243	0.0229	14.4	0.0132	0.0241	0.0108	1.57	0.143	0.334	0.0894	November 18, 2003	58
7	SXCF4330	SSGS Footprint SS14-2, Sect 1, Slice 1	0.746	0.0295	0.0278	2.73	0.0256	0.0398	0.0115	3.02	0.136	0.552	0.0815	November 24, 2003	52
8	SXCF4336	SSGS Footprint SS14-1, AP-2-4	0.606	0.0293	0.0243	16.9	0.0092	0.0117	0.0039	1.14	0.11	2.94	0.118	November 25, 2003	51
9	SXCF828	SSGS, East, Disk #1	11.7	0.05	2.01	660	0.29	0.046	0.145	6.819	3.68	7.73	0.31	May 4, 2001	986
		e and a star star and a star star a star			TABLE 2 -	Decayed Lis	ting (pCi/g)								
			T 1/2	T 1/2	T 1/2	T 1/2	T 1/2	T 1/2							
			4485.27	10446.15	1925.23275	11019.5925	157861.05	32050.6875	8813847.75	5259.6	2092882.5	36561.525	4967.4		
	SNEC Sample No	Location/Description	H-3	Sr-90	Co-60	Cs-137	Am-241	Pu-238	Pu-239	Pu-241	C-14	Ni-63	Eu-152	Total (pCi/g)	
1	SX10GW00321	Sediment Phase - SSGS East Sump @ 25', AV183, Well #1			1.84E+00	7.80E+01	8.75E-02	2.91E-02	4.00E-02				ļ	80.03	
2	SX10SD00368	SSGS Footprint Collection Tank Area AW-132 (Pumped)		1.83E-02	1.24E-01	5.06E+00	3.98E-02	1.46E-02	1.60E-02	1.51E+00				6.79	
3	SXCF1210	SSGS Footprint, Center Section, Core Bore # 2, Disk # 1	1.03E+01	5.65E-02	2.88E-02	2.55E-01	4.78E-02	4.80E-02	4.90E-02	6.02E+00	3.72E+00	7.20E+00	1.85E-01	27.87	
	SXCF3531	SSGS Footprint Sample # 5, Concrete Floor Core - SR-56	1.92E+00	1.66E-02	5.33E-02	3.67E+00	1.32E-01	1.15E-01	3.86E-02	2.36E+00	1.91E-01	2.38E+00	1.27E-01	11.01	
4	SXCE4323	SSGS Footprint SS14-1, AP-2-6	8.03E-01	2.55E-02	3.74E-02	4.01E+01	1.54E-02	3.23E-02	2.41E-02	1.55E+00	1.47E-01	2.50E+00	1.95E-01	45.38	
4	3/10/ 4020		7 775 04	2.42E-02	2.24E-02	1.43E+01	1.32E-02	2.41E-02	1.08E-02	1.56E+00	1.43E-01	3.34E-01	8.87E-02	17.34	
4 5 6	SXCF4325	SSGS Footprint, AP-2-7, Sect 1, Slice 1	1.112-01					The survey of the second s	1 1 1 1 1 1 1 1	1 2 005 .00	4 200 04	E EAE DA	1 0 005 00		
4 5 6 7	SXCF4325 SXCF4330	SSGS Footprint, AP-2-7, Sect 1, Slice 1 SSGS Footprint SS14-2, Sect 1, Slice 1	7.40E-01	2.94E-02	2.73E-02	2.72E+00	2.56E-02	3.98E-02	1.15E-02	3.00E+00	1.302-01	3.31E-01	8.09E-02	1.36	
4 5 6 7 8	SXCF4325 SXCF4330 SXCF4336	SSGS Footprint, AP-2-7, Sect 1, Slice 1 SSGS Footprint SS14-2, Sect 1, Slice 1 SSGS Footprint SS14-1, AP-2-4	7.40E-01 6.01E-01	2.94E-02 2.92E-02	2.73E-02 2.39E-02	2.72E+00 1.68E+01	2.56E-02 9.20E-03	3.98E-02 1.17E-02	1.15E-02 3.90E-03	3.00E+00 1.13E+00	1.36E-01 1.10E-01	2.94E+00	8.09E-02 1.17E-01	21.82	

KEY	
	Yellow Shaded Background = Positive Result
	Gray Shaded Background = MDA

BitC Engel to         Leaster Description         B-3         51-80         Co-40         First Part Part Part Part Part Part Part Par				TABLE	3 - Decaye	ed Listing of	Positive Nuc	lides & MDA	As Removed	(pCi/g)							
1         Norwinsting         State S	SNEC Sar	mple No	Location/Description	Н-3	Sr-90	Co-60	Cs-137	Am-241	Pu-238	Pu-239	Pu-241	C-14	NI-63	Eu-152	Total (pCi/		
2         355300008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         35530008         3	1 SX10GV	W00321	Sediment Phase - SSGS East Sump @ 25', AV183, Well #1				7.80E+01	8.75E-02							78.12		
2)         3507/110         3503 forgers diversity is in a set in a se	2 SX1050	D00368	SSGS Footprint Collection Tank Area AW-132 (Pumped)				5.06E+00								5.06		
4         3507/2011         35037 longenet Share, 4 A A A A         Image 4 S, Gorrerer Brock, A A A A         Image 4 S, Gorrerer Brock, A A A A           5         3507 (-202)         3503 7 longenet Share, A A A A         Image 4 S, Gorrerer Brock, B A A         Image 4 S, Gorrerer Brock, B A A           5         3507 (-202)         3503 7 longenet Share, A A A         Image 4 S, Gorrerer Brock, B A A         Image 4 S, Gorrerer Brock, B A A           5         3507 (-202)         3503 7 longenet Share, A A> A         Image 4 S, Gorrerer Brock, B A A         Image 4 S, Gorrerer Brock, B A A           6         3507 (-202)         3503 7 longenet Share, A A> A         Image 4 S, Gorrerer Brock, B A A         Image 4 S, Gorrerer Brock, B A A           7         A B A A         Image 4 S, B A A A A         Image 4 S, B A A A A A         Image 4 S, B A A A A A A A A A A A A	3 SXCF	F1210	SSGS Footprint, Center Section, Core Bore # 2, Disk # 1				2.55E-01								0.25		
9         3027422         3053 forgering 3544, AP-24         4015-01         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0	4 SXCF	3531	SSGS Footprint Sample # 5, Concrete Floor Core - SR-56				3.67E+00								3.67		
8         3501 Cogener, 84-92, 3ert, 8ize 1         1402-61         1           1         3507-029         3595 Toogener, 354-4, AP-24         1.082-61         1.48E-61         1           8         3507-029         3595 Toogener, 354-4, AP-24         1.141E-00         8.08C-19         1.48E-61         1           8         3507-029         3595 Toogener, 354-4, AP-24         1.141E-00         8.08E-101         1.48E-61         1           8         3507-029         3505 Eax, 0wk #1         1.141E-00         8.08E-101         1.48E-61         1           9         3507-029         3505 Toogener, 34-92         1.59%         98.03%         0.21%         0.16%           9         3507-029         1.59%         98.03%         0.21%         0.16%         0.06%           16         3507-029         3505 Toogener, 34-92         30.04%         100.00%         0.06%           16         3507-029         3507-029         3507-029         3507-029         3507-029         3507-029           16         3507-029         3508 Toogener, 34-92         100.00%         100.00%         100.00%           3507-109         3554 Toogener, 350-37         3508 Toogener, 350-48         100.00%         100.00%           35	5 SXCF	F4323	SSGS Footprint SS14-1, AP-2-6				4.01E+01								40.05		
7         35/27/203         35535 fooginer 3542, best, 5 best         2272-00         2         2         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0	6 SXCF	F4325	SSGS Footprint, AP-2-7, Sect 1, Slice 1				1.43E+01								14.35		
8         SXV-232         SSS 5 fooptime SS4-6, AP-24         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1         1	7 SXCF	F4330	SSGS Epotprint SS14-2, Sect 1, Slice 1				2.72E+00							1	2.72		
a         Storteal         Storteal         141E-00         528E-01         1.44E-01         1.44E-01           Synch         Synch         1.41E-00         8.68E-01         1.68E-01         1.44E-01         0           Synch         Synch         1.41E-00         8.68E-01         1.68E-01         1.44E-01         0           Synch         Synch         1.59%         96.03%         0.21%         0.16%         0           Synch         Synch         Synch         Synch         Synch         0.16%         0           Synch         Synch         Synch         Synch         Synch         Synch         0.16%         0           Synch         Synch         Synch         Synch         Synch         Synch         0         0           Synch         Synch         Synch         Synch         Synch         Synch         0         0         0           Synch         Synch         Synch         Synch         Synch         Synch         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0	8 SXCE	F4336	SSGS Epotprint SS14.1 AP.2.4				1.68E+01								16.8		
Direction         Direction <thdirection< th=""> <thdirection< th=""> <thd< td=""><td>9 SXCF</td><td>F828</td><td>SSGS Fact Dick #1</td><td></td><td></td><td>1.41E+00</td><td>6 20E+02</td><td>2 89F 01</td><td></td><td>1.45E.01</td><td></td><td></td><td></td><td></td><td>622 1</td></thd<></thdirection<></thdirection<>	9 SXCF	F828	SSGS Fact Dick #1			1.41E+00	6 20E+02	2 89F 01		1.45E.01					622 1		
Instrume	U UNCI		Manual Manual			1.415+00	9 695 -04	1 005 01		1 455 01					99 55		
Means to Totalize         1.59%         201.010         0.12%         0.16%         0.16%           TABLE 4 - Mean Percent of Total for Positive Nuclides           SHEC Sample ID         LocationOperciption         Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2">Colspan="2"           Sectors Colspan="2"           Sectors Colspan="2"           Colspan="2"           Sectors Colspan="2" <td <<="" colspan="2" td=""><td></td><td></td><td>mean⊃</td><td></td><td></td><td>1.412+00</td><td>201 619</td><td>0.142</td><td></td><td>1.4JE-01</td><td></td><td></td><td></td><td></td><td>00.33</td></td>	<td></td> <td></td> <td>mean⊃</td> <td></td> <td></td> <td>1.412+00</td> <td>201 619</td> <td>0.142</td> <td></td> <td>1.4JE-01</td> <td></td> <td></td> <td></td> <td></td> <td>00.33</td>				mean⊃			1.412+00	201 619	0.142		1.4JE-01					00.33
Internet of rotation         1.35%         90.03%         0.21%         0.16%           TABLE 4 - Mean Percent of Total for Positive Nuclides           Table 4 - Location/Description         Co-40         C 5417         Am.241         PU-220         Total           1 String of the set of			Sigma⇒ Maas V af Tatulat			4 509/	201.010	0.142		0.46%				P	100.00		
TABLE 4 - Mean Percent of Total for Positive Nuclides           SiteC sample to SxteGroup22t           Sediment Phase - SSG East Sum SSG Footprint Center Section Tank Area AVI-132 (Pumped)         Co-40         C s-137         Am-241         Pu-239         Total           SSKCF000022t         Sediment Phase - SSG East Sum SSG Footprint Center Section Tank Area AVI-132 (Pumped)         100.00%         100.00%         100.00%           SSKCF120         SSSG Footprint Simple 5, Concrete Floor Core - SR-66         1000.00%         1000.00%         1000.00%           SKCF120         SSSG Footprint Simple 5, Concrete Floor Core - SR-66         1000.00%         1000.00%         1000.00%           SKCF1205         SSG Footprint Sist-L, AP-24         0.02%         0.02%         1000.00%           SKCF1205         SSG Footprint Sist-L, AP-24         0.02%         0.02%         1000.00%           SKCF1205         SSG Footprint Sist-L, AP-24         0.02%         0.02%         1000.00%           S			Mean % of rotar⇒			1.39%	90.03%	0.21%		0.10%					100.00		
SHEC Sample No         LocationDescription         Co-60         Co-137         Am-241         PU-236         Total           1         SX100100221         Sediment Phase - 55G5 East Sump @ 25', AV183, Weil #1         99,395', 0.11%         100,00%         100,00%           2         SX0500266         SGS Footprint Centre Fellor, Core Bote #2, Disk #1         100,00%         100,00%         100,00%           3 SXCF1201         SSGS Footprint Start, AP-24         100,00%         100,00%         100,00%           4         SXCF231         SSGS Footprint Start, AP-24         100,00%         100,00%           6         SXCF4325         SSGS Footprint Start, AP-24         100,00%         100,00%           8         SXCF435         SSGS Footprint Start, AP-24         100,00%         100,00%           8         SXCF435         SSGS Footprint Start, AP-24         100,00%         100,00%           9         SXCF436         SSGS Footprint Start, AP-24         100,00%         0.02%         100,00%           9         SXCF436         SSGS Footprint Start, AP-24         0.0006%         0.02%         100,00%           9         SXCF436         SSGS Footprint Start, AP-34         0.02%         0.02%         100,00%           10         SSGS Footprint Start, AP-34<			TABLE 4 - Mean Percent of Tot	al for Pos	sitive Nucli	des											
SHEC Sample No         Location/Description         Co-40         C s-137         Am-241         Pu/239         Total           1         SX100/00024         Sediment/Sump 2/52, VH33, Well #1         99,89%         0.11%         100,00%           2         SX102/1002         SSG5 Footprint, Center Section, Core Ber # 2, Disk # 1         100,00%         100,00%           2         SX122/20         SSG5 Footprint, AP-2,8         100,00%         100,00%           3         SX12432         SSG5 Footprint, SSL4, AP-2,8         100,00%         100,00%           5         SX12432         SSG5 Footprint, SSL4, AP-2,8         100,00%         100,00%           5         SX12432         SSG5 Footprint, SSL4, AP-2,8         100,00%         100,00%           5         SX12432         SSG5 Footprint, SSL4, AP-2,4         100,00%         100,00%           5         SX12432         SSG5 Footprint, SSL4, AP-2,4         100,00%         100,00%           9         SX12728         SSG5 Footprint, SSL4, AP-2,4         0.001%         0.02%         100,00%           9         SX12728         SSG5 Footprint, SSL4, AP-2,4         0.001%         0.02%         100,00%           9         SX12728         SSG5 Footprint, SSL4, AP-2,4         0.001%         0.02%																	
1         SXI0000021         Sediment Phase - SSQ Fast Sumg 0; 27, AV83, Well #1         99.89%         0.1%         100.00%           2         SXI0000024         SSQ Footprint Collection Tank Area AV4.25 (Mumped)         100.00%         100.00%           2         SXI0000024         SSQ Footprint Sample F, Concrete Foot Core - SR.66         100.00%         100.00%           5         SXICF320         SSQ Footprint AP.2.7, Sect 1, Sile 4         100.00%         100.00%           6         SXICF320         SSQ Footprint AP.2.7, Sect 1, Sile 4         100.00%         100.00%           6         SXICF320         SSQ Footprint Safe 4, AP.2.6         100.00%         100.00%           7         SXICF320         SSQ Footprint Safe 4, AP.2.4         100.00%         100.00%           8         SXICF320         SSQ Footprint Safe 4, AP.2.4         100.00%         0.02%         100.00%           8         SXICF320         SSQ Footprint Safe 4, AP.2.4         100.00%         0.02%         100.00%           9         SXICF320         SSQ Footprint Safe 4, AP.2.4         0.23%         99.67%         0.02%         100.00%           1         Mean % of Total         Near % of Total         0.02%         100.00%         100.00%           1         SXICF0200 <td< td=""><td>SNEC Sar</td><td>mple No</td><td>Location/Description</td><td>Co-60</td><td>Cs-137</td><td>Am-241</td><td>Pu-239</td><td>Total</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></td<>	SNEC Sar	mple No	Location/Description	Co-60	Cs-137	Am-241	Pu-239	Total									
2         SSGS Footprint, Centre Section, Cent	1 SX10GV	W00321	Sediment Phase - SSGS East Sump @ 25', AV183, Well #1		99.89%	0.11%		100.00%									
3         3505 Footprint, Center: Section. Core Bore 4.2, Dark # 1         400,00%,         100,00%,           4         5307 S055 Footprint S354 + AP-26         100,00%,         100,00%,           5         3505 Footprint, AP-27, 6et 1; Site 4         100,00%,         100,00%,           6         3507 4225         S505 Footprint AP-27, 6et 1; Site 4         100,00%,         100,00%,           8         S505 Footprint S544, AP-24         100,00%,         100,00%,         100,00%,           8         S505 Footprint S544, AP-24         100,00%,         100,00%,         100,00%,           9         S505 Footprint S544, AP-24         100,00%,         0,02%,         100,00%,           9         S505 Footprint S544, AP-24         100,00%,         0,02%,         100,00%,           9         S505 Footprint S544, AP-24         100,00%,         0,02%,         100,00%,           10         S505 Footprint S544, AP-24         0,001         0,005,         0,02%,         100,00%,           10         S505 Footprint S544, AP-24         0,010         0,005,         0,02%,         100,00%,           10         S505 Footprint S544, AP-24         0,02%,         0,000,         0,02%,         100,00%,           10         S505 Footprint S544, AP-24         0,02%,	2 SX10SD	D00368	SSGS Footprint Collection Tank Area AW-132 (Pumped)		100.00%			100.00%									
4         SSC2 500         SSG5 Footprint SSL41, AP-26         100.00%           5         SSC2422         SSG5 Footprint AP-24, Sect 1, Sile 1         100.00%         100.00%           5         SSC2423         SSG5 Footprint AP-24, Sect 1, Sile 1         100.00%         100.00%           7         SSC2423         SSG5 Footprint SSL4, AP-24, Sect 1, Sile 1         100.00%         100.00%           8         SSC2423         SSG5 Footprint SSL4, AP-24, Sect 1, Sile 1         100.00%         100.00%           8         SSC2423         SSG5 Footprint SSL4, AP-24, Sect 1, Sile 1         0.23%, 99.70%, 0.02%, 100.00%         100.00%           8         SSC2423         SSG5 Footprint SSL4, AP-24, Sect 1, Sile 1         0.23%, 99.70%, 0.02%, 100.00%         100.00%           8         SSC2423         SSG5 Footprint SSL4, AP-24, Sect 1, Sile 1         0.23%, 99.70%, 0.02%, 100.00%         100.00%           8         SSC4423         SSG5 Footprint SSL4, AP-24, Sect 1, Sile 1         0.02%, 0.02%, 100.00%         1.00           SSC4423         SSG5 Footprint SSL4, AP-24, Sect 1, Sile 1         1.00E+00         1.02         1.00           SSSC5 Footprint SSL4, AP-24         1.00E+00         1.00         1.00         1.00           SSC4423         SSG5 Footprint SSL4, AP-24         1.00E+00         1.00	3 SXCF	F1210	SSGS Footprint, Center Section, Core Bore # 2. Disk # 1		100.00%			100.00%									
5         SVC7423         SSG5 Footprint S141, AP.24         100.00%         100.00%           5         SVC7423         SSG5 Footprint, AP.27, Sect 1, Sile 1         100.00%         100.00%           5         SVC7423         SSG5 Footprint, S142, Sect 1, Sile 1         100.00%         100.00%           5         SVC7423         SSG5 Footprint S141, AP.24         100.00%         100.00%           5         SVC7423         SSG5 Footprint S141, AP.24         0.02%         90.00%         100.00%           5         SVC7423         SSG5 Rootprint S141, AP.24         0.02%         90.00%         0.00%           5         SVC7423         SSG5 Rootprint S141, AP.24         0.02%         90.00%         0.00%           5         SVC7423         SSG5 Rootprint S141, AP.24         0.02%         90.00%         0.00%           6         SVC7423         SSG5 Rootprint S141, AP.24         0.02%         90.00%         0.02%           6         SVC7423         SSG5 Rootprint S141, AP.24         0.02%         0.02%         100.00%           5         SVC7423         SSG5 Rootprint S141, AP.24         1.00E+00         1.00         1.00           5         SVC7423         SSG5 Rootprint S141, AP.24         1.00E+00         1.00	4 SXCF3	3531	SSGS Footprint Sample # 5, Concrete Floor Core - SR-56		100.00%			100.00%									
6         SXCF4226         SSGS Footprint, AP-2-7, Sect 1, Silce 1         100.00%,         100.00%,           7         SXCF4330         SSGS Footprint SSH4, 2sect 1, Silce 1         100.00%,         100.00%,           9         SXCF4336         SSGS Footprint SSH4, 2sect 1, Silce 1         0.02%,         100.00%,           9         SXCF828         SSGS Footprint SSH4, 2sect 1, Silce 1         0.23%,         99.70%,         0.05%,         0.02%,           9         SXCF828         SSGS Footprint SSH4, 2sect 1, Silce 1         0.23%,         99.70%,         0.05%,         0.02%,         100.00%,           9         SXCF828         SSGS Footprint SSH4, 2sect 1, Silce 1         0.02%,         100.00%,         100.00%,           9         SXCF828         SSGS Footprint SSH4, Asec 2         0.001         0.001         0.005%,         0.02%,         100.00%,           9         SYCF828         SSGS Footprint SSH4, Asec 2         0.001         0.005%,         0.02%,         100.00%,           10         Location/Description         Co-80         Cs-137         Am-241         Pu-239         Total           10         SXVF120         SSGS Footprint SH4, Ase 3W/132 (Pumped)         1.00E+00         1.00           10         SSGF5ootprint SH4, Ase 3W/132 (Pumped) <td>5 SXCF</td> <td>4323</td> <td>SSGS Footbrint SS14-1, AP-2-6</td> <td></td> <td>100.00%</td> <td></td> <td></td> <td>100.00%</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>	5 SXCF	4323	SSGS Footbrint SS14-1, AP-2-6		100.00%			100.00%									
7         SXCF4330         SSGS Footprint SS14-2, Sect 1, Sile 1         100.00%         100.00%           8         SXCF4336         SSGS Footprint SS14-1, AP.2-4         0.02%         100.00%         100.00%           9         SXCF828         SSGS, East, Disk ≠ 1         Mean⇒         2.27E.03         1.00E+00         7.92E.04         2.33E.04         1.00           8         Sigma⇒         0.01         0.0005         0.0005         0.0005         0.000%           9         S7K         0.08%         0.02%         100.00%         0.0005           8         Mean % of Total⇒         0.23%         99.67%         0.008%         0.02%         100.00%           9         S7K0         0.008%         0.02%         100.00%         0.00%         0.02%         100.00%           9         S7K0         0.08%         0.02%         0.00%         0.02%         100.00%           0.001         0.0025         Storestart         0.02%         0.02%         100.00%           10         0.23%         99.67%         0.02%         100.00%         0.02%           11         Storestart         Storestart         1.00         1.00         1.00           12         Storestart<	6 SXCF	4325	SSGS Footprint, AP-2-7, Sect 1, Slice 1		100.00%			100.00%						1			
8         SXCF4336         SSGS Footprint SS14-1, AP-2-4         100.00%         100.00%           9         SXCF828         SSGS, East, Disk # 1         0.23%, 99.70%         0.02%, 100.00%         100.00%           0         Mean- Sigma= Nean %, of Total         1.00E+00         7.92E-04         2.33E-04         1.00           0.23%, 99.67%         0.001         0.0005         0.02%         100.00%           0.23%, 99.67%         0.08%         0.02%         100.00%           0.23%, 99.67%         0.08%         0.02%         100.00%           0.23%, 99.67%         0.08%         0.02%         100.00%           0.23%         99.67%         0.08%         0.02%         100.00%           0.23%         99.67%         0.08%         0.02%         100.00%           0.23%         99.67%         0.08%         0.02%         100.00%           0.23%         99.67%         0.08%         0.02%         100.00%	7 SXCF	F4330	SSGS Footprint SS14-2, Sect 1, Slice 1		100.00%			100.00%									
9         SXCF828         SSGS, East, Disk #1         0.23%         99.70%         0.05%         0.02%         100.00%           Sigma=>         0.001         0.0005         0.001         0.0005         0.001         0.0005           Mean % of Total=>         0.23%         99.70%         0.08%         0.02%         100.00%           Mean % of Total=>         0.23%         99.67%         0.08%         0.02%         100.00%           Mean % of Total=>         0.23%         99.67%         0.08%         0.02%         100.00%           SHEC Sample No         Location/Description         Co-60         Cs-137         Am-241         Pu-239         Total           1         SX10500324         Sediment Phase - SSGS East Sump @ 25, AV183, Well #1         1.00E+00         1.100           2         SX10500328         SSGS Footprint Collection Tank Area AW-532 (Pumped)         1.00E+00         1.000           3         SXCF1210         SSGS Footprint Sample #5, Concrete Floor Core - SR-56         1.00E+00         1.000           4         SXCF4325         SSGS Footprint Sample #5, Concrete Floor Core - SR-56         1.00E+00         1.000           5         SXCF4325         SSGS Footprint Sample #5, Concrete Floor Core - SR-56         1.00E+00         1.000 <td>8 SXCE</td> <td>4336</td> <td>SSGS Footprint SS14.1 AP.2.4</td> <td></td> <td>100.00%</td> <td></td> <td></td> <td>100.00%</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>	8 SXCE	4336	SSGS Footprint SS14.1 AP.2.4		100.00%			100.00%									
No.000         No.000         Nearch         2.27E-03         1.00E-00         7.92E-04         2.03E-04         1.00           Sigma⇒         0.001         0.0005         0.008%         0.02%         100.00%           Mean % of Total⇒         0.23%         99.67%         0.08%         0.02%         100.00%           TABLE 5 - Ratio to Cs-137 for Positive Nuclides           TABLE 5 - Ratio to Cs-137 for Positive Nuclides           SilEC Sample No         Location/Description           Sols East Sumg @ 25', AV183, Well #1         1.00E+00         1.010           SX106/00221         Sediment Phase - SSGS East Sumg @ 25', AV183, Well #1         1.00E+00         1.00           SX106/00221         Sediment Phase - SSGS East Sumg @ 25', AV183, Well #1         1.00E+00         1.00           SX105/0028         SSGS Footprint, Center Section, Core Bore #2, Disk #1         1.00E+00         1.00           SXCF323         SSGS Footprint Sample #5, Concrete Floor Core - SN-86         1.00E+00         1.00           SXCF423         SSGS Footprint Sample #5, Concrete Floor Core - SN-86         1.00E+00         1.00           SXCF423         SSGS Footprint Sample #5, Concrete Floor Core - S	9 SXCE	F828	SSGS Fast Disk #1	0.23%	99.70%	0.05%	0.02%	100.00%									
Image in the image in			Manant Manant	2 275 02	1.005+00	7.925.04	2 225 04	1.00									
Signal         0.001         0.0003         0.02%         100.00%           Mean % of Total         0.23%         99.67%         0.02%         100.00%           TABLE 5 - Ratio to Cs-137 for Positive Nuclides           TABLE 5 - Ratio to Cs-137 for Positive Nuclides           Silfe: Sample IIO         Location/Description         Co-60         Cs-137         Am-241         Pu-238         Total           1         SX105000321         Sediment Phase - SSGS East sump @ 25', AV183, Well #1         1.00E+00         1.00           2         SX105000388         SSGS Footprint, Center Section, Core Bore #2, Disk #1         1.00E+00         1.00           3         SXCF1210         SSGS Footprint Sample #5, Concrete Floor Core - SR-58         1.00E+00         1.00           4         SXCF323         SSGS Footprint, AP-27, Sect 1, Slice 1         1.00E+00         1.00           6         SXCF4326         SSGS Footprint SN+4, AP-2.4         1.00E+00         1.00           7         SXCF828         SSGS, East, Disk #1         2.27E-03         1.00E+00         1.00           8         SXCF4325         SSGS, East, Disk #1         2.27E-03         1.00E+00         1.00           8         SXCF4			Mean-J	2.212-03	0.001	0.0005	2.332-04	1.00									
TABLE 5 - Ratio to Cs-137 for Positive Nuclides           TABLE 5 - Ratio to Cs-137 for Positive Nuclides           SINEC Sample No         Location/Description         Co-60         Cs-137         Am-241         Pu-239         Total           1         SX10500388         SSGS Footprint Collection Tank Area AVI-32 (Pumped)         1.00E+00         1.100           2         SX10500388         SSGS Footprint Collection Tank Area AVI-32 (Pumped)         1.00E+00         1.00           3         SXCF1210         SSGS Footprint Collection Tank Area AVI-32 (Pumped)         1.00E+00         1.00           4         SXCF321         SSGS Footprint Sample # 5, Concrete Floor Core - SR-66         1.00E+00         1.00           5         SXCF4223         SSGS Footprint Sit4-1, AP-2-6         1.00E+00         1.00           6         SXCF4235         SSGS Footprint Sit4-1, AP-2-4         1.00E+00         1.00           8         SXCF4236         SSGS Footprint Sit4-1, AP-2-4         1.00E+00         1.00           8         SXCF4236         SSGS Footprint Sit4-1, AP-2-4         1.00E+00         1.00           8         SXCF4236         SSGS Footprint Sit4-1, AP-2-4         1.00E+00         1.00           8			Sigma⊸ Mean % of Total⇒	0.23%	99.67%	0.08%	0.02%	100.00%									
TABLE 5 - Ratio to Cs-137 for Positive Nuclides           SNEC Sample No         Location/Description         Co-80         Cs-137         Am-241         Pu-239         Total           1         SX105000380         SSGS Footprint Collection Tank Area XW-132 (Pumped)         1.00E+00         1.100           2         SX105000380         SSGS Footprint Collection, Core Bore 24, Disk # 1         1.00E+00         1.000           3         SXCF1210         SSGS Footprint, Center Section, Core Bore 24, Disk # 1         1.00E+00         1.000           4         SXCF323         SSGS Footprint Sath41, AP-2-6         1.00E+00         1.000           5         SXCF4326         SSGS Footprint, AP-2-7, Sect 1, Slice 1         1.00E+00         1.000           5         SSGS Footprint, AP-2-7, Sect 1, Slice 1         1.00E+00         1.000           5         SXCF4326         SSGS Footprint, AP-2-4, Sect 1, Slice 1         1.00E+00         1.000           5         SXCF4336         SSGS Footprint, AP-2-4, Sect 1, Slice 1         1.00E+00         1.000         1.000           6         SXCF4336         SSGS Footprint, AP-2-2, Sect 1, Slice 1         1.00E+00         1.000         1.000           5         SSGS Footprint Sst4-4, Sect 1, Slice 1         1.00E+00         4.05E-04         2.34E-04 </td <td></td> <td></td> <td></td> <td>U.C.U.</td> <td>0010110</td> <td>0.00 //</td> <td>0.02.1</td> <td>100.00 %</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>				U.C.U.	0010110	0.00 //	0.02.1	100.00 %									
SNEC Sample No         Location/Description         Co-80         Cs-137         Am-241         Pu-239         Total           1         SX106W00321         Sediment Phase - SGS East Sump @ 25', AV183, Well #1         1.00E+00         1.12E-03         1.00           2         SX105W00328         SSGS Footprint, Collection Tank Area AW-132 (Pumped)         1.00E+00         1.00           3         SXCF1210         SSGS Footprint, Center section, Core Bore #2, Disk #1         1.00E+00         1.00           4         SXCF331         SSGS Footprint Sample # 5, Concrete Floor Core - SR-56         1.00E+00         1.00           5         SXCF4323         SSGS Footprint Sat4-1, AP-2-6         1.00E+00         1.00           6         SXCF4325         SSGS Footprint, S14-1, AP-2-6         1.00E+00         1.00           7         SXCF4330         SSGS Footprint, S14-2, Sect 1, Slice 1         1.00E+00         1.00           8         SSGS Footprint S14-2, Sect 1, Slice 1         1.00E+00         1.00           8         SSGS Footprint S14-4, AP-2-4         1.00E+00         1.00           9         SXCF4336         SSGS Footprint S14-4, AP-2-4         1.00E+00         1.00           8         SSCF828         SSGS, East, Disk #1         2.27E-03         1.00E+00         2.3			TABLE 5 - Ratio to Cs-137 fr	or Positiv	e Nuclides												
SIEC Sample IIo         Location/Description         Co-80         Cs-137         Am-241         Pu-239         Total           1         SX105W00321         Sediment Phase - SSGS East Sump @ 25', AV183, Well #1         1.00E+00         1.12E-03         1.00           2         SX105W00326         SSGS Footprint, Collection Tank Area AW-132 (Pumped)         1.00E+00         1.00           3         SXCF1210         SSGS Footprint, Center Section, Core Bore #2, Disk #1         1.00E+00         1.00           4         SXCF323         SSGS Footprint Sample # 5, Concrete Floor Core - SR-68         1.00E+00         1.00           5         SXCF4323         SSGS Footprint Sat4.1, AP-2-6         1.00E+00         1.00           6         SXCF4326         SSGS Footprint, AP-2-7, Sect 1, Sice 1         1.00E+00         1.00           8         SXCF4330         SSGS Footprint Sat4.2, Sect 1, Sice 1         1.00E+00         1.00           8         SXCF4336         SSGS Footprint Sat4.4, AP-2-4         1.00E+00         1.00           8         SXCF828         SSGS Footprint Sat4.4, AP-2-4         1.00E+00         1.00           9         SXCF828         SSGS, East, Disk #1         2.27E-03         1.00E+00         4.65E-04         2.34E-04         1.00           8								1									
SX10GW00321         Sediment Phase - SSGS East Sump @ 25', AV183, Weil #1         1.00E+00         1.12E-03         1.00           SX10500038         SSGS Footprint Collection Tank Area AW-132 (Pumped)         1.00E+00         1.00           SXC1710         SSGS Footprint Collection Tank Area AW-132 (Pumped)         1.00E+00         1.00           SXC17301         SSGS Footprint Sample # 5, Concrete Floor Core - SR-68         1.00E+00         1.00           SXC17323         SSGS Footprint SS14-1, AP-2-8         1.00E+00         1.00           SXC17326         SSGS Footprint, AP-2-7, Sect 1, Slice 1         1.00E+00         1.00           SXC17330         SGGS Footprint SS14-1, AP-2-4         1.00E+00         1.00           SXC17336         SSGS Footprint SS14-1, AP-2-4         1.00E+00         1.00           SXC17336         SSGS Footprint SS14-1, AP-2-4         1.00E+00         1.00           SXC17336         SSGS Footprint SS14-1, AP-2-4         1.00E+00         1.00           SXC17828         SSGS Footprint SS14-1, AP-2-4         2.27E-03         1.00E           SXC17828         SSGS Footprint SS14-1, AP-2-4         2.27E-03         1.00E           SXC17828         SSGS Footprint SS14-1, AP-2-4         2.27E-03         1.00E           Mean % of Total=         0.023%         0.02% <td>SNEC San</td> <td>mple No</td> <td>Location/Description</td> <td>Co-60</td> <td>Cs-137</td> <td>Am-241</td> <td>Pu-239</td> <td>Total</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>	SNEC San	mple No	Location/Description	Co-60	Cs-137	Am-241	Pu-239	Total									
2         SX105D00388         SSGS Footprint Collection Tank Area AW-132 (Pumped)         1.00E+00         1.00           3         SXCF1210         SSGS Footprint, Center Section, Core Bore # 2, Disk # 1         1.00E+00         1.00           4         SXCF331         SSGS Footprint Sample # 5, Concrete Floor Core - SR-68         1.00E+00         1.00           5         SXCF4323         SSGS Footprint S14-1, AP-2-8         1.00E+00         1.00           6         SXCF4325         SSGS Footprint S14-1, AP-2-7, Sec1 1, Slice 1         1.00E+00         1.00           7         SXCF4330         SSGS Footprint S14-2, Sec1 1, Slice 1         1.00E+00         1.00           8         SXCF4336         SSGS Footprint S14-4, AP-2-4         1.00E+00         1.00           8         SXCF4336         SSGS Footprint S14-1, AP-2-4         1.00E+00         1.00           8         SXCF4336         SSGS Footprint S14-1, AP-2-4         1.00E+00         1.00           8         SXCF4336         SSGS S, East, Disk # 1         2.27E-03         1.00E+00         1.00           9         SXCF828         SSGS, East, Disk # 1         2.27E-03         1.00E+00         7.93E-04         1.00           8         Mean % of Total⇒         0.23%         99.67%         0.08%	SX10GW	W00321	Sediment Phase - SSGS East Sump @ 25', AV183, Well #1		1.00E+00	1.12E-03		1.00									
3         SXCF1210         SSGS Footprint, Center Section, Core Bore # 2, Disk # 1         1.00E+00         1.00           4         SXCF331         SSGS Footprint Sample # 5, Concrete Floor Core - SR-66         1.00E+00         1.00           5         SXCF4323         SSGS Footprint SS14-1, AP-2-8         1.00E+00         1.00           6         SXCF4326         SSGS Footprint SS14-1, Slice 1         1.00E+00         1.00           7         SXCF4330         SSGS Footprint SS14-2, Sect 1, Slice 1         1.00E+00         1.00           8         SXCF4336         SSGS Footprint SS14-1, AP-2-4         1.00E+00         1.00           8         SXCF4336         SSGS Footprint SS14-1, AP-2-4         1.00E+00         1.00           9         SXCF828         SSGS Footprint SS14-1, AP-2-4         1.00E+00         1.00           9         SXCF828         SSGS, East, Disk # 1         2.27E-03         1.00E+00         4.23E-04         1.00           9         Sigma=         0.0000         0.0005         0.000%         100.00%         100.00%	SX10SD	D00368	SSGS Footprint Collection Tank Area AW-132 (Pumped)		1.00E+00			1.00			1						
I         SXCF3S1         SSGS Footprint Sample # 5, Concrete Floor Core - SR-66         1.00E+00         1.00           5         SXCF4323         SSGS Footprint SX14.1, AP-2-6         1.00E+00         1.00           5         SXCF4326         SSGS Footprint SX14.1, AP-2-7, Sect 1, Slice 1         1.00E+00         1.00           5         SXCF4330         SSGS Footprint SX14.1, AP-2-7, Sect 1, Slice 1         1.00E+00         1.00           5         SXCF4330         SSGS Footprint SX14.1, AP-2.4         1.00E+00         1.00           1         SXCF4336         SSGS Footprint SX14.1, AP-2.4         1.00E+00         1.00           1         SXCF828         SSGS, East, Disk # 1         2.27E-03         1.00E+00         4.65E-04         2.34E-04         1.00           SIgma=         0.0000         0.0005         Image: 0.000%         0.02%         100.00%	SXCF	1210	SSGS Footprint, Center Section, Core Bore # 2. Disk # 1		1.00E+00			1.00									
SXCF4323         SSGS Footprint SS14-1, AP-2-6         1.00E+00         1.00           SXCF4325         SSGS Footprint, AP-2-7, Sect 1, Slice 1         1.00E+00         1.00           SXCF4330         SSGS Footprint SS14-2, Sect 1, Slice 1         1.00E+00         1.00           SXCF4336         SSGS Footprint SS14-1, AP-2-4         1.00E+00         1.00           SXCF4336         SSGS Footprint SS14-1, AP-2-4         1.00E+00         1.00           SXCF828         SSGS, East, Disk # 1         2.27E-03         1.00E+00         1.00           SSCF828         SSGS, East, Disk # 1         2.27E-03         1.00E+00         1.00           Sigmath         Meanth of Totalth         7.93E-04         2.34E-04         1.00           Meanth of Totalth         0.23%         99.67%         0.08%         0.02%         100.00%	SXCF3	3531	SSGS Footprint Sample # 5, Concrete Floor Core - SR-56		1.00E+00			1.00									
SXCF4326         SSGS Footprint, AP-2-7, Sect 1, Slice 1         1.00E+00         1.00           SXCF4330         SSGS Footprint SS14-2, Sect 1, Slice 1         1.00E+00         1.00           SXCF4336         SSGS Footprint SS14-1, AP-2-4         1.00E+00         1.00           SXCF828         SSGS, East, Disk # 1         2.27E-03         1.00E+00         1.00           SXCF828         SSGS, East, Disk # 1         2.27E-03         1.00E+00         7.93E-04         1.00           Sigma⇒         0.0000         0.0005         0.23%         99.67%         0.08%         0.02%         100.00%	SXCF4	4323	SSGS Footprint SS14-1, AP-2-8		1.00E+00			1.00									
SXCF4330         SSGS Footprint SS14-2, Sect 1, Slice 1         1.00E+00         1.00           8         SXCF4336         SSGS Footprint SS14-1, AP-2-4         1.00E+00         1.00           9         SXCF828         SSGS, East, Disk # 1         2.27E-03         1.00E+00         1.00           0         SXCF828         SSGS, East, Disk # 1         2.27E-03         1.00E+00         4.95E-04         2.34E-04         1.00           0         SXCF828         SSGS, East, Disk # 1         2.27E-03         1.00E+00         7.93E-04         1.00           0         Sigma⇒         0.0000         0.0005         0.000%         0.02%         100.00%	SXCF4	4325	SSGS Footprint, AP-2-7, Sect 1, Slice 1		1.00E+00			1.00									
SXCF4336         SSGS Footprint SS14.1, AP-2.4         1.00E+00         1.00           9         SXCF828         SSGS, East, Disk #1         2.27E-03         1.00E+00         4.65E-04         2.34E-04         1.00           9         SXCF828         SSGS, East, Disk #1         2.27E-03         1.00E+00         7.93E-04         2.34E-04         1.00           9         Sigma⇒         0.0000         0.0005	7 SXCEA	4330	SSGS Epotprint SS14-2 Sect 1 Slice 1		1.00E+00			1.00									
SXCF828         SSGS, East, Disk ≠ 1         2.27E-03         1.00E+00         4.65E-04         2.34E-04         1.00           SXCF828         SSGS, East, Disk ≠ 1         2.27E-03         1.00E+00         7.93E-04         2.34E-04         1.00           Sigma⇒         0.0000         0.0005	8 SYCE	4336	SSGS Footprint SS14.1 AP.2.4		1.00E+00			1.00									
Mean⇒         2.27E-03         1.00E+00         2.34E-04         1.00           Sigma⇒         0.0000         0.0005         0.00%         100.00%	SYCE	F828	SGC Fast Diek #1	2 27E.03	1.00E+00	4 65E-04	2 34E-04	1.00									
Intern⇒     2.2/E-03     1.00E+00     7.3/E-04     2.34E-04     1.00       Sigma⇒     0.0000     0.0005	JACF		5303, L031, DIAR # 1	2 275 02	1.000+00	7.025.04	2.34E.04	1.00									
sigma⇒ 0.0000 0.0005 Mean % of Total⇒ 0.23% 99.67% 0.08% 0.02% 100.00%			iliean⇒	2.21E-03	0.0000	1.93E-04	2.345-04	1.00									
intean % of iotal⊃ 0.23% 99.67% 0.02% 100.00%			sigma⇒	0.000	0.0000	0.0005	0.020	400.00%									
				0.23%	99.01%	0.00%	0.02%	100.00%									

4

# Table 6

۰.

.

	Effective DC	GL Calculator	for Cs-13	7 (dpm/100 c	:m^2)	Gross Act	HY DEGLWS	Gross Activity A	aministrative Limit
						13615	dpm/100 cm^2	10211	dpm/100 cm^2
	25.0	mrem/y TEDE Limi	t						
						朝秋秋秋 Ca:131	2Umid 推动结构	ATT CATST Admit	Netrative Umit 112
	SAMPLE NO(s)⇒	SSGS AREA				13571	dpm/100 cm^2	10178	dpm/100 cm^2
									l
						<b>SNEC ALS</b>	75%		
		• • • • • • • • • • • • • • • • • • •		· · · · · · · · · · · · · · · · · · ·	·····				···· · · ·
				Individual					
		Sample Input	•	Limits	Allowed		Beta dom/100	Alpha dpm/100	
	Isotope	(pCi/g, uCi, etc.)	% of Total	(dpm/100 cm^2)	dpm/100 cm^2	mrem/y TEDE	cm^2	cm^2	
1	Am-241	7.92E-04	0.079%	27	10.75	9.95	11/A	10.75	Am-241
2	C-14		0.000%	3,700,000	0.00	0.00	0.00	B/A	C-14
3	Co-60	2.27E-03	0.226%	7,100	30.81	0.11	30.81	ll'A	Co.60
4	Cs:137.14433433	410.1.00E+001838	C 99.672%	22123228,000	1#13570:59.5	利12:12:55	13:13570.6154	H/A	<b>Cs-137</b> 約約3時間在
5	Eu-152		0.000%	13,000	0.00	0.00	0 0 0	ll/A	Eu-152
6	н.з		. 0.000%	120,000,000	0.00	0.00	Not Detectable	lia.	H-3
7	NI-63		0.000%	1,800,000	0.00	0.00	liot Detectable	lia	NI-63
8	Pu-238		0.000%	30	0.00	0.00	ll/A	0.00	Pu-238
9	Pu-239	2.33E-04	0.023%	28_	3.16	2.82	li'A	3.16	Pu-239
10	Pu-241		0.000%		0.00	0.00	<b>Not Detectable</b>	11 A	Pu-241
11	Sr-90		0.000%	8,700	0.00	0.00	0.00	18/A	Sr-90
	1		100.000%		13615	25.0	13601	14	
					Maximum Permissible dpm/100 cm*2				

:

Ta	ble	<b>?</b> 7
----	-----	------------

••

	1										1
					LASSASHEC ALL AREA	75%	Total Activity Limit D	CGLW	2 HAOminis	Hinto Linita La	
Effective [	Effective DCGL Calculator for Cs-137 (in pCi/g)						6.58	pCi/g	4.94	pCi/g	
SAMPL	E NUMBER(s)⇒	SSGS AREA						• • •		<u> </u>	
							PROFESSION LIGHT SHE ACONSTANTING CONT				
15.24%	25.0	mrem/y TEDE I	Limit				6.56	pCi/g	4.92	pCl/g	
0.35%	21	mrem/y Drinki	ng Water (DW) Lir	nit	I Check for 25 mrem/y						
	Sample Input		•								
11	(pCi/g, uCi, 🕯		25 mrem/y TEDE	Cimremo Dive	A - Allowed pCilg for	B Allowed pclig	Value Checked from		This Sample	This Sample A	
Isotope	of Total, etc.)	% of Total	Limits (pCi/g)	ALIMITE (DCHol)	25 mrem/y TEDE	lor Amremly Divi	Column A or B		mrem/y TEDE	Semiremly DVV	
1 Am-241	0.001	0 079%	9.9	A.M.2.3.444	0.01	(1) 0.22 (1)	0 01		0 00	a.0.00 - 20	Am-241
2 C-14		0 000%	2.0	545	0.00	0.001	0 00		0 00	0.00	C-14
3 Co-60	0.0023	0 226%	3.5	G/0	0 01	0.66	0 01		0 02	0.00	Co-60
4 Cs-137	1.0000	99 671%	6.6	976 S-1	6.56	283,29,552	32478 6.56 P OK		3.79	57430.012.05	Cs-137
6 Eu-152		0 000%	10.1	1440	0.00	0.00	0.00		0 00	0.00	Eu.152
6 H-3		0 000%	132	Se SIMP	0.00	Sec. 0.00 - 1.1	0 00		0 00	0.001	H.3
7 Ni-63		0 000%	747	stat19000	0.00	server 0.00 - 4.	0 00		0 00	0.00	NI-63
8 Pu-238		0 000%	1.8	0,11	0.00	- 100 0 0 M	0.00		0 00	0.00	Pu-238
9 Pu-239	0.0002	0 023%	1.6	037	0 00	2007 (0) (0) (0) (0) (0) (0) (0) (0) (0) (0)	0.00		0 00	Sec.0.00-245	Pu-239
10 Pu-241		0 000%	86	- 1985 - Al	0 00	96.20.00	0 00		0 00	2250.00	Pu-241
11 Sr-90		0.000%	1.2	0.61	0 00	Sec.00 \$555	0 00		0 00	54%0,00,00	Sr-90
	1.00E+00	100.000%			6.58	284.22	6.58		3.810	0.014	
				Havimum Permissible	Havimum			To ilse Th			
	:				pCl/g	Permissible pCi/a			Sample input	Units Must Be In	
	l i				(25 mrem/y)	(4 mrem/y)			pCl/g no	t % of Total.	

•