

5.6 Procedures, Programs and Manuals

5.6.2.7 Not Used

5.6.2.8 Inservice Inspection Program

This program provides controls for inservice inspection of ASME Code Class 1, 2, 3, MC and CC components, including applicable supports. The program shall include the following:

- a. Provisions that inservice inspection of ASME Code Class 1, 2, 3, MC and CC components shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50.55a;
- b. The provisions of SR 3.0.2 are applicable to the frequencies for performing inservice inspection activities;
- c. Inservice inspection of each reactor coolant pump flywheel shall be performed at least once every twenty years. The inservice inspection shall be either an ultrasonic examination of the volume from the inner bore of the flywheel to the circle of one-half the outer radius or a surface examination for exposed surfaces of the disassembled flywheels. The recommendations delineated in Regulatory Guide 1.14, Positions 3, 4, and 5 of Section C.4.b shall apply.
- d. Nothing in the ASME Boiler and Pressure Vessel Code shall be construed to supersede the requirements of any TS.

(continued)