

Entergy Nuclear Northeast Entergy Nuclear Operations, Inc. Vermont Yankee P.O. Box 0500 185 Old Ferry Road Brattleboro, VT 05302-0500 Tel 802 257 5271

> August 1, 2005 BVY 05-071

ATTN: Document Control Desk U.S. Nuclear Regulatory Commission Washington, DC 20555

Subject: Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) <u>Clarifications to Relief Request RI-01 Table</u>

By letter dated October 1, 2003¹, as supplemented by letters dated December 23, 2003², January 22, 2004³ and June 8, 2005⁴, Vermont Yankee Nuclear Power Station (VY) submitted Relief Request RI-01. Relief Request RI-01 proposed to use various Boiling Water Reactor Vessel Internals Program guidelines as an alternative to certain requirements of Section XI of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code for Inservice Inspection of Reactor Pressure Vessel internal components.

Following discussion with your staff, VY is submitting a revised comparison table to correct a typographical error for one item and provide clarification to another. Accordingly, this letter and the attachment, provides a replacement table with the changes noted by revision bars

There are no regulatory commitments contained within this letter.

Please feel free to contact me at (802) 258-4236, if there are any questions regarding this submittal.

Sincerely, L'ulya

James M. DeVincentis Manager, Licensing Vermont Yankee Nuclear Power Station

Attachment (1)

cc: USNRC Region 1 Administrator USNRC Resident Inspector - VY USNRC Project Manager - VY Vermont Department of Public Service

ADUN

¹ Reference VY Letter to USNRC, BVY 03-89, "Supplement 2 to Fourth-Interval Inservice Inspection (ISI) Program Plan – Submittal of Relief Request RI-01," dated October 1, 2003.

 ² Reference VY Letter to USNRC, BVY 03-120, "Supplement to Relief Request RI-01," dated December 23, 2003.

³ Reference VY Letter to USNRC, BVY 04-07, "Supplement to Relief Request RI-01," dated January 22, 2004.

⁴ Reference VY Letter to USNRC, BVY 05-059, "Revised Response to Request for Additional Information Regarding Relief Request RI-01," dated June 8, 2005.

ATTACHMENT TO BVY 05-071

Revised Comparison Table Regarding Relief Request RI-01

.

ENTERGY NUCLEAR OPERATIONS, INC. VERMONT YANKEE NUCLEAR POWER STATION DOCKET NO. 50-271

Comparison of ASME Category B-N-1 and B-N-2 Requirements With BWRVIP Guidance Requirements (Note 1)

.

With BWR VIF Guidance Requirements (Note 1)								
ASME Item	Component	ASME Exam	ASME	ASME	Applicable	BWRVIP	BWRVIP	BWRVIP Frequency
No. Table		Scope	Exam	Frequency	BWRVIP	Exam	Exam	
IWB-2500-1					_ Document	Scope		
B13.10	Reactor Vessel Interior	Accessible	VT-3	Each period	BWRVIP-18,	Per VY Program Procedure PP 7027		
		Areas		-	25, 26, 38, 41.	See Attached Table 1		
		(Non-specific)			47, 48, 76			
B13.20	Interior Attachments Within	Accessible	VT-1	Each 10-	BWRVIP-48	Riser Brace	EVT-1	100% in first 12
2.0.20	Reltline – Riser Braces	Welds		vear	Table 3-2	Attachment	2.1.	vears 25% during
	Denime – Riser Draces	W CIUS		Interval	14010 5-2	Machinem		each subsequent 6
				mervar				voors
		-			DWDVID 49	Decelet		Fach 10 wars Internal
	Lower Surveinance Specimen				BWKVIP-48	Bracket	V I - I	Each 10-year Interval
	Holder Brackets				Table 3-2	Attachment		
B13.30	Interior Attachments Beyond	Accessible	VT-3	Each 10-	BWRVIP-48	Bracket	VT-3	Each 10-year Interval
	Beltline – Steam Dryer Hold-	Welds		year	Table 3-2	Attachment		
	down Brackets			Interval				
	Guide Rod Brackets				BWRVIP-48	Bracket	VT-3	Each 10-year Interval
					Table 3-2	Attachment		_
	Steam Dryer Support Brackets	1)	BWRVIP-48	Bracket	EVT-1	Each 10-year Interval
					Table 3-2	Attachment		·
	Feedwater Sparger Brackets				BWRVIP-48	Bracket	EVT-1	Each 10-year Interval
	ree and openger Drueners				Table 3-2	Attachment	2.11	
	Core Spray Pining Brackets	-			BWRVIP-48	Bracket	EVT-1	Every 4 Refueling
	Core offrag I fining Brackets				Table 3-2	Attachment	D.1-1	Cycles
	Upper and Middle Surveillance	-			DWDVID 49	Brocket	VT 2	Each 10 year Interval
	Specimen Holder Deselvate				Table 2.2	Attachmant	v 1-5	Each 10-year Interval
	Specifien Holder Brackets	-			1 able 5-2	Attachment		
	Shroud Support (weld H9)				BWRVIP-38	weld H9	EVI-I or	Maximum of 6 years
					3.1.3.2,		UT	for EVI-1, Maximum
		4			Figure 3-5			of 10 years for UT
	Shroud Support Legs (H12	(Rarely		1	BWRVIP-38	Not	Not	Not Required
	Welds)	Accessible)			3.2.3	Required	Required	(Note 2)
						(Note 2)	(Note 2)	
B13.40	Integrally Welded Core Support	Accessible	VT-3	Each 10-	BWRVIP-38	Welds H8,	EVT-1 or	Maximum 6 years for
	Structure – Shroud Support	Surfaces		year	3.1.3.2.	H9	UT	EVT-1, 10 years for
				Interval	Figure 3-5			UT
	Shroud				BWRVIP-76	Welds H1.	EVT-1 or	Maximum 10 years
				1	221	H2		
					BWRVIP-76	Vertical	EVT-1 or	Maximum 6 years for
					Eiguro 2 2	Ding Seg		one sided EVT 1 10
					rigule 5-5	Walda	01	
1		1				Delew U2		years for 01
					DIVIDUND	Below H2	1 100 0	
					BWRVIP-76	Tie-rod	VT-3	All four within 10
					3.5	Repair		years

NOTE 1: This Table provides only an overview of the requirements. For more details, refer to ASME Section XI, Table IWB-2500-1, and the appropriate BWRVIP document.

NOTE 2: Periodically VY will have access to the lower plenum welds due to maintenance activities not related to the inspection recommendations in the BWRVIP guidelines. In such cases, VY will perform a visual inspection of the shroud support leg welds to the extent practical. When inspection tooling and methodologies are developed that allows access to the lower plenum without disassembly beyond normal refueling activities, shroud support leg welds will be inspected with an appropriate NDE method. Results of inspections will be used to determine a re-inspection schedule. VY will adopt future inspection methods and schedules as they are developed and included into BWRVIP-38 and approved by the NRC staff.

.