



- NOTES:**
1. MOTOR OPER. FOR VLV. V-1-107 HAS BEEN REMOVED & VLV. IS GAGGED CLOSED.
 2. THIS DRAWING IS BASED ON BR-2002 SHEET 1 REVISION 59.
 3. ALL VALVES ARE PREFIXED BY V-1 UNLESS OTHERWISE NOTED.
 4. THIS DRAWING INCLUDES THE FOLLOWING LICENSE RENEWAL SYSTEMS:
 - MS - MAIN STEAM SYSTEM
 - IA - INSTRUMENT (CONTROL) AIR SYSTEM
 - DFED - DRYWELL FLOOR AND EQUIPMENT DRAINS
 - RHC - REACTOR HEAD COOLING SYSTEM
 5. MS-VE-XX ARE ACOUSTIC MONITOR SENSORS STRAPPED ONTO THE OUTER SURFACE OF THE PIPE. THESE SENSORS DO NOT PERFORM A PRESSURE BOUNDARY FUNCTION AND ARE THEREFORE NOT SUBJECT TO AGING MANAGEMENT REVIEW.

TABLE OF ADDITIONS & CHANGES				
NO	DATE	DESCRIPTION	REV'D	APP'D
0	7/03	INITIAL ISSUE FOR LICENSE RENEWAL	Z	X
			L	X
			M	X

MECHANICAL	
LICENSE RENEWAL DRAWING	
MAIN STEAM SYSTEM	
FLOW DIAGRAM	
OYSTER CREEK	
AmerGen	
SHEET 1 OF 4	LR-BR-2002 0

206