



- NOTES:**
1. ALL VALVES ON THIS SHEET ARE PREFIXED V-3 UNLESS OTHERWISE NOTED.
 2. THIS DRAWING IS BASED ON BR-2005 SHEET 2 REVISION 00.
 3. THIS DRAWING INCLUDES THE FOLLOWING LICENSE RENEWAL SYSTEMS:
 ESW- EMERGENCY SERVICE WATER SYSTEM
 SW- SERVICE WATER
 RDOO- ROOF DRAIN & OVERBOARD DISCHARGE
 4. SEAL WELL IS INCLUDED IN THE MISCELLANEOUS YARD STRUCTURES LICENSE RENEWAL STRUCTURE.
 5. THE TBOW HEAT EXCHANGER TUBE SIDE COMPONENTS ARE EVALUATED WITH THE SERVICE WATER SYSTEM. THE TBOW HEAT EXCHANGER SHELL SIDE COMPONENTS ARE EVALUATED WITH THE TBOW SYSTEM.
 6. RBOW HEAT EXCHANGER TUBE SIDE COMPONENTS, SHELL SIDE COMPONENTS, AND TUBES ARE EVALUATED WITH THE SERVICE WATER SYSTEM.
 7. THE 4" CPVC PIPE IS NOT REQUIRED TO SUPPORT VALVE V-3-978 OR THE BURIED 20" SERVICE WATER HEADER.
 8. THIS PORTION OF THE ESW AND OVERBOARD DISCHARGE PIPING IS BURIED, THEREFORE THE ATTACHED NON-SAFETY RELATED PIPING DOES NOT NEED TO BE INCLUDED IN SCOPE FOR STRUCTURAL SUPPORT.

TABLE OF ADDITIONS & CHANGES				MECHANICAL	
NO	DATE	DESCRIPTION	REV'D	CHK'D	APP'D
7	02/05	INITIAL ISSUE FOR LICENSE RENEWAL	J	M	K
0			N	A	P
0			Z	M	M

LICENSE RENEWAL DRAWING
 REACTOR & TURBINE BUILDING
 SERVICE WATER SYSTEM
 FLOW DIAGRAM
 OYSTER CREEK
 AmerGen

SHEET 2 OF 6 | LR-BR-2005 | 0

1013