



- NOTES:
1. ALL VALVES ON THIS SHEET ARE PREFIXED BY V-28 UNLESS OTHERWISE NOTED.
 2. VALVE FAILS CLOSED ON LOSS OF ELECTRICAL POWER.
 3. THIS DRAWING IS BASED ON OJ-3E-822-1000 REVISION 11.
 4. THIS DRAWING INCLUDES THE FOLLOWING LICENSE RENEWAL SYSTEMS:
SGTS - STANDBY GAS TREATMENT SYSTEM
IA - INSTRUMENT CONTROL AIR
 5. FILTER ELEMENTS ARE PERIODICALLY REPLACED AND ARE THEREFORE SHORT-LIVED AND NOT SUBJECT TO AGING MANAGEMENT REVIEW.

TABLE OF ADDITIONS & CHANGES				
NO	DATE	DESCRIPTION	REV'D	APP'D
0	7/05	INITIAL ISSUE FOR LICENSE RENEWAL	Z	M

MECHANICAL	
LICENSE RENEWAL DRAWING	
STANDBY GAS TREATMENT	
FLOW DIAGRAM	
DYSTER CREEK	
Amey-Sier	
SHEET 1 OF 1	LR-GU-3E-822-21-1000 0

D66