

From: Peter Tam /RA/
To: David Distel; David Helker
Date: 8/10/05 8:52AM
Subject: Oyster Creek -- Draft RAI re. Response to Generic Letter (GL) 2003-01 (TAC MB9832)

Dave:

This is follow-up of the telephone conference we held on 8/1/05. At the end of the conference we agreed to summarize the NRC staff comments in the form of a draft RAI. The following two paragraphs convey the draft RAI:

We have reviewed your response to GL 2003-01. Your responses to the GL do not confirm your assumptions for the inleakage characteristics of the control room envelope (CRE). In accordance with Requested Information items 1a and 1b of the GL, please describe the test and measurements you have performed which have demonstrated the inleakage characteristics of your CRE including its walls, floors and ceilings for radiological and hazardous chemical events are consistent with your licensing basis. Also, please describe how you have determined that the byproducts of a fire or the inadvertent actuation of a fire suppression system will not propagate such that reactor control would be unattainable from either the control room and the alternate shutdown panels.

We have reviewed your response to item 1(c) and find that, in addition to a Section 6 Program, for control room integrity, an additional technical specification to measure control room ventilation system makeup and recirculation flowrates is necessary to confirm your facility's licensing basis.

We plan to issue the above comments in a formal RAI. Please feel free to contact me to discuss.

Peter S. Tam, Senior Project Manager
Project Directorate I-1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

e-mail: pst@nrc.gov Tel.: 301-415-1451

CC: Andrzej Drozd; Harold Walker; John Hayes; Margie Kotzalas; Robert Dennig

Mail Envelope Properties

(42F9F875.862 : 12 : 334)

Subject: Oyster Creek -- Draft RAI re. Response to Generic Letter (GL) 2003-01 (TAC MB9832)
Creation Date: 8/10/05 8:52AM
From: Peter Tam
Created By: PST@nrc.gov

Recipients	Action	Date & Time
David distel (David Distel)	Transferred	08/10/05 8:52 AM
exeloncorp.com david.helker (David Helker)	Transferred	08/10/05 8:52 AM

nrc.gov OWGWPO01.HQGWDO01 AXD CC (Andrzej Drozd)	Delivered Opened	08/10/05 8:52 AM 08/10/05 9:10 AM
nrc.gov OWGWPO02.HQGWDO01 JJH CC (John Hayes) MXK5 CC (Margie Kotzalas)	Delivered Opened Opened	08/10/05 8:52 AM 08/10/05 9:21 AM 08/10/05 12:37 PM
nrc.gov TWGWPO02.HQGWDO01 HXW CC (Harold Walker)	Delivered Opened	08/10/05 8:52 AM 08/10/05 9:45 AM
nrc.gov owf4_po.OWFN_DO RLD CC (Robert Dennig)	Delivered	08/10/05 8:52 AM

Post Office
David

Delivered

Route
INternet:exeloncorp.
com
exeloncorp.com
nrc.gov
nrc.gov
nrc.gov
nrc.gov

OWGWPO01.HQGWDO01
OWGWPO02.HQGWDO01
TWGWPO02.HQGWDO01
owf4_po.OWFN_DO

08/10/05 8:52 AM
08/10/05 8:52 AM
08/10/05 8:52 AM
08/10/05 8:52 AM

Files
MESSAGE

Size
2559

Date & Time
08/10/05 08:52AM

Options

Auto Delete: No
Expiration Date: None
Notify Recipients: Yes
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard

To Be Delivered: Immediate
Status Tracking: Delivered & Opened