

LIMITING CONDITION FOR OPERATION

SURVEILLANCE REQUIREMENT

- f. The containment spray system shall be considered operable by verifying that lake water temperature does not exceed 83°F.
- g. If specification "f" cannot be met commence shutdown within one hour and be in hot shutdown within 8 hours and cold shutdown within 24 hours.

- f. Lake Water Temperature

Record at least once per 24 hours, and at least once per 8 hours when latest recorded water temperature is greater than or equal to 75°F and at least once per 4 hours when the latest recorded water temperature is greater than or equal to 79°F.