

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	C.2 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u> C.3 Initiate action to suspend OPDRVs.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.4.1.1 Verify secondary containment vacuum is ≥ 0.25 inch of vacuum water gauge.	24 hours
SR 3.6.4.1.2 Verify all required secondary containment removable walls and equipment hatches required to be closed are closed and sealed.	31 days
<p>-----NOTE----- Single door access openings between required zones within the secondary containment boundary may be opened for entry and exit. -----</p>	
SR 3.6.4.1.3 Verify one secondary containment access door in each access opening is closed.	31 days

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	C.2 Suspend CORE ALTERATIONS. <u>AND</u>	Immediately
	C.3 Initiate action to suspend OPDRVs.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.4.1.1 Verify secondary containment vacuum is \geq 0.25 inch of vacuum water gauge.	24 hours
SR 3.6.4.1.2 Verify all required secondary containment removable walls and equipment hatches required to be closed are closed and sealed.	31 days
<p style="text-align: center;">-----NOTE-----</p> <p style="text-align: center;">Single door access openings between required zones within the secondary containment boundary may be opened for entry and exit.</p> <p style="text-align: center;">-----</p>	31 days
SR 3.6.4.1.3 Verify one secondary containment access door in each access opening is closed.	

(continued)