

RS-05-084

10 CFR 50.71(e)(4)
10 CFR 50.48

August 16, 2005

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-001

Zion Nuclear Power Station, Units 1 and 2
Facility Operating License Nos. DPR-39 and DPR-48
NRC Docket Nos. 50-295 and 50-304

Subject: Zion Nuclear Power Station Fire Protection Report, Amendment 9

Reference: Letter from P. R. Simpson (Exelon Generation Company, LLC) to
U. S. NRC, "Amendment 8 to Zion Fire Protection Report," dated
August 21, 2003

In accordance with the requirements of 10 CFR 50.71, "Maintenance of records, making of reports," paragraph (e)(4), Exelon Generation Company, LLC is submitting Amendment 9 to the Fire Protection Report (FPR) for the Zion Nuclear Power Station (ZNPS), Units 1 and 2. This FPR amendment is being submitted within 24 months of the previous ZNPS FPR amendment that was submitted in the referenced letter. The ZNPS FPR is a document incorporated by reference in the ZNPS Defueled Safety Analysis Report. Accordingly, this amendment is due to be submitted by August 21, 2005.


A summary of the changes made to the ZNPS FPR is provided in Attachment 1. These changes reflect the changes that were made through July 5, 2005, under the provisions of 10 CFR 50.48, "Fire protection," paragraph (f), but not previously submitted to the NRC.

Attachment 2 provides the replacement pages for Amendment 9 of the ZNPS FPR as required by 10 CFR 50.71(e) and is accompanied by a list of effective pages and instructions for updating the ZNPS FPR. We have evaluated the FPR changes in accordance with 10 CFR 50.48(f) and concluded the changes do not reduce the effectiveness of fire protection for the facilities, systems and equipment which could result in a radiological hazard, taking into account the current decommissioning plant conditions and activities of ZNPS, and do not require prior NRC approval.

This submittal accurately presents changes made since the previous submittal and reflects information and analysis performed under the provisions of 10 CFR 50.48 but not previously submitted to the NRC.

If you have any questions regarding this letter, please contact Ms. Alison Mackellar at (630) 657-2817.

Respectfully,



Joseph A. Bauer
Licensing Manger

- Attachments:
1. Summary of Changes – Amendment 9, Fire Protection Report – Zion Station
 2. Zion Station – Fire Protection Report – Amendment 9, July 2005

ATTACHMENT 1

SUMMARY OF CHANGES AMENDMENT 9 OF THE FIRE PROTECTION REPORT - ZION STATION

The "Affected Pages" listed below are the pages revised in Amendment 9. Page numbers are identical between Amendment 8 and Amendment 9.

FPR Revision # 2003-03

This change resulted in changing the reference to the DSAR to Appendix A of the QATR. This change was administrative.

Affected Pages: 2-4

FPR Revision # 2004-01

This change resulted in removal of fire detection and dedicated hose stations inside the Unit 1 and Unit 2 containments. The detection covered areas that were considered Safety Related during plant operation. The cables no longer provide any Safety Related function or any function associated with the safe storage of fuel. Most of the cables have been de-energized. Sump pumps remain operational in these areas. Excluding the hose stations inside the containments, fire suppression will still be available from portable extinguishers and hose stations inside the Auxiliary Building. Access routes are available for fire response personnel responding to a fire inside the containments.

Affected Pages: 2-35, 3-7, 3-9, 3-15, 3-17

ATTACHMENT 2

ZION NUCLEAR POWER STATION
FIRE PROTECTION REPORT, AMENDMENT 9

To perform the August 2005 Zion Fire Protection Report update, please remove the existing pages and insert Amendment 9 pages as follows:

SECTION

REMOVE

INSERT

Title Page

Title page

Title page

List of Effective Pages

pages 1 and 2

pages 1 and 2

Table of Contents

pages 1 thru 7

pages 1 thru 7

Section 2

page 2-4

page 2-4

Section 2

page 2-35

page 2-35

Section 3

page 3-7

page 3-7

Section 3

page 3-9

page 3-9

Section 3

page 3-15

page 3-15

Section 3

page 3-17

page 3-17

ZION STATION

FIRE PROTECTION REPORT

Amendment 9, August 2005

Zion Fire Protection Report
Amendment 9

List of Effective Pages

| | |
|---------------------------|-------------|
| Title Page | Amendment 9 |
| List of Effective Pages | |
| 2 of 2 | Amendment 9 |
| Table of Contents | |
| 1 through 7 | Amendment 9 |
| Section 1 | |
| 1-1 through 1-3 | Amendment 7 |
| Section 2 | |
| 2-1 through 2-3 | Amendment 7 |
| 2-4 | Amendment 9 |
| 2-5 through 2-7 | Amendment 7 |
| 2-8 through 2-9 | Amendment 8 |
| 2-10 through 2-13 | Amendment 7 |
| 2-14 | Amendment 8 |
| 2-15 through 2-32 | Amendment 7 |
| 2-33 | Amendment 8 |
| 2-34 | Amendment 7 |
| 2-35 | Amendment 9 |
| 2-36 | Amendment 8 |
| 2-37 through 2-38 | Amendment 7 |
| 2-39 | Amendment 8 |
| 2-40 through 2-41 | Amendment 7 |
| 2-42 | Amendment 8 |
| Figures 2-1 through 2-15 | Amendment 7 |
| Figure 2-16 | Amendment 8 |
| Figures 2-17 through 2-21 | Amendment 7 |
| Figure 2-22 | Amendment 8 |
| Figures 2-23 through 2-45 | Amendment 7 |

Zion Fire Protection Report
Amendment 8

List of Effective Pages

Section 3

| | |
|---------------------|-------------|
| 3-1 through 3-6 | Amendment 7 |
| 3-7 | Amendment 9 |
| 3-8 | Amendment 7 |
| 3-9 | Amendment 9 |
| 3-10 through 3-14 | Amendment 7 |
| 3-15 | Amendment 9 |
| 3-16 | Amendment 7 |
| 3-17 | Amendment 9 |
| 3-18 through 3-20 | Amendment 7 |
| 3-21 | Amendment 8 |
| 3-22 through 3-33 | Amendment 7 |
| 3-34 | Amendment 8 |
| 3-35 | Amendment 7 |
| 3-36 | Amendment 8 |
| 3-37 through 3-39 | Amendment 7 |
| 3-40 | Amendment 8 |
| 3-41 | Amendment 7 |
| 3-42 | Amendment 8 |
| 3-43 through 3-161 | Amendment 7 |
| 3-162 | Amendment 8 |
| 3-163 through 3-195 | Amendment 7 |
| 3-196 | Amendment 8 |
| 3-197 | Amendment 7 |
| 3-198 | Amendment 8 |
| 3-199 through 3-255 | Amendment 7 |
| 3-256 through 3-257 | Amendment 8 |
| 3-258 through 3-261 | Amendment 7 |
| 3-262 | Amendment 8 |
| 3-263 through 3-272 | Amendment 7 |

ZION STATION FIRE PROTECTION REPORT - AMENDMENT 9

TABLE OF CONTENTS

| <u>SECTION</u> | <u>TITLE</u> | <u>PAGE</u> |
|----------------|--|-------------|
| 1.0 | INTRODUCTION | 1-1 |
| 1.1 | Site Description | 1-1 |
| 1.2 | Program Requirements | 1-1 |
| 1.3 | Program Definition / Status | 1-1 |
| 1.4 | Objectives | 1-2 |
| 1.5 | Background | 1-2 |
| 1.6 | Report Overview | 1-3 |
| 2.0 | FIRE PROTECTION PROGRAM ADMINISTRATION | 2-1 |
| 2.1 | Organization and Responsibility | 2-1 |
| 2.2 | Fire Prevention | 2-1 |
| 2.2.1 | Transient Combustible Materials Control | 2-2 |
| 2.2.2 | Potential Ignition Source Control | 2-2 |
| 2.2.3 | Fire Protection Impairments | 2-3 |
| 2.2.4 | Insurance | 2-3 |
| 2.3 | Emergency Response Organization | 2-3 |
| 2.3.1 | Incipient Fire Responder | 2-3 |
| 2.3.2 | Public Fire Department Response | 2-4 |
| 2.4 | Quality Assurance Program | 2-4 |
| 2.5 | Radiological Hazards | 2-4 |
| 2.5.1 | Spent Fuel Pool Systems and SSCs ITDC | 2-4 |
| 2.5.2 | Radioactive Contamination | 2-5 |
| 2.6 | Fire Hazards Analysis and Engineering Design | 2-7 |
| 2.6.1 | Fire Hazards Analysis | 2-7 |
| 2.6.2 | Fire Protection Features Design Criteria | 2-7 |
| 2.6.3 | Fire Protection Engineering Evaluations | 2-7 |
| 2.6.4 | Fire Protection System Description | 2-8 |
| 2.6.5 | Detection System Description / Design Features | 2-9 |
| 2.6.6 | Electrical Design Features and Criteria | 2-10 |
| 2.6.7 | Mechanical Design Features and Criteria | 2-10 |
| 2.6.8 | Structural Design Features and Criteria | 2-11 |
| 2.6.9 | HVAC Design Features and Criteria | 2-11 |
| 2.6.10 | Surveillance Testing / Maintenance | 2-12 |
| 2.6.11 | Compliance with NFPA Codes and Standards | 2-12 |
| 2.6.12 | Pre-Fire Plans | 2-13 |
| 2.7 | Administrative Technical Requirements | 2-15 |
| 2.8 | FHA Assumptions and Methodology | 2-15 |
| 2.8.1 | Fire Area and Fire Severity Identification | 2-16 |
| 2.8.1.1 | Definitions | 2-17 |

ZION STATION FIRE PROTECTION REPORT - AMENDMENT 9

TABLE OF CONTENTS

| <u>SECTION</u> | <u>TITLE</u> | <u>PAGE</u> |
|----------------|------------------------------|-------------|
| 2.8.1.2 | Identification of Fire Areas | 2-20 |
| 2.8.1.3 | Equivalent Fire Severities | 2-20 |
| 2.8.1.4 | Assumptions | 2-21 |
| 2.8.1.5 | Heat Load | 2-23 |
| 2.8.2 | Acronyms | 2-24 |
| 2.8.3 | References | 2-25 |

TABLES

| | | |
|-------------|----------------------------------|------|
| Table 2.6.1 | Fire Suppression Water System | 2-14 |
| Table 2.8.1 | Combustible Loading Summary | 2-26 |
| Table 2.8.2 | Fire Protection Features Summary | 2-34 |

FIGURES

| | |
|-------------|---|
| Figure 2-1 | General Arrangement Plan Main Floor EL 642'-0" |
| Figure 2-2 | General Arrangement Plan Mezz. Floor EL 617'-0" |
| Figure 2-3 | General Arrangement Plan Ground Floor EL 592'-0" |
| Figure 2-4 | General Arrangement Plan Basement Floor EL 560'-0" |
| Figure 2-5 | General Arrangement Plan Misc. Floors |
| Figure 2-6 | General Arrangement Fuel Handling Building |
| Figure 2-7 | General Arrangement Sections A-A & B-B |
| Figure 2-8 | General Arrangement Sections C-C & D-D |
| Figure 2-9 | General Arrangement Sections E-E & F-F |
| Figure 2-10 | General Arrangement Plan Main Floor EL 642'-0" Unit 2 |
| Figure 2-11 | General Arrangement Plan Mezz. Floor EL 617'-0" Unit 2 |
| Figure 2-12 | General Arrangement Plan Ground Floor EL 592'-0" Unit 2 |
| Figure 2-13 | General Arrangement Plan Basement Floor EL 560'-0" Unit 2 |
| Figure 2-14 | General Arrangement Crib House |
| Figure 2-15 | Detection And Suppression Systems (EL 642 FT) |
| Figure 2-16 | Detection And Suppression Systems (EL 630 FT) |
| Figure 2-17 | Detection And Suppression Systems (EL 617 FT) |
| Figure 2-18 | Detection And Suppression Systems (EL 592 FT) |
| Figure 2-19 | Detection And Suppression Systems (EL 579 FT) |
| Figure 2-20 | Detection And Suppression Systems (EL 560 FT) |
| Figure 2-21 | Detection And Suppression Systems (EL 542 FT) |
| Figure 2-22 | Detection And Suppression Systems (Crib House) |
| Figure 2-23 | Fire Barriers Plan Main Floor EL 642'-0" Unit 1 |
| Figure 2-24 | Fire Barriers Plan Main Floor EL 642'-0" Unit 2 |

ZION STATION FIRE PROTECTION REPORT - AMENDMENT 9

TABLE OF CONTENTS

| <u>SECTION</u> | <u>TITLE</u> | <u>PAGE</u> |
|----------------|---|-------------|
| Figure 2-25 | Fire Barriers Plan Main Floor EL 642'-0" Unit 1 | |
| Figure 2-26 | Fire Barriers Plan Main Floor EL 642'-0" Unit 2 | |
| Figure 2-27 | Fire Barriers Plan Mezz. Floor EL 617'-0" Unit 1 | |
| Figure 2-28 | Fire Barriers Plan Mezz. Floor EL 617'-0" Unit 2 | |
| Figure 2-29 | Fire Barriers Plan Mezz. Floor EL 617'-0" Unit 1 | |
| Figure 2-30 | Fire Barriers Plan Mezz. Floor EL 617'-0" Unit 2 | |
| Figure 2-31 | Fire Barriers Plan Floor EL 630'-0" Units 1&2 | |
| Figure 2-32 | Fire Barriers Plan Floor EL 630'-0" Unit 1 | |
| Figure 2-33 | Fire Barriers Plan Floor EL 630'-0" Unit 2 | |
| Figure 2-34 | Fire Barriers Plan Ground FL EL 592'-0" Unit 1 | |
| Figure 2-35 | Fire Barriers Plan Ground FLR EL 592'-0" Unit 2 | |
| Figure 2-36 | Fire Barriers Plan Ground Floor EL 592'-0" Unit 1 | |
| Figure 2-37 | Fire Barriers Plan Ground Floor EL 592'-0" Unit 2 | |
| Figure 2-38 | Fire Barriers Plan Floor EL 579'-0" Units 1&2 | |
| Figure 2-39 | Fire Barriers Plan Basement FL EL 560'-0" Unit 1 | |
| Figure 2-40 | Fire Barriers Plan Basement FLR EL 560'-0" Unit 2 | |
| Figure 2-41 | Fire Barriers Plan Basement FL EL 560'-0" Unit 1 | |
| Figure 2-42 | Fire Barriers Plan Basement FLR EL 560'-0" Unit 2 | |
| Figure 2-43 | Fire Barriers Plan EL 542'-0" Units 1&2 | |
| Figure 2-44 | Barrier, Suppression And Detection Fuel Handling Building | |
| Figure 2-45 | Fire Barriers Crib House | |

ZION STATION FIRE PROTECTION REPORT - AMENDMENT 9

TABLE OF CONTENTS

| <u>SECTION</u> | <u>TITLE</u> | <u>PAGE</u> |
|----------------|--|-------------|
| 3.0 | FIRE HAZARDS ANALYSIS | 3-1 |
| 3.0.a | Containment Buildings | 3-1 |
| 3.0.1 | Unit 1 Containment | 3-1 |
| 3.0.1.1 | Unit 1 Reactor Cavity (1.1-1) | 3-2 |
| 3.0.1.2 | Unit 1 Annular Area, Elevations 590 ft and 568 ft (1.2-1) | 3-4 |
| 3.0.1.3 | Unit 1 Steam Generator and Reactor Coolant Pump Area (1.3-1) | 3-6 |
| 3.0.1.4 | Unit 1 Operating Floor, Elevation 617 ft (1.4-1) | 3-8 |
| 3.0.2 | Unit 2 Containment | 3-10 |
| 3.0.2.1 | Unit 2 Reactor Cavity (1.2-1) | 3-10 |
| 3.0.2.2 | Unit 2 Annular Area, Elevations 590 ft and 568 ft (1.2-2) | 3-12 |
| 3.0.2.3 | Unit 2 Steam Generator and Reactor Coolant Pump Area (1.3-2) | 3-14 |
| 3.0.2.4 | Unit 2 Operating Floor, Elevation 617 (1.4-2) | 3-16 |
| 3.0.3 | Main Control Room Complex | 3-18 |
| 3.0.3.1 | Main Control Room (2.0-0) | 3-19 |
| 3.0.3.2 | Unit 1 Plant Computer Room (4.0-1) | 3-22 |
| 3.0.3.3 | Unit 2 Plant Computer Room (4.0-2) | 3-24 |
| 3.0.3.4 | Prime Computer Room (4.1-1) | 3-26 |
| 3.0.3.5 | Auxiliary Building Kitchen (18.6-1) | 3-28 |
| 3.0.3.6 | Work Control Center (18.6-2) | 3-30 |
| 3.0.4 | Unit 1 Outer Cable Spreading Room (3.1-1) | 3-32 |
| 3.0.5 | Unit 2 Outer Cable Spreading Room (3.1-2) | 3-35 |
| 3.0.6 | Unit 1 Stairwell Enclosure (18.6A-1) | 3-37 |
| 3.0.7 | Unit 2 Stairwell Enclosure (18.6A-2) | 3-38 |
| 3.0.8 | Unit 1 Inner Cable Spreading Room (3.2-1) | 3-39 |
| 3.0.9 | Unit 2 Inner Cable Spreading Room (3.3-2) | 3-41 |
| 3.0.10 | Unit 1 South Penetration Vault (3.3-1) | 3-43 |
| 3.0.11 | Unit 2 North Penetration Vault (3.3-2) | 3-45 |
| 3.0.12 | Unit 1 North Penetration Vault (3.4-1) | 3-47 |
| 3.0.13 | Unit 2 South Penetration Vault (3.4-2) | 3-49 |
| 3.0.14 | Unit 1 EDG 1B Switchgear Room (5.1-1) | 3-51 |
| 3.0.15 | Unit 2 EDG 2B Switchgear Room (5.1-2) | 3-54 |
| 3.0.16 | Unit 1 EDG 1A Switchgear Room (5.2-1) | 3-57 |
| 3.0.17 | Unit 2 EDG 2A Switchgear Room (5.2-2) | 3-59 |
| 3.0.18 | Unit 1 EDG 0 Switchgear Room (5.3-1) | 3-61 |
| 3.0.19 | Unit 2 EDG 0 Switchgear Room (5.3-2) | 3-63 |
| 3.0.20 | Unit 1 Nonessential Switchgear Room (5.4-1) | 3-66 |
| 3.0.21 | Unit 2 Nonessential Switchgear Room (5.4-2) | 3-68 |

ZION STATION FIRE PROTECTION REPORT - AMENDMENT 9

TABLE OF CONTENTS

| <u>SECTION</u> | <u>TITLE</u> | <u>PAGE</u> |
|----------------|---|-------------|
| 3.0.22 | Unit 1 Rod Drive MG Set Room (5.5-1) | 3-70 |
| 3.0.23 | Unit 2 Rod Drive MG Set Room (5.5-2) | 3-72 |
| 3.0.24 | Unit 1 Auxiliary Electric Equipment Room (5.6-1) | 3-74 |
| 3.0.25 | Unit 2 Auxiliary Electric Equipment Room (5.6-2) | 3-77 |
| 3.0.26 | Unit 1 Division 18 DC Distribution Panel (5.6A-1) | 3-80 |
| 3.0.27 | Unit 2 Division 28 DC Distribution Panel (5.6A-2) | 3-82 |
| 3.0.28 | Division 17/27 DC Battery & Distribution Room (7.0-0) | 3-83 |
| 3.0.29 | Unit 1 Division 19 Battery Room (7.1-1) | 3-84 |
| 3.0.30 | Unit 2 Division 29 Battery Room (7.1-2) | 3-86 |
| 3.0.31 | Unit 1 Division 18 Battery Room (7.2-1) | 3-88 |
| 3.0.32 | Unit 2 Division 28 Battery Room (7.2-2) | 3-90 |
| 3.0.33 | Unit 1 EDG 1B Room (9.1-1) | 3-92 |
| 3.0.34 | Unit 2 EDG 2B Room (9.1-2) | 3-94 |
| 3.0.35 | Unit 1 EDG 1A Room (9.2-1) | 3-96 |
| 3.0.36 | Unit 2 EDG 2A Room (9.2-2) | 3-98 |
| 3.0.37 | Unit 1 EDG 0 Room (9.3-1) | 3-100 |
| 3.0.38 | Unit 1 EDG 1B Diesel Fuel Oil Storage Room (10.1-1) | 3-102 |
| 3.0.39 | Unit 2 EDG 2B Diesel Fuel Oil Storage Room (10.1-2) | 3-104 |
| 3.0.40 | Unit 1 EDG 1A Diesel Fuel Oil Storage Room (10.2-2) | 3-106 |
| 3.0.41 | Unit 2 EDG 2A Diesel Fuel Oil Storage Room (10.2-2) | 3-108 |
| 3.0.42 | Unit 1 EDG 0 Diesel Fuel Oil Storage Room (10.3-1) | 3-110 |
| 3.0.43 | Turbine Building | 3-112 |
| 3.0.43.1 | Turbine Oil Room (8.1-0) | 3-113 |
| 3.0.43.2 | Unit 1 Turbine Building Basement, El. 560' (8.2-1) | 3-115 |
| 3.0.43.3 | Unit 2 Turbine Building Basement, El. 560' (8.2-2) | 3-117 |
| 3.0.43.4 | Sampling Room (8.3-0) | 3-119 |
| 3.0.43.5 | Auxiliary Heating Boiler Room (8.4-0) | 3-121 |
| 3.0.43.6 | Unit 1 Turbine Building, El. 592' (8.5-1) | 3-123 |
| 3.0.43.7 | Unit 2 Turbine Building, El. 592' (8.5-2) | 3-126 |
| 3.0.43.7a | BOP Battery Rooms Unit 2 El. 592' (8.5A-0) | 3-128 |
| 3.0.43.8 | Unit 1 Turbine Building, Mezzanine Floor (8.6-1) | 3-130 |
| 3.0.43.9 | Unit 2 Turbine Building, Mezzanine Floor (8.6-2) | 3-132 |
| 3.0.43.10 | Units 1 and 2 Turbine Building, Operating Floor (8.7-0) | 3-134 |
| 3.0.43.11 | Unit 2 Future Diesel Fuel Oil Storage Room (10.3-2) | 3-137 |
| 3.0.43.12 | QA Storage Room and Operating Offices (13.0-0) | 3-139 |
| 3.0.43.13 | Unit 1 Steam Pipe Tunnel (18.5-1) | 3-141 |
| 3.0.43.14 | Unit 2 Steam Pipe Tunnel (18.5-2) | 3-143 |

ZION STATION FIRE PROTECTION REPORT - AMENDMENT 9

TABLE OF CONTENTS

| <u>SECTION</u> | <u>TITLE</u> | <u>PAGE</u> |
|----------------|--|-------------|
| 3.0.44 | Auxiliary Building | 3-145 |
| 3.0.44.1 | Auxiliary Building, 542' Level (11.1-0) | 3-147 |
| 3.0.44.2 | Unit 1 RHR Pump 1A Room (11.1A-1) | 3-149 |
| 3.0.44.3 | Unit 2 RHR Pump 2A Room (11.1A-2) | 3-151 |
| 3.0.44.4 | Unit 1 RHR Pump 1B Room (11.1B-1) | 3-153 |
| 3.0.44.5 | Unit 2 RHR Pump 2B Room (11.1B-2) | 3-155 |
| 3.0.44.6 | Unit 1 Pipe Tunnel (11.1C-1) | 3-157 |
| 3.0.44.7 | Unit 2 Pipe Tunnel (11.1C-2) | 3-158 |
| 3.0.44.8 | Gas Decay Tanks Area (14.1-0) | 3-159 |
| 3.0.44.9 | Auxiliary Building, 560' Level (11.2-0) | 3-161 |
| 3.0.44.10 | Unit 1 Safety Injection Pump 1A Room (11.2A-1) | 3-163 |
| 3.0.44.11 | Unit 2 Safety Injection Pump 2A Room (11.2A-2) | 3-165 |
| 3.0.44.12 | Unit 1 Safety Injection Pump 1B Room (11.2B-1) | 3-167 |
| 3.0.44.13 | Unit 2 Safety Injection Pump 2B Room (11.2B-2) | 3-169 |
| 3.0.44.14 | Unit 1 RHR Heat Exchanger 1A Room (11.2C-1) | 3-171 |
| 3.0.44.15 | Unit 2 RHR Heat Exchanger 2A Room (11.2C-2) | 3-173 |
| 3.0.44.16 | Unit 1 RHR Heat Exchanger 1B Room (11.2D-1) | 3-175 |
| 3.0.44.17 | Unit 2 RHR Heat Exchanger 2B Room (11.2D-2) | 3-177 |
| 3.0.44.18 | Unit 1 Containment Spray Pump Room (11.2E-1) | 3-179 |
| 3.0.44.19 | Unit 2 Containment Spray Pump Room (11.2E-2) | 3-181 |
| 3.0.44.20 | Unit 1 Pipe Chase (11.2F-1) | 3-183 |
| 3.0.44.21 | Unit 2 Pipe Chase (11.2F-2) | 3-184 |
| 3.0.44.22 | Auxiliary Building, 579' Level (11.3-0) | 3-185 |
| 3.0.44.23 | Unit 1 Centrifugal Charging Pump 1A Room (11.3A-1) | 3-187 |
| 3.0.44.24 | Unit 2 Centrifugal Charging Pump 2A Room (11.3A-2) | 3-189 |
| 3.0.44.25 | Unit 1 Centrifugal Charging Pump 1B Room (11.3B-1) | 3-191 |
| 3.0.44.26 | Unit 2 Centrifugal Charging Pump 2B Room (11.3B-2) | 3-193 |
| 3.0.44.27 | Unit 1 Reciprocating Charging Pump 1C Room (11.3C-1) | 3-195 |
| 3.0.44.28 | Unit 2 Reciprocating Charging Pump 2C Room (11.3C-2) | 3-197 |
| 3.0.44.29 | Unit 1 Refueling Water Storage Tank Room (11.3D-1) | 3-199 |
| 3.0.44.30 | Unit 2 Refueling Water Storage Tank Room (11.3D-2) | 3-200 |
| 3.0.44.31 | Unit 1 Pipe Chase (11.3E-1) | 3-201 |
| 3.0.44.32 | Unit 2 Pipe Chase (11.3E-2) | 3-202 |
| 3.0.44.33 | Holdup Tanks (11.1D-0) | 3-203 |
| 3.0.44.34 | Crystallizer (14.2A-0) | 3-204 |
| 3.0.44.35 | Auxiliary Building, 592' Level (11.4-0) | 3-205 |
| 3.0.44.36 | Unit 1 Letdown Heat Exchanger Room (11.4A-1) | 3-207 |
| 3.0.44.37 | Unit 2 Letdown Heat Exchanger Room (11.4A-2) | 3-209 |
| 3.0.44.38 | Unit 1 Seal Water Heat Exchanger Room (11.4B-1) | 3-211 |
| 3.0.44.39 | Unit 2 Seal Water Heat Exchanger Room (11.4B-2) | 3-213 |
| 3.0.44.40 | Unit 1 Pipe Chase (11.4C-1) | 3-215 |
| 3.0.44.41 | Unit 2 Pipe Chase (11.4C-2) | 3-216 |
| 3.0.44.42 | Dry Active Waste Storage (14.3A-0) | 3-217 |
| 3.0.44.43 | Drum Filling (14.3B-0) | 3-219 |
| 3.0.44.44 | Radwaste Annex, Truck Loading Zone (11.3C-0) | 3-221 |
| 3.0.44.45 | DAW Storage (11.4D-0) | 3-222 |

ZION STATION FIRE PROTECTION REPORT - AMENDMENT 9

TABLE OF CONTENTS

| <u>SECTION</u> | <u>TITLE</u> | <u>PAGE</u> |
|----------------|--|-------------|
| 3.0.44.46 | Auxiliary Building, 617' Level (11.5-0) | 3-224 |
| 3.0.44.47 | HVAC Equipment Room (11.5A-0) | 3-227 |
| 3.0.44.48 | Unit 1 Volume Control Tank Room (11.5B-1) | 3-230 |
| 3.0.44.49 | Unit 2 Volume Control Tank Room (11.5B-2) | 3-232 |
| 3.0.44.50 | Unit 1 Pipe Chase (11.5C-1) | 3-234 |
| 3.0.44.51 | Unit 2 Pipe Chase (11.5C-2) | 3-235 |
| 3.0.44.52 | Radiation Protection Offices and Labs (11.5D-0) | 3-236 |
| 3.0.44.53 | Unit 1 Containment Purge Air Equipment Room (11.6-1) | 3-238 |
| 3.0.44.54 | Unit 2 Containment Purge Air Equipment Room (11.6-2) | 3-240 |
| 3.0.44.55 | Tool Crib (14.4A-0) | 3-242 |
| 3.0.44.56 | Waste Gas Room (14.4B-0) | 3-244 |
| 3.0.44.57 | Radwaste Evaporator Room (14.4C-0) | 3-246 |
| 3.0.44.58 | Spent Resin Storage Area (14.4D-0) | 3-248 |
| 3.0.44.59 | Auxiliary Building, 642' Level (11.7-0) | 3-250 |
| 3.0.45 | Fuel Handling Building (12.0-0) | 3-252 |
| 3.0.46 | West Service Building (18.2-0) | 3-255 |
| 3.0.47 | Technical Support Center (TSC) (18.3-0) | 3-257 |
| 3.0.48 | East Service Building (18.7-0) | 3-258 |
| 3.0.49 | Outer Crib House (18.4A-0) | 3-260 |
| 3.0.50 | Inner Crib House (18.4B-0) | 3-263 |
| 3.0.51 | Fuel Oil Tank Area (18.8-0) | 3-266 |
| 3.0.52 | Unit 1 Transformers (18.9-1) | 3-267 |
| 3.0.53 | Unit 2 Transformers (18.9-2) | 3-269 |
| 3.0.54 | Waste Water Treatment Center (15.0-0) | 3-270 |
| 3.0.55 | Illinois Department of Nuclear Safety (IDNS) | 3-271 |
| 3.0.56 | Miscellaneous Areas | 3-272 |

ZION STATION
FIRE PROTECTION REPORT

2.3.2 Public Fire Department Response

The City of Zion Fire Department is fewer than 2.0 miles west of the site. This full time fire department is contacted immediately upon the receipt of a valid fire alarm. The City of Zion also has two city water hydrants at the north and south ends of the site. The north hydrant is inside the protected area.

The Zion Municipal Fire Department (ZMFD) is trained and equipped for fire fighting to ensure adequate manual fire fighting capability for all areas of the plant containing radiological and/or fire hazards. The ZMFD responds to all types of fires, including large structural fires. The ZMFD requests additional backup units as needed for suppression assistance. The onsite incipient fire responder assists the ZMFD as required. Emergency Response Capability utilizing the ZMFD shall be reassessed periodically as required per station procedures (ZAP 900-01).

Training shall be available to the local fire department to delineate responsibilities, duties, and operational precautions when fighting fires onsite. Zion Station Pre-Fire Plans shall be made available to the local fire department. Where practicable, the training of the local fire department should be coordinated with that of the incipient fire responders.

At least annually, one fire drill will include the Zion Fire Department. The Zion Fire Department may also participate in annual personnel training exercises. At these training exercises, radiological training, special procedures, and equipment hazards are explained. Plant security procedures allow modification or suspension of normal security measures during fires or fire drills, consistent with 10CFR73.55(a)(1) and Regulatory Guide 5.65.

2.4 QUALITY ASSURANCE PROGRAM

QA requirements are described in the EGC Quality Assurance Topical Report (QATR).

Engineered/quality requirements for ITDC SSCs are described in Appendix A of the QATR.

Onsite fire protection systems, structures, and components associated with the protection of equipment required to be functional should be designed, installed, and maintained in accordance with the applicable (state and federal) regulatory requirements, NFPA codes and standards and generally accepted industry practices.

2.5 RADIOLOGICAL HAZARDS

2.5.1 Spent Fuel Pool Systems and SSCs ITDC

Spent Fuel Pool Systems and SSCs designated as ITDC are discussed in DSAR Chapter 3. As discussed in DSAR chapters 3 and 5, these systems are not credited with the mitigation of any remaining analyzed accidents.

The spent fuel pool structure and cooling support systems are built of materials that are inherently resistant to fires. There are no credible fire scenarios that will impact the water filled, steel reinforced, concrete structure or the fuel under water. The spent fuel building structure acts as a fire barrier to prevent fire spread into the spent fuel area from an external fire. A radiological hazard in the spent fuel building resulting from fire is not a credible event.

ZION STATION
FIRE PROTECTION REPORT

TABLE 2.8.2
FIRE PROTECTION FEATURES SUMMARY

| AREA DESCRIPTION | FIRE AREA/ZONE | AUTOMATIC FIRE DETECTION | AUTOMATIC FIRE SUPPRESSION | SUPPRESSION SYSTEM TYPE | ATR REQUIRED SUPPRESSION (NOTE 1) |
|-----------------------------------|-------------------|---|----------------------------------|-------------------------------|---|
| · Unit 1 Containment | | | | | |
| · Reactor Cavity | 1.1-1 | NO | NO | | |
| · Annular Area | 1.2-1 | NO | NO | | |
| · Steam Gen. & RCP | 1.3-1 | NO | NO | | |
| · Operating Floor | 1.4-1 | NO | NO | | NO |
| · Unit 2 Containment | | | | | |
| · Reactor Cavity | 1.1-2 | NO | NO | | |
| · Annular Area | 1.2-2 | NO | NO | | |
| · Steam Gen. & RCP | 1.3-2 | NO | NO | | |
| · Operating Floor | 1.4-2 | NO | NO | | NO |
| · Main Control Room Complex | | | | | |
| · Main Control Rm | 2.0-0 | YES | NO | | |
| · Unit 1 Plant Computer Rm | 4.0-1 | YES | NO | | |
| · Unit 2 Plant Computer Rm | 4.0-2 | YES | NO | | |
| · Prime Computer Rm | 4.1-1 | YES | NO | | |
| · Auxiliary Building Kitchen | 18.6-1 | YES | NO | | |
| · Work Control Center | 18.6-2 | YES | NO | | |
| · Unit 1 Outer Cable Spreading Rm | 3.1-1 | YES | NO | | |
| · Unit 2 Outer Cable Spreading Rm | 3.1-2 | YES | NO | | |
| · Unit 1 Stairwell Enclosure | 18.6A-1 | YES (PARTIAL) (Inside Cable Enclosure) | NO | | |
| · Unit 2 Stairwell Enclosure | 18.6A-2 | NO | NO | | |
| · Unit 1 Inner Cable Spreading Rm | 3.2-1 | YES | NO | | |
| · Unit 2 Inner Cable Spreading Rm | 3.2-2 | YES | NO | | |

ZION STATION
FIRE PROTECTION REPORT

Fire Protection Criteria and Measures

This fire zone contains no automatic suppression or detection systems. |

Manual fire suppression equipment, including portable fire extinguishers and hose stations are available at |
containment entry for fire responder use. Access routes are available to fire response personnel |
responding to a fire in this zone. |

Design-Basis Fire

The design-basis fire would result if cable insulation in the zone burned. It could also spread to the other |
zones inside the containment, since the walls and floors separating these zones are not designated as fire |
barriers. The fire would not spread beyond the containment.

The design-basis fire is unlikely for the following reasons:

- a. The containment is a controlled access area.
- b. All lubricating oil normally present has been drained.

A fire in this fire zone cannot affect adjacent fire areas because this zone shares no boundaries with any |
adjacent fire areas.

ZION STATION
FIRE PROTECTION REPORT

Combustible Material and Fire Loading

The combustible material in this fire area consisted of 104 gallons of lube oil (which has been drained), about 420 lb of cable insulation in trays and cabinets, about 48 ft of nuclear instrumentation cable, about 35 lb of flexible connectors (HVAC), 18 modules each of HEPA and pre-filters, 2688 lb of wood, and 4320 lb of charcoal filters. With a floor area of 12,266 ft² and a total heat content of 1.161×10^8 Btu, the average fire loading in this area is about 9.465×10^3 Btu/ft² with an equivalent fire severity of 7 minutes.

The administrative transient combustible load limit for this fire zone is 8,525 Btu/ft².

Fire Protection Criteria and Measures

This fire zone has no general area automatic fire suppression or detection.

Manual fire suppression equipment including portable fire extinguishers and hose stations are available at containment entry for fire responder use. Access routes to this fire zone are available for responding fire response personnel.

Design-Basis Fire

The design-basis fire would result if the combustible materials in this zone burned. This fire could spread to other zones in the containment, since the zone boundaries are not designated as fire barriers, but it would not spread out of the containment building.

The design-basis fire is unlikely, since this zone has a low fire loading and the combustibles present are not evenly distributed, making the likelihood of a fire spreading rather small.

Any fire likely to start in this zone would remain confined to a small area and would not cause any major damage.

ZION STATION
FIRE PROTECTION REPORT

Fire Protection Criteria and Measures

This fire zone contains no automatic suppression or detection systems.

Manual fire suppression equipment including portable fire extinguishers and hose stations are available at containment entry for fire responder use. Access routes are available to fire response personnel responding to a fire in this zone.

Design-Basis Fire

The design-basis fire would result and all of the cable insulation burned. All of the equipment in the zone would be damaged. The fire could spread to adjacent zones, since the zone walls are not designated as fire barriers, but would be contained inside the containment building.

The design-basis fire is unlikely for the following reasons:

- a. The containment is a controlled access area.
- b. All lubricating oil normally present in the RCP's has been drained, and other cable load is spread out.

A fire in this fire zone cannot affect adjacent fire areas because this zone shares no boundaries with any adjacent fire areas.

ZION STATION
FIRE PROTECTION REPORT

Combustible Material and Fire Loading

The combustible material in this fire area consisted of about 523.8 lb of cable insulation in trays and cabinets, about 10 ft of nuclear instrumentation cable, about 35 lb of flexible connectors (HVAC), 18 modules each of HEPA and pre-filters, 2688 lb of wood, 4320 lb of charcoal filters, 7.2 lbs of plastic battery casings. With a floor area of 12,266 ft² and a total heat content of 1.774×10^8 Btu, the average fire loading in this area is about 10,158 Btu/ft² with an equivalent fire severity of 8 minutes. The administrative transient combustible load limit for this fire zone is 8,525 Btu/ft².

Fire Protection Criteria and Measures

This fire zone has no general area automatic fire suppression or detection.

Manual fire suppression equipment including portable fire extinguishers and hose stations are available at containment entry for fire responder use. Access routes to this fire zone are available for responding fire response personnel.

Design-Basis Fire

The design-basis fire would result if the combustible materials in this zone burned. This fire could spread to other zones in the containment, since the zone boundaries are not designated as fire barriers, but it would not spread out of the containment building.

The design-basis fire is unlikely, since this zone has a low fire loading, and the combustibles present are not evenly distributed, making the likelihood of a fire spreading rather small.

Any fire likely to start in this zone would remain confined to a small area, and would not cause any major damage.