BAW-1543(NP), Revision 4, Supplement 5-A May 2005

THE OWNERS GROUP

Reactor Vessel Working Group

SUPPLEMENT TO THE MASTER INTEGRATED REACTOR VESSEL SURVEILLANCE PROGRAM

SUPPLEMENT TO THE MASTER INTEGRATED REACTOR VESSEL SURVEILLANCE PROGRAM

by

J. B. Hall

Prepared for

B&W Owners Group Reactor Vessel Working Group Dominion Generation Duke Energy Corporation Entergy Operations, Inc. Exelon Corporation FirstEnergy Nuclear Operating Company Florida Power Corporation Florida Power & Light Company Nuclear Management Company

Prepared by

Framatome ANP, Inc. An AREVA and Siemens Company 3315 Old Forest Road P. O. Box 10935 Lynchburg, Virginia 24506-0935





UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

May 16, 2005

Mr. Jerald S. Holm Director, Regulatory Affairs Framatome ANP 3815 Old Forest Road Lynchburg, VA 24501

SUBJECT: FINAL SAFETY EVALUATION FOR BABCOCK AND WILCOX OWNERS GROUP TOPICAL REPORT BAW-1543(NP), REVISION 4, SUPPLEMENT 5, "SUPPLEMENT TO THE MASTER INTEGRATED REACTOR VESSEL SURVEILLANCE PROGRAM" (TAC NO. MC1762)

Dear Mr. Holm:

By letter dated December 19, 2003, Babcock and Wilcox Owners Group (B&WOG) submitted BAW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor Vessel Surveillance Program" to the U. S. Nuclear Regulatory Commission (NRC) staff for review. On February 1, 2005, an NRC draft safety evaluation (SE) regarding our approval of BAW-1543(NP), Revision 4, Supplement 5, was provided for your review and comments. By letter dated February 21, 2005, you commented on the draft SE. The staff's disposition of your comments on the draft SE are discussed in the attachment to the final SE enclosed with this letter.

The staff has found that BAW-1543(NP), Revision 4, Supplement 5, is acceptable for referencing in licensing applications to the extent specified and under the limitations delineated in the Topical Report (TR) and in the enclosed SE. The SE defines the basis for the acceptance of the TR.

Our acceptance applies only to material provided in the subject TR. We do not intend to repeat our review of the acceptable material described in the TR. When the TR appears as a reference in license applications, our review will ensure that the material presented applies to the specific plant involved. License amendment requests that deviate from this TR will be subject to a plant-specific review in accordance with applicable review standards.

In accordance with the guidance provided on the NRC website, we request that B&WOG publish accepted proprietary and non-proprietary versions of this TR within three months of receipt of this letter. The accepted versions shall incorporate this letter and the enclosed SE after the title page. Also, they must contain historical review information including NRC requests for additional information and your responses. The accepted versions shall include a "-A" (designating accepted) following the TR identification symbol.

J. Holm

If future changes to the NRC's regulatory requirements affect the acceptability of this TR, B&WOG and/or licensees referencing it will be expected to revise the TR appropriately, or justify its continued applicability for subsequent referencing.

Sincerely,

Aerbert N. Berkow, Director Project Directorate IV Division of Licensing Project Management Office of Nuclear Reactor Regulation

Project No. 693

Enclosure: Safety Evaluation



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

MASTER INTEGRATED REACTOR VESSEL SURVEILLANCE PROGRAM

TOPICAL REPORT BAW-1543, REVISION 4, SUPPLEMENT 5

1.0 INTRODUCTION

By letter dated December 19, 2003, the Babcock and Wilcox (B&W) Owners Group (B&WOG) Reactor Vessel Working Group submitted, for NRC approval, topical report (TR) BAW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor Vessel Surveillance Program." The revisions contained in this supplement were necessary due to a commitment not being met in Supplement 4, because capsules OC1-D and OC3-F could not be removed from Crystal River Unit 3.

2.0 BACKGROUND

By letter dated April 10, 2001, the B&WOG submitted, for staff approval, report BAW-1543, Revision 4, Supplement 4, "Supplement to the Master Integrated Reactor Vessel Surveillance Program." BAW-1543, Revision 4, reported the essential features of the master integrated reactor vessel surveillance program (MIRVSP) for all operating B&W 177-fuel assembly (FA) plants and those participating Westinghouse plants having B&W-fabricated reactor vessels. These reactor vessels include seven B&W-designed 177- FA plants and six Westinghouse-designed plants with B&W-fabricated reactor vessels. The program was built upon the integrated surveillance program developed by the B&WOG for the B&W 177-FA plants. All 13 reactors are of the same basic design concept: pressurized water reactor, operating at about 550 °F and 2250 pounds per square inch (psi) nominal inlet temperature and pressure, and with low enrichment fuel (approximately 2 percent to 4 percent enrichment).

The irradiation schedules for the B&WOG MIRVSP include the plant-specific capsules for the B&W- and Westinghouse-designed vessels, and the supplementary weld metal surveillance capsules and higher fluence supplementary weld metal surveillance capsules. All the irradiations, with the exception of Capsule W1 and the Westinghouse plant-specific capsules, are performed in the B&W host reactors, Crystal River Unit 3 and Davis-Besse. Capsule W1, an irradiation capsule of the Westinghouse-design, was irradiated in Surry Unit 2 and was subsequently tested. The Westinghouse plant-specific capsules are irradiated in their respective plants. An updated list of the status of the Westinghouse and B&W plant-specific/integrated surveillance capsules is attached.

The staff evaluated the B&WOG's basis for the integrated program concept. The criteria as provided by Appendix H to Title 10 to the *Code of Federal Regulations*, Part 50, "Reactor Vessel Material Surveillance Program Requirements," were met; therefore, the staff determined the MIRVSP to be acceptable. By letter dated June 11, 1991, BAW-1543, Revision 3, was

approved by the NRC. The staff noted that the discussions of BAW-1543, Revision 4, were essentially the same as those found in BAW-1543, Revision 3, except for an update of some of the units' withdrawal schedules. BAW-1543, Revision 4, Supplement 1, contained quantitative information which was, in general, fluence dependent and, therefore, subject to change. This revision reflected revised fluence values for some units and revised some withdrawal schedules to comply with American Society for Testing and Materials (ASTM) Standard E 185-73, "Standard Recommended Practice for Surveillance Tests for Nuclear Reactor Vessels." It was anticipated that future revisions to BAW-1543 would only involve the Revision 4 Supplement. BAW-1543, Revision 4, Supplement 2, reflected the revised fluence values and the revised withdrawal schedules, and, therefore, replaced BAW-1543, Revision 4, Supplement 1.

The B&WOG later revised and replaced Supplement 2 of Revision 4 of the subject report with Supplement 3. In Supplement 3, the B&WOG deleted Rancho Seco, R.E. Ginna, and Zion Units 1 and 2 from the program. In addition, the B&WOG updated the capsule status and the peak end-of-license fluences for several plants. In Supplement 4, the B&WOG incorporated the disposal plan for stored capsules, updated the status for various capsules, and incorporated current fluence levels. The B&WOG submitted Supplement 5 because the last supplement included a commitment regarding Capsules OC1-D and OC3-F; however, that commitment could not be met because these capsules could not be removed from Crystal River Unit 3.

3.0 EVALUATION

Appendix H to 10 CFR Part 50 includes criteria to monitor changes in the fracture toughness properties of ferritic materials in the reactor vessel beltline region of light-water nuclear power reactors which result from exposure of these materials to neutron irradiation and the thermal environment. Appendix H to 10 CFR Part 50 endorses ASTM Standard E 185-73. Appendix H states that "[t]he design of the surveillance program and the withdrawal schedule must meet the requirements of the edition of ASTM E 185 that is current on the issue date of the ASME [American Society of Mechanical Engineers] Code [Boiler and Pressure Vessel Code] to which the reactor vessel was purchased. Later editions of ASTM E 185 may be used, but including only those editions through 1982."

ASTM Standard E 185-82, "Standard Practice for Conducting Surveillance Tests for Light Water Cooled Nuclear Power Reactor Vessels" and ASTM Standard E 185-66, "Recommended Practice for Surveillance Tests on Structural Materials in Nuclear Reactors" cover procedures for monitoring the radiation-induced changes in the mechanical properties of ferritic materials in the beltline of light-water cooled nuclear power reactor vessels. These practices include guidelines for designing a minimum surveillance program, selecting materials, and evaluating test results.

The staff evaluated the withdrawal schedule for each of the B&W and Westinghouse plant-specific reactor vessel surveillance programs, as provided in BAW-1543(NP), Revision 4, Supplement 5, and determined that the withdrawal schedules were prepared in accordance with ASTM Standard E 185-82 for each of the subject units except for Turkey Point Units 3 and 4. Additional details of the staff's assessment are provided below. It should be noted that this evaluation will focus on the staff's review of the B&WOG's revised withdrawal schedules, as provided in BAW-1543(NP), Revision 4, Supplement 5. As stated previously, capsules OC1-D and OC3-F could not be removed; therefore, credit for these two capsules could no longer be taken for Oconee Unit 1 and Oconee Unit 3, respectively. The staff independently reviewed the

surveillance capsule withdrawal schedules for Oconee Unit 1 and Oconee Unit 3, to ensure that the subject units' surveillance capsule program would still comply with the requirements of ASTM Standard E 185-82.

The staff found that the capsule withdrawal schedule for Oconee Unit 1 adequately met the requirements of ASTM Standard E 185-82, in that four capsules have been withdrawn and tested, and the last capsule that was tested, OC1-C, had a fluence of 1 to 2 times the end-of-life fluence. Therefore, the staff determined that the inability to withdraw capsule OC1-D had no impact on the ability of the Oconee Unit 1 surveillance capsule program to meet the Appendix H requirements.

The staff found that the capsule withdrawal schedule for Oconee Unit 3 adequately met the requirements of ASTM Standard E 185-82, in that three capsules have been tested and an additional capsule, capsule CR3-LG2, which contains the limiting beltline material for Oconee Unit 3 (heat number 72442), was tested and had a fluence of 1 to 2 times the end-of-life fluence for Oconee Unit 3. Therefore, the staff determined that the inability to withdraw capsule OC3-F had no impact on the ability of the Oconee Unit 3 surveillance capsule program to meet the Appendix H requirements.

The staff noted that the Nuclear Management Company (NMC) added a supplemental capsule, to be removed and tested, to the Point Beach Unit 2 surveillance program. Also, the B&WOG updated the status of capsules Y and X of Surry Unit 2 and Turkey Point Unit 3, respectively, to indicate that they had been tested. The staff found that these revisions were enhancements or updates to the program and are, therefore, acceptable to the staff.

On May 26, 2004, the staff requested that the B&WOG remove or address the relevance of the statement, "The owners of plants that have been granted license renewal have made no commitments to test or use information from the capsules that continue to be irradiated under the MIRVSP," because future applicants may wish to take credit for information obtained from the MIRVSP, as opposed to using plant-specific information in order to meet the requirements of 10 CFR Part 50, Appendix H. By letter dated July 7, 2004, the B&WOG indicated that the statement will be removed upon issuance of the approved version of BAW-1543, Revision 4, Supplement 5. The staff found this acceptable.

The staff determined that the withdrawal schedules for Oconee Unit 2, Three Mile Island Unit 1 (TMI-1), Crystal River Unit 3, Arkansas Nuclear One Unit 1, Davis-Besse, Point Beach Unit 2, Surry Unit 1, and Turkey Point Unit 4, as provided in Tables VI and VII of BAW-1543(NP), Revision 4, Supplement 5, did not change from Supplement 4 and, therefore, still comply with the requirements of ASTM Standard E 185-82, as stated in the staff's safety evaluation dated July 31, 2001. However, the staff noted that the information in Table VIII, of the subject TR, did not accurately list the capsules to be withdrawn and tested for Oconee Units 1, 2 and 3, and TMI-1. The B&WOG listed capsules for these subject plants that were no longer going to be withdrawn and tested, i.e., Capsule OC1-D for Oconee Unit 1, Capsule OC2-F for Oconee Unit 2, Capsule OC3-F for Oconee Unit 3, and Capsules F and D for TMI-1.

During a telephone conference call that was held on November 23, 2004, the staff discussed this issue with the B&WOG, who indicated that it would revise Table VIII of the report to accurately list the capsules that were going to replace those that were no longer going to be withdrawn and tested. The staff noted that the withdrawal schedule for Oconee Unit 1 already

met the requirements of ASTM Standard E185-82; however, the table still needed revision, because the capsules listed were not correct. The B&WOG indicated that Oconee Unit 2's limiting material is contained in Capsule A5 (which was irradiated in Davis Besse), which was tested and satisfied the fifth capsule requirement of ASTM Standard E185-82 for Oconee Unit 2. For Oconee Unit 3, the limiting material is contained in Capsule CR3-LG2, which was tested and satisfied the fifth capsule requirement of ASTM Standard E185-82, for Oconee Unit 3. The TMI-1 limiting material is contained in Capsule TMI2-LG2, which was tested and satisfied the fifth capsule requirement of ASTM Standard E185-82.

By supplemental letter dated January 5, 2005, the B&WOG revised Table VIII to the BAW-1543(NP), Revision 4, Supplement 5 report. The staff found that the revised table accurately listed the withdrawal schedules for Oconee Units 1, 2, and 3, and TMI-1. As stated above, the staff found that each of these plants met the capsule withdrawal schedule requirements of ASTM Standard E185-82, even though the original capsules were not going to be withdrawn and tested for Oconee Units 2 and 3 and TMI-1, because there are other capsules in the MIRVSP that contain the same limiting material for the subject plants that will be withdrawn and tested, and, therefore, will satisfy the requirements of ASTM Standard E185-82.

Turkey Point Units 3 and 4 surveillance capsule withdrawal schedules were prepared in accordance with ASTM Standard E 185-66. The Turkey Point Units 3 and 4 reactor vessels were purchased to the Summer 1966 Addenda to the 1965 ASME Code. ASTM Standard E 185-66 was the surveillance capsule standard in effect at the time the Turkey Point Units 3 and 4 reactor vessels were purchased. Since the Turkey Point Units 3 and 4 capsule withdrawal schedules meet the ASTM Standard E 185 edition that was current at the time the reactor vessels were purchased, the withdrawal schedules meet the requirements of Appendix H to 10 CFR Part 50.

It should also be noted that, by letter dated February 8, 1985, a safety evaluation report (SER) was submitted to Florida Power & Light Company, which indicated that the NRC approved an integrated surveillance program for Turkey Point Units 3 and 4. The SER indicated that the only capsules to be tested at Turkey Point Units 3 and 4 in accordance with ASTM Standard E 185 requirements, are those that contain weld metal specimens.

4.0 <u>CONCLUSION</u>

Based on the staff's review of the B&WOG MIRVSP, the staff found that the revised withdrawal schedules, as indicated in Report BAW-1543(NP), Revision 4, Supplement 5, are acceptable for the B&W-designed 177-FA plants and the Westinghouse-designed plants with B&W-fabricated reactor vessels. The proposed withdrawal schedules satisfy the ASTM Standard E 185-82 for all plants participating in the B&WOG MIRVSP except for Turkey Point Units 3 and 4. Turkey Point Units 3 and 4 satisfy the ASTM Standard E 185-66. Since this edition of the standard was current at the time the reactor vessels were purchased, the Turkey Point Units 3 and 4 surveillance capsule withdrawal schedules satisfy the requirements of Appendix H to 10 CFR Part 50. Also, it should be noted that the NRC previously approved an integrated surveillance program for Turkey Point Units 3 and 4.

The staff concluded that the proposed withdrawal schedules of BAW-1543(NP), Revision 4, Supplement 5, comply with Appendix H to 10 CFR Part 50. Therefore, the staff approves the revised withdrawal schedule for each of the plants included in the B&WOG MIRVSP.

5.0 REFERENCES

- 1. BAW-1543, Revision 4, Supplement 4, "Supplement to the Master Integrated Reactor Vessel Surveillance Program," April 2001.
- 2. NRC letter to A. Mendiola, from K. Wichman, NRC, "Safety Evaluation of BAW-1543, Master Integrated Reactor Vessel Surveillance Program, Revision 4, Supplement 4," July 31, 2001, ML012130374.
- 3. Code of Federal Regulations, Title 10, Part 50, Appendix H, "Reactor Vessel Material Surveillance Program Requirements."
- 4. American Society for Testing and Materials, "Recommended Practice for Surveillance Tests on Structural Materials in Nuclear Reactors," ASTM E 185-66.
- 5. American Society for Testing and Materials, "Recommended Practice for Surveillance Tests for Nuclear Reactor Vessels," ASTM E 185-70.
- American Society for Testing and Materials, "Standard Practice for Conducting Surveillance Tests for Light Water Cooled Nuclear Power Reactor Vessels," ASTM E 185-82.
- 7. NUREG-1511, Supplement 2, "Reactor Pressure Vessel Status Report," October 2000.

Principal Contributor: M. Khanna

Date: May 16, 2005

STATUS OF WESTINGHOUSE PLANT-SPECIFIC SURVEILLANCE CAPSULES

PLANT	CAPSULE ID	TARGET FLUENCE	STATUS	NOTES
POINT BEACH 1	N P R,S,T,V	4.5E19	STANDBY REMOVED TESTED	1 3
POINT BEACH 2	N P R,S,T,V W	5.0E19	STANDBY REMOVED TESTED SUPPL CAPSULE	1 3 2
SURRY 1	S U W Y Z T,V,X	3.9E19 3.0E19 4.3E19 5.2E19	STANDBY STANDBY TESTED STANDBY STANDBY TESTED	4 4 5 4 1
SURRY 2	V,X,Y S T U W Z	3.8E19 3.6E19 3.4E19	TESTED TESTED STANDBY STANDBY TESTED STANDBY	5 1 . 1 5 4
TURKEY POINT 3	S,T,V,X U,W,Y,Z		TESTED STANDBY	*
TURKEY POINT 4	S,T X U,V,W,Y,Z	3.85E19	TESTED STANDBY STANDBY	*

NOTES:

1. TO BE WITHDRAWN AND STORED

2. TO BE WITHDRAWN AND TESTED

4. WILL REMAIN FOR LIFE EXTENSION 5. DOSIMETRY

3. WITHDRAWN AND STORED

• During the Turkey Point license renewal review, the applicant stated that the standby capsules can be used to gather data on fluence, spectrum, temperature, and neutron flux during the license renewal period.

Attachment

PLANT	CAPSULE ID	TARGET FLUENCE	STATUS	NOTE
OCONEE 1	F,E,A,C B		TESTED REMOVED	1
OCONEE 2	C,A,E B,D,F TMI2-LG1 A5		TESTED REMOVED TESTED TESTED	1
OCONEE 3	A,B,D C,E L1 CR3-LG2		TESTED REMOVED TESTED TESTED	1
TMI 1	E, C, W1 [°] B,D,F CR3-LG1 TMI2-LG2		TESTED REMOVED TESTED TESTED	1
CRYSTAL RIVER 3	B,C,D,F A, E		TESTED REMOVED	1
ANO 1	E,B,A,C D, F		TESTED REMOVED	1
DAVIS-BESSE 1	F,B,A,D C, E		TESTED REMOVED	1

STATUS OF BABCOCK AND WILCOX PLANT-SPECIFIC (INTEGRATED) SURVEILLANCE CAPSULES

NOTE:

- 1. Capsule contains only base metal specimens, or weld data already exists at the expected/received capsule fluences or data is available at fluences greater than the expected/received capsule fluences, so will be disposed of in accordance with the March 17, 2000, letter from D.L. Howell to the USNRC Document Control Desk.
- Irradiated in Surry and subsequently tested.

PAGE NO LINE NOs.	PROPOSED CHANGE AND REASON	STAFF'S DISPOSITION
1 - 13	Add "participating" prior to the words 'Westinghouse plants." Not all Westinghouse plants having B&W fabricated reactor vessels participated in the program.	Accepted
1 - 14	Change "nine" to "six." As of April 10, 2001, the submittal date of Supplement 4 of BAW-1 543, Revision 4, there were six Westinghouse- designed plants with B&W fabricated reactor vessels participating in the program.	Accepted
1 - 16	Change "16" to "13" for accuracy (see above comments).	Accepted
1 - 17	Add "about" prior to "550 °F" for accuracy.	Accepted
1 - 25	Change "is being" to "was" for accuracy.	Accepted
2 - 17	Change "archive specimens" to "stored capsules" for clarification.	Accepted
3 - 11	Delete "and test." OC1-D was a standby capsule with no commitment for testing.	Accepted
3 - 18	Delete "and test." OC3-F was a standby capsule with no commitment for testing.	Accepted
3 - 21	Change "the B&WOG" to "NMC" for accuracy.	Accepted - NMC defined
4 - 11, 12, 14	Change "fourth" to "fifth" for accuracy.	Accepted
7 - 5, 6	Under the fifth column entitled "Notes," omit Note 3 for consistency. None of the other capsule irradiation locations are noted	Accepted
7 - 6	Under the second column entitled "Capsule ID," omit Capsule ID "F." This capsule was unable to be removed and is still in the reactor.	Accepted
7 - 7	Under the second column entitled "Capsule ID," Omit Capsule ID "A," or substitute with "W1."	Accepted - Note 2 also removed. W1 was irradiated in Surry.
7 - 17	Omit Note 3 for consistency.	Accepted

.

Duke Energy Corporation Entergy Operations, Inc. Progress Energy, Florida Oconee 1, 2, 3 ANO-1 Crystal River 3



 AmerGen Energy Company, LLC
 TMI-1

 FirstEnergy Nuclear Operating Company
 D-B

 Framatome ANP, Inc. (FANP)
 D-B

Working Together to Economically Provide Reliable and Safe Electrical Power

February 21, 2005 NRC:05:012 BWOG:05:1867

Document Control Desk U.S. Nuclear Regulatory Commission Washington D.C. 20555-0001

Comments on Draft Safety Evaluation for BAW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor Vessel Surveillance Program"

Ref. 1: Letter, Robert A. Gramm (NRC) to Jerald S. Holm (Framatome ANP), "Draft Safety Evaluation for Babcock and Wilcox Owners Group Topical Report BAW-1543(NP), Revision 4, Supplement 5, 'Supplement to the Master Integrated Reactor Vessel Surveillance Program' (TAC No. MC1762)," February 3, 2005.

The NRC issued a draft safety evaluation on BAW-1543(NP), Revision 4, Supplement 5, and requested that the B&WOG review for any factual errors or clarity concerns. On behalf of the B&WOG, Framatome ANP has reviewed the draft SER provided in Reference 1.

The SER contains minor errors and clarifications which we recommend correcting. A marked up copy of the pages in the draft SER containing the errors is provided in Attachment A. Attachment B provides a summary table of the minor clarifications.

On behalf of the B&WOG, Framatome appreciates this opportunity to offer clarifying comments.

Sincerely,

Yerold & Holm

Jerald S. Holm, Director Regulatory Affairs

enclosures

cc: D.G. Holland Project 693 Reactor Vessel Working Group

How K Rushl

Howard Crawford, Chairman B&W Owners Group Steering Committee

Framatome ANP, Inc. B&W Owners Group 3315 Old Forest Road Lynchburg, VA 24501 Phone: 434-832-3635 Fax: 434-832-4121 **Document Control Desk** February 21, 2005

NRC:05:012/BWOG:05:1867 Page A-1

Attachment A

FEB-03-2005 10:59

0.03/09

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

DRAFT SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

MASTER INTEGRATED REACTOR VESSEL SURVEILLANCE PROGRAM

TOPICAL REPORT BAW-1543, REVISION 4, SUPPLEMENT 5

t 1.0 INTHODUCTION

By letter dated December 19, 2003, the Babcock and Wilcox (B&W) Owners Group (B&WOG) 2 Reactor Vessel Working Group submitted, for NRC approval, topical report (TR) 3 8AW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor 4 Vessel Surveillance Program." The revisions contained in this supplement were necessary due 5 6 to a commitment not being met in Supplement 4, because capsules OC1-D and OC3-F could not be removed from Crystal River Unit 3. 7

8 BACKGROUND **2.**0

a

10 11 12

13 14

15 16

17

18 19

21

23

28

PARTICIPATING

By letter dated April 10, 2001, the B&WOG submitted, for staff approval, report BAW-1543, Revision 4, Supplement 4, "Supplement to the Master Integrated Reactor Vessel Surveillance Program." BAW-1543, Revision 4, reported the essential features of the master integrated reactor vessel surveillance program (MIRVSP) for all operating B&W 177-fuel assembly (FA) plants and those Westinghouse plants having B&W-fabricated reactor vessels. These reactor vessels include seven B&W-designed 177- FA plants and wire Westinghouse-designed plants with B&W-fabricated reactor vessels. The program was built upon the integrated surveillance program developed by the B&WOG for the B&W 177-FA plants. All tegratectors are of the same basic design concept: pressurized water reactor, operating at 550 *F and 2250 psi nominal iniet temperature and pressure, and with low enrichment fuel (approximately 2% to 4% enrichment). ABOUT.

20 The Irradiation schedules for the B&WOG MIRVSP include the plant-specific capsules for the B&W- and Westinghouse-designed vessels, and the supplementary weld metal surveillance 22 capsules and higher fluence supplementary weld metal surveillance capsules. All the intacliations, with the exception of Capsule W1 and the Westinghnuss plant-specific capsules, are performed in the B&W host reactors, Crystal River Unit 3 and Davis-Besse. Capsule W1, an imadiation capsule of the Westinghouse-design, is being imadiated in Suny Unit 2. The Westinghouse plant-specific capsules are irrediated in their respective plants. An updated list of the status of the Westinghouse and B&W plant-specific/integrated surveillance capsules is provided in Attachment 1.

29 The staff evaluated the B&WOG's basis for the integrated program concept. The criterion as 30 provided by Appendix H to10 CFR Part S0, "Reactor Vessel Material Surveillance Program

13

14

15

16

17 18

19

20 21 - 2 -

Requirements," were met; therefore, the staff determined the MIRVSP to be acceptable. By 1 lotter dated June 11, 1991, BAW-1543, Revision S, was approved by the NRC. The staff noted 2 3 that the discussions of BAW-1543, Revision 4, were essentially the same as those found in BAW-1543, Revision 3, except for an update of some of the units' withdrawal schedules, 4 BAW-1543, Revision 4, Supplement 1, contained quantitative information which was, in 5 general, fluence dependent and, therefore, subject to change. This revision reflected revised 6 7 fluence values for some units and revised some withdrawel schedules to comply with American Society for Testing and Materials (ASTM) Standard E 185-73, "Standard Recommended 8 Practice for Surveillance Tests for Nuclear Reactor Vessels." It was anticipated that future 8 revisions to BAW-1543 would only involve the Revision 4 Supplement. BAW-1543, Revision 4, 10 Supplement 2, reflected the revised fluence values and the revised withdrawei schedules, and, 11 therefore, replaced BAW-1543, Revision 4, Supplement 1. 12

The BAWOG later revised and replaced Supplement 2 of Revision 4 of the subject report with Supplement 3. In Supplement 9, the B&WOG deleted Rancho Saco, R.E. Ginna, and Zion Units 1 and 2 from the program. In addition, the B&WOG updated the capsule status and the peak end-of-license fluences for several plants. In Supplement 4, the B&WOG incorporated the disposal plan for archive specimene, updated the status for various capsules, and incorporated current fluence levels. The B&WOG submitted Supplement 5 because the last supplement included a commitment regarding Capaules OC1-D and OC3-F; however, that commitment could not be met because these capsules could not be removed from Crystal Hiver Unit 3. STOLED CAPEULES

22 3.0 EVALUATION

Appendix H to 10 CFR Part 50 Includes criteria to monitor changes in the fracture toughness 23 proparties of ferritic materials in the reactor vessel beltline region of light-water nuclear power 24 25 reactors which result from exposure of these materials to neutron irradiation and the thermal 26 27 environment, Appendix H to 10 CFR Part 50 endorses ASTM E 185-73. Appendix H states that "juhe design of the surveillance program and the withdrawal schedule must meet the 28 requirements of the edition of ASTM E 185 that is current on the issue date of the ASME [American Society of Mechanical Engineers] Code [Boiler and Pressure Vessel Code] to which 29 30 the reactor vessel was purchased. Later editions of ASTM E 165 may be used, but including 31 only those editions through 1982."

32 ASTM E 185-82, "Standard Practice for Conducting Surveillance Tests for Light Water Cooled 33 Nuclear Power Reactor Vessels" and ASTM E 185-66, "Recommended Practice for 34 Surveillance Tests on Structural Materials in Nuclear Reactors" cover procedures for monitoring 35 the radiation-induced changes in the mechanical properties of territic materials in the beltline of 36 light-water cooled nuclear power reactor vessels. These practices include guidelines for 37 designing a minimum surveillance program, selecting materials, and evaluating test results.

38 The staff evaluated the withdrawal schedule for each of the B&W and Westinghouse 39 plant-specific reactor vessel surveillance programs, as provided in BAW-1543(NP), Revision 4,

- Supplement 5, and determined that the withdrawal schedules were prepared in accordance with 40 41 ASTM E 185-82 for each of the subject units except for Turkey Point Units 3 and 4. Additional
- 42 details of the staffs assessment are provided below. It should be noted that this evaluation will

8 9

10

11

12

13

14

15

16

17

18

19

20

21 22 23 - 0 -

focus on the staff's review of the B&WOG's revised withdrawal schedules, as provided in
 BAW-1543 (NP), Revision 4, Supplement 5.

As stated previously, capsules OC1-D and OC3-F could not be removed; therefore, credit for
 these two capsules could no longer be taken for Oconee Unit 1 and Oconee Unit 3,
 respectively. The staff independently reviewed the surveillance capsule withdrawal schedules
 for Oconee Unit 1 and Oconee Unit 3, to ansure that the subject units' surveillance capsule
 program would still comply with the requirements of ASTM E 185-82.

The staff found that the capsule withdrawal schedule for Oconee Unit 1 adequately met the requirements of ASTM E 195-82, in that four capsules have been withdrawn and tested, and the last capsule that was tested, OC1-C, had a fluence of 1 to 2 times the end-of-life fluence. Therefore, the staff determined that the inability to withdraw and test capsule OC1-D had no impact on the ability of the Oconee Unit 1 surveillance capsule program to meet the Appendix H requirements.

The staff found that the capsule withdrawal schedule for Oconee Unit 3 adequately met the requirements of ASTM E 185-82, in that three capsules have been tasted and an additional capsule, capsule CH3-LG2, which contains the limiting bettine material for Oconee Unit 3 (heat number 72442), was tasted and had a fluence of 1 to 2 times the end-of-life fluence for Oconee Unit 3. Therefore, the staff determined that the inability to withdraw.aad-test capsule OC3-F had no impact on the ability of the Oconee Unit 3 surveitiance capsule program to meet the Appendix H requirements.

The staff noted that the BAWOG added a supplemental capsule, to be removed and tested, to the Point Beach Unit 2 surveillance program. Also, the B&WOG updated the status of capsules Y and X of Surry Unit 2 and Turkey Point Unit 3, respectively, to indicate that they had been tested. The staff found that these revisions were enhancements or updates to the program and are, therefore, acceptable to the staff.

tasted. The staff found that these revisions were enhancements or updates to the program and
are, therefore, acceptable to the staff.
On May 26, 2004, the staff requested that the 8&WOG remove or address the relevance of the
statement, "The owners of plants that have been granted license renewal have made no
commitments to test or use information from the capsules that continue to be irradisted under
the MIRVSP," because truere applicants may wish to take predit for information obtained from
the MIRVSP, as opposed to using plant-specific information in order to meet the requirements
of 10 CFR Part 50, Appendix H. By lefter dated July 7, 2004, the B&WOG indicated that the
statement will be removed upon issuance of the approved version of BAW-1543, Revision 4,
Supplement 5. The staff found this acceptable.

35 The staff determined that the withdrawal schedules for Ocones Unit 2, Three Mile Island Unit 1 38 (TMI-1), Crystal River Unit 3, Arkansas Nuclear One Unit 1, Davis-Besse, Point Beach Unit 2, 37 Surry Unit 1, Turkey Point Unit 4, as provided in Tables VI and VII of BAW-1543(NP), Revision 38 4, Supplement 5, did not change from Supplement 4 and, therefore, still comply with the 39 requirements of ASTM E 185-82, as stated in the staff's safety evaluation dated July 31, 2001. 40 However, the staff noted that the information in Table VIII, of the subject topical report, did not 41 accurately list the capsules to be withdrawn and tested for Oconee Units 1, 2 and 3, and TMI-1.

Document Control Desk February 21, 2005

1

2

3

4

5

6

7

NRC:05:012/BWOG:05:1867 Page A-4

The B&WOG listed capsules for these subject plants that were no longer going to be withdrawn and tested, i.e., Capsule OC1-D for Oconee Unit 1, Capsule OC2-F for Oconee Unit 2, Capsule OC3-F for Oconee Unit 3, and Capsules F and D for TMI-1.

During a conference call that was held on November 23, 2004, the staff discussed this issue with the B&WOG, who indicated that it would revise Table VIII of the report to accurately list the capaules that were going to replace those that were no longer going to be withdrawn and tested. The staff noted that the withdrawal schedule for Oconee Unit 1 already met the requirements of ASTM E185-82; however, the table still needed revision, because the capsules listed were not correct. The B&WOG indicated that Oconee Unit 2's limiting material is costained in Capsule A5 (which was irradiated in Davis Besse), which was tested and satisfied the fourth capsule requirement of ASTM E185-82 for Oconee Unit 2. For Oconee Unit 3, the limiting material is contained in Capsule CR3-LG2, which was tested and satisfied the fourth capsule requirement of ASTM E185-82 for Oconee Unit 3. And for TMI-1 the limiting material is contained in Capsule TMI2-LG2, which was tested and satisfied the fourth capsule requirement of ASTM E185-82.

By supplemental letter dated January 5, 2005, the B&WOG revised Table VIII to the BAW-1543(NP), Revision 4, Supplement 5 report. The staff found that the revised table accurately listed the withdrawal schedules for Oconee Units 1, 2, and 3, and TMI-1. As stated above, the staff found that each of these plants met the capsule withdrawal schedule requirements of ASTM E185-82, even though the original capsules were not going to be withdrawn and tested for Oconee Units 2 and 3 and TMI-1, because there are other capsules in the MIRVSP that contain the same limiting material for the subject plants that will be withdrawn and tested, and, therefore, will satisfy the requirements of ASTM E185-82.

the MIRVSP that contain the same limiting material for the subject plants that will be withdrawn and tested, and, therefore, will satisfy the requirements of ASTM E185-82.
Turkey Point Units 3 and 4 were prepared in accordance with ASTM E 185-86. The Turkey Point Units 3 and 4 reactor vessels were purchased to the Summer 1968 Addenda to the 1965 ASME Code. ASTM E 185-66 was the surveillance capsule standard in effect at the time the Turkey Point Units 3 and 4 reactor vessels were purchased. Since the Turkey Point Units 3 and 4 capsule withdrawal schedules meet the ASTM E 185 edition that was ourrent at the time the reactor vessels were purchased, the withdrawal schedules meet the requirements of Appendix H to 10 CFR Part 50.

32 It should also be noted that, by letter dated February 8, 1985, a safety evaluation report (SER) 33 was submitted to Florida Power & Light Company, which indicated that the NRC approved an 34 integrated aurvailance program for Turkey Point Units 3 and 4. The SER indicated that the 35 only capsules to be tested at Turkey Point Units 3 and 4. In accordance with ASTM E 185 36 requirements, are those that contain weld metal specimens.

37 4.0 <u>CONCLUSIÓN</u> 38

Based on the staff's review of the B&WOG MIRVSP, the staff found that the revised withdrawal
 schedules, as indicated in Report BAW-1543(NP), Revision 4, Supplement 5, are acceptable
 for the B&W-designed 177-FA plants and the Westinghouse-designed plants with B&W fabricated reactor vessels. The proposed withdrawal schedules satisfy the ASTM E 185-82
 Standard for all plants participating in the B&WOG MIRVSP except for Turkey Point Units 3 and
 Turkey Point Units 3 and 4 satisfy the ASTM E 185-66 Standard. Since this edition of the

Document Control Desk February 21, 2005

1

standard was current at the time the reactor vessels were purchased, the Turkey Point Units 3 and 4 surveillance capsule withdrawal schedules satisfy the requirements of Appendix H to 2 3 10 CFR Part 50. Also, it should be noted that the NRC previously approved an integrated ž surveillance program for Turkey Point Units 3 and 4.

The statif concluded that the proposed withdrawal schedules of BAW-1543(NP), Revision 4, 5 Supplement 5, comply with Appendix H to 10 CFR Part 50. Therefore, the staff approves the 6 revised withdrawal schedule for each of the plants included in the B&WOG MIRVSP. 7

8 REFERENCES 5.0

- BAW-1543, Revision 4, Supplement 4, "Supplement to the Master Integrated Reactor 9 1. Vessel Surveillance Program," April 2001. 10
- NRC letter to A. Mendiola, from K. Wichman, NRC, "Safety Evaluation of BAW-1543, 2. 11 Mester Integrated Reactor Vessel Surveillance Program, Revision 4, Supplement 4, 12 13 July 31, 2001.
- Code of Federal Regulations, Title 10, Part 50, Appendix H, "Reactor Vessel Material 14 3. 15 Surveillance Program Requirements."
- American Society for Testing and Materials, 'Recommanded Practice for Surveillance 16 4. Tests on Structural Materials in Nuclear Reactors," ASTM E 185-66. 17
- American Society for Testing and Materials, "Recommended Practice for Surveillance 18 5. Tests for Nuclear Reactor Vassels," ASTM E 185-70. 19
- American Society for Testing and Materials, "Standard Practice for Conducting 20 6. Surveillance Tests for Light Water Cooled Nuclear Power Reactor Vessels,* 21 22 ASTM E 185-82.
- NUREG-1511, Supplement 2, "Reactor Pressure Vessel Status Report," October 2000. 23 7.

1

2	PLANT	CAPSULE ID	TARGET FLUENCE	STATUS	NOTES
3	POINT BEACH 1	N P R,S,T,V	4.5E19	STANDBY REMOVED TESTED	1 3
4	POINT BEACH 2	N P R,S,T,V W	5.0E19	STANDBY REMOVED TESTED SUPPL CAPSULE	1 9 2
5	SURRY 1	\$ U W	3.9E19 3.0E19	STANDBY STANDBY TESTED STANDBY	4 4 5
		z T,V,X	4.3E19 6.2E19	STANDBY STANDBY TESTED	-• 1
6	SURRY 2	VXY S T U W	3.8E19 3.6E19	TESTED TESTED STANDBY STANDBY TESTED	5 1 1 5
7	TURKEY POINT 3	۲ 5,T,V,X U,W,Y,Z	24E18	TESTED STANDBY	
8	TURKEY POINT 4	S,T X U,V,W,Y,Z	3.85E19	TESTED STANDBY STANDBY	•

STATUS OF WESTINGHOUSE PLANT-SPECIFIC SURVEILLANCE CAPSULES

9

10

NOTES: 1. TO BE WITHDRAWN AND STORED 2. TO BE WITHDRAWN AND TESTED 3. WITHDRAWN AND STORED 4. WILL REMAIN FOR LIFE EXTENSION 5. DOSIMETRY 3. WITHDRAWN AND STORED

11 12

13

 During the Turkey Point license renewal review, the applicant stated that the standby capsules can be used to gather data on fluence, spectrum, temperature, and neutron flux during the license renewal period. 14 15

Attachment 7

1 2

3	PLANT	CAPSULE ID	TARGET FLUENCE	STATUS	NOTES
4	OCONEE 1	F,E,A,C B		TESTED REMOVED	1
5	OCONEE 2	C,A,E B,D,F TM12-LG1 A5		TESTED REMOVED TESTED TESTED	۱ کار
	OCONEE 3	A,B,D, C,E,F L1 CR3-LG2		TESTED REMOVED TESTED TESTED	1 ,8
7	TMI 1	E, C B,D,F _A~ CR3-LG1 TMI2-LG2		TESTED REMOVED NOT TESTED TESTED TESTED	1 2
8	CRYSTAL RIVER 3	B,C,D,F A, E		TESTED REMOVED	1
9	ANO 1	E,B,A,C D, F		TESTED REMOVED	1
10	DAVIS-BESSE 1	F,B,A,D C, E		TESTED REMOVED	1

STATUS OF BABCOCK AND WILCOX PLANT-SPECIFIC (INTEGRATED) SURVEILLANCE CAPSULES

11 NOTES:

12

13 14 15

1.

Capsule contains only base metal speciment, or weld data already exists at the expected/received capsule fluences or data is available at fluences greater than the expected/received capsule fluences, so will be disposed of in accordance with the March 17, 2000, letter from D.L. Howell to the USNRC Document Control Desk.

16 2. Withdrawn and Stored

- 17 3. ---- Irradiated in Davis Beese-----

Attachment B

SUMMARY TABLE OF PROPOSED CHANGES

PAGE NO.	LINE(S) NO.	PROPOSED CHANGE AND REASON
1	13	Add "participating" prior to the words "Westinghouse plants." Not all Westinghouse plants having B&W- fabricated reactor vessels participated in the program.
1	14	Change "nine" to "six." As of April 10, 2001, the submittal date of Supplement 4 of BAW-1543, Revision 4, there were six Westinghouse-designed plants with B&W-fabricated reactor vessels participating in the program.
1	16	Change "16" to "13" for accuracy (see above comments).
1	17	Add "about" prior to "550°F" for accuracy.
1	25	Change "is being" to "was" for accuracy.
2	17	Change "archive specimens" to "stored capsules" for clarification.
3	11	Delete "and test." OC1-D was a standby capsule with no commitment for testing.
3	18	Delete "and test." OC3-F was a standby capsule with no commitment for testing.
3	21	Change "the B&WOG" to "NMC" for accuracy.
4	11, 12, 14	Change "fourth" to "fifth" for accuracy.
7	5, 6	Under the fifth column entitled "Notes," omit note 3 for consistency. None of the other capsule irradiation locations are noted.
7	6	Under the second column entitled "Capsule ID," omit Capsule ID "F." This capsule was unable to be removed and is still in the reactor.
7	7	Under the second column entitled "Capsule ID," Omit Capsule ID "A," or substitute with "W1."
7	17	Omit note 3 for consistency.

 Duke Energy Company
 Oconee 1, 2, 3

 Entergy Operations, Inc.
 ANO-1

 Florida Power Corporation
 Crystal River 3

AmerGen Energy Company, LLC TMI-1
FirstEnergy Nuclear Operating Company D-B
Framatome ANP

Working Together to Economically Provide Reliable and Safe Electrical Power

January 5, 2005 OG :05:1859 NRC:05:001

Document Control Desk U.S. Nuclear Regulatory Commission Washington, D.C. 20555-0001

Supporting Materials for Review of BAW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor Vessel Surveillance Program"

- Ref.: 1. Letter, James F. Mallay (Framatome ANP), to Document Control Desk (NRC), "Request for Review and Approval of BAW-1543(NP), Revision 4, Supplement 5, 'Supplement to the Master Integrated Reactor Vessel Surveillance Program'," OG:03:1838, NRC:03:091, December 19, 2003.
- Ref.: 2. Letter, James F. Mallay (Framatome ANP) to Document Control Desk (NRC), "Response to RAI on BAW-1543(NP), Revision 4, Supplement 5, 'Supplement to the Master Integrated Reactor Vessel Surveillance Program'," OG:04:1847, NRC:04:030, July 7, 2004.
- Ref.: 3. Letter, James F. Mallay (Framatome ANP) to Document Control Desk (NRC), "Supporting Materials for Review of BAW-1543(NP), Revision 4, Supplement 5, 'Supplement to the Master Integrated Reactor Vessel Surveillance Program'," OG:04:1855, NRC:04:068, November 30, 2004.

On behalf of the B&W Owners Group Reactor Vessel Working Group, Framatome ANP (FANP) requested the NRC's review and approval for referencing in licensing actions the topical report BAW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor Vessel Surveillance Program," (Reference 1). Our response to a Request for Additional Information was provided in Reference 2. A supplemental request for clarification of the contents of Table VIII of the report was discussed in a telephone call on November 23, 2004 (Reference 3). A second request for further clarification of the contents of Table VIII was discussed in a telephone call on December 1, 2004, between Mr. Brian Hall of FANP and Ms. Meena Khanna of the NRC.

Framatome ANP, Inc. B&W Owners Group 3315 Old Forest Road Lynchburg, VA 24501 Phone: 434-832-3635 Fax: 434-832-4121 Document Control Desk January 5, 2004

.

.!

NRC:05:001/OG:05:1859 Page 2

Attachment I provides a revised Table VIII that clarifies how Oconee Unit 2, Oconee Unit 3 and TMI are meeting the minimum number of capsules to be withdrawn and tested in accordance with ASTM E185-82. This table completely replaces the table submitted in Reference 3.

We would appreciate your timely review.

Very truly yours,

Jeeold & Holm

Jerald S. Holm, Director Regulatory Affairs

Enclosure

cc: D. G. Holland B&WOG Reactor Vessel Working Group Project 693

Attachment 1

Comparison of the Plant-Specific Surveillance Capsules with ASTM E 185 Requirements

Table VIII. Comparison of the Plant-Specific Surveillance Capsules with ASTM E 185 Requirements

		ASTM E 185-82 5 Capsule Program Requirement				
Plant	1.5 EFPY or Fluence > 5E18 △RT _{NDT} ≈ 50°F	3 EFPY or Fluence Midway Between First and Third Capsule	6 EFPY or T/4 EOL Fluence	15 EFPY or 1S EOL Fluence	EOL or 1-2 Times EOL Fluence (Capsule may be held w/o testing)	
Oconee-1 Oconee-2 Oconee-3 TMI-1 Crystal River-3 ANO-1 Davis-Besse Point Beach-1 Point Beach-2 Surry-1 Surry-2 Turdee: Boint 2	F-I/T C-I/T A-I/T E-I/T B-I/T E-I/T F-I/T V-I/T V-I/T X-I/T	(a) A-I/T B-I/T W1/T (a) (a) (a) S-I/T T-I/T W-I/T ^(b) W-I/T ^(b)	E-1/T TMI2-LG1/T L1/T CR3-LG1/T C-1/T B-1/T B-1/T T-1/T R-1/T V-1/T V-1/T	A-I/T E-I/T D-I/T C-I/T D-I/T A-I/T D-I/T R-I/T X-I/T Y-I/T Y-I/T	C-I/T A5/T CR3-LG2/T TMI2-LG2/T F-I/T C-I/T A-I/T P-I/NT P-I/NT S,U-R S-I/T ^(b) ;T-R	
Turkey Point-3	T-1/T	S-I/T	X-R	V-R	U,W-R	

Legend: I/T = Irradiated and tested

I/NT = Irradiated and not tested

R = In reactor

^(a) Only 4 capsules required per ASTM E185-82.

^(b) Only dosimetry evaluated.

Duke Energy Company	Oconee 1, 2, 3) (\frown	AmerGen Energy Company, LLC	TMI-1
Entergy Operations, Inc.	ANO-1	The B&W		FirstEnergy Nuclear Operating Company	D-B
Florida Power Corporation	Crystal River 3	Owner	s Group	Framatome ANP	

Working Together to Economically Provide Reliable and Safe Electrical Power

November 30, 2004 NRC:04:068 OG:04:1855

Document Control Desk U.S. Nuclear Regulatory Commission Washington, D.C. 20555-0001

Supporting Materials for Review of BAW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor Vessel Surveillance Program"

- Ref.: 1. Letter, James F. Mallay (Framatome ANP) to Document Control Desk (NRC), "Request for Review and Approval of BAW-1543(NP), Revision 4, Supplement 5, 'Supplement to the Master Integrated Reactor Vessel Surveillance Program'," OG:03:1838, NRC:03:091, December 19, 2003.
- Ref.: 2. Letter, James F. Mallay (Framatome ANP) to Document Control Desk (NRC), "Response to RAI on BAW-1543(NP), Revision 4, Supplement 5, 'Supplement to the Master Integrated Reactor Vessel Surveillance Program'," OG:04:1847, NRC:04:030, July 7, 2004.

On behalf of the B&W Owners Group Reactor Vessel Working Group, Framatome ANP requested the NRC's review and approval for referencing in licensing actions the topical report BAW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor Vessel Surveillance Program," (Reference 1). Our response to a Request for Additional Information was provided in Reference 2. A supplemental request for clarification of the contents of Table VIII of the report was discussed in a telephone call on November 23, 2004.

Attachment 1 provides a revised Table VIII that clarifies how Oconee Unit 2, Oconee Unit 3 and TMI are meeting the minimum number of capsules to be withdrawn and tested in accordance with ASTM E185-82. This table completely replaces the table submitted in Reference 1.

We will appreciate your timely review.

Very truly yours,

James F. Mallay, Director Regulatory Affairs

cc: D. G. Holland B&WOG Reactor Working Vessel Group Project 693

> Framatome ANP B&W Owners Group 3315 Old Forest Road Lynchburg, VA 24501 Phone: 434-832-2981 Fax: 434-832-4121

Attachment 1

	ASTM E 185-82 5 Capsule Program Requirement					
Plant	1.5 EFPY or Fluence > 5E18 △RT _{NDT} ≈ 50°F	3 EFPY or Fluence Midway Between First and Third Capsule	6 EFPY or T/4 EOL Fluence	15 EFPY or IS EOL Fluence	EOL or 1-2 Times EOL Fluence (Capsule may be held w/o testing)	
Oconee-1	E-I/T	F-I/T	A_1/T	C-I/T	BJAIT	
Oconee-2	C-1/T	A-1/T	TMI2-LG1/T	E-I/T	A5/T	
Oconce-3	A-1/T	B-I/ T	L1/T	D-I/T	CR3-LG2/T	
TMI-1	E-I/T	W1/T	CR3-LG1/T	C-I/T	TMI2-LG2/T	
Crystal River-3	B-1/T	C-I/T	D-1/T	F-I/T	A-I/NT	
ANO-1	E-I/T	B-I/T	A-I/T	C-I/T	D-I/NT	
Davis-Besse	F-1/T	B-I/T	A-I/T	D-1/T	C-I/NT	
Point Beach-1	V-I/T	S-I/T	T-1/T	R-1/T	P-I/NT	
Point Beach-2	V-I/T	T-I/T	R-1/T	S-1/T	P-I/NT	
Surry-1	Т-1/Т	W-I/T*	V-I/T	X-I/T	S,U-R	
Surry-2	X-I/T	₩-I/T*	V-I/T	Y-I/T	S-I/T*;T-R	
Turkey Point-3	T-I/T	V-I/T	S-I/T	X-I/T	U,W-R	
Turkey Point-4	T-I/T	S-I/T	X-R	V-R	U,W-R	

Table VIII. Comparison of the Plant-Specific Surveillance Capsules with ASTM E 185 Requirements

Legend: I/T = Irradiated and tested

I/NT = Irradiated and not tested

 $\mathbf{R} =$ In reactor

* Only dosimetry evaluated.



Working Together to Economically Provide Reliable and Safe Electrical Power

July 7, 2004 NRC:04:030 OG:04:1847

Document Control Desk U.S. Nuclear Regulatory Commission Washington, D.C. 20555-0001

Response to RAI on BAW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor Vessel Surveillance Program"

- Ref.: 1. Letter, James F. Mallay (Framatome ANP), to Document Control Desk (NRC), "Request for Review and Approval of BAW-1543(NP), Revision 4, Supplement 5, 'Supplement to the Master Integrated Reactor Vessel Surveillance Program'," OG:03:01838, NRC:03:091, December 19, 2003.
- Ref.: 2. Memo, Drew Holland (NRC), to James F. Mallay (Framatome ANP), "Request for Additional Information Regarding Topical Report BAW-1543," May 26, 2004.

On behalf of the B&W Owners Group Reactor Vessel Working Group, Framatome ANP requested the NRC's review and approval for referencing in licensing actions the topical report BAW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor Vessel Surveillance Program." In Reference 2, the NRC requested additional information to facilitate the completion of its review. The response to this request, which is non-proprietary, is contained in the attachment to this letter.

Very truly yours,

ment

James F. Mallay, Director Regulatory Affairs

Enclosure

cc: D. G. Holland B&WOG Reactor Vessel Working Group Project 693

> Framatome ANP B&W Owners Group 3315 Old Forest Road Lynchburg, VA 24501 Phone: 434-832-2981 Fax: 434-832-2475

Document Control Desk July 7, 2004

Attachment A

Response to RAI related to BAW-1543, Revision 4, Supplement 5

I. Appendix H to Title 10 of the Code of Federal Regulations Part 50 (Appendix H to 10 CFR Part 50), Paragraph III.C, "Requirements for an Integrated Surveillance Program" allows licensees with plants that have similar design and operating features to implement an integrated surveillance program with the approval of the Director of the Office of Nuclear Reactor Regulation. The Babcock and Wilcox (B&W) MIRVP was established in 1977 to provide a basis for sharing information between B&W designed and fabricated plants. In 1988, the MIRVP was expanded to include Westinghouse designed plants with B&W fabricated reactor vessels. In the introduction of BAW-1543, Revision 4, Supplement 5 (page 2) the licensee states that the Westinghousedesigned, B&W reactor vessel fabricated plant surveillance capsule withdrawal schedules are not MIRVP commitments, but merely reflect the current plans of these reactor vessel working group member plants.

Question 1. If the Westinghouse designed plants' withdrawal schedules are not commitments, explain how each plant that participates in the MIRVP meets Appendix H requirements for an integrated surveillance program.

Response 1. The Westinghouse designed plants (Point Beach 1 & 2, Surry 1 & 2, and Turkey Point 3 & 4) have their own surveillance programs that meet the requirements of 10CFR50 Appendix H. The Westinghouse plant owners participate in the MIRVP in order to share and use the limiting Linde 80 weld information generated in the MIRVP. However, in the Point Beach license renewal application (currently under review) Nuclear Management Company commits to using data from MIRVP capsules currently being irradiated.

Question 2. Explain how the MIRVP is incorporated into each individual plant's licensing basis (i.e. is the surveillance capsule withdrawal schedule in the Technical Specifications or the final safety analysis report?).

Response 2. The Turkey Point 3 & 4 UFSAR states that when the two MIRVP capsules that contain the SA-1101 weld (the same heat contained Turkey Point 3 & 4) are tested, the data will be evaluated and considered as appropriate. The Surry 1 & 2 UFSAR states that their withdrawal schedule is consistent with the guidelines of the MIRVP. The Point Beach 1 & 2 UFSAR cites the MIRVP as a supplement to the Point Beach 1 & 2 plant specific surveillance programs.

The B&W designed units (Oconee 1, 2, & 3, Arkansas Nuclear One 1, Davis-Besse, Crystal River 3, and Three Mile Island 1) meet 10CFR50 Appendix H through the MIRVP as documented in their respective UFSARs. In addition, the MIRVP is cited in the Arkansas Nuclear One 1 and the Oconee 1, 2, & 3 license renewal application and SERs in the Reactor Vessel Integrity Section. Also, the owners of some of the B&W designed plants cite the MIRVP in their Reactor Coolant System Pressure/Temperature Limit Sections of their Technical Specifications.

Question 3. Due to recent reviews of license renewal applications, the staff has identified the need for license conditions with regard to reactor vessel surveillance programs for the period of extended operation. This license condition specifies that applicants will be required to submit any changes to surveillance capsule withdrawal schedules to the NRC for review and approval during the period of extended operation. For clarity, the staff requests that the applicant remove the following statement on page 3 of BAW-1543, Revision 4, Supplement 5: "The owners of plants that have been granted license renewal have made no commitments to test or use information from the capsules that continue to be irradiated under the MIRVP." Future applicants may wish to take credit for information obtained from the MIRVP as opposed to using plant specific information in order to meet the requirements of Appendix H to 10 CFR Part 50. If you conclude that the statement is relevant and should be maintained in the topical report, provide justification for this conclusion.

Response 3. The statement will be removed upon issuance of the approved version of BAW-1543 Revision 4, Supplement 5.

Duke Energy Company Entergy Operations, Inc. Florida Power Corporation Oconee 1, 2, 3 ANO-1 Crystal River 3



TM⊩1 D-B

Working Together to Economically Provide Reliable and Safe Electrical Power

December 19, 2003 OG:03:1838 NRC:03:091

Document Control Desk ATTN: Chief, Planning, Program and Management Support Branch U.S. Nuclear Regulatory Commission Washington, D.C. 20555-0001

Request for Review and Approval of BAW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor Vessel Surveillance Program"

Ref.: 1. Letter, James F. Mallay (Framatome ANP) to Document Control Desk (NRC), "Removal of Surveillance Capsules at Crystal River, Unit 3," NRC:03:071, October 22, 2003.

On behalf of the B&W Owners Group Reactor Vessel Working Group, Framatome ANP requests the NRC's review and approval for referencing in licensing actions the topical report BAW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor Vessel Surveillance Program."

This supplement addresses the capsules contained in the Crystal River Unit 3 holder tube position that could not be removed and disposed of as described in Reference 1. These two capsules are standby capsules and are not required to fulfill the commitments in the reactor vessel surveillance program. Also, they are not relied on as part of any license renewal action. The requirements of 10CFR50 Appendix H have already been met using other capsules in the B&WOG Master Integrated Reactor Vessel Surveillance Program.

A CD is enclosed that contains a non-proprietary copy of BAW-1543(NP), Revision 4, Supplement 5.

We will appreciate your timely review.

Very truly yours,

ames Manay Ism

James F. Mallay, Director **Regulatory Affairs**

Enclosures

cc: J. W. Foster D. G. Holland Project 693

> Framatome ANP B&W Owners Group 3315 Old Forest Road Lynchburg, VA 24501 Phone: 434-832-3635 Fax: 434-832-4121

BAW-1543, Revision 4, Supplement 5 December 2003

SUPPLEMENT TO THE MASTER INTEGRATED REACTOR VESSEL SURVEILLANCE PROGRAM

by

J. B. Hall

B&W Document No. 43-1543S-08 (See Section 2 for document signatures)

Prepared for

B&W Owners Group Reactor Vessel Working Group Dominion Generation Duke Energy Corporation Entergy Operations, Inc. Exelon Corporation FirstEnergy Nuclear Operating Company Florida Power Corporation Florida Power & Light Company Nuclear Management Company

Prepared by

Framatome ANP, Inc. 3315 Old Forest Road P. O. Box 10935 Lynchburg, Virginia 24506-0935



SUMMARY

The Master Integrated Reactor Vessel Surveillance Program (MIRVP) was initiated in 1977 for the B&W 177-FA Plants. Its purpose was to augment the existing reactor vessel surveillance programs and to provide a basis for sharing information between plants. All of the early vintage B&W manufactured reactor vessels were fabricated using the submerged arc welding process and particular consumables which resulted in welds that are sensitive to fast neutron exposures. The welds in these early vintage B&W manufactured reactor vessels are referred to as the Linde 80 class of materials. In 1988, the MIRVP was further modified to include a series of plants with the Westinghouse Nuclear Steam Supply System (NSSS) for which B&W manufactured the reactor vessels. These vessels have virtually identical welds as were used in the B&W 177-FA plants. The overall objective of the MIRVP is to provide the data necessary to assure compliance with Federal Regulations.^(a) Individual B&W Owners Group Reactor Vessel Working Group members may cite this document, as needed, in support of their reactor vessel surveillance program, which must meet the requirements of 10 CFR 50 Appendix H.

This document is a supplement to the base document, "Master Integrated Reactor Vessel Surveillance Program," BAW-1543.^(b) Both the base document and the current supplement are used to document the progress of the MIRVP, especially the withdrawal schedule of the RVSP capsules. The last full revision to the base document reviewed and approved by the NRC is Revision 4.^(c) This document is being revised due to a commitment made by the B&W Owners Group to the U.S. Nuclear Regulatory Commission when the OC1-D and OC3-F capsules could not be removed from Crystal River Unit 3.^(d) The last supplement to this document reviewed and approved by the NRC is BAW-1543A, Revision 4, Supplement 4.^(c)

^(e) Nuclear Regulatory Commission Safety Evaluation Report, "Safety Evaluation for BAW-1543, Revision 4, Supplement 4, "Supplement to the Master Integrated Reactor Vessel Surveillance Program," (TAC No. MB1859), October 19, 2001.



^(a) Title 10, Code of Federal Regulations, Part 50, "Domestic Licensing of Production and Utilization Facilities", Vol. II, U.S. Nuclear Regulatory Commission, Washington, D.C.

^(b) L.S. Harbison, "Master Integrated Reactor Vessel Surveillance Program," <u>BAW-1543, Revision 4</u>, B&W Nuclear Technologies, Inc., Lynchburg, Virginia, February 1993.

^(c) Nuclear Regulatory Commission Safety Evaluation Report, "Babcock & Wilcox Owners Group (B&WOG) Reactor Vessel Working Group Report," BAW-1543, Revision 4, Supplement 2, "Supplement to the Master Integrated Reactor Vessel Surveillance Program" (TAC No. M98089), July 11, 1997.

^(d) James F. Mallay, Regulatory Affairs, B&W Owners Group to Document Control Desk, Chief, Planning, Program and Management Support Branch, "Removal of Surveillance Capsules at Crystal River, Unit 3," OG:03:1837; NRC:03:071, Project No. 693, October 22, 2003.

SUMMARY OF REVISIONS

Section	Description
Summary	Updated to reflect current revision.
Section 1	Included revision statement for Supplement 5 changes. References to changes made in Supplement 4 were deleted. The last sentence on page 3 was deleted.
Table II	Added Point Beach Unit 2 Supplemental Capsule. Updated status of Turkey Point Unit 3 Capsule X and Surry Unit 2 Capsule Y.
Table III	Changed "End of Thirteenth Fuel Cycle" to "Withdrawal Not Planned" for capsules OC1-D and OC3-F. Updated status of capsules slated for disposal.
Table IV	Updated status of capsules.
Table V	Added Point Beach Unit 2 Supplemental Capsule. Updated status of Turkey Point Unit 3 Capsule X and Surry Unit 2 Capsule Y. Corrected Surry Unit 2 Capsule Y final capsule location.
Table VI	Changed Time of Removal from "End of Cycle 13" to "Not Planned" for capsules OC1-D and OC3-F. Changed status of capsule DB1-LG2 to "Testing in progress" from "will be disposed." Fluence was revised for TMI1-C.
Table VII	Added Point Beach Unit 2 Supplemental Capsule. Updated status of Turkey Point Unit 3 Capsule X and Surry Unit 2 Capsule Y.
Table VIII	Updated status of Turkey Point Unit 3 Capsule X and Surry Unit 2 Capsule Y. Removed standby capsule column and changed capsules for the B&W designed plants to show compliance with ASTM E185 using only tested capsules.
Table IX	Updated license expiration dates and Peak EOL fluence values to reflect license renewal approvals.



CONTENTS

Page 1

1.0	Introduction	.2
2.0	Certification	.23
3.0	References	.24

LIST OF TABLES

<u>Table</u>	<u>P</u>	age
Table I.	B&W 177-FA Plant-Specific Reactor Vessel Surveillance Program - Detailed Summary	4
Table II.	Westinghouse Plant-Specific Reactor Vessel Surveillance Program – Detailed Summary	6
Table III.	Capsule Insertion and Withdrawal Schedule for Crystal River Unit 3	8
Table IV.	Capsule Insertion and Withdrawal Schedule for Davis-Besse	11
Table V.	Capsule Insertion and Withdrawal Schedule for the Westinghouse Plant-Specific RVSPs	14
Table VI.	Summary Status of the B&W Surveillance Capsules	.16
Table VII.	Summary Status of the Westinghouse Surveillance Capsules	19
Table VIII.	Comparison of the Plant-Specific Surveillance Capsules with ASTM E 185 Requirements	21
Table IX.	Peak End-of-Life Inside Surface Fluences and Significant Licensing Dates	22



1.0 INTRODUCTION

The B&W Owners Group (B&WOG) document, BAW-1543, Revision 4, reports the essential features of a Master Integrated Reactor Vessel Surveillance Program (MIRVP) for all operating B&W 177-FA plants and those Westinghouse-designed plants having B&W-fabricated reactor vessels.⁽¹⁾ This supplementary document to BAW-1543, Revision 4, contains surveillance capsule insertion and withdrawal schedules for the B&W 177-FA plants and the Westinghouse-designed plants participating in the B&WOG Reactor Vessel Working Group (RVWG). In addition, the insertion and withdrawal schedules for the B&WOG supplementary capsules are provided. This document, Supplement 5, is a revision to and replaces Supplement 4 in its entirety.

Table I and Table II are listings of plant-specific surveillance capsules and directs the reader to the appendices of BAW-1543, Revision 4, where additional information can be found on material and capsule specifications. These tables also provide a listing of surveillance capsule reports. Table I provides information for the B&W plant-specific capsules and Table II provides information for the Westinghouse plant-specific capsules. Table II was revised by updating the status of capsule TP3-X and adding the Point Beach Unit 2 supplemental capsule.

Table III and Table IV provide capsule insertion and withdrawal schedules for B&W host plants Crystal River Unit 3 and Davis-Besse, respectively. Table III was revised by changing the withdrawal time of capsules OC1-D and OC3-F.

Table V provides capsule insertion and withdrawal schedules for the Westinghouse-designed plants participating in the RVWG. The Westinghouse-designed plant withdrawal schedules listed in Table V are not MIRVP commitments, but merely reflect the current plan of these RVWG member plants. Table V was revised by updating the status of capsule TP3-X and adding the Point Beach Unit 2 supplemental capsule.

Table VI and Table VII summarize the status of all MIRVP capsules for B&W and Westinghousedesigned plants, respectively. These tables state whether the capsules have been withdrawn or are still being irradiated. For capsules that have been withdrawn and tested, the appropriate surveillance capsule report number has been listed. For those capsules that are being irradiated, the target and expected fluences are listed along with the insertion and/or withdrawal date. The Westinghousedesigned plant withdrawal schedules listed in Table VII are not MIRVP commitments, but merely reflect the current plan of these RVWG member plants. Table VI was revised by changing the withdrawal time for capsules OC1-D and OC3-F. Table VII was revised by updating the status of capsule TP3-X and adding the Point Beach Unit 2 supplemental capsule.



Table VIII shows the conformance of the RVWG member plant-specific surveillance programs to the requirements of ASTM E 185-82.⁽⁴⁾ Table VIII was revised by updating the status of capsule TP3-X.

Table IX lists licensing dates and anticipated reactor vessel peak end-of-life fluences. License expiration dates and Peak EOL fluence values were updated to reflect license renewal approvals.



Table I.	B&W 1	1 77-FA	Plant-Specific	Reactor	Vessel
Su	rveillanc	e Prog	ram - Detailed	Summar	y

Capsule	Туре	Table of Material Specifications ^(a)	Table of Capsule Specifications ^(b)	Irradiation Site	Report Date	Report			
Oconee U Topical R	Oconee Unit 1 Topical Report BAW-10006A, Revision 3 ⁽⁵⁾								
A	Ι	A-1	D-1	OC1/CR3	Aug. 84	BAW-1837 ⁽⁶⁾			
B	II	A-1	D-1	OC1/CR3					
C	I	A-1	D-1	OC1/CR3	Oct. 88	BAW-2050 ⁽⁷⁾			
	II T	A-l	D-1	OC1/CR3					
		A-I	D-I	OCI	Sept. 77	BAW-1436 ⁽³⁾			
		A-1	D-1	OCI	Sept. 75	BAW-1421, Rev. 1 ⁽⁷⁾			
Oconee U Topical R	Init 2 eport BA	W-10006A, Revisio	on 3						
A	Ι	A-2	D-2	OC2/CR3	Dec. 81	BAW-1699 ⁽¹⁰⁾			
В	II	A-2	D-2	OC2/CR3					
C	I	A-2	D-2	OC2	May 77	BAW-1437 ⁽¹¹⁾			
D	II	A-2	D-2	OC2/CR3					
E	I	A-2	D-2	OC2/CR3	Oct. 88	BAW-2051 ⁽¹²⁾			
F	II	A-2	D-2	OC2/CR3					
Oconee U Topical R	Init 3 eport BA	W-10100A ^{(c)(13)}							
A	V	A-3	D-3	OC3	Jul. 77	BAW-1438 ⁽¹⁴⁾			
В	VI	A-3	D-3	OC3/CR3	Oct. 81	BAW-1697 ⁽¹⁵⁾			
C	V	A-3	D-3	OC3/CR3					
D	VI	A-3	D-3	OC3/CR3	May 92	BAW-2128, Rev. 1 ⁽¹⁶⁾			
E	V	A-3	D-3	OC3/CR3					
F	VI	A-3	D-3	OC3/CR3					
Three Mil Topical R	Three Mile Island Unit 1 Topical Report BAW-10006A, Revision 3								
A	Ι	A-4	D-4	TMI1/TMI2	(d)	BAW-2042 ⁽¹⁷⁾			
В	II	A-4	D-4	TMI1/CR3					
С	I	A-4	D-4	TMI1/CR3	Mar. 86	BAW-1901 ⁽¹⁸⁾			
D	п	A-4	D-4	TMI1/CR3					
E	I	A-4	D-4	TMI1	Jan. 77	BAW-1439 ⁽¹⁹⁾			
F	II	A-4	D-4	TMI1/CR3					

(a) Refer to BAW-1543, Revision 4, Appendix A.

^(b) Refer to BAW-1543, Revision 4, Appendix D.

^(c) The Oconee Unit 3 capsules were fabricated before BAW-10100A was published; however, it is the Oconee Unit 3 program that is described in BAW-10100A.
 ^(d) Capsule used for Three Mile Island Unit 2 capsule requalification.



Capsule	Туре	Table of Material Specifications ^(a)	Table of Capsule Specifications ^(b)	Irradiation Site	Report Date	Report			
Crystal Ri Topical R	Crystal River Unit 3 Topical Report BAW-10100A								
Α	III	A-5	D-5	CR3					
В	IV	A-5	D-5	CR3	Jun. 82	BAW-1679, Rev. 1 ⁽²⁰⁾			
					Mar. 82	BAW-1718 ⁽²¹⁾			
C	III	A-5	D-5	CR3	Mar. 86	BAW-1898 ⁽²²⁾			
D	IV	A-5	D-5	CR3	Mar. 86	BAW-1899 ⁽²³⁾			
					Apr. 86	BAW-1914 ⁽²⁴⁾			
Е	III	A-5	D-5	CR3					
F	IV	A-5	D-5	CR3	Sept. 88	BAW-2049 ⁽²⁵⁾			
					Oct. 93	BAW-2172 ⁽²⁶⁾			
Arkansas Topical R A B C D E F	Nuclear (eport BA I II I II II II	Dne Unit 1 W-10006A, Revisio A-6 A-6 A-6 A-6 A-6 A-6 A-6	D-6 D-6 D-6 D-6 D-6 D-6 D-6	ANO1/DB1 ANO1/DB1 ANO1/DB1 ANO1/DB1 ANO1 ANO1/DB1	Jul. 84 Nov. 81 Oct. 89 Apr. 77 	BAW-1836 ⁽²⁷⁾ BAW-1698 ⁽²⁸⁾ BAW-2075, Rev. 1 ⁽²⁹⁾ BAW-1440 ⁽³⁰⁾			
Davis-Bes Topical R	sse eport BA	W-10100A							
A	III	A-8	D-8	DB1	Jun. 89	BAW-1882, Rev. 1 ⁽³¹⁾			
В	IV	A-8	D-8	DB1	May 84	BAW-1834 ⁽³²⁾			
					Jun. 85	BAW-1867 ⁽³³⁾			
C	III	A-8	D-8	DB1					
D	IV	A-8	D-8	DB1	Dec. 90	BAW-2125 ⁽³⁴⁾			
					Oct. 93	BAW-2208 ⁽³⁵⁾			
Е	III	A-8	D-8	DB1					
F	IV	A-8	D-8	DB1	Jan. 82	BAW-1701 ⁽³⁶⁾			
					Mar. 82	BAW-1719 ⁽³⁷⁾			

Table I (cont'd).B&W 177-FA Plant-Specific Reactor VesselSurveillance Program - Detailed Summary

(a) Refer to BAW-1543, Revision 4, Appendix A.

^(b) Refer to BAW-1543, Revision 4, Appendix D.



Capsule	Туре	Table of Material Specifications ^(a)	Table of Capsule Specifications ^(b)	Report Date	Report				
Point Beach U WCAP-7513 ⁽¹⁾	Point Beach Unit 1 WCAP-7513 ⁽³⁸⁾								
N	IV	A-10	D-10						
Р	IV	A-10	D-10						
R	III	A-10	D-10	Aug. 78	WCAP-9357 ⁽³⁹⁾				
S	1V	A-10	D-10	Nov. 76	WCAP-8739 ⁽⁴⁰⁾				
T	III	A-10	D-10	Dec. 84	WCAP-10736 ⁽⁴¹⁾				
V	III	A-10	D-10	Jun. 73	BCL Report ⁽⁴²⁾				
Point Beach U WCAP-7712 ^{(*}	Jnit 2 43)								
N	IV	A-11	D-11						
Р	IV	A-11	D-11						
R	V	A-11	D-11	Dec. 79	WCAP-9635 ⁽⁴⁴⁾				
S	v	A-11	D-11	Aug. 91	BAW-2140 ⁽⁴⁵⁾				
Т	IV	A-11	D-11	Aug. 78	WCAP-9331 ⁽⁴⁶⁾				
v	V	A-11	D-11	Jun. 75	BCL Report ⁽⁴⁷⁾				
Suppl.	Suppl.	(c)	(c)	Jan. 03	ATI -021-030-2003-1 ⁽⁷⁶⁾				
Surry Unit 1 WCAP-7723 ⁽⁴	48)								
S	VI	A-12	D-12						
T	VII	A-12	D-12	Jun. 75	BCL Report ⁽⁴⁹⁾				
U	VI	A-12	D-12						
V	VII	A-12	D-12	Feb. 87	WCAP-11415 ⁽⁵⁰⁾				
W	VI	A-12	D-12	Mar. 79	BCL-585-8R ⁽⁵¹⁾				
X	VII	A-12	D-12	Apr. 98	BAW-2324 ⁽⁵²⁾				
Y	VI	A-12	D-12						
Z	VII	A-12	D-12						

Table II. Westinghouse Plant-Specific Reactor Vessel Surveillance Program - Detailed Summary

^(a) Refer to BAW-1543, Revision 4, Appendix A.

^(b) Refer to BAW-1543, Revision 4, Appendix D.
 ^(c) This Westinghouse designed capsule contains Charpy, compact fracture toughness and tensile specimens fabricated from Linde 80 welds SA-1101 (Heat 71249), WF-67 (Heat 72442), and WF-182-1 (Heat 821T44).



Capsule	Туре	Table of Material Specifications ^(a)	Table of Capsule Specifications ^(b)	Report Date	Report				
Surry Unit 2 WCAP-8085 ⁽²	Surry Unit 2 WCAP-8085 ⁽⁵³⁾								
S	VIII	A-13	D-13	Dec. 96	WCAP-14810 ⁽⁵⁴⁾				
Т	VIII	A-13	D-13						
U	VIII	A-13	D-13						
V	VIII	A-13	D-13	Jun. 87	WCAP-11499 ⁽⁵⁵⁾				
W	VIII	A-13	D-13	Feb. 81	BCL-585-026 ⁽⁵⁶⁾				
X	VIII	A-13	D-13	Sept. 75	BCL Report ⁽⁵⁷⁾				
Y	IX	A-13	D-13	Feb. 03	WCAP-16001 ⁽⁷⁹⁾				
Z	IX	A-13	D-13						
Turkey Point WCAP-7656 ⁽²	Unit 3 58)								
S	VI	A-14	D-14	May 79	SwRI-02-5131 ⁽⁵⁹⁾				
Т	VII	A-14	D-14	Dec. 75	WCAP-8631 ⁽⁶⁰⁾				
U	VI	A-14	D-14						
V	VII	A-14	D-14	Aug. 86	SwRI-06-8575 ⁽⁶¹⁾				
W	VI	A-14	D-14						
X	VII	A-14	D-14	Sept. 02	WCAP-15916 ⁽⁷⁵⁾				
Y	VI	A-14	D-14						
Z	Vl	A-14	D-14						
Turkey Point WCAP-7660 ^(t)	Turkey Point Unit 4 WCAP-7660 ⁽⁶²⁾								
S	VI	A-15	D-15	May 79	SwRI-02-5380 ⁽⁵⁹⁾				
T	VII	A-15	D-15	Jun. 76	SwRI-02-4221 ⁽⁶³⁾				
U	VI	A-15	D-15						
V	VII	A-15	D-15						
W	VI	A-15	D-15						
X	VII	A-15	D-15						
Y	VI	A-15	D-15						
<u>Z</u>	VI	A-15	D-15						

Table II (cont'd). Westinghouse Plant-Specific Reactor Vessel Surveillance Program - Detailed Summary

^(a) Refer to BAW-1543, Revision 4, Appendix A.

^(b) Refer to BAW-1543, Revision 4, Appendix D.



Holder Tube	Location in Holder Tube	Insert	Withdraw	Capsule Status ^(a)			
Installed a	t Initial Fuel Load						
XW XW	Top Bottom	CR3-B (WC ^(b)) CR3-D (WC)					
End of Fir	st Fuel Cycle (1A)						
WZ WZ ZY	Top Bottom Top	CR3-LG1 (WC) CR3-LG2 (WC) CR3-C (W ^(c))					
ZY YZ YZ	Bottom Top Bottom	CR3-A (W) OC2-A (W) OC1-A (W)					
YX YX XW WX WX	Top Bottom Top Top Bottom	OC2-E (W) OC3-D (W) CR3-E (W) OC3-B (W) CR3-F (WC)	CR3-B (WC)	Tested			
End of Fir	st Fuel Cycle (1B) No changes.						
End of Se	cond Fuel Cycle						
YZ WX	Тор Тор	OC1-C (W) TMI1-C (W)	OC2-A (W) OC3-B (W)	Tested Tested			
End of Th	End of Third Fuel Cycle						
End of Fo	urth Fuel Cycle						
YZ WZ WZ	Bottom Top Bottom	OC1-B None None	OC1-A (W) CR3-LG1 (WC) CR3-LG2 (WC) (WZ now empty)	Tested Tested Tested			

Table III. Capsule Insertion and Withdrawal Schedulefor Crystal River Unit 3



End of Fithb Fuel CycleWX WW WZ WZ BottomTOP TMI1-BCR3-D (WC) CR3-C (W) CR3-D (WC)Tested Tested Tested CR3-D (WC) CR3-C (W) NoneTested Tested Tested Tested TestedWZ WZ WZ WZTop BottomCC2-B (WZ no longer empty)NoneTested TestedTop WX Top TM2-DIGCC2-B (WZ no longer empty)NoneTestedFind of Sixth Fuel CycleTM12-DIG (MZ no longer empty)OC2-E (W) CC3-E (WC) OC1-C (W)Tested Tested Tested Tested Tested Tested Tested Tested YZTop YZ SottomTM12-DIG (M2-LG1 (WC) OC1-C (W)OC1-C (W) Tested Tested Tested Tested Tested Tested Tested Tested Tested Tested TM12-LG2 (WC)TM11-B Tested Tes	Holder Tube	Location in Holder Tube	Insert	Withdraw	Capsule Status ^(a)
$\begin{array}{c c c c c c c c c c c c c c c c c c c $	End of Fit	th Fuel Cycle			
XW ZYBottom TopTM11-B OC3-F (W)CR3-D (WC) CR3-C (W)Tested TestedWZ WZTop 	WX	Тор	OC3-C (W)	TMI1-C (W)	Tested
ZY WZTop Top BottomOC3-F (W) OC2-B CR3-LG2 (WC) (WZ no longer empty)CR3-C (W) NoneTestedWZBottomCR3-LG2 (WC) (WZ no longer empty)NoneNoneFuel CycleTM12-D(d) ZOC2-E (W) CR3-F (WC)Tested TestedYZTopTM12-D(d) TM12-LG1 (WC)OC1-C (W) OC1-C (W)Tested TestedYZBottomTM12-D(d) from YX top A2 (WC)TM11-B TM12-D(d) to XW bottom OC3-D (W)1YXTopA2 (WC) OC3-E (W)CC3-D (W) CC3-B1End of EighthFuel CycleTM12-D(d) TopTested TestedZYBottomOC1-D NoneCR3-A (W) CC3-B (W)2ZYBottomOC1-D NoneCR3-A (W) CC3-B (W)2ZYBottomNone NoneTM12-D(d) TM12-D(d) TestedZWBottomNone TM12-D(d)CR3-A (W) C2XWBottomNoneCR3-A (W) C2-B2XWBottomNoneTM12-D(d) C CXWBottomNoneCR3-A (W) C2-F2XWBottomTM11-D1End of EighthTupTupTestedYZTopOC2-FCR3-LG2 (WC)TestedYZTopOC2-DTM12-D(d)CR3-LG2 (WC)TestedYWBottomTM12-D(d)CC3-LG2 (WC)TestedYZTopOC2-DTM12-LG1 (WC) CR3-LG2 (WC)<	XW	Bottom	TMI1-B	CR3-D (WC)	Tested
WZ WZTop BottomOC2-B CR3-LG2 (WC) (WZ no longer empty)NoneEnd of Sixtle Fuel Cycle(WZ no longer empty)NoneYXTop MXTMI2-DIGI POPOC2-E (W) CR3-F (WC)Tested TestedYZTop TopTMI2-LG1 (WC) TMI2-LG1 (WC)OC1-C (W) OC1-D OC1-DTested TMI2-DIGI to XW bottom OC3-D (W)Tested TestedYXTop Top A2 (WC)TMI1-B TMI2-DIGI from YX top OC3-E (W)TMI1-B TMI2-DIGI to XW bottom OC3-D (W)1 T TestedYXTop BottomA2 (WC) OC3-E (W)CR3-A (W) CC3-B2 1End of EightFuel CycleCR3-A (W) TMI2-DIGI2 TopZYBottom BottomOC1-D None NoneCR3-A (W) CC3-B (W)2 2 2 1ZYBottom BottomOC2-F NoneOC3-C (W) CC3-C (W) 2 2 12 2 2 2 2 2 2 2 2 2 2 2 3 <td>ZY</td> <td>Тор</td> <td>OC3-F (W)</td> <td>CR3-C (W)</td> <td>Tested</td>	ZY	Тор	OC3-F (W)	CR3-C (W)	Tested
WZBottomCR3-LG2 (WC) (WZ no longer empty)NoneEnd of SixthFuel CycleYXTopTMI2-D ^(d) OC2-E (W)TestedYXBottomTMI1-FCR3-F (WC)TestedYZTopTMI2-LG1 (WC)OC1-C (W)TestedYZBottomTMI2-LG2 (WC)OC1-B1End of Sventh Fuel CycleTMI2-D ^(d) from YX topTMI2-D ^(d) to XW bottom1YXTopA2 (WC)OC3-D (W)TestedYXBottomA4 (WC)OC3-D (W)TestedYXBottomOC1-DCR3-A (W)2YXTopOC3-E (W)OC2-B1End of EighthFuel CycleTM12-D ^(d) to XW bottomYXBottomOC1-DCR3-A (W)2XWBottomOC1-DCR3-C (W)2XWTopNoneCR3-E (W)2XWBottomNoneTM12-D ^(d) XWBottomNoneTM12-D ^(d) XWBottomNoneTM12-D ^(d) XWBottomTopOC2-F2XWBottomTM12-D ^(d) Tm12-LG1 (WC)TestedYZTopOC2-DTM12-LG1 (WC)TestedYZTopOC2-DTM12-LG1 (WC)TestedYZTopOC2-DTM12-LG1 (WC)TestedYZBottomTM12-D ^(d) CR3-LG2 (WC)TestedYZTopOC2-DTM12-D(WX (WZ	Тор	OC2-B	None	
Image: Constraint of the second se	WZ	Bottom	CR3-LG2 (WC)	None	
End of Six Fuel CycleYXTopTMI2-D(d)OC2-E (W)TestedYZTopTMI2-LG1 (WC)OC1-C (W)TestedYZTopTMI2-LG2 (WC)OC1-B1End of Summer Kuel CycleXWBottomTMI2-D(d) from YX topTMI1-B1YXTopA2 (WC)TMI2-D(d) fo XW bottomYXBottomA4 (WC)OC3-D (W)TestedYXBottomA4 (WC)OC3-D (W)TestedYZBottomOC3-E (W)OC3-B1End of Eight Fuel CycleTopOC3-E (W)2XWBottomOC1-DCR3-A (W)2XWTopNoneCR3-A (W)2XWTopOC2-FOC3-C (W)2WXTopOC2-FOC3-C (W)2WXTopOC2-DTMI2-D(d)TestedYZTopOC2-DTMI2-D(G)TestedWXTopOC2-DTMI2-LG1 (WC)TestedWXTopOC2-DTMI2-D(d)TestedWXTopOC2-DTMI2-D(d)TestedWZBottomTMI2-D(d)TestedTestedWXTopOC2-DTMI2-LG1 (WC)TestedWXTopOC2-DTMI2-LG1 (WC)TestedWXBottomTMI2-D(d)CR3-LG2 (WC)TestedWXSottomTopNoneOC2-F2WXBottomNoneOC2-F		<u> </u>	(WZ no longer empty)		
YXTopTMI2-D(d)OC2-E (W)TestedWXBottomTMI1-FCR3-F (WC)TestedYZTopTMI2-LG1 (WC)OC1-C (W)TestedYZBottomTMI2-LG2 (WC)OC1-B1End of Seventh Fuel CycleTMI2-D(d) from YX topTMI1-B1YXTopA2 (WC)TMI2-D(d) to XW bottomYXBottomA4 (WC)OC3-D (W)TestedWZTopOC3-E (W)OC2-B1End of Eiverth Fuel CycleCR3-A (W)2XWBottomOC1-DCR3-A (W)2XWTopNoneCR3-E (W)2XWBottomOC1-DCR3-A (W)2XWTopOC2-FOC3-C (W)2XWBottomTM1-DTM1-F1End of NoneTM1-DTM1-F1End of Teuth Fuel CycleTopOC2-FC3-C (W)YZTopOC2-DTM12-D(d)YZTopOC2-DTM12-LG1 (WC)TestedWZBottomTM12-D(d)CR3-LG2 (WC)TestedEnd of Teuth Fuel CycleTopC2-DTM12-LG1 (WC)TestedWXTopNoneOC2-F2WXBottomNoneC2-F2WXBottomNoneC2-F2WXBottomNoneC2-F2WXBottomNoneMU2-LG1 (WX now empty)2	End of Siz	th Fuel Cycle			
WX YZBottom TopTMI1-F TM12-LG1 (WC)CR3-F (WC) OC1-C (W)Tested Tested TestedYZTopTM12-LG1 (WC)OC1-C (W)OC1-C (W)End of Seventh Fuel CycleVOC1-B1XWBottomTM12-D ^(d) from YX top A2 (WC)TM11-B TM12-D ^(d) to XW bottom1YXTopA2 (WC)TM12-D ^(d) to XW bottom OC3-D (W)YXBottomA4 (WC)OC3-D (W)TestedWZTopOC3-E (W)OC2-B1End of Eighth Fuel CycleCR3-A (W)2ZYBottomOC1-DCR3-A (W)2XWTopNoneTM12-D ^(d) XWBottomOC2-FOC3-C (W)2XWTopOC2-FOC3-C (W)2WXTopOC2-DTM12-LG1 (WC) CR3-LG2 (WC)TestedWXTopOC2-DTM12-LG1 (WC) CR3-LG2 (WC)TestedEnd of Tenth Fuel CycleYZTopOC2-DTM12-LG1 (WC) CR3-LG2 (WC)TestedEnd of Tenth Fuel CycleWXBottomTM12-D ^(d) C2-F2WXTopNoneOC2-F2WXTopNoneOC2-F2WXBottomNoneOC2-F2WXBottomNoneOC2-F2WXBottomNoneOC2-F2WXBottomNone </td <td>YX</td> <td>Тор</td> <td>TMI2-D^(d)</td> <td>OC2-E (W)</td> <td>Tested</td>	YX	Тор	TMI2-D ^(d)	OC2-E (W)	Tested
YZ YZTop BottomTMI2-LG1 (WC) TMI2-LG2 (WC)OC1-C (W) OC1-BTested 1End of Seventh Fuel CycleTM12-D(a) from YX top TopTM11-B A2 (WC)TM12-D(a) to XW bottom OC3-D (W)1YXBottomTM12-D(a) from YX top A2 (WC)TM12-D(a) to XW bottom OC3-D (W)1YXBottomA4 (WC)OC3-D (W)TestedWZTopOC3-E (W)OC2-B1End of Eighth Fuel CycleCR3-A (W) Z2ZYBottomOC1-DCR3-A (W) Z2XWTopNoneTM12-D(a) Z (XW now empty)WXTopOC2-FOC3-C (W)2WXTopOC2-D TM12-DTM1-F1End of Nimth Fuel CycleTested ZTestedYZTopOC2-D TM12-D(a)TM12-LG1 (WC) CR3-LG2 (WC)Tested TestedEnd of Term Fuel CycleWXTopNoneCC2-FZWXBottomTM12-D(a) CR3-LG2 (WC)Tested TestedEnd of Term Fuel CycleZWXTopNoneCC2-F2WXTopNoneCC2-F2WXBottomNoneCC2-F2WXTopNoneCC2-F2WXBottomNoneCC2-F2WXBottomNoneCC2-F2WXBottomNoneCC2-F2WX	WX	Bottom	TMI1-F	CR3-F (WC)	Tested
YZBottomTMl2-LG2 (WC)OC1-B1End of Sevent Fuel CycleTMl2-D ^(d) from YX topTMl1-B1YXBottomA2 (WC)TMl2-D ^(d) to XW bottomYXBottomA4 (WC)OC3-D (W)TestedWZTopOC3-E (W)OC2-B1End of Eiger Karlen Ka	YZ	Тор	TMI2-LG1 (WC)	OC1-C (W)	Tested
End of Seventh Fuel CycleXWBottomTMI2-D ^(d) from YX topTMI1-B1YXTopA2 (WC)TMI2-D ^(d) to XW bottomYXBottomA4 (WC)OC3-D (W)TestedWZTopOC3-E (W)OC2-B1End of Eigen CycleZYBottomOC1-DCR3-A (W)2XWTopNoneCR3-E (W)2XWTopNoneCR3-E (W)2XWBottomNoneCR3-E (W)2XWBottomNoneCR3-E (W)2XWBottomNoneCR3-E (W)2XWTopOC2-FOC3-C (W)2WXTopOC2-FOC3-C (W)2WXBottomTMI1-DTMI1-F1End of Viewel SectorYZTopOC2-DTMI2-LG1 (WC)TestedWZBottomTM12-D ^(d) CR3-LG2 (WC)TestedEnd of Tube CycleWXTopNoneWXTopNoneMOREOC2-F2WXTopNoneOC2-F2WXTopNoneOC2-F2WXTopNoneOC2-F22WXBottomNoneOC2-F22WXBottomNoneOC2-F22WXBottomNoneOC2-F2<	YZ	Bottom	TMI2-LG2 (WC)	OC1-B	1
XWBottomTMI2-D(d) from YX topTMI1-B1YXTopA2 (WC)TMI2-D(d) to XW bottomYXBottomA4 (WC)OC3-D (W)TestedWZTopOC3-E (W)OC2-B1End of Eight Fuel CycleZYBottomOC1-DCR3-A (W)2XWTopNoneCR3-E (W)2XWTopNoneTMI2-D(d)2XWBottomOC2-FOC3-C (W)2XWTopOC2-FOC3-C (W)2XXTopOC2-FOC3-C (W)2WXTopOC2-DTMI1-F1End of Nint Fuel CycleYZTopOC2-DTMI2-LG1 (WC)TestedYZTopOC2-DTMI2-LG1 (WC)TestedWZBottomTMI2-D(d)CR3-LG2 (WC)TestedEnd of The LycleWXTopNoneWXTopNoneWXTopNoneMXTopNone2WXTopNone2WXTopNone2WXTopNone2WXTop2NONEOC2-F2YZTopNone2WXTopNone2WXTopNone2	End of Se	venth Fuel Cycle		·	
YXTop BottomA2 (WC) A4 (WC)TMI2-D(d) to XW bottom OC3-D (W) TestedYXBottomA4 (WC)OC3-D (W)TestedWZTopOC3-E (W)OC2-B1End of Eigentautor (Colspan="4">Colspan="4"Colspan	XW	Bottom	TMI2-D ^(d) from YX top	TMI1-B	1
YXBottomA4 (WC)OC3-D (W)TestedWZTopOC3-E (W)OC2-B1End of Eighth Fuel CycleZYBottomOC1-DCR3-A (W)2XWTopNoneCR3-E (W)2XWBottomNoneTMI2-D ^(d) XWBottomNoneTMI2-D ^(d) WXTopOC2-FOC3-C (W)2WXBottomTM11-DTM11-F1End of NirrerYZTopOC2-DTM12-LG1 (WC)TestedWZBottomTM12-D ^(d) CR3-LG2 (WC)TestedEnd of EigenEnd of EigenSoftomTOPNoneCR3-LG2 (WC)TestedEnd of EigenWXTopNoneOC2-F2WXTopNoneOC2-F2WXTopNoneTM11-D22WXBottomNoneTM11-D22	YX	Тор	A2 (WC)	TMI2-D ^(d) to XW bottom	
WZTopOC3-E (W)OC2-B1End of Eight Fuel CycleZZYBottomOC1-DCR3-A (W)2XWTopNoneCR3-E (W)2XWBottomNoneTMI2-D ^(d) XWBottomOC2-FOC3-C (W)2WXTopOC2-FOC3-C (W)2WXBottomTMI1-DTMI1-F1End of Nith Fuel CycleYZTopOC2-DTMI2-LG1 (WC)TestedWZBottomTM12-D ^(d) CR3-LG2 (WC)TestedEnd of Eight Fuel CycleEnd of Eight Fuel CycleWXTopNoneOC2-F2WXTopNoneOC2-F2WXTopNoneTM11-D2WXBottomNoneTM11-D2	YX	Bottom	A4 (WC)	OC3-D (W)	Tested
End of Eisht Fuel CycleZYBottomOC1-DCR3-A (W)2XWTopNoneCR3-E (W)2XWBottomNoneTM12-D ^(d) WXTopOC2-FOC3-C (W)2WXBottomTM11-DTM11-F1End of Ninter Fuel CycleYZTopOC2-DTM12-LG1 (WC)TestedWZBottomTM12-D ^(d) CR3-LG2 (WC)TestedEnd of Tui2-bEnd of Tui2-bTM12-D(M)TestedWXTopNoneCC2-F2WXTopNoneOC2-F2WXTopNoneOC2-F2WXTopNoneOC2-F22WXBottomNoneTM11-D22WXBottomNoneTM11-D22	WZ	Тор	OC3-E (W)	OC2-B	1
ZY XWBottom Top NoneOC1-D NoneCR3-A (W) CR3-E (W) TM12-D(d)2XWBottomNoneTM12-D(d) (XW now empty) (XW now empty)WXTop BottomOC2-F TM11-DOC3-C (W) TM11-F2WXBottomTM11-DTM11-F1End of Nith Fuel CycleYZTop BottomOC2-D TM12-D(d)TM12-LG1 (WC) CR3-LG2 (WC)Tested TestedEnd of Tenth Fuel CycleEnd of Tenth Fuel CycleWXTop BottomNoneOC2-F TM12-D(d)2WXTop BottomNoneOC2-F TM11-D2WXTop BottomNoneTM11-D TM11-D2WXBottomNoneTM11-D TM11-D2	End of Ei	ghth Fuel Cycle			
XW XWTop BottomNoneCR3-E (W) TMI2-D(d)2 (XW now empty)WXTop BottomOC2-F TMI1-DOC3-C (W) TMI1-F2WXBottomTMI1-DTMI1-F1End of N WZTop BottomOC2-D TMI2-D(d)TMI2-LG1 (WC) Tested CR3-LG2 (WC)Tested TestedEnd of T WZEnd of T TM2-D(d)TMI2-D(d)Tested TestedEnd of T TM2-D(d)TMI2-D(d)Tested TestedEnd of TTM12-D(d)Tested TestedEnd of TTM12-D(d)Tested TestedWXTop BottomNoneOC2-F2 TM11-D2WXTop BottomNoneTM11-D22WXBottomNoneTM11-D22	ZY	Bottom	OC1-D	CR3-A (W)	2
XWBottomNoneTMI2-D(d) (XW now empty)WXTopOC2-FOC3-C (W)2WXBottomTMI1-DTMI1-F1End of Nirrer1YZTopOC2-DWZBottomOC2-DTMI2-LG1 (WC)TestedWZBottomTM12-D(d)CR3-LG2 (WC)TestedEnd of TerrerEnd of TerrerEnd of Eleventh Fuel CycleWXTopNoneOC2-F2WXTopNoneWXTopNoneOC2-F2WXBottomNoneTM11-D2WXBottomNoneCWX now empty)2	XW	Тор	None	CR3-E(W)	2
WX WXTop BottomOC2-F TMI1-D(XW now empty) OC3-C (W) TMI1-F2 1End of N-I YZTop BottomOC2-D TMI2-DG1 (WC)Tested Tested TestedYZTop BottomOC2-D TMI2-DG4TMI2-LG1 (WC) CR3-LG2 (WC)Tested TestedEnd of T-I VFuel CycleIEnd of Testel CycleEnd of E-I WXTop NoneNone OC2-FWXTop BottomNoneMXTop BottomNoneC2-F TMI1-D 2 (WX now empty)	XW	Bottom	None	TMI2-D ^(d)	
WXTopOC2-FOC3-C (W)2WXBottomTMI1-DTMI1-F1End of Ninth Fuel CycleYZTopOC2-DTMI2-LG1 (WC)TestedWZBottomTMI2-D ^(d) CR3-LG2 (WC)TestedEnd of Tenth Fuel CycleEnd of Einth Fuel CycleWXTopNoneOC2-F2WXTopNoneOC2-F2WXBottomNoneTMI1-D2WXBottomNoneTMI1-D2				(XW now empty)	
WXBottomTMI1-DTMI1-F1End of Ninth Fuel CycleYZTopOC2-DTMI2-LG1 (WC)TestedWZBottomTMI2-D ^(d) CR3-LG2 (WC)TestedEnd of Tenth Fuel CycleEnd of Eleventh Fuel CycleEnd of Eleventh Fuel CycleVMXTopNoneMXTopNoneOC2-F2WXBottomNoneTMI1-D2WXBottomNone(WX now empty)1	WX	Тор	OC2-F	OC3-C (W)	2
End of Nirrer Fuel CycleYZTop BottomOC2-D TMI2-D(d)TMI2-LG1 (WC) CR3-LG2 (WC)Tested TestedEnd of Testel CycleNot changes.End of Elventh Fuel CycleWXTop BottomNoneOC2-F TMI1-D Q (WX now empty)	WX	Bottom	TMI1-D	TMI1-F	1
YZ WZTop BottomOC2-D TMI2-D(d)TMI2-LG1 (WC) CR3-LG2 (WC)Tested TestedEnd of Tenth Fuel CycleNo changes.End of Eleventh Fuel CycleWX WXTop BottomNoneOC2-F WX2 (WX now empty)2	End of Ni	nth Fuel Cycle			
WZBottomTMI2-D(d)CR3-LG2 (WC)TestedEnd of Tube Sector Secto	YZ	Тор	OC2-D	TMI2-LG1 (WC)	Tested
End of Tenth Fuel Cycle No changes. End of Eleventh Fuel Cycle WX Top None OC2-F 2 WX Bottom None TMI1-D 2 (WX now empty) (WX now empty) 1 1	WZ	Bottom	TMI2-D ^(d)	CR3-LG2 (WC)	Tested
No changes. End of Eleventh Fuel Cycle WX Top None OC2-F 2 WX Bottom None TMI1-D 2 (WX now empty) (WX now empty) 2	End of Te	nth Fuel Cycle	•		
End of Eleventh Fuel CycleWXTopNoneOC2-F2WXBottomNoneTMI1-D2(WX now empty)(WX now empty)2	1	No changes.			
WXTopNoneOC2-F2WXBottomNoneTMI1-D2(WX now empty)(WX now empty)2	End of Ele	eventh Fuel Cycle			
WXBottomNoneTMI1-D2(WX now empty)(WX now empty)	WX	Тор	None	OC2-F	2
(WX now empty)	WX	Bottom	None	TMI1-D	2
				(WX now empty)	

Table III (cont'd). Capsule Insertion and Withdrawal Schedule for Crystal River Unit 3



Holder Tube	Location in Holder Tube	Insert	Withdraw	Capsule Status ^(a)
End of Tw	velfth Fuel Cycle			
YZ	Тор	None	OC2-D	2
YZ	Bottom	None	TMI2-LG2 (WC)	3
			(YZ now empty)	
WZ	Тор	None	OC3-E (W)	2
WZ	Bottom	None	TMI2-D ^(d)	2
			(WZ now empty)	
	No changes.			
End of Se	venteenth Fuel Cv			
VV	Ten	Niene	A2 (WG)	4
	Top Dottom	None	A2(WC)	4
Y X	Bottom	None	A4(WC)	4
			(YX now empty)	
Withdraw	al Not Planned			
ZY	Тор	None	OC3-F (W)	2
ZY	Bottom	None	OC1-D	2

Table III (cont'd). Capsule Insertion and Withdrawal Schedule for Crystal River Unit 3

^(a) 1 =Capsule has been disposed of in accordance with Reference 2.

2 = Capsule will be disposed of at the convenience of the B&WOG in accordance with Reference 2.

3 = Capsule removed, specimens will be tested, dosimetry evaluated, and thermal monitors evaluated.

4 = Capsule to be removed, specimens will be tested, dosimetry evaluated, and thermal monitors evaluated.

^(b) (WC) = Capsule contains weld metal and compact fracture toughness specimens.

(c) (W) = Capsule contains weld metal specimens.

^(d) Dummy capsule.



Holder Tube	Location in Holder Tube	Insert	Withdraw	Capsule Status ^(a)
Installed a	t Initial Fuel Load			
WZ	Тор	AN1-B		
WZ	Bottom	$RS1-B(WC^{(b)})$		
ZY	Тор	TE1-B (WC)		
ZY	Bottom	TE1-F (WC)		
YZ	Тор	$AN1-A(W^{(c)})$		
YZ	Bottom	AN1-C (W)		
YX	Тор	RS1-D (WC)		
YX	Bottom	TE1-C (W)		
XW	Тор	TE1-D (WC)		
XW	Bottom	RS1-C (W)		
WX	Тор	TE1-A (W)		
	Bottom	RS1-F (WC)		
End of Fir	st Fuel Cycle			
W7	Ton	DB1-LG1 (WC)	AN1-R	Tested
W7	Bottom	RS1_F (W)	RS1_R (WC)	Tested
ZY	Bottom	DB1-L(W)	TE1-E(WC)	Tested
				Testea
End of Se	cond Fuel Cycle			
YX	Тор	RS1-A (W)	<u>RS</u> 1-D (WC)	Tested
End of Th	ird Fuel Cycle			
YZ	Тор	AN1-D	AN1-A (W)	Tested
ZY	Тор	TE1-E (W)	TE1-B (WC)	Tested
End of Fo	urth Fuel Cycle			
YX	Тор	AN1-F	RS1-A (W)	2
WZ	Top	RS1-F from WX bottom	DB1-LG1 (WC)	Tested
WX	Тор	None	TE1-A (W)	Tested
WX	Bottom	None	RS1-F to WZ top	
			(WX now empty)	
End of Fif	th Fuel Cycle			
WZ	Ton	Nona		Testad
WZ	Bottom	None	$\mathbf{RS1-F}(\mathbf{WC})$	
VY Z	Dottoin	None	(WZ now empty)	
YZ	Тор	TMI2-C ^(d)	AN1-D to XW bottom	
YZ	Bottom	TMI2-E ^(d)	AN1-C (W)	Tested
XW	Bottom	AN1-D from YZ top	RS1-C(W)	2

Table IV. Capsule Insertion and Withdrawal Schedulefor Davis-Besse



Holder Tube	Location in Holder Tube	Insert	Withdraw	Capsule Status ^(a)				
End of Siz	End of Sixth Fuel Cycle							
XW	Тор	None	TE1-D (WC)	Tested				
XW	Bottom	None	AN1-D	1				
V7	Tan	A2 (WC)	(XW now empty)					
	1 op Bottom	A3 (WC)	$TMI2 = C^{(d)}$					
WZ	Ton	$I_2(WC)$						
WZ	Bottom	L1 (WC)						
End of Se	venth Fuel Cycle							
YX	Тор	EPRI Capsule ^(a)	AN1-F	1				
YX	Bottom		TE1-C (W)	2				
WX	Top	IBSP-2 ^(a)						
WX	Bottom	(WV no longer empty)						
		(wx no longer empty)						
End of Eig	ghth through Tenth	n Fuel Cycles						
1	No changes.							
End of El	eventh Euel Cycle							
	Tam	Nor						
	Bottom	None	DP1 LC2 (WC)					
	Dottom	None	(7V now empty)	+				
YX	Top	None	EPRI Capsule ^(d)					
YX	Bottom	None	A5 (WC)	Tested				
			(YX now empty)					
End of Ty	velfth Fuel Cycle							
V7	Top	Dummy $I_2(WC)$		Tected				
W7	Top	None	A3 (WC) L2 (WC) to V7 top	Tested				
WZ WZ	Bottom	None	$L_2(WC)$ to L_2 top	Tested				
			(WZ now empty)	103100				
WX	Тор	None	IBSP-2 ^(d)					
WX	Bottom	None	IBSP-1 ^(d)					
			(WX now empty)					
End of Th	End of Thirteenth through Sixteenth Evel Cycles							
No changes								

Table IV (cont'd). Capsule Insertion and Withdrawal Schedule for Davis-Besse



Table IV (cont'd). Capsule Insertion and Withdrawal Schedule for Davis-Besse

Holder Tube	Location in Holder Tube	Insert Withdraw		Capsule Status ^(a)			
End of Sev	End of Seventeenth Fuel Cycle						
YZ	Тор	None	Dummy-L2 (WC)	2			
YZ	Bottom	None	A1 (WC)	3			
			(all holder tubes empty)				

^(a) 1 = Capsule has been disposed of in accordance with Reference 2.

2 = Capsule will be disposed of in accordance with Reference 2.

3 =Capsule to be removed, specimens will be tested, dosimetry evaluated, and thermal monitors evaluated.

4 = Testing in Progress.

^(b) (WC) = Capsule contains weld metal and compact fracture toughness specimens.

(c) (W) = Capsule contains weld metal specimens.

^(d) Not part of the B&WOG MIRVP.



Nuclear Plant	Capsule Location ^(a)	Capsule Identification ^(b)	Insert	Withdraw	Capsule Status ^(c)
Point Beach	13°	V (WC)		EOC-1	Tested
Unit 1	13°	R (WC)		EOC-5	Tested
	23°	T (WC)		EOC-11	Tested
	33°	S (W)		EOC-3	Tested
	23°	P (W)		EOC-21	Removed/Stored
	<u>33°</u>	N(W)		EOL	2, 4, 5
Point Beach	13°	V (WC)		EOC-1	Tested
Unit 2	13°	R (WC)		EOC-5	Tested
	23°	T (W)		EOC-3	Tested
	33°	S (WC)		EOC-16	Tested
	23°	P (W)		EOC-22	Removed/Stored
	33°	N (W)		EOL	2, 4, 5
	13°	Suppl. (W)	<u>EOC-25</u>	EOC-33	1
Surry Unit 1	15°	T (WC)		EOC-1	Tested
	15°	V (WC)		EOC-8	Tested
	35°	W		EOC-4	Tested ^(d)
	25°	S		EOL	2,4
	25°	X (WC)		EOC-12	
	15°	X (WC)	EOC-12	EOC-14	Tested
	25°	Z (WC)		EOC-12	3a
	15°	Z(WC)	EOC-12	EOL	2, 4, 5
	35°			EOC-14	36
	15°		EOC-14	EOL EOL	4, 5
	45°		 FOO 12	EOC-12	3a
	25°		<u>EUC-12</u>	EOL	4, 5
Surry Unit 2	15°	X (W)		EOC-1	Tested
	15°	V (W)		EOC-8	Tested
	25°	W (W)		EOC-4	Tested ^(d)
	25°	Y (WC)		EOC-12	
	15°	Y (WC)	EOC-12	EOC-17	Tested
	25°	U (W)		EOC-22	2, 5
	35°	Z (WC)		EOC-12	3a
	25°	Z (WC)	EOC-12	EOL	4, 5
	35°	T (W)		EOC-17	3b
	15°	T (W)	EOC-17	EOL	4, 5
	45°	S (W)		EOC-13	6
	15°	W1 $(WC)^{(e)}$	EOC-10	EOC-14	Tested

Table V. Capsule Insertion and Withdrawal Schedule for
the Westinghouse Plant-Specific RVSPs



Nuclear Plant	Capsule Location ^(a)	Capsule Identification ^(b)	Insert	Withdraw	Capsule Status ^(c)
Turkey Point	0°	T (WC)		EOC-1	Tested
Unit 3	10°	S		EOC-4	Tested
	20°	V (WC)		EOC-9	Tested
	0°	X (WC)		EOC-21	Tested
	30°	U		EOLEx	7
	30°	Y		EOLEx	7
	40°	W		EOLEx	7
	40°	Z		EOLEx	7
Turkey Point	0°	T (WC)		EOC-1	Tested
Unit 4	10°	S		EOC-3	Tested
	0°	X (WC)		EOC-27	1
	20°	V (WC)		EOL	8
	30°	U		EOLEx	7
	30°	Y		EOLEx	7
	40°	W		EOLEx	7
	40°	Z		EOLEx	7

Table V (cont'd). Capsule Insertion and Withdrawal Schedule for
the Westinghouse Plant-Specific RVSPs

Notes:

(c)

- ^(a) Capsule locations are relative with regard to quadrant; e.g., 0° is equivalent to 90°, 180°, or 270°.
- $^{(b)}$ W = Capsule contains weld metal specimens.
 - WC = Capsule contains weld metal and WOL specimens.
 - 1 = Capsule to be removed, specimens will be tested, dosimetry evaluated, and thermal monitors evaluated.
 - 2 = Capsule to be removed and placed in storage. Dosimetry may be evaluated at this time.
 - 3a = Capsule reinserted in higher lead factor location.
 - 3b = Capsule to be reinserted in higher lead factor location.
 - 4 = Capsule to be maintained in location to EOL.
 - 5 = Standby capsule to be removed at 1-2 times the vessel EOL fluence.
 - 6 = Capsule was evaluated for dosimetry and placed in storage.
 - 7 = The last capsule will not be withdrawn prior to the 55^{th} year.
 - 8 = Standby EOL capsule, as needed.
- ^(d) Only dosimetry was evaluated.
- (e) HUPCAP, not a plant-specific capsule.



	Capsule Contents			Fluence, n/cm^2 (x10 ¹⁹)			
Capsule ID	Weld Metal	Fracture Toughness Specimens	Status/ Location	Target	Expected/ Received	Time of Removal	Comments
OC1-F			Tested		0.057		Reported in BAW-1421, Rev. 1 ⁽⁹⁾ ;
							fluence corrected in BAW-1436 ⁽⁸⁾
OC1-E	X		Tested		0.150		Reported in BAW-1436 ⁽⁸⁾
OC1-B			Removed		0.700 ^(a)		Has been disposed ⁽²⁾
OC1-A	X		Tested		0.895		Reported in BAW-1837 ⁽⁶⁾
OC1-C	X		Tested		0.986		Reported in BAW-2050 ⁽⁷⁾
OC1-D			CR3-ZY	N/A	1.163 ^(b)	Not Planned	Disposal at convenience of B&WOG ⁽²⁾
OC2-C	X		Tested		$0.102^{(c)}$		Reported in BAW-1437 ⁽¹¹⁾
OC2-A	x		Tested		0.337		Reported in BAW-1699 ⁽¹⁰⁾
OC2-B			Removed		$0.562^{(d)}$		Has been disposed ⁽²⁾
OC2-E	X		Tested		1.210		Reported in BAW-2051 ⁽¹²⁾
OC2-D			Removed		0.803 ^(b)		Will be disposed ^{(2)}
OC2-F			Removed		0.803 ^(b)		Will be disposed ⁽²⁾
OC3-A	X		Tested		0.081 ^(c)		Reported in BAW-1438 ⁽¹⁴⁾
OC3-B	X		Tested		0.312		Reported in BAW-1697 ⁽¹⁵⁾
OC3-C	X		Removed		0.783 ^(b)		Will be disposed ⁽²⁾
OC3-D	X	`	Tested		1.45		Reported in BAW-2128, Rev. 1 ⁽¹⁶⁾
OC3-E	X		Removed		1.262 ^(b)		Will be disposed ⁽²⁾
OC3-F	X		CR3-ZY	N/A	1.723 ^(b)	Not Planned	Disposal at convenience of B&WOG ⁽²⁾
TMI1-E	X		Tested		0.107		Reported in BAW-1439 ⁽¹⁹⁾
TMI1-B			Removed		$0.444^{(d)}$		Has been disposed ⁽²⁾
TMI1-C	X		Tested		$0.882^{(e)}$		Reported in BAW-1901 ⁽¹⁸⁾
TMI1-A	X		Removed		Unknown		Held in storage - reported in BAW-2042 ⁽¹⁷⁾
TMI1-D			Removed		0.816 ^(b)		Will be disposed ⁽²⁾
TMI1-F	·		Removed		0.631 ^(b)		Has been disposed ⁽²⁾

Table VI. Summary Status of the B&W Surveillance Capsules

-



	1						1
	Capsule Contents			Fluence, $n/cm^2 (x10^{19})$			
Capsule ID	Weld Metal	Fracture Toughness Specimens	Status/ Location	Target	Expected/ Received	Time of Removal	Comments
CR3-B	X	Ż	Tested		0.117		Reported in BAW-1679, Rev. 1 ⁽²⁰⁾ and
							BAW-1718 ⁽²¹⁾
CR3-C	X		Tested		0.656		Reported in BAW-1898 ⁽²²⁾
CR3-D	X	Х	Tested		0.750		Reported in BAW-1899 ⁽²³⁾ and BAW-1914 ⁽²⁴⁾
CR3-F	Х	Х	Tested		1.08		Reported in BAW-2049 ⁽²⁵⁾ and BAW-2172 ⁽²⁶⁾
CR3-A	Х		Removed		1.240 ^(b)		Will be disposed ⁽²⁾
CR3-E	X		Removed		1.240 ^(b)		Will be disposed ⁽²⁾
AN1-E	X		Tested		0.0727		Reported in BAW-1440 ⁽³⁰⁾
AN1-B			Tested		0.428		Reported in BAW-1698 ⁽²⁸⁾
AN1-A	X		Tested		1.03		Reported in BAW-1836 ⁽²⁷⁾
AN1-C	X		Tested		1.46		Reported in BAW-2075, Rev. 1 ⁽²⁹⁾
AN1-D			Removed		$0.760^{(d)}$		Has been disposed ⁽²⁾
AN1-F			Removed		0.783 ^{b)}		Has been disposed ⁽²⁾
TE1-F	X	X	Tested		0.196		Reported in BAW-1701 ⁽³⁶⁾ and BAW-1719 ⁽³⁷⁾
TE1-B		X	Tested		0.592		Reported in BAW-1834 ⁽³²⁾ and BAW-1867 ⁽³³⁾
TE1-A	x		Tested		1.29		Reported in BAW-1882, Rev. 1 ⁽³¹⁾
TE1-D	X	Х	Tested		0.962		Reported in BAW-2125 ⁽³⁴⁾ and BAW-2208 ⁽³⁵⁾
TE1-C	X		Removed		1.593 ^(d)		Will be disposed ⁽²⁾
TE1-E	X		Removed		1.267 ^(b)		Will be disposed ⁽²⁾

Table VI (cont'd). Summary Status of the B&W Surveillance Capsules

-



	Capsule Contents			Fluence, n/cm^2 (x10 ¹⁹)			
Capsule ID	Weld Metal	Fracture Toughness Specimens	Status/ Location	Target	Expected/ Received	Time of Removal	Comments
CR3-LG1	X	X	Tested		0.500-0.779		Reported in BAW-1910P ⁽⁶⁴⁾
CR3-LG2	X	Х	Tested		1.19-1.95		Reported in BAW-2254P ⁽⁶⁵⁾
DB1-LG1	X	X	Tested		0.661-1.03		Reported in BAW-1920P ⁽⁶⁶⁾
DBI-LG2		Х	Removed		1.621(*)		Testing in Progress.
TMI2-LG1	x	х	Tested		0.585-0.992		Reported in BAW-2253P ⁽⁶⁷⁾
TMI2-LG2	X	Х	Removed		1.520 ^(b)		Currently being tested and evaluated.
A1	X	Х	DB1-YZ	3.000	$2.441^{(b)}$	End of Cycle 17	
A2		X		3.000	2.370	End of Cycle 17	 Demented in DAW 2412 ⁽⁶⁸⁾
			CP2 VV	3 000	1.100	End of Cycle 17	Reported in BAW-2412
A5	X	X	Tested		0.637-1.042		Reported in BAW-2360P ⁽⁶⁹⁾
LI	X	X	Tested		1.26		Reported in BAW 2400 ⁽⁷⁰⁾
L2	X	Х	DB1-YZ	1.700	2.441 ^(b)	End of Cycle 17	

Table VI (cont'd). Summary Status of the B&W Surveillance Capsules

^(a) BAW-1543, Revision 3⁽³⁾

^(b) BAW-2108, Revision 1⁽⁷¹⁾

 $^{\rm (c)}$ NUREG CR-4816, Volumes 1 & $2^{(72)}$

^(d) BAW-2108⁽⁷³⁾

^(e) Fluence revised in 86-5021026-01⁽⁷⁷⁾



	Capsule Contents			Fluence, n	$/cm^{2}(x10^{19})$		
Capsule 1D	Weld Metal	Fracture Toughness Specimens	Status/ Location ^(a)	Target	Expected	Time of Removal	Comments
PB1-N	X	X	33°	4.500	4.500	End of Life	Standby
PB1-P	X		Removed				Held in Storage
PB1-R	X	Х	Tested				Reported in WCAP-9357 ⁽³⁹⁾
PB1-S	X		Tested				Reported in WCAP-8739 ⁽⁴⁰⁾
PB1-T	X	Х	Tested				Reported in WCAP-10736 ⁽⁴¹⁾
PB1-V	X	X	Tested				Reported in BCL report dated 6/73 ⁽⁴²⁾
Suppl.	X	X	13°	4.988	4.988	End of Cycle 33	Supplemental
PB2-N	X		33°	5.000	5.000	End of Life	Standby
PB2-P	X		Removed				Held in storage
PB2-R	X	Х	Tested				Reported in WCAP-9635 ⁽⁴⁴⁾
PB2-S	X	Х	Tested				Reported in BAW-2140 ⁽⁴⁵⁾
PB2-T	X		Tested				Reported in WCAP-9331 ⁽⁴⁶⁾
PB2-V	X	X	Tested				Reported on BCL report dated 6/75 ⁽⁴⁷⁾
S1-S			25°	3.900	3.900	Remain for Lifex	Standby ^(b)
SI-T	X	Х	Tested				Reported in BCL reported dated 6/75 ^{(49) (d)}
S1-U			45°/25°	3.000	3.000	Remain for Lifex	Standby, transferred to 25° at EOC-12
S1-V	X	Х	Tested				Reported in WCAP-11415 ^{(50) (d)}
S1-W			Dosimetry				Reported in BCL-585-8R ⁽⁵¹⁾
S1-X	X	Х	Tested				Reported in BAW-2324 ⁽⁵²⁾
S1-Y			35°	4.300	4.300	Remain for Lifex	Standby, transferred to 15° at EOC-14
S1-Z	X	Х	25°/15°	5.200	5.200	End of Life	Standby, transferred to 15° at EOC-12

Table VII. Summary Status of the Westinghouse Surveillance Capsules



	Capsule Contents			Fluence, n	$/cm^2 (x10^{19})$		
Capsule ID	Weld Metal	Fracture Toughness Specimens	Status/ Location ^(a)	Target	Expected	Time of Removal	Comments
S2-S	X		Dosimetry				Evaluated for dosimetry only. Results
S2-T	х		35°	3.800	3.800	End of Life	Standby, transfer to 15° at EOC-17
S2-U	X		25°	3.600	3.600	End of Cycle 22	Standby
S2-V	Х		Tested				Reported in WCAP-11499 ⁽⁵⁵⁾
S2-W	Х		Dosimetry				Reported in BCL-585-026 ⁽³⁶⁾
S2-X	X		Tested				Reported in BCL report dated 9/75 ⁽⁵⁷⁾
S2-Y	X	X	Tested				Reported in WCAP-16001 ⁽⁷⁹⁾
S2-Z	X	X	35°/25°	3.400	3.400	Remain for Lifex	Standby, transferred to 25° at EOC-12
<u>S2-W1</u>	X	X	Tested				Reported in BAW-2350P ⁽⁷⁴⁾
TP3-S			Tested				Reported in SwRI-02-5131 ⁽⁵⁹⁾
TP3-T	X	Х	Tested				Reported in WCAP-8631 ⁽⁶⁰⁾
TP3-U			30°			End of Lifex	Standby ^(c)
TP3-V	X	Х	Tested				Reported in SwRI-06-8575 ⁽⁶¹⁾
TP3-W			40°			End of Lifex	Standby ^(c)
TP3-X	Х	Х	Tested				Reported in WCAP-15916 ⁽⁷⁵⁾
TP3-Y			30°			End of Lifex	Standby ^(c)
TP3-Z			40°			End of Lifex	Standby ^(c)
TP4-S			Tested				Reported in SwRI-02-5380 ⁽⁵⁹⁾
TP4-T	X	Х	Tested				Reported in SwRI-02-4221 ⁽⁶³⁾
TP4-U			30°			End of Lifex	Standby ^(c)
TP4-V	Х	Х	20°			End of Life	Standby
TP4-W			40°			End of Lifex	Standby ^(c)
TP4-X	x	Х	0°	3.850	3.850	End of Cycle 27	Standby
TP4-Y			30°			End of Lifex	Standby ^(c)
TP4-Z			40°			End of Lifex	Standby ^(c)

Table VII (cont'd). Summary Status of the Westinghouse Surveillance Capsules

^(a) All locations are relative with regard to quadrant; e.g., 0° is equivalent to 90°, 180°, or 270°.

^(d) Fluence revised in 86-5020802-01⁽⁷⁸⁾



^(b) To be withdrawn at EOC-17 if cavity dosimetry is not installed.

^(c) The last capsule will not be withdrawn prior to the 55th year.

	ASTM E 185-82 5 Capsule Program Requirement							
Plant	1.5 EFPY or Fluence > 5E18 $\triangle RT_{NDT} \approx 50^{\circ}F$	3 EFPY or Fluence Midway Between First and Third Capsule	6 EFPY or T/4 EOL Fluence	15 EFPY or IS EOL Fluence	EOL or 1-2 Times EOL Fluence (Capsule may be held w/o testing)			
Oconee-1	F-I/T	(a)	E-I/T	A-I/T	 C-I/T			
Oconee-2	C-I/T	A-I/T	TMI2-LG1-I/T	E-I/T	A5-I/T			
Oconee-3	A-I/T	B-I/T	L1-I/T	D-I/T	CR3-LG2-I/T			
TMI-1	E-I/T	W1-I/T	CR3-LG1-I/T	C-I/T	TMI2-LG2-I/T			
Crystal River-3	B-I/T	(a)	C-I/T	D-I/T	F-I/T			
ANO-1	E-I/T	(a)	B-I/T	A-I/T	C-I/T			
Davis-Besse	F-I/T	(a)	B-I/T	D-I/T	A-I/T			
Point Beach-1	V-I/T	S-I/T	T-I/T	R-I/T	P-I/NT			
Point Beach-2	V-I/T	T-I/T	R-I/T	S-I/T	P-I/NT			
Surry-1	T-I/T	W-I/T ^(b)	V-I/T	X-I/T	S,U-R			
Surry-2	X-I/T	W-I/T ^(b)	V-I/T	Y-I/T	S-I/T ^(b) ;T-R			
Turkey Point-3	T-I/T	V-I/T	S-I/T	X-I/T	U,W-R			
Turkey Point-4	T-I/T	S-I/T	X-R	V-R	U,W-R			

Table VIII. Comparison of the Plant-Specific Surveillance Capsules with ASTM E 185 Requirements

Legend: I/T = Irradiated and tested

I/NT = Irradiated and not tested

R = In reactor

^(a) Only 4 capsules required per ASTM E185-82.

^(b) Only dosimetry evaluated.



Plant	Date Construction Permit Issued	Date Operating License Issued	License Expiration	Peak EOL IS Fluence, n/cm ² (E > 1 MeV)
Oconee-1	November 6, 1967	February 6, 1973	February 5, 2033 ^(a)	1.31E+19
Oconee-2	November 6, 1967	October 6, 1973	October 5, 2033 ^(a)	1.28E+19
Oconee-3	November 6, 1967	July 19, 1974	July 18, 2034 ^(a)	1.26E+19
TMI-1	May 18, 1968	April 19, 1974	April 19, 2014	8.16E+18
Crystal River-3	September 25, 1968	December 3, 1976	December 2, 2016	8.03E+18
ANO-1	December 6, 1968	May 21, 1974	May 20, 2034 ^(a)	1.44E+19
Davis-Besse	March 24, 1971	April 22, 1977	April 22, 2017	1.07E+19
Point Beach-1	July 19, 1967	October 5, 1970	October 5, 2010	2.85E+19
Point Beach-2	July 25, 1968	March 8, 1973	January 7, 2013	3.12E+19
Surry-1	June 25, 1968	May 25, 1972	May 24, 2032 ^(a)	5.40E+19
Surry-2	June 25, 1968	January 29, 1973	January 28, 2033 ^(a)	5.34E+19
Turkey Point-3	April 27, 1967	July 19, 1972	July 19, 2032 ^(a)	4.50E+19
Turkey Point-4	April 27, 1967	April 10, 1973	April 10, 2033 ^(a)	4.50E+19

Table IX. Peak End-of-Life Inside Surface Fluences and Significant Licensing Dates

(a) Includes 20 year license renewal term.



2.0 CERTIFICATION

This supplement to BAW-1543, Revision 4, is an accurate description of the capsule irradiation plan for the Master Integrated Reactor Vessel Surveillance Program.

BOHal <u>6-30-05</u> Date

J. B. /Aall Materials and Structural Analysis Unit

This report has been reviewed and is an accurate description of the revised master integrated reactor vessel surveillance program.

7/25/05

H. P. Gunawardane Materials and Structural Analysis Unit

Date

Verification of independent review.

25/2005

Date

A. D. McKim, Manager Materials and Structural Analysis Unit

This report has been approved for release.

W. **R**. Gray Program Manager



3.0 REFERENCES

- 1. L. S. Harbison, "*Master Integrated Reactor Vessel Surveillance Program*," <u>BAW-1543</u>, <u>Revision 4</u>, B&W Nuclear Technologies, Inc., Lynchburg, Virginia, February 1993.
- 2. Memorandum, D. L. Howell, Project Manager, B&W Owners Group Services to Document Control Desk, U. S. Nuclear Materials by the B&W Owners Group Reactor Vessel Working Group, OG-1783, Project No. 693, March 17, 2000.
- S. Fyfitch, L. B. Gross and A. L. Lowe, Jr., "Master Integrated Reactor Vessel Surveillance Program," <u>BAW-1543</u>, Revision 3, Babcock & Wilcox Nuclear Power Division, Lynchburg, Virginia, September 1989.
- 4. ASTM Standard E 185-82, "Standard Practice for Conducting Surveillance Tests for Light-Water Cooled Nuclear Power Reactor Vessels," American Society for Testing and Materials, Philadelphia, Pennsylvania.
- G. J. Snyder and G. S. Carter, "Reactor Vessel Material Surveillance Program," <u>BAW-10006A</u>, Revision 3, Babcock & Wilcox Power Generation Division, Lynchburg, Virginia, January 1975.
- 6. A.L. Lowe, Jr., et al., "Analysis of Capsule OCI-A Duke Power Company Oconee Nuclear Station Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-1837</u>, Babcock & Wilcox Utility Power Generation Division, Lynchburg, Virginia, August 1984.
- A.L. Lowe, Jr., <u>et al.</u>, "Analysis of Capsule OCI-C Duke Power Company Oconee Nuclear Station Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-2050</u>, Babcock & Wilcox Nuclear Power Division, Lynchburg, Virginia, October 1988.
- 8. A.L. Lowe, Jr., <u>et al.</u>, "Analysis of Capsule OCI-E Duke Power Company Oconee Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-1436</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, September 1977.
- A.L. Lowe, Jr., et al., "Analysis of Capsule OCI-F Duke Power Company Oconee Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-1421, Revision 1</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, September 1975.
- A.L. Lowe, Jr., <u>et al.</u>, "Analysis of Capsule OCII-A Duke Power Company Oconee Nuclear Station, Unit 2 Reactor Vessel Materials Surveillance Program," <u>BAW-1699</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, December 1981.



- A.L. Lowe, Jr., et al., "Analysis of Capsule OCII-C Duke Power Company Oconee Nuclear Station, Unit 2 Reactor Vessel Materials Surveillance Program," <u>BAW-1437</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, May 1977.
- A.L. Lowe, Jr., <u>et al.</u>, "Analysis of Capsule OCII-E Duke Power Company Oconee Nuclear Station Unit 2 Reactor Vessel Materials Surveillance Program," <u>BAW-2051</u>, Babcock & Wilcox Nuclear Power Division, Lynchburg, Virginia, October 1988.
- H. S. Palme, <u>et al.</u>, "Compliance with 10CFR50, Appendix H, for Oconee Class Reactors," <u>BAW-10100A</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, February 1975.
- A.L. Lowe, Jr., <u>et al.</u>, "Analysis of Capsule OCIII-A Duke Power Company Oconee Nuclear Station, Unit 3 Reactor Vessel Materials Surveillance Program," <u>BAW-1438</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, July 1977.
- A.L. Lowe, Jr., <u>et al.</u>, "Analysis of Capsule OCIII-B Duke Power Company Oconee Nuclear Station, Unit 3 Reactor Vessel Materials Surveillance Program," <u>BAW-1697</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, October 1981.
- A.L. Lowe, Jr., <u>et al.</u>, "Analysis of Capsule OCIII-D Duke Power Company Oconee Nuclear Station Unit 3 Reactor Vessel Materials Surveillance Program," <u>BAW-2128</u>, <u>Revision 1</u>, B&W Nuclear Technologies, Inc., Lynchburg, Virginia, May 1992.
- S. Fyfitch and W. A. McInteer, "Requalification of the TMI-2 Reactor Vessel Surveillance Program Capsules," <u>BAW-2042</u>, Babcock & Wilcox Nuclear Power Division, Lynchburg, Virginia, August 1988.
- A.L. Lowe, Jr., <u>et al.</u>, "Analysis of Capsule TMI1-C GPU Nuclear Three Mile Island Nuclear Station Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-1901</u>, Babcock & Wilcox Nuclear Power Division, Lynchburg, Virginia, March 1986.
- A.L. Lowe, Jr., et al., "Analysis of Capsule TMI-1E from Metropolitan Edison Company Three Mile Island Nuclear Station Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-1439</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, January 1977.
- A.L. Lowe, Jr., et al., "Analysis of Capsule CR3-B Florida Power Corporation Crystal River Unit 3 Reactor Vessel Materials Surveillance Program," <u>BAW-1679, Revision 1</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, June 1982.
- A.L. Lowe, Jr., et al., "Fracture Toughness Test Results from Capsule CR3-B Florida Power Corporation Crystal River Unit 3 Reactor Vessel Materials Surveillance Program," <u>BAW-1718</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, March 1982.



- 22. A.L. Lowe, Jr., <u>et al.</u>, "Analysis of Capsule CR3-C Florida Power Corporation Crystal River Unit 3 Reactor Vessel Materials Surveillance Program," <u>BAW-1898</u>, Babcock & Wilcox Nuclear Power Division, Lynchburg, Virginia, March 1986.
- 23. A.L. Lowe, Jr., et al., "Analysis of Capsule CR3-D Florida Power Corporation Crystal River Unit 3 Reactor Vessel Materials Surveillance Program," <u>BAW-1899</u>, Babcock & Wilcox Nuclear Power Division, Lynchburg, Virginia, March 1986.
- 24. A.L. Lowe, Jr., et al., "Fracture Toughness Test Results from Capsule CR3-D Florida Power Corporation Crystal River Unit 3 Reactor Vessel Materials Surveillance Program," BAW-1914, Babcock & Wilcox Nuclear Power Division, Lynchburg, Virginia, April 1986.
- 25. A.L. Lowe, Jr., et al., "Analysis of Capsule CR3-F Florida Power Corporation Crystal River Unit 3 Reactor Vessel Materials Surveillance Program," <u>BAW-2049</u>, Babcock & Wilcox Nuclear Power Division, Lynchburg, Virginia, September 1988.
- A.L. Lowe, Jr., et al., "Fracture Toughness Test Results from Capsule CR3-F Florida Power Corporation Crystal River Unit 3 Reactor Vessel Materials Surveillance Program," <u>BAW-2172</u>, B&W Nuclear Technologies, Inc., Lynchburg, Virginia, October 1993.
- A.L. Lowe, Jr., et al., "Analysis of Capsule ANI-A Arkansas Power & Light Company Arkansas Nuclear One, Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-</u> <u>1836</u>, Babcock & Wilcox Utility Power Generation Division, Lynchburg, Virginia, July 1984.
- A.L. Lowe, Jr., et al., "Analysis of Capsule ANI-B Arkansas Power & Light Company's Arkansas Nuclear One, Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-1698</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, November 1981.
- A.L. Lowe, Jr., et al., "Analysis of Capsule ANI-C Arkansas Power & Light Company Arkansas Nuclear One, Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-</u> <u>2075, Revision 1</u>, Babcock & Wilcox Nuclear Power Division, Lynchburg, Virginia, October 1989.
- A.L. Lowe, Jr., et al., "Analysis of Capsule ANI-E Arkansas Power & Light Company Arkansas Nuclear One, Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-1440</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, April 1977.
- A.L. Lowe, Jr., et al., "Analysis of Capsule TE1-A The Toledo Edison Company Davis-Besse Nuclear Power Station Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-1882, Revision 1</u>, Babcock & Wilcox Nuclear Power Division, Lynchburg, Virginia, June 1989.



- A.L. Lowe, Jr., et al., "Analysis of Capsule TE1-B The Toledo Edison Company Davis-Besse Nuclear Power Station Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-1834</u>, Babcock & Wilcox Utility Power Generation Division, Lynchburg, Virginia, May 1984.
- A.L. Lowe, Jr., et al., "Fracture Toughness Test Results from Capsule TE1-B The Toledo Edison Company Davis-Besse Nuclear Power Station Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-1867</u>, Babcock & Wilcox Nuclear Power Division, Lynchburg, Virginia, June 1985.
- A.L. Lowe, Jr., et al., "Analysis of Capsule TE1-D The Toledo Edison Company Davis-Besse Nuclear Power Station Unit 1 Reactor Vessel Materials Surveillance Program," BAW-2125, B&W Nuclear Technologies, Inc., Lynchburg, Virginia, December 1990.
- A.L. Lowe, Jr., et al., "Fracture Toughness Test Results from Capsule TE1-D The Toledo Edison Company Davis-Besse Nuclear Power Station Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-2208</u>, B&W Nuclear Technologies, Inc., Lynchburg, Virginia, October 1993.
- A.L. Lowe, Jr., et al., "Analysis of Capsule TE1-F The Toledo Edison Company Davis-Besse Nuclear Power Station Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-1701</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, January 1982.
- A.L. Lowe, Jr., et al., "Fracture Toughness Test Results from Capsule TE1-F The Toledo Edison Company Davis-Besse Nuclear Power Station Unit 1 Reactor Vessel Materials Surveillance Program," <u>BAW-1719</u>, Babcock & Wilcox Nuclear Power Generation Division, Lynchburg, Virginia, March 1982.
- 38. S. E. Yanichko, "Wisconsin Michigan Power Company Point Beach Unit No. 1 Reactor Vessel Radiation Surveillance Program," <u>WCAP-7513</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, June 1970.
- 39. S.E. Yanichko and S. L. Anderson, "Analysis of Capsule R from the Wisconsin Electric Power Company Point Beach Unit No. 1 Reactor Vessel Radiation Surveillance Program," <u>WCAP-9357</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, August 1978.
- 40. S.E. Yanichko and S. L. Anderson, "Analysis of Capsule S from the Wisconsin Electric Power Company and Wisconsin Michigan Power Company Point Beach Unit No. 1 Reactor Vessel Radiation Surveillance Program," <u>WCAP-8739</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, November 1976.
- 41. S.E. Yanichko, et al., "Analysis of Capsule T from the Wisconsin Electric Power Company and Wisconsin Michigan Power Company Point Beach Unit No. 1 Reactor Vessel Radiation Surveillance Program," WCAP-10736, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, December 1984.



- 42. J.S. Perrin, et al., "Point Beach Nuclear Plant Unit No. 1 Pressure Vessel Surveillance Program: Evaluation of Capsule V, Final Report to Wisconsin Electric Power Company," Battelle Memorial Institute, Columbus, Ohio, June 15, 1973.
- 43. S.E. Yanichko and G. C. Zula, "Wisconsin Michigan Power Company and The Wisconsin Electric Power Company Point Beach Unit No. 2, Reactor Vessel Radiation Surveillance Program," WCAP-7712, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, June 1971.
- 44. S. E. Yanichko, <u>et al.</u>, "Analysis of Capsule R from the Wisconsin Electric Power Company Point Beach Unit No. 2 Reactor Vessel Radiation Surveillance Program," <u>WCAP-9635</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, December 1979.
- 45. A.L. Lowe, Jr., et al., "Analysis of Capsule S Wisconsin Electric Power Company Point Beach Unit No. 2 Reactor Vessel Materials Surveillance Program," <u>BAW-2140</u>, B&W Nuclear Technologies, Inc., Lynchburg, Virginia, August 1991.
- 46. J. A. Davidson, <u>et al.</u>, "Analysis of Capsule T from the Wisconsin Electric Power Company Point Beach Unit No. 2 Reactor Vessel Radiation Surveillance Program," <u>WCAP-9331</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, August 1978.
- 47. J. S. Perrin, et al., "Point Beach Nuclear Plant Unit No. 2 Pressure Vessel Surveillance Program: Evaluation of Capsule V, Final Report to Wisconsin Electric Power Company," Battelle Columbus Laboratories, Columbus, Ohio, June 10, 1975.
- 48. S. E. Yanichko, "Virginia Electric and Power Company Surry Unit No. 1 Reactor Vessel Radiation Surveillance Program," <u>WCAP-7723</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, July 1971.
- 49. J. S. Perrin, <u>et al.</u>, "*Final Report on Surry Unit No. 1 Pressure Vessel Irradiation Capsule Program: Examination and Analysis of Capsule T*," Battelle Columbus Laboratories, Columbus, Ohio, June 24, 1975.
- S. E. Yanichko and V. A. Perone, "Analysis of Capsule V from the Virginia Electric and Power Company Surry Unit 1 Reactor Vessel Radiation Surveillance Program," <u>WCAP-11415</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, February 1987.
- J. S. Perrin, et al., "Final Report on Surry Unit No. 1 Nuclear Plant Reactor Pressure Vessel Surveillance Program: Examination and Analysis of Capsule W to Virginia Electric and Power Company," <u>BCL-585-8R</u>, Battelle Columbus Laboratories, Columbus, Ohio, March 30, 1979.



- 52. M. J. DeVan and S. Q. King, "Analysis of Capsule X Virginia Power Surry Unit No. 1 Reactor Vessel Material Surveillance Program," <u>BAW-2324</u>, Framatome Technologies, Inc., Lynchburg, Virginia, April 1998.
- 53. S. E. Yanichko and D. J. Lege, "Virginia Electric and Power Company Surry Unit No. 2 Reactor Vessel Radiation Surveillance Program," <u>WCAP-8085</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, June 1973.
- 54. S. L. Abbott and J. D. Perock, "Analysis of Dosimetry from Capsule S from the Virginia Electrice and Power Company Surry Unit 2 Reactor Vessel Surveillance Program," <u>WCAP-14810</u>, December 1996.
- 55. S. E. Yanichko and V. A. Perone, "Analysis of Capsule V from the Virginia Electric and Power Company Surry Unit 2 Reactor Vessel Radiation Surveillance Program," <u>WCAP-11499</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, June 1987.
- 56. E. O. Fromm, et al., "Final Report on Surry Unit No. 2 Nuclear Plant Reactor Pressure Vessel Surveillance Program: Examination and Analysis of Capsule W to Virginia Electric and Power Company," <u>BCL-585-026</u>, Battelle Columbus Laboratories, Columbus, Ohio, February 27, 1981.
- 57. J. S. Perrin, <u>et al.</u>, "*Final Report on Surry Unit No. 2 Pressure Vessel Irradiation Capsule Program: Examination and Analysis of Capsule X to Virginia Electric and Power Company*," Battelle Columbus Laboratories, Columbus, Ohio, September 2, 1975.
- 58. S. E. Yanichko, "Florida Power and Light Company Turkey Point Unit No. 3 Reactor Vessel Radiation Surveillance Program," <u>WCAP-7656</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, May 1971.
- E. B. Norris, "Reactor Vessel Material Surveillance Program for Capsule S Turkey Point Unit No. 3 Capsule S - Turkey Point Unit No. 4," <u>Final Report SwRI Project No. 02-5131</u> <u>SwRI Project No. 02-5380</u>, Southwest Research Institute, San Antonio, Texas, May 1979.
- 60. S. E. Yanichko, <u>et al.</u>, "Analysis of Capsule T from the Florida Power and Light Company Turkey Point Unit No. 3 Reactor Vessel Radiation Surveillance Program," <u>WCAP-8631</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, December 1975.
- 61. P. K. Nair and E. B. Norris, "*Reactor Vessel Material Surveillance Program for Turkey Point Unit No. 3: Analysis of Capsule V*," <u>Final Report SwRI Project No. 06-8575</u>, Southwest Research Institute, San Antonio, Texas, August 1986.
- 62. S. E. Yanichko, "Florida Power and Light Company Turkey Point Unit No. 4 Reactor Vessel Radiation Surveillance Program," <u>WCAP-7660</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, May 1971.



- 63. E. B. Norris, "*Reactor Vessel Material Surveillance Program for Turkey Point Unit No. 4 Analysis of Capsule T,*" <u>Final Report SwRI Project No. 02-4221</u>, Southwest Research Institute, San Antonio, Texas, June 14, 1976.
- 64. A.L. Lowe, Jr., et al., "Analysis of Capsule CR3-LG1 Babcock & Wilcox Owners Group Integrated Reactor Vessel Materials Surveillance Program," <u>BAW-1910P</u>, Babcock & Wilcox Nuclear Power Division, Lynchburg, Virginia, August 1986.
- 65. M. J. DeVan, et al., "Test Results of Capsule CR3-LG2 B&W Owners Group Master Integrated Reactor Vessel Surveillance Program," <u>BAW-2254P</u>, B&W Nuclear Technologies, Inc., Lynchburg, Virginia, October 1995.
- 66. A.L. Lowe, Jr., et al., "Analysis of Capsule DB1-LG1 Babcock & Wilcox Owners Group Integrated Reactor Vessel Materials Surveillance Program," <u>BAW-1920P</u>, Babcock & Wilcox's Nuclear Power Division, Lynchburg, Virginia, October 1986.
- 67. M. J. DeVan, et al., "Test Results of Capsule TMI2-LG1 B&W Owners Group Master Integrated Reactor Vessel Surveillance Program," <u>BAW-2253P</u>, B&W Nuclear Technologies, Inc., Lynchburg, Virginia, October 1995.
- 68. J. B. Hall and J. Newman, "Analysis of the B&W Owners Group Capsule A3- Master Integrated Reactor Vessel Surveillance Program," <u>BAW-2412</u>, Framatome ANP, Inc., Lynchburg, Virginia, April 2002.
- 69. M. J. DeVan, E. Giavedoni and K. K. Yoon, "Analysis of A5 Capsule, B&W Owners Group--Master Integrated Reactor Vessel Surveillance Program," <u>BAW-2360P</u>, Framatome Technologies, Inc., Lynchburg, Virginia, June 1999.
- J. B. Hall and J. Newman, "Analysis of the B&W Owners Group Capsule L1- Reactor Vessel Material Surveillance Program," <u>BAW-2400</u>, Framatome ANP, Inc., Lynchburg, Virginia, March 2002.
- 71. L. Petrusha, "Fluence Tracking System," <u>BAW-2108</u>, Revision 1, B&W Nuclear Technologies, Inc., Lynchburg, Virginia, May 1992.
- 72. F. W. Stallman, "*The Pressure Vessel Steel Embrittlement Data Base (EDB)*," <u>NUREG/CR-4816, Volumes 1 and 2</u>, Oak Ridge National Laboratory, Oak Ridge, Tennessee, June 1988.
- 73. N. L. Snidow, *"Fluence Tracking System,"* <u>BAW-2108</u>, B&W Nuclear Technologies, Inc., Lynchburg, Virginia, March 1990.
- 74. M. J. DeVan, E. Giavedoni and K. K. Yoon, "Test results of W1 Capsule, B&W Owners Group – Master Integrated Reactor Vessel Surveillance Program," <u>BAW-2350P</u>, Framatome Technologies, Inc., Lynchburg, Virginia, April 1999.



- 75. J. H. Ledger, G. K. Roberts, and J. Conermann, "Analysis of Capsule X from the Florida Power and Light Company Turkey Point Unit 3 Reactor Vessel Radiation Surveillance Program," <u>WCAP-15916</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, September 2002.
- 76. W. L. Server and J. R. Pfefferle, "Master Curve Fracture Toughness Application for Point Beach Nuclear Plant Unit 2," <u>ATI -021-030-2003-1</u>, ATI Consulting, Dublin, California, January 2003.
- 77. J. W. Newman, Jr., "*TMI1 Capsule C Fluence Analysis Report*," <u>86-5021026-01</u>, Framatome ANP, Lynchburg, Virginia, January 2003.
- 78. J. W. Newman, Jr., "Surry 1 Capsule T and V Fluence Analysis Report," <u>86-5020802-01</u>, Framatome ANP, Lynchburg, Virginia, January 2003.
- 79. T. J. Laubham, J. Conermann, and S. L. Anderson "Analysis of Capsule Y from Dominion Surry Unit 2 Reactor Vessel Radiation Surveillance Program," <u>WCAP-16001</u>, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, February 2003.



Summary of Change Pages

SUMMARY OF REVISIONS

Section	Description
Summary	Updated to reflect current revision.
Section 1	Included revision statement for Supplement 5 changes. References to changes made in Supplement 4 were deleted. The last sentence on page 3 was deleted.
Table II	Added Point Beach Unit 2 Supplemental Capsule. Updated status of Turkey Point Unit 3 Capsule X and Surry Unit 2 Capsule Y.
Table III	Changed "End of Thirteenth Fuel Cycle" to "Withdrawal Not Planned" for capsules OC1-D and OC3-F. Updated status of capsules slated for disposal.
Table IV	Updated status of capsules.
Table V	Added Point Beach Unit 2 Supplemental Capsule. Updated status of Turkey Point Unit 3 Capsule X and Surry Unit 2 Capsule Y. Corrected Surry Unit 2 Capsule Y final capsule location.
Table VI	Changed Time of Removal from "End of Cycle 13" to "Not Planned" for capsules OC1-D and OC3-F. Changed status of capsule DB1-LG2 to "Testing in progress" from "will be disposed." Fluence was revised for TMI1-C.
Table VII	Added Point Beach Unit 2 Supplemental Capsule. Updated status of Turkey Point Unit 3 Capsule X and Surry Unit 2 Capsule Y.
Table VIII	Updated status of Turkey Point Unit 3 Capsule X and Surry Unit 2 Capsule Y. <u>Removed standby capsule column and changed capsules for the</u> <u>B&W designed plants to show compliance with ASTM E185 using only</u> <u>tested capsules.</u>
Table IX	Updated license expiration dates and Peak EOL fluence values to reflect license renewal approvals.



-

iii

Table VIII shows the conformance of the RVWG member plant-specific surveillance programs to the requirements of ASTM E 185-82.⁽⁴⁾ Table VIII was revised by updating the status of capsule TP3-X.

Table IX lists licensing dates and anticipated reactor vessel peak end-of-life fluences. License expiration dates and Peak EOL fluence values were updated to reflect license renewal approvals. The owners of plants that have been granted license renewal have made no - commitments to test or use information from the capsules that continue to be irradiated under-the MIRVP.



Plant	1.5 EFPY or Fluence > 5E18 $\triangle \text{RT}_{\text{NDT}} \approx 50^{\circ}\text{F}$	3 EFPY or Fluence Midway Between First and Third Capsule	6 EFPY or T/4 EOL Fluence	15 EFPY or IS EOL Fluence	EOL or 1-2 Times EOL Fluence (Capsule may be held w/o testing)	Standby (1-2 Times IS FOL Fluence)
Oconee-1 Oconee-2 Oconee-3 TMI-1 Crystal River-3 ANO-1 Davis-Besse Point Beach-1 Point Beach-2 Surry-1 Surry-2 Turkey Point-3 Turkey Point-4	F-I/T C-I/T A-I/T E-I/T B-I/T E-I/T F-I/T V-I/T V-I/T T-I/T X-I/T T-I/T T-I/T	(a) $E +/T$ A-I/T $7/2$ B-I/T V W C -I/T C (a) $C +/T$ (a) $E +/T$ (b) C -I/T C W-I/T*(b) W -I/T*(b) W -I/T*(b) V -I/T S -I/T	E K -I/T 12-L6/ B -I/MT L1 C -I/MT 3-L6/ K -I/MT C B -I/T B K -I/T B K -I/T T-I/T R-I/T V-I/T V-I/T S-I/T X-R	A & 1/T E-I/T D-I/T C, C D-I/XT 7/ D X-I/T A & -I/T B-I/T R-I/T S-I/T X-I/T Y-I/T X-I/T V-R	C B-I/NT A5 B-I/NT R3-262 E-I/NT F A-I/NT F A-I/NT C B-I/NT P-I/NT P-I/NT S,U-R(b) S-I/T*;T-R U,W-R U,W-R	D-R FI/NT FAR B-ZNT E-I/NT I-I/NT E-I/NT N-R N-R Y,Z-R U,Z-R Y,Z-R Y,Z-R Y,Z-R

Table VIII. Comparison of the Plant-Specific Surveillance Capsules with ASTM E 185 Requirements

Legend: I/T = Irradiated and tested

I/NT = Irradiated and not tested

R = In reactor (a) Only 4 copsules required per ASTME 185-82. (b) * Only dosimetry evaluated.

