

R


NOV 9 1993

Mr. John Hermanson
Assistant Regional Administrator
for Federal-State Operations
Occupational Safety and Health
Administration
230 S. Dearborn Street
Room 3244
Chicago, IL 60604

Dear Mr. Hermanson:

In accordance with the October 21, 1988 Memorandum of Understanding between the Nuclear Regulatory Commission (NRC) and the Occupational Safety and Health Administration (OSHA), I am enclosing information regarding ABB Combustion Engineering of Hematite, Missouri, an NRC licensee, that may be of interest to your agency. The NRC point of contact for any follow-up information related to this issue is Mr. William Troskoski, who can be reached at 301-504-2474. Thank you for your cooperation.

Sincerely,



Roland Lickus, Chief
State and Government Affairs

Enclosure: As stated

cc w/enclosure:
F. Combs, NMSS
L. Cunningham, NRR
R. Troskoski, NMSS
G. France, RIII

RIII

Lickus/ps
11/9/93

RIII

Shear
11/9/93

L-84

NON-RADIOLOGICAL HAZARDS DATA SHEET

PART I - ISSUE

NRC Licensee: ABB Hematite

Description of Issue:

(1) Licensee has not done an OSHA PSM analysis as required for anyone with greater than 10,000 lbs. of ammonia stored on-site, and (2) ammonia storage tank vessel integrity is not periodically inspected as required (?) by ASME.

How information was obtained:

During a site "visit" to develop chem safety criteria for licensing and inspection procedures, SAIC contractors identified concerns.

Licensee representative informed:

H. Eckridge, Manager Regulatory Compliance; and M. Michalson, Licensing Engineer were informed on October 14, 1993.

Licensee comments:

Licensee to review requirements.

Other persons informed:

M. Smith and J. Roth, FCOB, FCSS, NMSS

Signature - _____ Date _____
NRC Inspector

Part II - Followup

Description of Corrective Actions:

Signature - _____ Date _____
NRC Inspector

CC: Regional Office
NMSS:IMNS
NRR:ILPB