Docket No. 70-36 License SNM-33

March 31, 1994

Gary L. Shear, Chief Fuel Cycle and Decommissioning Branch U. S. Nuclear Regulatory Commission Region III 801 Warrenville Road Lisle, Illinois 60532-4351

SUBJECT: REVISION TO EFFLUENT MONITORING REPORT - JULY THROUGH DECEMBER, 1993

Dear Mr. Shear:

In accordance with 10 CFR 70.59, this letter transmits effluent monitoring data for facilities operated under license SNM-33. This effluent release data covers the period July 1, 1993 through December 31, 1993. This report replaces the report dated, February 21,1994, reference RC/10184 which had erroneous data due to a transcription error.

Airborne Releases: 5.65×10^4 Curies (3.25×10^{10} ft³)Liquids Releases: 1.05×10^{-2} Curies (6.05×10^6 liters)

If you have any questions concerning this matter, please do not hesitate to call me at (314) 937-4691 ext. 399.

Cordially yours.

n Oler

Robert W. Sharkey Manager, Regulatory Compliance

RWS/sld RC/10191

Enclosure

cc: R. M. Bernero, Director Office of NMSS U.S. Nuclear Regulatory Commission Washington DC 20555

data : rov:

ABB Combustion Engineering Nuclear Fuel

1-92

Combustion Engineering, Inc.

Post Office Box 107 3300 State Road P Hematite, MO 63047 Telephone (314) 937-4691 (314) 296-5640 Fax (314) 937-7955

APR 1 3 1993