

AUG 11 2005

LR-N05-0417



U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

**MONTHLY OPERATING REPORT
SALEM GENERATING STATION UNIT 2
DOCKET NO. 50-311**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 2 Technical Specifications, the operating statistics for **July 2005** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "C. Fricker", written over a horizontal line.

Carl J. Fricker
Salem Plant Manager

Attachments

C Distribution

IE24

DOCKET NO.: 50-311
 UNIT: Salem 2
 DATE: 8/8/05
 COMPLETED BY: J. Hiles
 TELEPHONE: (856) 339-3068

Reporting Period July 2005

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)
 Maximum Dependable Capacity (MWe-Net)
 No. of hours reactor was critical
 No. of hours generator was on line (service hours)
 Unit reserve shutdown hours
 Net Electrical Energy (MWH)

1131		
1116		
Month	Year-to-date	Cumulative
744	4263	140198
744	4224	136481
0	0	0
823901	4748039	140832389

UNIT SHUTDOWNS

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT

(1) Reason

A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training/License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other

(2) Method

1 - Manual
 2 - Manual Trip/Scram
 3 - Automatic Trip/Scram
 4 - Continuation
 5 - Other (Explain)

DOCKET NO.: 50-311
UNIT: Salem 2
DATE: 8/8/05
COMPLETED BY: R. Ritzman
TELEPHONE: (856) 339-1445

Summary Of Monthly Operating Experience

- Salem 2 began the month at approximately 100% reactor power and operated there throughout the month.
- At the end of the month, Salem 2 completed 81 days of continuous on-line operation.