

PROPRIETARY INFORMATION

August 22, 2005

Mr. Ronnie L. Gardner
Manager, Site Operations
and Regulatory Affairs
Framatome ANP
3315 Old Forest Road
Lynchburg, VA 24501

SUBJECT: DRAFT SAFETY EVALUATION FOR FRAMATOME ANP TOPICAL REPORT (TR) ANF-1358(P), REVISION 3, "THE LOSS OF FEEDWATER HEATING TRANSIENT IN BOILING WATER REACTORS" (TAC NO. MC4260)

Dear Mr. Gardner:

By letter dated August 19, 2004, Framatome ANP (FANP) submitted ANF-1358(P), Revision 3, "The Loss of Feedwater Heating Transient in Boiling Water Reactors" to the U.S. Nuclear Regulatory Commission (NRC) staff for review. Enclosed for FANP's review and comment are copies of the NRC staff's draft safety evaluation (SE) for the TR.

Pursuant to Section 2.390 of Title 10 of the *Code of Federal Regulations* (10 CFR), we have determined that the draft SE provided as Enclosure 1 contains proprietary information. Proprietary information contained in Enclosure 1 is indicated in **bold**. We have prepared a non-proprietary version of the draft SE (Enclosure 2). However, we will delay placing Enclosure 2 in the public document room for a period of 10 working days from the date of this letter to provide you with the opportunity to comment on the proprietary aspects. If you believe that any information in Enclosure 2 is proprietary, please identify such information line-by-line and define the basis pursuant to the criteria of 10 CFR 2.390. After 10 working days, the non-proprietary version of the draft SE will be made publicly available, and an additional 10 working days are provided to you to comment on any factual errors or clarity concerns contained in the draft SE. The final SE will be issued after making any necessary changes. The NRC staff's disposition of your comments on the draft SE will be discussed in the final SE.

PROPRIETARY INFORMATION

PROPRIETARY INFORMATION

R. Gardner

-2-

To facilitate the NRC staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes.

If you have any questions, please contact Michelle C. Honcharik at 301-415-1774.

Sincerely,

/RA/

Robert A. Gramm, Chief, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Project No. 728

Enclosures: 1. Draft SE (Proprietary)
2. Draft SE (Non-proprietary)

Enclosure 1 transmitted herewith contains sensitive unclassified information. When separated from Enclosure 1, this document is decontrolled.

PROPRIETARY INFORMATION

PROPRIETARY INFORMATION

R. Gardner

-2-

To facilitate the NRC staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes.

If you have any questions, please contact Michelle C. Honcharik at 301-415-1774.

Sincerely,

/RA/

Robert A. Gramm, Chief, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Project No. 728

Enclosures: 1. Draft SE (**Proprietary**)
2. Draft SE (Non-proprietary)

Enclosure 1 transmitted herewith contains sensitive unclassified information. When separated from Enclosure 1, this document is decontrolled

DISTRIBUTION (w/encl 2):
PUBLIC (No DPC for 10 working days)
PDIV-2 Reading
RidsNrrDlpmLpdiv (HBerkow)
RidsNrrDlpmLpdiv2 (RGramm)
RidsNrrPMMHoncharik
RidsNrrLADJohnson
RidsOgcRp
RidsAcrsAcnwMailCenter
FAkstulewicz
RidsNrrDlpmLpdiv1 (DTerao)

PROP. SE: ML052360434 PKG: 052360406
ADAMS ACCESSION NO.: LTR.: ML052360389 NRR-043 *No substantive changes

OFFICE	PDIV-1/PM	PDIV-1/LA	Tech Branch*	PDIV-1/SC	PDIV-2/SC	PDIV/D
NAME	MHoncharik	DJohnson	FAkstulewicz	DTerao	RGramm	HBerkow
DATE	8/11/05	8/10/05	7/25/05	8/15/05	8/18/05	8/22/05

DOCUMENT NAME: E:\Filenet\ML052360389.wpd
Enclosure 1 Document name: G:\DLPM\PDIV-2\Framatome\ANF-1358_draft SE PROPRIETARY.wpd

OFFICIAL RECORD COPY

1 The LFWH transient can occur in two ways:
2

- 3 1) a steam extraction line to a feedwater heater is closed, or
- 4
- 5 2) the feedwater is bypassed around a feedwater heater.
- 6

7 The first case produces a gradual drop in the temperature of the feedwater. In the second
8 case, the feedwater bypasses the heater and no heating occurs. Both cases cause a decrease
9 in the temperature of the feedwater entering the reactor vessel. The decrease in feedwater
10 temperature results in an increase in the core inlet subcooling, which collapses voids and thus
11 increases the core average power and shifts the axial power distribution towards the bottom of
12 the core. Voids begin to build up at the bottom again because of this axial shift, acting as
13 negative feedback to the void collapse process. This feedback moderates the core power
14 increase. This feedback also tends to flatten the core radial power distribution.

15
16 The LFWH event is analyzed with either the FANP 3-D core simulator model MICROBURN-B
17 (Reference 7) or MICROBURN-B2 (Reference 8). These computer codes were reviewed and
18 approved by the NRC staff. The LFWH event is a slow (>100 seconds) transient and can be
19 modeled by analyzing [].
20

21 The methodology employed involves evaluating the LFWH event at a large number of reactor
22 operating state points (power, flow, exposure, and control rod pattern) obtained from several
23 operating BWRs, over many fuel load cycles. The plant types (BWR/3, 4, 5, and 6) are diverse
24 in the respect that they have different power densities, core designs, core average void fraction,
25 fuel types, cycle lengths, and feedwater temperatures.

26
27 The assumptions used in the analysis include the following:
28

- 29 1) The reactor is in steady-state equilibrium before and after the event.
- 30
- 31 2) The xenon concentration does not change during the event.
- 32
- 33 3) The plant is conservatively assumed to be operating in the manual flow control mode,
34 and the total core flow remains constant.
- 35
- 36 4) A reactor scram is not assumed.
- 37

38 FANP confirmed the applicability of this approach by transient analyses and plant startup tests
39 and, as mentioned earlier, it was previously approved by the NRC staff (Reference 6). Actual
40 and projected state points from eight operating BWR plants were used as initial conditions. The
41 proposed revision is based on an expanded database which includes 1686 simulated LFWH
42 events, representing 1069 operating state points from 26 operating/projected cycles, including
43 the BWR/6 Maximum Extended Operating Domain. The database includes various mixtures of
44 Global Nuclear Fuels (GNF) and FANP fuel assemblies, and the most recent fuel types
45 (geometry and enrichments) and combinations of fuel types, various fuel loading schemes, and
46 control rod sequences associated with modern fuel and core designs.

47
48 FANP incorporated the LHGR calculations in Reference 2. FANP reported that the LHGR
49 analyses demonstrated that during the event, the maximum LHGR for FANP and GNF fuel was
50 within the acceptable range of the steady-state limit. These LHGR bounding values can be
51 compared to cycle specific AOO limits.
52

1 FANP evaluated the bias of the data calculated using the bounding CPR relation and found that
2 the revised correlation provided conservative results for each plant and cycle, with no obvious
3 trends or biases that would offset the conservatism of the correlation.
4

5 The analysis has demonstrated that the MCPR after a LFWH event can be directly correlated to
6 the MCPR prior to the LFWH event by plant operating parameters. The analytical model
7 developed from this analysis was adjusted accordingly from the currently approved model
8 described in Reference 6 to bound all of the calculated results. In Reference 4, in response to
9 a question from the NRC staff, FANP further stated that the bounding correlation for
10 determining delta-CPR reported in Reference 2 gives slightly more conservative values than in
11 the originally approved Reference 6, because it includes the original data, as well as additional
12 data, that covers more diverse core conditions. Additional conservatism was incorporated in
13 defining the bounding fit coefficients.
14

15 Under normal operations and AOOs, GDC 10 requires that fuel and cladding be protected from
16 excessive strain and overheating. To protect against such failures, FANP imposes
17 requirements that the fuel centerline temperature cannot exceed the melting point and the
18 cladding strain during a transient cannot exceed 1 percent. [
19

20] This limit is a result of performing the fuel
21 centerline melt and the cladding transient strain analyses using the NRC-approved
22 methodology and criteria. The mechanical analyses were performed using the NRC-approved
23 methodology as described in the TR EMF-85-74, Revision 0, Supplement 1 and
24 Supplement 2(P)(A), "RODEX2A (BWR) Fuel Rod Thermal-Mechanical Evaluation Model"
25 (Reference 11). The mechanical design criteria are contained in the NRC-approved TR
26 ANF-89-98(P)(A) Revision 1, "Generic Mechanical Design Criteria for BWR Fuel Designs"
27 (Reference 12). In Reference 4, in response to the NRC staff's RAI, FANP further stated that
28 typically, [
29

30] FANP has shown in Reference 2 that the increase in
31 LHGR for the LFWH event was found to be less than the AOO LHGR limit.
32

33 The NRC staff concludes that the results of the analysis presented in Reference 2 are
34 applicable to BWR plants, given that all the limitations and conditions outlined in Section 4.0 of
35 this SE are observed.
36

37 4.0 LIMITATIONS AND CONDITIONS

38
39 The following restrictions are imposed on the use of Reference 2:
40

- 41 1) The methodology applies to BWR/3, BWR/4, BWR/5, and BWR/6 plants, and the fuel
42 types which were part of the database ([
43]), provided that the exposure, [
44]
45] are within the range covered by the data points presented in Reference 2.
46
- 47 2) To confirm applicability of the correlation to fuel types outside the database, FANP will
48 perform additional calculations using the methodology, as described in Section 3.0 of
49 this SE. In addition, FANP calculations will be consistent with the methodology
50 described in Reference 10 and comply with the guidelines and conditions identified in
51 the associated NRC staff SE.

- 1 3) The methodology applies only to the MCPROL and the LHGR for the LFWH event.
2

3 5.0 CONCLUSION
4

5 The NRC staff reviewed Reference 2, which is a revised version to the previously approved
6 Reference 6. Both TRs describe a generic methodology for evaluating the LFWH transient.
7 Reference 2 is based on an expanded database, including current core designs, and resulted in
8 changes to the coefficients of the CPR correlation approved earlier by the NRC staff.
9 Reference 2 also extends the methodology to the determination of the LHGR. The NRC staff
10 concluded that:

- 11
12 1) FANP used results from NRC staff-approved computer codes to develop this
13 methodology and the revised CPR correlation.
14
15 2) The database of LFWH events represents a wide range of operating state points for
16 BWRs, as well as various types of fuel design. For the fuel types outside the database,
17 FANP will perform additional calculations, as outlined in Section 3.0, in order to justify
18 applicability of the correlation.
19
20 3) The revised correlation, by design, yields conservative results relative to those
21 calculated using NRC-approved methodologies.
22
23 4) The results have no obvious trends or biases that affect the conservatism of the revised
24 correlation.
25

26 Therefore, within the restrictions noted in Section 4.0, the NRC staff finds Reference 2
27 acceptable for referencing in licensing submittals.
28

29 6.0 REFERENCES
30

- 31 1. Letter from J. F. Mallay, Framatome ANP to NRC, "Request for Review and Approval of
32 ANF-1358(P) Revision 3, "The Loss of Feedwater Heating Transient in Boiling Water
33 Reactors," dated August 19, 2004. Agencywide Documents Access and Management
34 System (ADAMS) Accession No. ML042390335.
35
36 2. ANF-1358(P), Revision 3, "The Loss of Feedwater Heating Transient in Boiling Water
37 Reactors," by P. Wang, June 2004. ADAMS Accession No. for non-proprietary version
38 is ML042390407, and ML042390425 for the proprietary version.
39 3. Letter from Framatome ANP to NRC, "Request for Additional Information - ANF-1358(P)
40 Revision 3, "The Loss of Feedwater Heating Transient in Boiling Water Reactors," dated
41 April 15, 2005. ADAMS Accession No. for non-proprietary version is ML052170292, and
42 ML051090418 for the proprietary version.
43
44 4. Letter from Framatome ANP to NRC, "Request for Additional Information - ANF-1358(P)
45 Revision 3, "The Loss of Feedwater Heating Transient in Boiling Water Reactors," dated
46 April 27, 2005. ADAMS Accession No. for non-proprietary version is ML051190250, and
47 ML051190255 for the proprietary version.
48
49 5. Letter from Framatome ANP to NRC, "Request for Additional Information - ANF-1358(P)
50 Revision 3, "The Loss of Feedwater Heating Transient in Boiling Water Reactors," dated
51 June 3, 2005. ADAMS Accession No. ML051580374.

- 1 6. ANF-1358(P)(A), Revision 1, "The Loss of Feedwater Heating Transient in Boiling Water
2 Reactors," Advanced Nuclear Fuels Corporation, September 1992.
- 3
- 4 7. XN-NF-80-19(P)(A), Volume 1 Supplement 3, Supplement 3 Appendix F, and
5 Supplement 4, "Advanced Nuclear Fuels Methodology for Boiling Water Reactors:
6 Benchmark Results for the CASMO-3G/MICROBURN-B Calculation Methodology,"
7 Advanced Nuclear Fuels Corporation, November 1990.
- 8
- 9 8. EMF-2158(P)(A), Revision 0, "Siemens Power Corporation Methodology for Boiling
10 Water Reactors: Evaluation and Validation of CASMO-4/MICROBURN-B2," Siemens
11 Power Corporation, October 1999.
- 12
- 13 9. Generic Letter 83-11, Supplement 1, "Licensee Qualifications for Performing Safety
14 Analyses," dated June 24, 1999. ADAMS Accession No. ML031080345.
- 15
- 16 10. EMF-2245(P)(A), Revision 0, "Application of Siemens Power Corporation's Critical
17 Power Correlations to Co-Resident Fuel," August 2000. ADAMS Accession No. for
18 package is ML003753187, ML003753223 for proprietary version, and ML003753200 for
19 non-proprietary version.
- 20
- 21 11. EMF-85-74, Revision 0, Supplement 1 and Supplement 2(P)(A), "RODEX2A (BWR)
22 Fuel Rod Thermal-Mechanical Evaluation Model," February 1998.
- 23
- 24 12. ANF-89-98(P)(A), Revision 1, "Generic Mechanical Design Criteria for BWR Fuel
25 Designs," May 1995.
- 26
- 27

28 Principal Contributor: M. Razzaque