



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
611 RYAN PLAZA DRIVE, SUITE 400
ARLINGTON, TEXAS 76011-4005

August 24, 2005

Gregg R. Overbeck, Senior Vice
President, Nuclear
Arizona Public Service Company
P.O. Box 52034
Phoenix, Arizona 85072-2034

SUBJECT: MEETING SUMMARY DISCUSSING PALO VERDE PERFORMANCE ISSUES

Dear Mr. Overbeck:

This refers to the management meeting conducted at the U.S. Nuclear Regulatory Commission (NRC) Region IV Office, Arlington, Texas, on August 18, 2005. The meeting attendance list and a copy of the presentations are included as Enclosures 1 and 2. No commitments were made by the licensee during the conference.

In accordance with Section 2.390 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter and its enclosures will be available electronically for public inspection in the NRC's Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Should you have any questions concerning this matter, we will be pleased to discuss them with you.

Sincerely,

A handwritten signature in black ink, appearing to read "Troy W. Pruett", with a long horizontal line extending to the right.

Troy W. Pruett, Chief
Project Branch D
Division of Reactor Projects

Dockets: 50-528
50-529
50-530
Licenses: NPF-41
NPF-51
NPF-74

Enclosures:
1. Attendance List
2. Presentations

Arizona Public Service Company

-2-

cc w/enclosures:

Steve Olea

Arizona Corporation Commission

1200 W. Washington Street

Phoenix, AZ 85007

Douglas K. Porter, Senior Counsel

Southern California Edison Company

Law Department, Generation Resources

P.O. Box 800

Rosemead, CA 91770

Chairman

Maricopa County Board of Supervisors

301 W. Jefferson, 10th Floor

Phoenix, AZ 85003

Aubrey V. Godwin, Director

Arizona Radiation Regulatory Agency

4814 South 40 Street

Phoenix, AZ 85040

Craig K. Seaman, Director

Regulatory Affairs

Palo Verde Nuclear Generating Station

Mail Station 7636

P.O. Box 52034

Phoenix, AZ 85072-2034

Hector R. Puente

Vice President, Power Generation

El Paso Electric Company

310 E. Palm Lane, Suite 310

Phoenix, AZ 85004

Jeffrey T. Weikert

Assistant General Counsel

El Paso Electric Company

Mail Location 167

123 W. Mills

El Paso, TX 79901

John W. Schumann

Los Angeles Department of Water & Power

Southern California Public Power Authority

P.O. Box 51111, Room 1255-C

Los Angeles, CA 90051-0100

John Taylor
Public Service Company of New Mexico
2401 Aztec NE, MS Z110
Albuquerque, NM 87107-4224

Thomas D. Champ
Southern California Edison Company
5000 Pacific Coast Hwy, Bldg. D1B
San Clemente, CA 92672

Robert Henry
Salt River Project
6504 East Thomas Road
Scottsdale, AZ 85251

Brian Almon
Public Utility Commission
William B. Travis Building
P.O. Box 13326
1701 North Congress Avenue
Austin, TX 78701-3326

Karen O'Regan
Environmental Program Manager
City of Phoenix
Office of Environmental Programs
200 West Washington Street
Phoenix, AZ 85003

Electronic distribution by RIV:
 Regional Administrator (**BSM1**)
 DRP Director (**ATH**)
 DRS Director (**DDC**)
 DRS Deputy Director (**KMK**)
 Senior Resident Inspector (**GXW2**)
 Branch Chief, DRP/D (**TWP**)
 Senior Project Engineer, DRP/D (**NFO**)
 Team Leader, DRP/TSS (**RLN1**)
 RITS Coordinator (**KEG**)

SISP Review Completed: NP ADAMS: Yes No Initials: NP
 Publicly Available Non-Publicly Available Sensitive Non-Sensitive

R:/Reactor/ PV/MS 8-18-05.wpd

RIV:DRP:SR/D	C:DRP/D			
NHTaylor	TWPruett			
<u>NP</u>	<u>NP</u>			
8/23/05	8/23/05			

OFFICIAL RECORD COPY

T=Telephone

E=E-mail

F=Fax

PUBLIC MEETING ATTENDANCE

LICENSEE/FACILITY	Palo Verde Nuclear Generating Station
DATE/TIME	August 18, 2005 12:00 p.m.
MEETING LOCATION	Region IV Offices, Arlington, Texas

NRC REPRESENTATIVES

NAME (PLEASE PRINT)	ORGANIZATION	TITLE
NICK TAYLOR	DRP BRANCH D	PROJECT ENGINEER
VICTOR DRICKS	OPA	PUBLIC AFFAIRS OFFICER
Thomas Woodson	DRS Engineering Branch 2	Engineering Associate
JERRY HOLSOMBACK	DRS - NASA ROTATION	
Neil O'Keefe	DRS - ESI	Acting Branch Chief
Jeremy Groom	DRS	Reactor Inspector (NSPDP)
Jared Nadel	DRS	Reactor Inspector, NSPDP
Cale Young	DRP	Reactor Engineer
Matthew Young	DRS Engineering Associate Engineering Branch 1	Engineering Associate
Steven Alferink	DRS	Reactor Inspector (NSPDP)
PABLO BENVENUTO	DRP	RESIDENT INSPECTOR
Greg Warnick	NRC/DRP	Senior Resident Inspector
Art Howell	NRC/DRP	Director
Kris Kennedy	DRS	Acting Deputy Director

PUBLIC MEETING ATTENDANCE

LICENSEE/FACILITY	Palo Verde Nuclear Generating Station
DATE/TIME	August 18, 2005 12:00 p.m.
MEETING LOCATION	Region IV Offices, Arlington, Texas

NRC REPRESENTATIVES

NAME (PLEASE PRINT)	ORGANIZATION	TITLE
RYAN LANTZ	DRS OPERATIONS BRANCH	ACTING BRANCH CHIEF
GEROND GEORGE	DRS	
ART HOWELL	DRP	DIVISION DIRECTOR
KRISS KENNEDY	DRS	DEPUTY DIVISION DIRECTOR
TROY PRUETT	DRP BRANCH D	BRANCH CHIEF
JEFF CLARK	DRS ENGINEERING BRANCH 1	BRANCH CHIEF
GREG WARNICK	DRP	SENIOR RESIDENT INSPECTOR
BRUCE MALLET	REGION IV	REGIONAL ADMINISTRATOR
MEL FIELDS	NRR	PROJECT MANAGER
LISA MARIE JARRIEL	OFFICE OF ENFORCEMENT	
JULIUS PERSENSKY	OFFICE OF RESEARCH	


PUBLIC MEETING ATTENDANCE

LICENSEE/FACILITY	Palo Verde Nuclear Generating Station
DATE/TIME	August 18, 2005 12:00 p.m.
MEETING LOCATION	Region IV Offices, Arlington, Texas

LICENSEE REPRESENTATIVES

NAME (PLEASE PRINT)	ORGANIZATION	TITLE
David Mauldin	Eng & Support	Vice President
Craig Seaman	Reg. Affairs	Director
Carl Churchman	Engineering	Director
Gayle Schiavone	Human Resources	Dept Leader
Steve Coppock	Engineering	Dept Leader
Mike Sontag	Perf. Improvement	Dept. Leader
Jeanne Copsey	Employee Concerns	Dept. Leader
Chris Anensen	Communications	communications Representative

NRC Management Meeting



August 18, 2005

Introduction

David Mauldin

**Vice President, Nuclear Engineering
& Support**



Palo Verde Condition Reporting (CRDR) Trending Process

**Mike Sontag,
Department Leader,
Performance Improvement**



Presentation Overview

- ◆ Overview of Condition Reporting Reporting Disposition Request Trending Process
- ◆ Coding Specifics/Details
- ◆ Trending Data Utilization
- ◆ Sample Information
- ◆ Outputs of Trending Activities
- ◆ Challenges/Weaknesses
- ◆ Future Actions
- ◆ Conclusion



CRDR Trending Baseline Information

- ◆ **Approximately 4,000 CRDRs per year**
- ◆ **CRDR Trending and coding controlled by two procedures:**
 - **Condition Reporting**
 - **Trend Analysis and Coding**
- ◆ **Codes applied by dedicated group of personnel within the Performance Improvement Department**
- ◆ **CRDR codes applied twice as applicable**
 - **All coding information maintained in an electronic database which allows for custom reports, queries and graphs via a frontline user tool called “Trend-O-Matic”**



Coding Specifics/Details

- ◆ **Codes applied to each and every CRDR**
- ◆ **Each CRDR is coded, as a minimum, for:**
 - **Category (Program, Process, or Sensitive Issue)**
 - **Subcategory (where category is broad enough to require further subdivision)**
 - **Cause**
 - **Causal Organization**



Coding Specifics/Details

- ◆ **Approximately 80 major trending categories**
- ◆ **200+ subcategories**
 - **Not all categories have subcategories**
 - **Categories and subcategories developed based on known industry issues, operating experience (internal/external), and topic sensitivity — both nuclear safety and industrial safety**
- ◆ **Approximately 125 Cause Codes initially derived from INPO Human Performance Enhancement System (HPES) model**



Coding Specifics/Details



Active CRDR Trending Category + Sub Category Descriptions

Tagging Clearance Process/Activity (Operations) NAO

Any condition reported which involves inadequate implementation of Tagging and Clearance program requirements. This could be administrative in nature or it can be problems with actual equipment, hardware (condition or positions), or tags out in the field.

TC-Administrative

CRDRs associated with Tagging and Clearance (Permit and Tagging Process, 40DP-90P29) administrative issues, (Permit Generation and Audits per 40DP-90P29); e.g., permit procedure deficiencies, inadequate creation of permits, etc. Contact Ed Sonn @ ext. 6175 for info.

TC-Caution Tag

CRDRs associated with errors involving Caution / Yellow tags. Sub-category added per recommendation from INPO 01-002 (Guidelines for the Conduct of Operations at Nuclear Power Plants), dated May 2001, Chapter VI (Plant Status and Configuration Control), Section C.3 (pg 109). CRDRs populated starting in January 2000.
Contact Ed Sonn @ ext. 6175 for info.

TC-Field Implementation

CRDRs associated with Tagging and Clearance (Permit) field implementation issues (Permit Processing per 40DP-90P29) e.g., hanging of tags, tag verification, component positioning during permit process, etc. Contact Ed Sonn @ ext. 6175 for info.

Trending categories and subcategories:

- Each has description available on the Performance Monitoring web site for all to use
- New categories and subcategories can be established or modified as needed
- Changes are documented in Trending Database to provide continuity

- [Link to descriptions](#)



Coding Specifics/Details

Categories and Subcategories

- ◆ **An Upper Control Limit (UCL) is set for each category and subcategory**
 - **Adjustable limit typically based on two standard deviations above the statistical mean for an 18-month period (norm)**
 - **Some set more conservatively at management discretion**
 - **Used as an early-warning flag, one of several factors causing us to “go look” for potential trend**
 - **UCL values reviewed every six-months for validity, reset as needed, applying conservative approach**
 - **Lower UCL values as performance improves**
 - **Resist increasing UCL values if occurrence rates increase**



Coding Specifics/Details

Initial Cause	Code
* = Code added or description revised 2/4/2004	
Work Practices (WP) Relates to methods worker uses to provide assurance of safe and successful task performance.	WP
<i>Self-checking</i> not applied to ensure correct unit or train	WP01
<i>System alignment, tagout, restoration</i> not verified	WP02
<i>Equipment condition not checked</i> (temperature, pressure, etc.) before starting work	WP03
<i>Self-checking not applied</i> to ensure correct component prior to each action	WP04
<i>Self-checking not applied</i> to ensure intended action is correct before it is performed	WP05
<i>Self-checking not applied</i> to ensure expected response	WP06
<i>Procedures, drawings, etc.</i> , when required not used	WP07
<i>*Documents not followed correctly</i> when used or referenced in the conduct of tasks and activities. [This is not a default for "procedure non-adherence" unless no other cause for the non-adherence can be found]	WP08
<i>Up-to-date documents</i> not used	WP09

Initial Cause	Code
* = Code added or description revised 2/4/2004	
<i>*Improper Operator response</i> to abnormal conditions, especially where protective or safety functions are bypassed or defeated	WP16
<i>*Operator failure to shutdown when required</i> by procedures or administrative limits to protect core	WP17
Work Schedule (WS) Relates to the Worker's Schedule, not the work scheduling process.	WS
<i>Alertness / vigilance</i> reduced	WS01
<i>Drowsiness</i> on the job	WS02
<i>Reaction time</i> slowed	WS03
<i>Ability to control movement</i> precisely reduced	WS04
<i>Ability to interpret, comprehend, and diagnose</i> reduced	WS05
<i>Judgments or decisions impaired</i>	WS06
<i>Repetitive tasks</i> performance problems	WS07
<i>Attention span</i> reduced	WS08
<i>Day dreaming</i> , frequent attention to non-work subjects	WS09
<i>Work schedule conflicts</i> with worker preference	WS10
<i>*Pressure to continue to operate</i> when conditions warrant safe shutdown	WS11

- Cause Codes used
in Trending:
- Each has description available on the Performance Monitoring web site for all to use
 - Can be rolled up to summary level in major areas of human performance



Coding Specifics/Details

Cause Codes used in Trending:

Can be rolled up to higher level code groupings, as well as to individual codes. Major groupings include:

- ◆ **WP-Work Practices; WS-Work Schedule;**
- ◆ **VC-Verbal Communication; WC-Written Communication;**
- ◆ **ID-Interface Design; EC-Environmental Conditions;**
- ◆ **WO-Work Organization & Planning; SM-Supervisory Methods;**
- ◆ **TM-Training/Qualification Methods; CM-Change Management;**
- ◆ **RM-Resource Management; MM-Managerial Methods**

◆ [Link to current cause codes](#)



Trending Data Utilization

“Trend-O-Matic”

- ◆ Electronic data collection and analysis tool
- ◆ Single database for corrective action program data, with links to industry data
- ◆ “Click of the mouse” produces trend graphs, charts, reports and raw data on human errors and program performance
- ◆ Accessible to all site personnel on PC desktop and through Performance Monitoring Intranet web site



Trending Data Utilization

Trend-O-Matic Attributes

- ◆ **User-friendly** – available on every computer
- ◆ **Line organizations use to track performance in areas of interest**
- ◆ **Nuclear Assurance and Performance Improvement use to help detect trends and identify focus areas**
- ◆ **Tailored to individual needs**
 - **User-selectable report parameters**
 - **Extract raw data for further analysis**
- ◆ **Limitation:**
 - **Not substitute for detailed analysis to determine what the data means and its significance**



Trending Data Utilization

Trend-O-Matic


Extracts Information Based on CRDR Coding

- ◆ Types of errors, organizations in which they are occurring in and their frequency (trends)
- ◆ Trends in CRDRs related to categories (programs, processes, activities or sensitive issues) and related subcategories
- ◆ Coding and trends for human performance causes and causal organizations
- ◆ Correlation to higher-level INPO Plant Information Center (PIC) data



Sample Information

Typical Category Trend Chart and Data Report



Standard Report
includes:


- Distribution by causal organizations
- Narratives for all items making up the data points
- Raw data for export to other applications

• [Link to sample detailed report](#)



Sample Information

Typical Category Trend Chart & Data Report



Approximate Distribution of Tagging & Clearance Error Occurrences Causal Organization

Standard Report includes:

- Distribution by Causal Organizations
- Narratives for all items making up the data points
- Raw Data for export to other applications

Category Trend Analysis (Details)


Category: Tagging Clearance

Start Date: 01/01/04

End Date: 06/30/05

Significant Address: CRDR Potentially_Significant

Year	Month	SRC	Date	CRDR#	Occurrences within this CRDR	CRDR Types	Details:
2005	06	6724	2005	2810845	1	Significant	The Maintenance Dept permit and tagging performance indicator was RED for the April, 2005 Tagging annunciator window. ADVERSE SHEA
2005	06	6722	2005	2809815	1	Potentially_Significant	(U-3)AN RP practices of keeping permits/sign on sheets at the RP Island has resulted in some unanticipated problems. ADVERSE FLADAGER
2005	06	6745	2005	2808762	1	Significant	(U-1)P permit 116421, hung for pre SGRP outage work had unexpected impacts. ADVERSE COXUN(WIC)
2005	06	6720	2005	2797214	1	Significant	(U-3)P permit 114761 was not hung for W/O ADVERSE MARKER
2005	06	5724	2005	2800574	1	Potentially_Significant	During the implementation of Permit #14734 for maintenance on valve 1PLRN0013 it was discovered that permit boundaries were inadequate. ADVERSE COXUN(WIC)




Sample Information

Typical Human Error Trend Chart & Data Report

Standard Report
includes:

- Trend in selected type of error for a given organization
- Distribution by Causal Organizations
- Narratives for all items making up the data points
- Raw Data for export to other applications



• [Link to sample HP Cause detailed report](#)



Outputs of Trending Activities

Monitoring for and Identifying Trends Using CRDR Data

- ◆ **Monthly – review trend data for categories, subcategories and human performance errors in each major area and organization**
 - Upper Control Limits (UCL) for categories and subcategories provide one of several tools used to trigger closer look
 - Equally important considerations:
 - Shape, slope and duration of trends
 - Proximity to UCL and how long sustained
 - Magnitude of “noise level”
 - Acceptable level based on significance and impact
 - PID communicates results to line and oversight counterparts



Outputs of Trending Activities

Monitoring for and Identifying Trends Using CRDR Data

- ◆ **Semi-annual trend report rolls up higher-level issues and confirmed adverse trends**
 - **Hard copy distribution to executive management and oversight groups**
 - **Electronic distribution to department leaders and above for dissemination within their organizations**
- ◆ **As needed – when daily CRDR reviews, trending and other activities indicate a new issue may be emerging**



Output of Trending Activities

Trend CRDRs June 2003 – June 2005

- ◆ **91 CRDRs placed in “Trend” Category**
- ◆ **20 Initiated by Nuclear Assurance / Performance Improvement**
 - 4 for INPO/NRC-identified issues
- ◆ **71 initiated by line organizations**
 - 4 for INPO/NRC-identified issues
 - Many based on data provided by NAD/PID
 - Line encouraged to write own trend CRDRs



Challenges/Weaknesses

- ◆ **Upper Control Limits**
 - Too high in some areas
 - All have been re-evaluated
 - Approximately 60% were reset, majority were minor changes of less than 10%
 - Established 6-month periodicity for reevaluation
 - No UCLs for Human Performance Cause Codes
 - More complex than category UCLs
 - Benchmark options and best practices at Corrective Action Program Owner's Group (CAPOG) Conference at end of August



Challenges/Weaknesses

- ◆ High norms in some areas had become acceptable
 - Factored into re-evaluation of UCLs
 - Some UCLs now set more conservatively than purely statistical calculated value to help drive acceptable norms down
- ◆ Management involvement and engagement in trending issues



Future Actions

- ◆ **Change Performance Improvement Department reporting structure to report through the Vice President-Operations**
 - Improve line ownership of corrective action program
 - Date: November 30, 2005
- ◆ **Designate Corrective Action Program Coordinators within major line organizations**
 - Improve line ownership and accountability
 - Date: November 30, 2005
- ◆ **Senior Vice President Nuclear meeting presentation of Trend Report content upon distribution**
 - Date: On next scheduled report issuance



Future Actions

- ◆ **Benchmark established best practice programs for development of human performance upper control limits**
 - **Date: September 30, 2005**
- ◆ **Reinstitute site-level human performance cause trend reporting as separate section in semi-annual trend report**
 - **Date: End of 2005 Trend Report**



Conclusion

- ◆ **Overview of CRDR trending process**
- ◆ **Coding specifics/details**
- ◆ **Trending data utilization**
- ◆ **Sample information**
- ◆ **Outputs of trending activities**
- ◆ **Challenges/weaknesses**
- ◆ **Future actions**
 - Closing remarks



Equipment Trending

Steve Coppock

Department Leader, System Engineering

Carl Churchman

Director, Nuclear Engineering



Presentation Outline


- ◆ **Maintenance Rule Trending**
- ◆ **Failure Data Trending**
- ◆ **Equipment Performance Trending**
- ◆ **Further Actions**
- ◆ **Conclusion**



Corrective Maintenance Work Orders (Approximate Per Year)

**PV Total
Systems
= 121**

41 high-risk systems	48 low-risk systems	32 systems not in scope
-------------------------------------	------------------------------------	--



Maintenance Rule Trending

- ◆ Reliability and unavailability performance criteria are established in accordance with 10CFR50.65
- ◆ Equipment failures are entered into the corrective action program
- ◆ About 350 failures per year, approximately 50 are functional failures
- ◆ Reliability and unavailability performance criteria are tracked and reported monthly by Engineering Services



Maintenance Rule Trending


PVNGS - Maintenance Rule Unavailability Performance Report

Date of Report 8/11/05 8:11

Time Period - Year 05, Month July

Unit 1 Unit 2 Unit 3

MIR System	Description	Unit 1			Unit 2			Unit 3		
		Value	1st%	2nd%	Value	1st%	2nd%	Value	1st%	2nd%
AFA	Auxiliary Feedwater Train A	0.45	1.20	1.60	0.31	1.20	1.60	0.43	1.20	1.60
AFB	Auxiliary Feedwater Train B	0.04	0.68	0.90	0.16	0.68	0.90	0.13	0.68	0.90
AFN	Auxiliary Feedwater Train N	0.04	0.68	0.90	0.03	0.68	0.90	0.02	0.68	0.90
CDN	Condensate System	0.00	5.00	5.00	0.00	5.00	5.00	0.00	5.00	5.00
CHA	Chem & Vol Control / Charging Pmp A	2.65	7.50	10.00	2.12	7.50	10.00	2.49	7.50	10.00
CHA APSS	Chem & Vol Control - Aux Press Spray Val	0.00	1.50	2.00	0.00	1.50	2.00	0.00	1.50	2.00
CHB	Chem & Vol Control / Charging Pmp B	2.09	7.50	10.00	3.09	7.50	10.00	6.60	7.50	10.00
CHB APSS	Chem & Vol Control - Aux Press Spray Val	0.00	1.50	2.00	0.00	1.50	2.00	0.00	1.50	2.00
CHE	Chem & Vol Control / Charging Pmp E	2.77	7.50	10.00	2.32	7.50	10.00	2.41	7.50	10.00
CON	Control Oil	1.60	3.75	5.00	0.58	3.75	5.00	0.49	3.75	5.00
CSA	Containment Spray Train A	1.35	1.50	2.00	1.00	1.50	2.00	1.23	1.50	2.00



Maintenance Rule Trending

PVNGS - Maintenance Rule Reliability Performance Report

Date of Report 8/11/05 8:33

Time Period - Year 05, Month July

<u>Unit</u>	<u>MR System</u>	<u>Description</u>	<u>Risk</u>	<u>Goal #</u>	<u>Failure Goals</u>	<u>Failures</u>
1	AFA	Auxiliary Feedwater Train A	HRS	1st	2 failures for 20 demands	0
	AFB	Auxiliary Feedwater Train B	HRS	1st	2 failures for 30 demands	0
	AFN	Auxiliary Feedwater Train N	HRS	1st	2 failures for 30 demands	0
	CHA	Chem & Vol Control / Charging Pmp A	HRS	1st	4 failures for 18 months	0
	CHA APSS	Chem & Vol Control - Aux Press Spray Valves Train A	HRS	1st	3 failures for 36 months	0
	CHB	Chem & Vol Control / Charging Pmp B	HRS	1st	4 failures for 18 months	0
	CHB APSS	Chem & Vol Control - Aux Press Spray Valves Train B	HRS	1st	3 failures for 36 months	0
	CHE	Chem & Vol Control / Charging Pmp E	HRS	1st	4 failures for 18 months	0
	CSA	Containment Spray Train A	HRS	1st	2 failures for 12 demands	0
	CSB	Containment Spray Train B	HRS	1st	2 failures for 12 demands	0
	ECA	Essential Chilled Water Train A	HRS	1st	2 failures for 30 demands	0
	ECB	Essential Chilled Water Train B	HRS	1st	2 failures for 30 demands	0



Maintenance Rule Trending

- ◆ **System Engineers meet with the Maintenance Rule Expert Panel when performance criteria are exceeded**
- ◆ **Corrective action program is used to establish corrective actions when performance criteria have been exceeded**
- **Recent examples:**
 - **Unit 2 Start-up Channel Reliability criteria not met**
 - **Unit 3 Plant Level Unplanned Capability Loss criteria was exceeded due to reactor coolant pump oil seal performance**



Summary/Challenges

- ◆ **Good over-all management of establishing and monitoring against performance criteria**
- ◆ **Good ownership of maintenance rule process by the system engineers, probabilistic risk-assessment group, and the expert panel**
- ◆ **Improvement is needed to resolve equipment for systems in a(1), some equipment issues are long-standing**



Failure Data Trending

- ◆ **System Engineers look at corrective maintenance work orders quarterly**
 - Various reports are available for review (failures by system, and by cross system)
 - Primary focus is on ensuring Maintenance Rule Functional Failures have not been missed
 - Other sources include system team meetings and condition reports
- ◆ **Engineers also look for trends at the component level**
 - Motor-operated valves
 - Air-operated valves
 - Check valves
 - Breakers
 - Large motors



Quarterly Failure Data by System

FIND IT FAST : [ON HOME](#) | [PHONEBOOK](#) | [COMPANY WEB SITES](#) | [BROWSE BY TOPIC](#) | [SEARCH](#)

PV | [Company Links](#) | [External Links](#)

FDT
Failure Data Trending




[Home](#) | [Help](#)

05Q2 FDT Quarterly Failure Report -- 4/1/2005 thru 6/30/2005

Date produced: 7/5/2005 8:03:38 AM

SYSTEM	COUNT	SYSTEM	COUNT	SYSTEM	COUNT
<u>CD</u>	5	<u>CE</u>	1	<u>CH</u>	3
<u>CP</u>	1	<u>CW</u>	2	<u>DG</u>	4
<u>DS</u>	1	<u>ED</u>	7	<u>EW</u>	1
<u>EP</u>	7	<u>FW</u>	1	<u>GH</u>	1
<u>GR</u>	2	<u>HF</u>	2	<u>IA</u>	2
<u>MA</u>	2	<u>MB</u>	1	<u>MI</u>	13
<u>MX</u>	1	<u>NG</u>	2	<u>NH</u>	2
<u>PB</u>	1	<u>PH</u>	1	<u>PN</u>	1
<u>QE</u>	8	<u>RC</u>	4	<u>RJ</u>	15
<u>RK</u>	2	<u>RM</u>	1	<u>SA</u>	2
<u>SB</u>	1	<u>SC</u>	10	<u>SD</u>	4
<u>SE</u>	2	<u>SG</u>	14	<u>SH</u>	2
<u>SI</u>	7	<u>SK</u>	2	<u>SP</u>	14
<u>SQ</u>	5	<u>WC</u>	1		



Quarterly Cross-System Failure Report

FIND IT FAST: [ON HOME](#) | [PHONEBOOK](#) | [COMPANY WEB SITES](#) | [BROWSE BY TOPIC](#) | [SEARCH](#)

FDT
Failure Data Trending

[Home](#) | [Help](#)


[PV](#) | [Company Links](#) | [External Links](#)

Cross-System Failure Report

Date report produced: 7/5/2005 8:17:55 AM


For System AF

Component Type	Component Population	Component Failures
<u>CKTBRK</u>	6615	80
Comp-Mnfr-Model Group	Group Population	Failures in Group
<u>CKTBRK-M302-910PDD031</u>	430	13
Sys-Comp-Mnfr-Model Group	System Population	Failures in System
<u>AF-CKTBRK-M302-910PDD031</u>	30	1
<u>CD-CKTBRK-M302-910PDD031</u>	12	2
<u>ED-CKTBRK-M302-910PDD031</u>	15	1
<u>EW-CKTBRK-M302-910PDD031</u>	6	1
<u>FT-CKTBRK-M302-910PDD031</u>	6	1
<u>HP-CKTBRK-M302-910PDD031</u>	18	1
<u>MT-CKTBRK-M302-910PDD031</u>	36	1
<u>SG-CKTBRK-M302-910PDD031</u>	108	2
<u>SI-CKTBRK-M302-910PDD031</u>	36	1
<u>WC-CKTBRK-M302-910PDD031</u>	9	1



Examples of recent trends identified

- ◆ **Spent fuel pool clean-up pump seal leakage**
- ◆ **Safety injection tank vent valve leakage**
- ◆ **Main control board switch contact block cracking**
- ◆ **Emergency light lamp failures**
- ◆ **The four above items were entered into corrective action program**
- ◆ **Some items are handled by managing the issue at the system team level or by initiating corrective maintenance**



Summary/Challenges

- ◆ **The effectiveness of the cross-system failure data trending process needs improvement**
 - **Upfront coding by maintenance needs improvement for equipment repaired or replaced; Nuclear assurance department input**
 - **Cause codes require improvement; existing codes are not typically used by maintenance or engineering**
 - **Consistency needs improvement; many people input cause codes**
 - **Procedures need clarification; process and expectations are not clear**



Performance Trending

- ◆ **System Engineering Equipment Trending is based on EPRI’s “SYSMON”**
 - Important functions are identified
 - Equipment important to maintaining the functions are identified and the failure modes determined
 - Monitoring plans are established around these failure modes and trended using a site computer code (SENTRI)




SYSMON Example

Mechanism	Decreased pump flow for a given pump head due to pump wear and/or degradation.	Component		Source		Grade	
Indicator	Pump mini-flow and full flow surveillance testing.	<input checked="" type="checkbox"/> <input type="checkbox"/>	<u>1MSIAP02</u>	IPDAS		GREEN	
Data Source	73ST-9SI10 (HPSI Miniflow) 73ST-9XI33 (HPSI Full Flow) IPDAS	<input checked="" type="checkbox"/> <input type="checkbox"/>	<u>1MSIAP02</u>	IPDAS		GREEN	
Collection Frequency	Quarterly Refueling Dependent upon ST to IPDAS input.	<input checked="" type="checkbox"/> <input type="checkbox"/>	<u>1MSIBP02</u>	IPDAS		GREEN	
Monitoring Frequency	Quarterly Refueling SENTRI SE notification of new IPDAS data.	<input checked="" type="checkbox"/> <input type="checkbox"/>	<u>1MSIBP02</u>	IPDAS		GREEN	
Trending Method	Reviewed by Operations and reviewed by IST. Completed by Operations and reviewed by IST. Plot DP and Flow versus time for both mini-flow and full flow.	<input checked="" type="checkbox"/> <input type="checkbox"/>	<u>2MSIAP02</u>	IPDAS		GREEN	
Acceptance Bands	Per 73ST-9SI10 Per 73ST-9XI33 Look for a degrading trend.	<input checked="" type="checkbox"/> <input type="checkbox"/>	<u>2MSIAP02</u>	IPDAS		GREEN	
Action	Per 73ST-9SI10, LCOs 3.5.3 & 3.5.4 Per 73ST-9XI33, LCOs 3.5.3 & 3.5.4 Notify IST Pump Engineer	<input checked="" type="checkbox"/> <input type="checkbox"/>	<u>2MSIBP02</u>	IPDAS		GREEN	
Industry/Regulatory Requirements	yes	<input checked="" type="checkbox"/> <input type="checkbox"/>	<u>2MSIBP02</u>	IPDAS		GREEN	
		<input checked="" type="checkbox"/> <input type="checkbox"/>	<u>3MSIAP02</u>	IPDAS		GREEN	
		<input checked="" type="checkbox"/> <input type="checkbox"/>	<u>3MSIAP02</u>	IPDAS		GREEN	
		<input checked="" type="checkbox"/> <input type="checkbox"/>	<u>3MSIBP02</u>	IPDAS		GREEN	
		<input checked="" type="checkbox"/> <input type="checkbox"/>	<u>3MSIBP02</u>	IPDAS		GREEN	



SYSMON Example

Degradation Mechanism	
Decreased pump flow for a given pump head due to pump wear and/or degradation.	
Degradation Indicator	
Pump mini-flow and full flow surveillance testing.	
Latest Date	Latest Value
4/23/2004 12:00:00 AM	1078.5
Previous Date	Previous Value
4/23/2004 12:00:00 AM	1078.5
Alarm Indicator	Active
	Yes
Unit	EQ Tag
UNIT 1	MSIAP02
Source Location	Point(s) to match
 IPDAS	Appl ID 35852 Program ID PV Measurement category FULL FLOW Measurement type DP Measurement point N/A Measurement unit PSID
Comparison Type	Value(s)
Range (2 High / 2 Low)	Low Low 1000 Low 1050 High 1100 High High 1134.7




Other forms Performance Trending

OS PI

- Engineering's primary tool for equipment performance trending
- Tied to the plant computer, CORA, and other sources: about 70,000 data points available for monitoring
- Many custom screens for systems have been developed



Example of OS PI Screen



Other Forms Of Equipment Trending

- ◆ **SmartSignal**
 - **Advanced condition monitoring software**
 - **Provides a much earlier warning of performance degradation than other technologies**
 - **Used for monitoring equipment such as RCP seals, turbine, feedwater pumps/turbines, most safety related instrumentation**



SmartSignal Example


SmartSignal eCM - Status : Machine Graph Sensor View - Microsoft Internet Explorer provide...

SmartSignal Machine: U2 Main Turbine;
[Turbine Bearing Vibration]


Orientation: Horizontal
Sensor: ZMTY183P
Start Date: 5/2/2004 End Date: 5/9/2004
Start Time: 00:00:00 End Time: 12:58:41

Sensor: ZMTY183P

5.9196 , 5/6/2004 7:11:47 PM Actual Vs. Model



1.3847 , 5/6/2004 7:11:47 PM Residual



< PREV NEXT > UPDATE PRINT CLOSE



Monitoring Catches

- ◆ **Containment spray header over-fill (level fluctuations seen with changing containment pressure)**
- ◆ **Safety Injection check valve back leakage (SIT level changes)**
- ◆ **Degrading 1st stage RCP seal**
- ◆ **Failed turbine oil discharge check valve**
- ◆ **Degrading capacitors in station battery chargers**
- ◆ **Degrading non-class station batteries**
- ◆ **Examples above entered into CAP via WO process**



Summary/Challenges

- ◆ **Several good monitoring “catches” have been identified**
- ◆ **The focus of some system engineers has been side tracked by emergent plant issues; some gaps exist with implementation**
- ◆ **Attrition in system engineering has reduced resources and challenged effectiveness**
- ◆ **Procedure requirements are weak, too much flexibility**



Future Actions


- ◆ **Revise procedures to provide improved guidance for cross system trending and performance trending (3rd quarter 2005)**
 - **“Repair/Replacement” coding by maintenance**



Corrective Maintenance Work Orders (Approximate Per Year)

**PV Total
Systems
= 121**

41 high-risk systems
48 low-risk systems
32 systems not in scope



Future Actions

- ◆ **Revise procedures to provide improved guidance for cross system trending and performance trending (3rd quarter 2005)**
 - **“Repair/Replacement” coding by maintenance**
 - **New failure cause codes**
 - **Expectations for cross-system and performance trending**
- ◆ **Improve System Team Steering Committee effectiveness (ongoing)**
- ◆ **Address resource allocation issues in System Engineering (4th quarter 2005)**



Synergy Report
Nuclear Safety Culture
and Safety Conscious
Work Environment

Jeanne Copsey
Department Leader
Employee Concerns



Presentation Outline


- ◆ **Results of 2005 Synergy Assessment**
- ◆ **Actions Taken in Response to 2005 Synergy Assessment**
- ◆ **Future Actions to Promote NSC/SCWE**
- ◆ **Conclusion**



Results of 2005 Synergy Assessment

Scope and Methodology

- ◆ 155 questions
- ◆ 2 opportunities for write-in comments – more than 1,700 comments received
- ◆ Focused on
 1. Nuclear Safety Culture (NSC)
 - Nuclear safety values, behaviors and practices including CRDR process
 - Safety Conscious Work Environment (SCWE)
 - Employee Concern Program (ECP) effectiveness
 2. General Culture and Work Environment (GCWE)
 3. PVNGS Requested Special Topics
 - Leadership, Management and Supervision Topics
 - MITR and DPO Process Effectiveness
 - Industrial Safety and Health Program Effectiveness



Results of 2005 Synergy Assessment

Administration of Survey

- ◆ **February/March 2005**
- ◆ **1861 responses = 86.6% participation**
- ◆ **Results provided to Palo Verde May 2005**



Results of 2005 Synergy Assessment

Report Conclusions

“PVNGS personnel are strongly committed to Nuclear Safety (NS) excellence as evidenced through their demonstrated willingness to take appropriate actions in response to potential Nuclear Safety (NS) issues or concerns and their supporting behaviors and practices aimed at operational NS and continuous improvement.”

- 97.3% believe NS is the first and over-riding priority at PVNGS
- 98.5% would inform their supervision and/or document using the corrective action process (CRDR report)
- 96.3% would escalate the matter up the management chain if not satisfied with response



Results of 2005 Synergy Assessment

Report Conclusions (cont.)

- ◆ SCWE is strong and relatively uniform across the site
- ◆ Work culture in work groups is generally considered strong
 - Frontline exhibit questioning attitudes
 - PVNGS is a “good place to work”
- ◆ PVNGS culture has served well in producing strong Nuclear Safety and business performance results
- ◆ PVNGS at an important “crossroads”
 - Culture will have to develop greater capacities to align with current business needs
- ◆ Growing concerns about allocation of resources, lost expertise and workload








Results of 2005 Synergy Assessment

Report Conclusions (cont.)

- ◆ Culture has benefited from several inherent strengths
 - ◆ e.g. high standards, teamwork, trust and dedication of the workforce, etc.
- ◆ Emerging pressures appear to be exposing weaknesses in areas which are becoming more critical at times of change
 - ◆ e.g. communications, change management, recognition and personnel development
- ◆ Uneasiness about whether or not “critical” standards will continue to be maintained while PVNGS faces the need to conduct business with fewer resources



Results of 2005 Synergy Assessment

<u>Rating Scale</u>	<u>Metric Mean Range</u>
 Significantly Less-than-Adequate (S-LTA) Less-than-adequate (LTA)	< 2.50 2.50-2.84
 Nominally LTA (N-LTA) Nominally Adequate (NA)	2.85-2.99 3.00-3.15
 Adequate (A) Adequate-to-Good (A-G) Good (G)	3.16-3.30 3.31-3.50 3.51-3.70
 Good-VG (G-VG) Very Good (VG)	3.71-3.90 3.91-4.20
 VG-Excellent (VG-E) Excellent (E)	4.21-4.50 > 4.50



Results of 2005 Synergy Assessment

Cultural Model / Metric	Nuclear Safety Culture (NSC)	NS Values, Behaviors & Practices (NS VBP)	Safety Conscious Work Env. (SCWE)	Employee Concerns Program (ECP)	General Culture & Work Env. (GCWE)
- Measured Status	Very Good	Very Good	VG-Exc.	Good-VG	Good
- Cultural Metric / Trend ¹	4.07 +2.9%	3.95 n/a	4.47 n/a	3.77 n/a	3.70 n/a
- 2005 Industry Percentile	86th percentile	85th percentile	85th percentile	76th percentile	91st percentile

Very Good overall response rate of 86.6% (1,861 / 2,150).

[1] Based upon the Integrated Performance Indicator (IPI), which is a less robust measure of the NSC and includes nominal GCWE influence. This indicator is computed based upon respondents' current ratings and retrospective inquiries for the same areas looking back approx. one year.



Results of 2005 Synergy Assessment

Special Topic	Status	Ratings (mean / neg. %)
<u>Leadership, Mgmt. & Supv. Topics</u> - Exhibiting PVNGS Values & Principles - Department Leader Communications - Senior Management Leadership	<u>Adeq. - Good</u> Good Good Adeq. - Good	<u>3.50 / 16.1%</u> 3.54 / 15.6% 3.62 / 12.8% 3.35 / 19.7%
Mgmt. Issues Tracking Resolution (MITR)	Good	3.56 / 12.9%
Diff. Prof. Opinion (DPO) Process	Good - VG	3.89 / 6.9%
Industrial Safety & Health Program	Good - VG	3.88 / 6.6%



Results of 2005 Synergy Assessment

Nuclear Safety Culture Relative Strengths

The following NSC survey questions were rated >4.25 ('Very Good to Excellent'):

- Nuclear safety is the first and over-riding priority (4.26, 97.3% aff.)
- Raising potential Nuclear Safety issues / concerns being favorably received by:
 - Immediate supervision (4.44, 97.6% aff.)
 - Management (4.29, 96.2% aff.)
- If one identified a potential Nuclear Safety issue or concern, would:
 - Inform supv. and/or document on CRDR (4.56, 98.5 aff.)
 - For any activity that could potentially compromise economic viability or security of PVNGS (4.73, 99.4% aff.)
 - Take up the mgmt. chain if unsatisfied by supv.'s response (4.43, 96.3% aff.); supported by perceptions of an "open door" (4.38, 97.0% aff.)



Results of 2005 Synergy Assessment

Nuclear Safety Culture Relative Strengths (cont.)

- ◆ **No negative reaction (during the past year) for having raised an issue or concern related to nuclear safety by:**
 - **Supervision (4.86, 96.4% affirmative)**
 - **Peers (4.84, 95.9% affirmative)**
 - **Mgmt. (4.82, 95.4% affirmative)**
- ◆ **Unawareness of someone who, during the past year, had experienced a negative reaction from supervision or management for having raised an issue/concern related to nuclear safety (4.43, 85.8% affirmative)**



Results of 2005 Synergy Assessment

GCWE Relative Strengths

The following GCWE survey questions were rated >4.00 'VG':

◆ High-performing work culture within work groups:

- Quality consciousness and attention to details (4.15, 97.6% aff.)
- Obtaining supv. / mgmt. input before taking actions on matters beyond normal work procedures / processes (4.13, 97.1% aff.)
- Self-critical and having questioning attitudes (4.09, 96.5% aff.)
- Striving to improve performance (4.09, 95.3% aff.)
- Identifying one's own problems (4.09, 97.2% aff.)
- Holding selves accountable for high performance (4.08, 94.3% aff.)
- Making conservative, well-balanced decisions (4.02, 96.5% aff.)



Results of 2005 Synergy Assessment

GCWE Relative Strengths (cont.)

- Within Departments:
 - Having high standards and applying these in the conduct of business (4.10, 95.7% aff.)
 - Placing importance on performance and results (4.06, 94.6% aff.)
 - Having personal satisfaction in current work assignments (4.01, 93.4% aff.)



Results of 2005 Synergy Assessment

Special Topics – Relative Strengths

The following survey questions were rated >3.90 (“Very Good”):

- ◆ **Industrial Safety and Health (ISH) program:**
 - Adhering strictly with ISH requirements (4.06, 95.9% aff.)
 - Department Leaders effectively communicating needs for improving ISH behaviors (3.93, 94.8% aff.)
- ◆ **DPO process effectiveness:**
 - Management support for using the DPO process (3.90, 93.7% aff.)
 - Willingness to use the DPO process for potential Nuclear Safety issues or concerns – based upon the absence of negative reactions (4.05, 94.2% aff.)



Results of 2005 Synergy Assessment

NSC Relative Weaknesses

All NSC survey questions were rated >3.60 (“Good” or better) with the following exceptions:

- Confidence management is making well thought-out decisions in the allocation of resources to assure that NS is maintained (3.42, 19.4% neg.)
- Confidence in CRDR process ensuring potential NS problems are:
 - Addressed in a timely manner (3.50, 11.5% neg.)
 - Resolved in an effective manner (3.55, 11.1% neg.)



Results of 2005 Synergy Assessment

- “During the past year, do you know someone who has experienced a negative reaction from supv. or mgmt. for having raised an issue or concern related to NS?”
- 4.43 mean
 - 14.2% indicating “Yes” (industry median = 17.9%)
 - 77th industry percentile

The following organizations were notably lower than the PVNGS ‘norm’:

	<u>Mean</u>	<u>Aff. %</u>
Project Eng.	3.86	28.6%
Nuclear Fuels Mgmt.	3.92	27.0%
Rad Services	3.94	26.5%
I&C – Maint. Programs	3.97	25.8%
Maint. Planning	4.05	23.8%
Unit 3 Ops	4.20	20.0%



Results of 2005 Synergy Assessment

GCWE Relative Weaknesses

All GCWE survey questions were rated >3.50 (“Good” or “Better”) with the following exceptions:

- Satisfaction with communications:
 - On priorities as used in decisions and resource allocation (3.29, 21.1%neg.)
 - On future plans for PVNGS (3.47, 14.4% neg.)
 - Department management effectively communicating the basis for changes in programs, policies and procedures (3.43, 16.1% neg.)
- Concerns about workload having an adverse impact on:
 - Maintaining plant material condition or reliability (3.37, 19.7% neg.)
 - Assuring the quality of work products (3.47, 17.4% neg.)



Results of 2005 Synergy Assessment

GCWE Relative Weaknesses (cont.)

Personnel development and management:

- Effectiveness in developing people through coaching, training and mentoring (3.23, 24.5% neg.)
- Supervision and management holding people accountable for performance and results (3.27, 23.6% neg.)
- Effectively recognizing performance and accomplishments (3.29, 23.3% neg.)
- Effective training on technical / functional aspects of peoples' jobs (3.37, 20.3% neg.)
- Departmental effectiveness in planning and implementing changes in the way business is done (3.38, 16.6% neg.)



Results of 2005 Synergy Assessment

Special Topics – Relative Weaknesses

All Special Topic survey questions were rated >3.50 (“Good” or “Better”), with the following exceptions:

LMS Relative Weaknesses

Dept. supv. & mgmt. exhibiting PVNGS Values and Principles:

- Helping to execute work with maximum efficiency (3.43, 18.7% neg.)
- Develop effective and efficient plans and processes (3.48, 17.2% neg.)

◆ Dept. Leaders effectively communicating improvement needs associated with:

- Attaining appropriate staffing levels and expertise in each org (3.24, 24.9% neg.)
- Management leadership, personnel management and business management effectiveness (3.47, 16.5% neg.)



Results of 2005 Synergy Assessment

LMS Relative Weaknesses (cont.)

Senior Management leadership:

- Establishing a clear strategy for success (3.45, 15.6% neg.)
- Demonstrating teamwork (3.38, 18.1% neg.)
- Openness and honesty in communications and interactions (3.34, 20.2% neg.)
- Setting positive example practicing what preached (3.32, 21.9% neg.)
- Providing effective leadership ensuring that necessary changes are being made (3.31, 20.1% neg.)
- Being sufficiently visible and accessible to employees (3.30, 22.6% neg.)



Results of 2005 Synergy Assessment

The following orgs triggered the PVNGS 'relative norms' targeting criteria based upon low means and/or high negative response rates:

Organization	Priority Level	NSC	SCWE	GCWE
Operations Support	1	3.78 12.1% neg.	7.2% neg.	3.32 23.9% neg.
Project Eng.	2	3.85 14.2% neg.	4.10 11.8% neg.	
I&C - Maint. Programs	2	3.84 9.9% neg.	4.24 7.9% neg.	
Proc.-Stores-Finance	3			3.31 23.5% neg.
Valve Services	3	8.5% neg.		3.41 19.5% neg.
RP Operations	3			3.43
Work Management	3			3.48 18.3% neg.
Rad Services	3	9.3% neg.		3.50 17.7% neg.
Maint. Planning	4	9.6% neg.		




Results of 2005 Synergy Assessment

Recommendations

- ◆ **Nuclear Safety Culture:**
 - Continue to reinforce ‘standards’ related to NS performance expectations
 - Continue to improve the effectiveness of the CRDR, ECP and self-assessment processes
 - Address locales with SCWE opportunities
- ◆ **General Culture and Work Environment / Leadership, Management and Supervision:**
 - More effective communications of the bases for decisions on staffing and resource allocation, on work management and on change management practices
 - Increased visibility and involvement of senior management
 - Greater attention to personnel management practices and personnel development
- ◆ **Organizational Initiatives:**
 - Address opportunities in the identified organizations



Actions Taken in Response to 2005 Synergy Assessment



Actions Taken

- ◆ **Site-wide FYI communication on results of the Synergy Assessment issued**
- ◆ **Action plan developed for communicating results of Synergy Assessment**
- ◆ **Leaders provided with results related to their area:**
 - **Focus on 6-8 questions with lowest mean score**
 - **Engage team in discussion about assessment results to better understand issues**
 - **Develop plans as necessary to address issues**



Actions Taken (cont)

- ◆ **The 9 Departments that fell below PV “norm” developed formal action plans to address areas of concern**
 - **These action plans are currently being tracked by ECP in review CRDR**
- ◆ **Other more general recommendations from the assessment have been evaluated and cross-referenced to existing corrective actions, tracked against progress with the 2005 Business Plan or specific actions are being developed to address relative weaknesses or other recommendations**



Actions Taken

- ◆ **Ongoing Leadership Assessment and Training**
 - 360-degree evaluations
 - Crucial Conversations
 - CRDR 101
 - Industrial Safety Awareness Training
 - Performance Management Process
- ◆ **Standards and Expectations White Book**
- ◆ **Procedural Use and Adherence Training**
- ◆ **Issuance of ‘Nuclear Safety Principals’ Policy**
- ◆ **Benchmarking of Self-Assessment Process**
- ◆ **Increased Leader Meetings with Senior Management**
- ◆ **Process Simplification Team**



Priority Level 2

I&C Maintenance Programs

- ◆ Continue to communicate the changes and/or enhancements being made to the CRDR process. 10/1/05
- ◆ Periodically pulse the I&C team members for issues relative to the CRDR program requiring resolution. 7/15/05
- ◆ ECP Department Leader to discuss EC Program with I&C team members. 10/1/05
- ◆ ECP Department Leader to spend day as helper to the I&C Technicians to better establish relationship and build rapport. 10/1/05



Priority 3

RP Ops/Rad Svcs Action Plan

- ◆ Reinstitution of all-hands meetings to improve communications. 10/1/05
- ◆ Publish weekly summary of department issues and events. 9/1/05
- ◆ Address accountability concerns with mid-year performance assessment feedback. 9/2/05
- ◆ Implement recognition initiatives. Complete
- ◆ Employ field observation program with revised criteria for field time. 8/19/05



Future Actions to Promote NSC/SCWE



Future Actions to Promote NSC/SCWE

- ◆ **NSC/SCWE components of Annual Site Access Training updated**
- ◆ **Continue focus on visibility of ECP program**
- ◆ **ECP Website**
- ◆ **Issuance of new Integrated Issues Resolution Process (IIRP) brochure and posters**
- ◆ **Updated SCWE Training for Leaders in 2006**
- ◆ **IIRP Self Assessment 2006**
- ◆ **Conduct Synergy Assessment in 2007**



Conclusion

- ◆ **A positive and healthy nuclear safety culture and safety conscious work environment exists at Palo Verde**
- ◆ **APS will continue to take actions to foster and promote a NSC and SCWE at Palo Verde**

