

## PLANT SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

---

- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, shows the methyl iodide penetration less than 2.5% when tested in accordance with ASTM D3803-1989 at a temperature of 30°C (86° F) and a relative humidity of 70%.
- d. At least once per 18 months by:
  - 1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 3 inches Water Gauge while operating the filter train at a flow rate of 9000 cfm  $\pm$  10%.
  - 2. Verifying that the filter trains start on a Containment Phase A Isolation test signal.
  - 3. Verifying that the system maintains the spent fuel storage area and the ESF pump rooms at a pressure equal to or more negative than minus 1/4 inch water gauge relative the outside atmosphere while maintaining a total system flow of 9000 cfm  $\pm$  10%.
  - 4. Verifying that the heaters dissipate 32  $\pm$  3.2 kw when tested in accordance with ANSI N510-1975.
- e. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter banks remove greater than or equal to 99.95% of the DOP when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 9000 cfm  $\pm$  10%.
- f. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorbers remove greater than or equal to 99.95% of a halogenated hydrocarbon refrigerant test gas when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 9000 cfm  $\pm$  10%.