

[illegible]

FEB 27 1964

UNITED NUCLEAR CORPORATION

2

LINE 1/2" LA-4 BE LABELED "FROM PUMPS (1-P-2A & B)" INSTEAD OF (1-2A & B)

THE FIRST QUESTION RELATES DIRECTLY TO NUCLEAR SAFETY.

6. IN ADDITION TO WATER AND ACID LINES ENTERING THE STRIP ACID TANKS (1-D-6A & B) WHAT OTHER MATERIAL MAY ENTER THESE TANKS FROM THE HOSE LINES. DWG. A-904 IS NOT CLEAR ON THIS POINT. REFERENCE: BLRILL : 70-820

DISTRIBUTION:

Doc. Rm.
Compliance (2)
Br. & Div. rfs
Suppl.
C EB
R. Layfield

John A. Shaw
1/28/64