

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.5.3.1	Verify the IC System: a. Shellside water level \geq 6 feet; and b. Shellside water temperature \leq 210°F.	24 hours
SR 3.5.3.2	Verify each IC System manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.	31 days
SR 3.5.3.3	Verify the IC System actuates on an actual or simulated automatic initiation signal.	24 months
SR 3.5.3.4	-----NOTE----- Not required to be performed until 12 hours after adequate reactor power is achieved to perform the test. ----- Verify IC System heat removal capability to remove design heat load.	60 months