SURVEILLANCE REQUIREMENTS (continued)

-	-	SURVEILLANCE	FREQUENCY
SR	3.8.4.2	Verify battery cells, cell plates, and racks show no visual indication of physical damage or abnormal deterioration that could degrade battery performance.	18 months
SR	3.8.4.3	Remove visible terminal corrosion, verify battery cell to cell and terminal connections are clean and tight, and are coated with anti-corrosion material.	18 months
SR	3.8.4.4	Verify each battery charger supplies ≥ 300 amps at ≥ 125 V for ≥ 4 hours.	18 months
SR	3.8.4.5	1. The modified performance discharge test in SR 3.8.4.6 may be performed in lieu of the service test in SR 3.8.4.5.	
		 This Surveillance shall not be performed in MODE 1, 2, 3, or 4. 	
		Verify battery capacity is adequate to supply, and maintain in OPERABLE status, the required emergency loads for the design duty cycle when subjected to a battery service test.	18 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

		SURVEILLANCE	FREQUENCY
SR	3.8.4.6	This Surveillance shall not be performed in MODE 1, 2, 3, or 4.	
		Verify battery capacity is ≥ 80% for the "A" Battery and 91% for the "B" battery of the manufacturer's rating when subjected to a performance discharge test or a modified performance discharge test.	60 months
			AND
			12 months when battery shows degradation or has reached 85% of expected life with capacity < 100% of manufacturer's rating.
			AND
			24 months when battery has reached 85% of expected life with capacity ≥ 100% of manufacturer's rating.