

DRAFT 8-18-2005

1 SCRAMS WITH COMPLICATIONS

2 Purpose

3 This indicator monitors that subset of unplanned automatic and manual scrams that require additional
4 operator actions beyond that of the "normal" scram. Such events or conditions present more challenges to
5 the operations staff and therefore are more risk-significant than uncomplicated scrams.
6

7 Indicator Definition

8 The number of unplanned scrams while critical, both manual and automatic, during the previous 4
9 quarters that require additional operator actions as determined by the flowchart for this indicator.
10

11 Data Reporting Elements

12 The following data are reported for each reactor unit:

- 13
- 14 • the number of unplanned automatic and manual scrams while critical in the previous quarter
15 that required additional operator response as determined by the flowchart criteria.
16

17 Calculation

18 The indicator is determined using the values reported for the previous 4 quarters as follows:

19
20 value = total unplanned scrams while critical in the previous 4 quarters that required additional
21 operator response as determined by the flowchart criteria.
22

23 Definition of Terms

24 *Scram*: means the shutdown of the reactor by the rapid addition of negative reactivity by any means, e.g.,
25 insertion of control rods, boron, use of diverse scram switch, or opening reactor trip breakers. This does
26 NOT include a reactor scram signal that inserts the shutdown banks in Mode 3 or a preplanned opening of
27 the reactor trip breakers in Mode 1 or 2 as directed by an approved procedure.
28

29 *Criticality*, for the purposes of this indicator, typically exists when a licensed reactor operator declares the
30 reactor critical. There may be instances where a transient initiates from a subcritical condition and is
31 terminated by a scram after the reactor is critical—this condition would count as a scram.
32

33 Flowchart Question Definitions

34 PWR

35 Did two or more control rods fail to fully insert?

36
37
38 Did control rods that are required to move on a reactor scram fully insert into the core as evidenced by the
39 Emergency Operating Procedure/Instruction (EOP) evaluation criteria? As an example for some
40 Westinghouse PWR evaluation schemes using rod bottom light indications, "if more than one-rod bottom
41 light is NOT illuminated, this question must be answered "Yes". The basis of this step is to determine if
42 additional actions are required by the operators as a result of the failure of all rods to insert. Additional
43 actions, such as emergency boration, pose a complication beyond the normal scram response that this
44 metric is attempting the measure. It is allowable to have one control rod not fully inserted since core
45 protection design accounts for one control rod remaining fully withdrawn from the core on a reactor
46
47

1 scram. This question MUST be evaluated using the criteria contained in the plant EOP used to verify that
2 control rods inserted. During performance of this step of the EOP the licensee staff would not need to
3 apply the "Response Not Obtained" actions. Other means not specified in the EOPs are not allowed to
4 satisfy this step of this metric.

5
6
7
8 **Did the turbine trip?**
9

10 Did the turbine trip automatically/manually as required on the reactor trip signal? To be successful steam
11 flow to the main turbine must have been isolated by the turbine trip logic actuated by the reactor trip
12 signal, or operator action from a single switch or pushbutton. The allowance of operator action to trip the
13 turbine is based on the operation of the turbine trip logic from the operator action if directed by the
14 Emergency Operating Procedure. Operator action to close valves or secure pumps to trip the turbine
15 beyond use of a single turbine trip switch would count in this indicator as a complication beyond the
16 normal reactor scram response.

17
18 **Was power lost to any ESF bus?**
19

20 During the reactor scram or during the period operators are responding to the reactor scram using reactor
21 scram response procedures, was power lost to any ESF bus that was not restored automatically by the
22 emergency AC (EAC) power system? Operator action to close the EAC output/feeder breaker from a
23 single switch on the main control board is allowed as an acceptable action to satisfy this metric. Any
24 other actions beyond closing the output/feeder breaker are considered as complications beyond the normal
25 scram response. This question is looking for a loss of power at any time for any duration where the bus
26 was not energized/re-energized. The bus must have:

- 27 > remained energized until the scram response procedure was exited, or
- 28 > been re-energized automatically by the plant EAC power system (i.e., EDG), or
- 29 > been re-energized by an operator by closing a single output/feeder breaker from a single switch
30 on the main control board

31 The question applies to all ESF busses (switchgear, load centers, motor control centers and DC busses)
32 that are designed to re-energize automatically. This does NOT apply to 120-volt power panels. It is
33 expected that operator action to re-energize an ESF bus from a single switch would not take longer than
34 10 minutes in order to be exempt from this indicator.

35
36 **Was a Safety Injection signal received?**
37

38 Was a Safety Injection signal generated either manually or automatically during or prior to the reactor
39 scram response? The consideration here is whether the operator had to respond to abnormal conditions that
40 required a safety injection or respond to the actuation of additional equipment that would not normally
41 actuate on an uncomplicated scram. This would include any condition that challenged RCS inventory,
42 pressure, or temperature severely enough to require a safety injection. A manual reactor scram in
43 response to a severe steam generator tube leak beyond the capacity of the normal at power running
44 charging system should be counted even if a safety injection was not used since additional charging
45 pumps were started. Taking actions to control RCS inventory due to a large SG tube leak while
46 responding to a reactor scram is beyond the response for a normal scram.

47
48 **Was Main Feedwater available or recoverable using approved plant procedures?**
49

50 If operating prior to the scram, was Main Feedwater operating and/or available during the reactor scram
51 response? The consideration for this question is whether Main Feedwater could be used to feed the steam
52 generators if necessary. The qualifier of "recoverable using approved plant procedures" will allow a
53 licensee to answer yes to this question if there is no physical equipment restraint to prevent the operations

1 staff from starting the necessary equipment, aligning the required systems, or satisfying required logic
2 using plant procedures approved for use and in place prior to the reactor scram occurring.

3
4 The operations staff must be able to start and operate the required equipment using normal alignments and
5 approved normal and off-normal operating procedures. Manual operation of controllers/equipment, even
6 if normally automatic, is allowed if addressed by procedure. Situations that require maintenance activities
7 or non-proceduralized operating alignments will not satisfy this question. Additionally the restoration of
8 Feedwater must be capable of feeding the Steam Generators in a reasonable period of time. Operations
9 should be able to start a Main Feedwater pump and start feeding Steam Generators with the Main
10 Feedwater System within 30 minutes. During startup conditions where Main Feedwater was not placed in
11 service prior to the scram, this question would not be considered, and should be skipped.

12
13 **Was the scram response procedure completed without re-entering another EOP?**

14
15 The response to the scram must be completed without transitioning to another EOP. This step is used to
16 determine if the scram was a simple scram that did not require using other procedures beyond the normal
17 scram response. Exiting the normal scram response procedure to the plants normal operating procedures
18 without using another EOP satisfies this step. The discretionary use of the lowest level Function
19 Restoration Guideline (Yellow Path) by the operations staff is an approved exception to this requirement.

20
21 **BWR**

22
23 **Did Control Rods fail to Shut Down the Reactor?**

24
25 Withdrawn control rods are required to be inserted to or beyond position 02 or it has been determined that
26 the reactor will remain shutdown under all conditions without boron ensure the reactor will have required
27 shutdown margin in a cold, xenon free state.

28
29 The basis of this step is to determine if additional actions are required by the operators to ensure the plant
30 remains shutdown as a result of the failure of all rods to insert. Additional actions, such as boron
31 injection, or other actions to insert control rods to maintain shutdown, pose a complication beyond the
32 normal scram response that this metric is attempting the measure. This question MUST be evaluated
33 using the criteria contained in the plant emergency procedure (EP) used to verify that control rods
34 inserted.

35
36 **Was automatic pressure control established following the initial transient?**

37
38 To be successful, Reactor pressure must be controlled following the initial transient without the automatic
39 use of SRV(s). In other words, automatic opening of SRV(s) may have initially occurred as a result of the
40 transient, but automatic cycling of the SRV(s) is not occurring subsequently. Additionally the SRV(s)
41 cannot fail open. Failure of the pressure control system (i.e. turbine valves / turbine bypass valves /
42 manual reactor pressure control using SRV(s) / HPCI / RCIC) to maintain reactor pressure or failed open
43 SRV(s) count in this indicator as a complication beyond the normal reactor trip response.

44
45
46 **Was power lost to any ESF bus?**

47
48 During the reactor scram or during the period operators are responding to the reactor scram using reactor
49 scram response procedures, was power lost to any ESF bus that was not restored automatically by the
50 emergency AC (EAC) power system. Operator action to close the EAC output/feeder breaker from a
51 single switch on the main control board is allowed as an acceptable action to satisfy this metric. Any
52 other actions beyond closing the output/feeder breaker are considered as complications beyond the normal
53 scram response. This question is looking for a loss of power at any time for any duration where the bus
54 was not energized/re-energized. The bus must have:

- 1 > remained energized until the scram response procedure was exited, or
- 2 > been re-energized automatically by the plant EAC power system (i.e., EDG), or
- 3 > been re-energized by an operator by closing a single output breaker from a single switch on the
- 4 main control board

5 The question applies to all ESF busses (switchgear, load centers, motor control centers and DC busses)
6 that are designed to re-energize automatically. This does NOT apply to 120-volt power panels. It is
7 expected that operator action to re-energize an ESF bus from a single switch would not take longer than
8 10 minutes in order to be exempt from this indicator.

9
10 **Was a Level 1 Injection signal received?**

11
12 Was a Level 1 Injection signal generated either manually or automatically during the reactor scram
13 response? The consideration here is if the operator had to respond to abnormal conditions that required a
14 low pressure safety injection or respond to the actuation of additional equipment that would not normally
15 actuate on an uncomplicated scram. This question would include any condition that challenged RCS
16 inventory, or Drywell pressure severely enough to require a safety injection.


17
18 **Was Main Feedwater available or recoverable using approved plant procedures?**

19
20 If operating prior to the scram, was Main Feedwater operating and/or available during the reactor scram
21 response? The consideration for this question is whether Main Feedwater could be used to feed the
22 Reactor Vessel if necessary. The qualifier of "recoverable using approved plant procedures" will allow a
23 licensee to answer yes to this question if there is no physical equipment restraint to prevent the operations
24 staff from starting the necessary equipment, aligning the required systems, or satisfying required logic
25 using plant procedures approved for use and in place prior to the reactor scram occurring.


26
27 The operations staff must be able to start and operate the required equipment using normal alignments and
28 approved normal or off-normal operating procedures. Manual operation of controllers/equipment, even if
29 normally automatic, is allowed if addressed by procedure. Situations that require maintenance activities
30 or non-proceduralized operating alignments will not satisfy this question. Additionally the restoration of
31 Feedwater must be capable of feeding the Reactor Vessel in a reasonable period of time. Operations
32 should be able to start a Main Feedwater pump and start feeding the Reactor Vessel with the Main
33 Feedwater System within 30 minutes. During startup conditions where Main Feedwater was not placed in
34 service prior to the scram, this question would not be considered, and should be skipped.

35
36 **Was reactor pressure/drywell pressure stabilized below Emergency Procedure entry values and**
37 **reactor level stabilized above Emergency Procedure entry values?**

38
39 This step is used to determine if the scram was a normal "simple" scram that did not require using other
40 procedures beyond the "typical" scram response. Following the initial transient maintaining the reactor
41 and drywell pressure below Emergency Procedure entry values while ensuring level is above Emergency
42 Procedure entry values satisfies this step.



BWR



1 **Clarifying Notes**

2

3 Scrams from a condition where the Reactor is not critical do not count in this indicator.

4

5 This indicator includes unplanned scrams. Unplanned scrams counted for this indicator are also counted for the
6 *Unplanned Scrams per 7000 Critical Hours* indicator.

7

8

9