



Westinghouse Electric Company
Nuclear Services
P.O. Box 355
Pittsburgh, Pennsylvania 15230-0355
USA

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Direct tel: (412) 374-4643
Direct fax: (412) 374-4011
e-mail: greshaja@westinghouse.com

Attention: J. S. Wermiel, Chief
Reactor Systems Branch
Division of Systems Safety and Analysis

Our ref: LTR-NRC-05-50

August 23, 2005

Subject: BEACON™ Core Monitoring System
Response to NRC's Draft Safety Evaluation By the Office Of Nuclear Reactor Regulation
Topical Report WCAP-12472-P, Addendum 3, "BEACON Core Monitoring and Operation
Support System" (Non-Proprietary)

Dear Mr. Wermiel:

Enclosed is a non-proprietary version of Westinghouse's proprietary review of NRC's Draft Safety Evaluation By the Office Of Nuclear Reactor Regulation Topical Report WCAP-12472-P, Addendum 3, "BEACON Core Monitoring and Operation Support System."

Very truly yours,

A handwritten signature in black ink, appearing to read 'J. A. Gresham', written over a printed name and title.

J. A. Gresham, Manager
Regulatory Compliance and Plant Licensing

Enclosure

cc: B. J. Benney, NRR
F. M. Akstulewicz, NRR
A. C. Attard, NRR
W.L. Jensen, NRR

BEACON™ trademark property of Westinghouse Electric Company LLC

T008

COPYRIGHT NOTICE

The reports transmitted herewith each bear a Westinghouse copyright notice. The NRC is permitted to make the number of copies of the information contained in these reports which are necessary for its internal use in connection with generic and plant-specific reviews and approvals as well as the issuance, denial, amendment, transfer, renewal, modification, suspension, revocation, or violation of a license, permit, order, or regulation subject to the requirements of 10 CFR 2.390 regarding restrictions on public disclosure to the extent such information has been identified as proprietary by Westinghouse, copyright protection notwithstanding. With respect to the *non-proprietary versions of these reports*, the NRC is permitted to make the number of copies beyond those necessary for its internal use which are necessary in order to have one copy available for public viewing in the appropriate docket files in the public document room in Washington, DC and in local public document rooms as may be required by NRC regulations if the number of copies submitted is insufficient for this purpose. Copies made by the NRC must include the copyright notice in all instances and the proprietary notice if the original was identified as proprietary.

**Response to NRC's Draft Safety Evaluation
By the Office Of Nuclear Reactor Regulation
Topical Report WCAP-12472-P, Addendum 3
"BEACON Core Monitoring and Operation Support System"**

August 23, 2005

Westinghouse Electric Company LLC
P.O. Box 355
Pittsburgh, Pennsylvania 15230-0355

© 2005 Westinghouse Electric Company LLC
All Rights Reserved

**Response to NRC's Draft Safety Evaluation
By the Office Of Nuclear Reactor Regulation
Topical Report WCAP-12472-P, Addendum 3
"BEACON Core Monitoring and Operation
Support System" (TAC No. MC4958)**

No proprietary information was identified by Westinghouse in the NRC's Draft Safety Evaluation for WCAP-12472-P, Addendum 3. Included below are some clarifications for readability and corrections. Changes are note in italics, underline text.

1. Page 3; Line 21 "conditions than the single channel BEACON DNBR calculator. Therefore, CETOP-D will give"
Recommendation: "conditions than the single channel BEACON DNBR calculator. Therefore, CETOP-D will give BEACON and"
Reason: More correct statement.
2. Page 3; Line 32 "components will be reevaluated when the core design differs sufficiently to have an impact on"
Recommendation: "components will be reevaluated when the core fuel design or sensor characteristics differs sufficiently to have an impact on"
Reason: More correct statement.
3. Page 5; Line 35 "at C-E COLSS plants under the following combined conditions:"
Recommendation: "at C-E COLSS PWR plants under the following combined conditions:"
Reason: More correct statement.
4. Page 6; Line 16 "the application of the merged BEACON-COLSS core system, the application of CETOP-D to"
Recommendation: "the application of the merged BEACON-COLSS core monitoring system, the application of CETOP-D to"
Reason: More correct statement.