ATTACHMENT 2

Calculation DRE02-0037, "Re-analysis of Control Rod Drop Accident (CRDA) Using Alternative Source Terms," Revision 1

温止 」。

1 -

l

.

Design Analysis (Major	Revision)	Last Page No. 4 18	1/Att. F-2
Analysis No.: '	DRE02-0037	Revision: ² 1	
Title: ³	Re-analysis of Control Rod Dr	op Accident (CRDA) Using Alternative Source T	erms
EC/ECR No.: *	356383	Revision: ⁵ 0	
Station(s): 7	Dresden	Component(s): 14	
Unit No.: *	2&3		
Discipline: *	N		
Descrip. Code/Keyword: ¹⁰	N01, R01, R02 /AST, CRDA		
Safety/QA Class: "	SR		
System Code: 12	. 00		
Structure: 13			
CONTROLLED DOCUME	NT REFERENCES 15		
Document No.:	From/To	Document No.:	From/To
DRE04-0030, R	1 From	DR-357-M-004, R0	From
DRE01-0028, R	1 From	GE-NE-A22-00103-64-01, R0	From
DRE01-0071, R	0 From		
DRE01-0040, R	0 From		
is this Design Analysis S	aleguards information? 14	Yes 🗋 No 🖾 🛛 I	1 yes, see SY-AA-101-106
Does this Design Analys Assumptions? ¹⁷	is contain Unverified	Yes 🗋 No 🖾	f yes, ATVAR#:
This Design Analysis SUPERCEDES: ¹⁸ DRE02-0037, Rev. 0 In its entirety.			
Description of Revision (list affected pages for partials): 19			
Description of Revision	list affected pages for partials):	19	enurety.
Description of Revision This revision incorporates Nuclear Station Alternative Mechanical Vacuum Pump radiation signal from the M condenser. Revised X/Q 1.183 are included to direct	Tist affected pages for partials): responses to pertinent NRC Rec Source Term License Amender so operation following a CRDA, I ain Steam Line Radiation Monit values from a new calculation ar thy indicate conformance with th	19 quest for Additional Information (RAIs) with re- nent Applications. The revisions are to remov- based on their tripping closed at the initiation tors, and to remove deposition credit for relea e also utilized. Finally, additional assumption is Regulatory Guide.	entirety. espect to all Exelon re any consideration of of a CRDA from a high ses from the gland seal s from Regulatory Guide
Description of Revision This revision Incorporates Nuclear Station Alternative Mechanical Vacuum Pump radiation signal from the M condenser. Revised X/Q 1.183 are included to direct Preparer: ²⁰	list affected pages for partials): responses to pertinent NRC Re- Source Term License Amendm so operation following a CRDA, I ain Steam Line Radiation Monit values from a new calculation ar thy indicate conformance with th Harold Rothstein	19 quest for Additional Information (FAIs) with re- nent Applications. The revisions are to remov- based on their tripping closed at the initiation fors, and to remove deposition credit for relea re also utilized. Finally, additional assumption is Regulatory Guide.	entirety. espect to all Exelon re any consideration of of a CRDA from a high ses from the gland seal s from Regulatory Guide $\frac{9}{6}/\frac{12}{5}/55$
Description of Revision This revision incorporates Nuclear Station Alternative Mechanical Vacuum Pump radiation signal from the M condenser. Revised X/Q v 1.183 are included to direct Preparer: ²⁰	list affected pages for partials): responses to pertinent NRC Rec Source Term License Amendre so operation following a CRDA, I lain Steam Line Radiation Monit values from a new calculation ar tily indicate conformance with the Harold Rothstein Print Name	19 quest for Additional Information (RAIs) with re- nent Applications. The revisions are to remov- based on their tripping closed at the initiation fors, and to remove deposition credit for relea re also utilized. Finally, additional assumption is Regulatory Guide.	entirety. espect to all Exelon re any consideration of of a CRDA from a high ses from the gland seal s from Regulatory Guide <u><u></u> <u></u> <u></u> <u></u> <u></u> <u></u> <u></u> <u></u> <u></u> <u></u></u>
Description of Revision This revision incorporates Nuclear Station Alternative Mechanical Vacuum Pump radiation signal from the M condenser. Revised X/O 1.183 are included to direct Preparer: ²⁰ Method of Review: ²¹	Tist affected pages for partials): responses to pertinent NRC Rec Source Term License Amender so operation following a CRDA, I lain Steam Line Radiation Monit ralues from a new calculation ar ty indicate conformance with th Harold Rothstein Print Name Detailed Review	19 quest for Additional Information (RAIs) with re- nent Applications. The revisions are to remov- based on their tripping closed at the initiation tors, and to remove deposition credit for relea e also utilized. Finally, additional assumption is Regulatory Guide. <u>Hammatical Sign Name</u> Atternate Calculations (attached)	entirety. espect to all Exelon re any consideration of of a CRDA from a high ses from the gland seal s from Regulatory Guide <u><u><u></u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u></u>
Description of Revision This revision incorporates Nuclear Station Alternative Mechanical Vacuum Pump radiation signal from the M condenser. Revised X/O 1.183 are included to direct Preparer: ²⁰ Method of Review: ²¹ Reviewer: ²²	Tist affected pages for partials): responses to pertinent NRC Rec Source Term License Amender so operation following a CRDA, t lain Steam Line Radiation Monit ralues from a new calculation and thy indicate conformance with the Harold Rothstein Print Name Detailed Review Source Term License Paul Reichert	19 quest for Additional Information (RAIs) with re- nent Applications. The revisions are to remov- based on their tripping closed at the initiation tors, and to remove deposition credit for relea re also utilized. Finally, additional assumption is Regulatory Guide.	entirety. espect to all Exelon re any consideration of of a CRDA from a high ses from the gland seal s from Regulatory Guide <u><u><u></u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u></u>
Description of Revision This revision Incorporates Nuclear Station Alternative Mechanical Vacuum Pump radiation signal from the M condenser. Revised X/Q v 1.183 are included to direct Preparer: ³⁰ Method of Review: ²¹ Reviewer: ²² Review AJJ:Tional Notes: ³³ HUAA1212 Thick	Tist affected pages for partials): responses to pertinent NRC Rec Source Term License Amendre so operation following a CRDA, I ain Steam Line Radiation Monit values from a new calculation are tily indicate conformance with th Harold Rothstein Print Name Detailed Review Paul Reichert Print Name Independent review S PartY reviews S	19 quest for Additional Information (RAIs) with re- nent Applications. The revisions are to remov- based on their tripping closed at the initiation tors, and to remove deposition credit for relea e also utilized. Finally, additional assumption is Regulatory Guide. <u>Sign Name</u> Atternate Calculations (attached) □ <u>Sign Name</u> Peer review □ <u>Yoon (Stl.)</u> , W.McCundy (wPR), A.	entirety. espect to all Exelon re any consideration of of a CRDA from a high ses from the gland seal s from Regulatory Guide <u>8/12/65</u> Date Testing [] <u>8/12/25</u> Date Zarechnak(4418)
Description of Revision This revision incorporates Nuclear Station Alternative Mechanical Vacuum Pump radiation signal from the M condenser. Revised X/O v 1.183 are included to direct Preparer: ²⁰ Method of Review: ²¹ Reviewer: ²² Reviewer: ²² Review AJJ:Tiond Notes: ²³ HUAA1212 Thicl (~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	Tist affected pages for partials): responses to pertinent NRC Rec Source Term License Amender so operation following a CRDA, I lain Steam Line Radiation Monit ralues from a new calculation are thy indicate conformance with th Harold Rothstein Print Name Detailed Review Paul Reichert Print Name Independent review Part Y reviews Part Y reviews Print Name Print Name Part Y reviews Print Name Print Name Part Y reviews Print Name Print Name Part Y reviews Print Name	19 quest for Additional Information (RAIs) with report Applications. The revisions are to remove based on their tripping closed at the initiation tors, and to remove deposition credit for release easo utilized. Finally, additional assumption is Regulatory Guide.	entirely. espect to all Exelon re any consideration of of a CRDA from a high ses from the gland seal s from Regulatory Guide <u>8/12/65</u> Date Testing [] <u>8/12/25</u> Date <u>8/12/25</u> Date <u>8/12/25</u> Date <u>8/12/25</u> Date <u>8/12/25</u> Date <u>8/12/25</u> Date <u>8/12/25</u> Date
Description of Revision (This revision Incorporates Nuclear Station Alternative Mechanical Vacuum Pump radiation signal from the M condenser. Revised X/O v 1.183 are included to direct Preparer: ³⁰ Method of Review: ²¹ Reviewer: ²² Reviewer: ²² Reviewer: ²³ Reviewer: ²⁴ External Approver: ²⁴ Exelon Reviewer: ²³	Tist affected pages for partials): responses to pertinent NRC Rec Source Term License Amender so operation following a CRDA, I lain Steam Line Radiation Monit ralues from a new calculation and thy indicate conformance with th Harold Rothstein Print Name Detailed Review Paul Reichert Print Name Independent review Part (review Part (review Print Name Print Name	19 quest for Additional Information (RAIs) with report Applications. The revisions are to remove based on their tripping closed at the initiation tors, and to remove deposition credit for release easo utilized. Finally, additional assumption is Regulatory Guide.	entirety. espect to all Exelon re any consideration of of a CRDA from a high ses from the gland seal s from Regulatory Guide <u>8/12/85</u> Date <u>8/12/25</u> Date <u>8/12/25</u> Date <u>8/12/25</u> Date <u>8/12/25</u> Date <u>8/12/25</u> Date <u>8/12/65</u> Date
Description of Revision (This revision Incorporates Nuclear Station Alternative Mechanical Vacuum Pump radiation signal from the M condenser. Revised X/Q v 1.183 are included to direct Preparer: ²⁰ Method of Review: ²¹ Review: ²¹ Review: ²² Review: ²³ Review: ²⁴ External Approver: ²⁴ Exelon Reviewer: ²³ Is a Supplemental Review	Thist alfected pages for partials): responses to pertinent NRC Res- Source Term License Amendmon so operation following a CRDA, I an Steam Line Radiation Monit values from a new calculation and thy indicate conformance with the Harold Rothstein Print Name Detailed Review Paul Reichert Print Name Independent review \square For Party review \square For Print Name Marty review \square For Print Name Print Name Print Name Print Name Print Name Print Name Print Name Print Name Print Name Print Name Yest Yest Yest Yest Yest	19 quest for Additional Information (FAIs) with repeated on their tripping closed at the initiation tors, and to remove deposition credit for release easo utilized. Finally, additional assumption is Regulatory Guide.	entirety. espect to all Exelon re any consideration of of a CRDA from a high ses from the gland seal s from Regulatory Guide $\frac{\frac{8}{12}/5}{Date}$ Testing [] $\frac{8}{12}/25$ Date Carechnak(4418) $\frac{7}{12}(er)$ Date $\frac{8}{13}/5$ Date $\frac{8}{13}/5$ Date Attachment 3
Description of Revision This revision incorporates Nuclear Station Alternative Mechanical Vacuum Pump radiation signal from the M condenser. Revised X/Q v 1.183 are included to direct Preparer: ²⁰ Method of Review: ²¹ Review: ²¹ Review: ²¹ Review Add: Tion of Notes: ²² Review Add: Tion of External Approver: ²⁴ Exelon Reviewer: ²³ Is a Supplemental Review Exelon	Thist affected pages for partials): responses to pertinent NRC Re- source Term License Amendm so operation following a CRDA, I lain Steam Line Radiation Monit ralues from a new calculation and thy indicate conformance with the Harold Rothstein Print Name Detailed Review Paul Reichert Print Name Independent review \square for Party review \square for Print Name Party review \square for Print Name Print Name Print Name Print Name Print Name Print Name Yes Print Name Yes Print Name Yes	19 quest for Additional Information (FAIs) with re- nent Applications. The revisions are to remove based on their tripping closed at the initiation fors, and to remove deposition credit for relea- te also utilized. Finally, additional assumptions is Regulatory Guide. 	entirety. espect to all Exelon re any consideration of of a CRDA from a high set from the gland seal s from Regulatory Guide <u>8/12/05</u> Date Testing [] <u>8/12/05</u> Date 2arechnat(418) <u>8/12/05</u> Date <u>8/12/05</u> Date <u>8/12/05</u> Date <u>8/12/05</u> Date <u>8/12/05</u> Date <u>8/12/05</u> Date <u>8/12/05</u> Date <u>8/12/05</u> Date <u>8/12/05</u> Date <u>8/12/05</u> Date <u>8/12/05</u> <u>0</u> Date <u>8/12/05</u> <u>0</u> <u>8/12/05</u> <u>0</u> <u>8/12/05</u> <u>0</u> <u>8/12/05</u> <u>0</u> <u>8/12/05</u> <u>0</u> <u>8/12/05</u> <u>0</u> <u>8/12/05</u> <u>0</u> <u>8/12/05</u> <u>0</u> <u>8/12/05</u> <u>0</u> <u>8/12/05</u> <u>0</u> <u>8/12/05</u> <u>0</u> <u>8/12/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/13/05</u> <u>0</u> <u>8/14</u> <u>0</u> <u>8/14</u> <u>0</u> <u>8/14</u> <u>0</u> <u>8/14</u> <u>0</u> <u>8/14</u> <u>0</u> <u>8/14</u> <u>0</u> <u>8/14</u> <u>0</u> <u>8/14</u> <u>0</u> <u>8/14</u> <u>0</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u> <u>10</u>
Description of Revision (This revision incorporates Nuclear Station Alternative Mechanical Vacuum Pump radiation signal from the M condenser. Revised X/O v 1.183 are included to direct Preparer: ²⁰ Method of Review: ²¹ Reviewer: ²² Review AJJ:Tion J Notes: ²³ Notes: ²³ Kutanic (Construction) Notes: ²⁴ External Approver: ²⁴ Exelon Reviewer: ²⁷ Is a Supplemental Reviewer: ²⁷	Tist affected pages for partials): responses to pertinent NRC Rec Source Term License Amender so operation following a CRDA, I lain Steam Line Radiation Monit ralues from a new calculation and thy indicate conformance with th Harold Rothstein Print Name Detailed Review ⊠ Paul Reichert Print Name Independent review ⊠ PartY reviews by: J.John Harold Rothstein Print Name Independent review ⊠ PartY reviews by: J.John Harold Rothstein Print Name NertY reviews by: J.John Harold Rothstein Print Name Required? ²⁴ Yes E. Flick Print Name	19 quest for Additional Information (RAIs) with report Applications. The revisions are to remove based on their tripping closed at the initiation tors, and to remove deposition credit for release easo utilized. Finally, additional assumption is Regulatory Guide.	entirety. espect to all Exelon re any consideration of of a CRDA from a high ses from the gland seal s from Regulatory Guide $\frac{g/12/bs}{Date}$ Testing [] $\frac{g/12/bs}{S/12/25}$ Date $\frac{g/12/cs}{Date}$

ATTA CHMENT 1 Design Analysis Cover Sb

....

PAGE NO. 2

Table of Contents

1.	PU	RPOSE/OBJECTIVE	3
2.	ME	THODOLOGY AND ACCEPTANCE CRITERIA	3
	2.1.	General Description	3
	2.2.	Core Source Term	4
	2.3.	Fuel Damage Assessment	4
	2.4.	Radioactivity Transport	4
	2.5.	Release Pathways	4
	2.6.	Dose Conversion Factors	5
	2.7.	Control Room Dose Model	5
	2.8.	EAB and LPZ Dose Model	5
	2.9.	Acceptance Criteria	5
3.	. A	ASSUMPTIONS	8
4.	DE	SIGN INPUT	9
	4.1.	^x / _o Calculations (Meteorology)	9
	4.2.	Plant Data	9
	4.3.	Control Room Data	10
	4.4.	Source Terms	10
5.	RE	FERENCES	11
6.	CA	LCULATIONS	12
	6.1.	Source Term Calculation	12
	6.2.	Dose Calculations	12
	6.3.	SJAE Release Pathway	15
7.	SU	MMARY AND CONCLUSIONS	17
8.	OW	VNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL DESIGN ANALYSIS	18

ATTACHMENTS:

- Α. Release Fraction Assessment Spreadsheet [3 pgs.]
- B.
- RADTRAD Output Files [27 pgs.] RADTRAD Source Term "NIF" Input [10 pgs.] RADTRAD Release Fraction "RFT" Input [2 pgs.] С.
- D.
- Ε. Steam Jet Air Ejector (SJAE) Path Assessment and formulae [2 pgs.]
- F. Computer Disclosure Sheets [2 pgs.]

1. PURPOSE/OBJECTIVE

The objective of this calculation is to re-analyze the radiological consequences of a Control Rod Drop Accident (CRDA) as described in UFSAR Section 15.4.10. The re-analysis is based on the use of Alternative Source Terms (AST) as defined in Regulatory Guide (RG) 1.183 (Ref. 2) Appendix C and with scenario guidance from NEDO-31400A (Ref. 19).

The design basis CRDA results in the release of radioactivity to the condenser. For the case where the condenser is isolated from the reactor after release of activity to the condenser (Scenario 1 of Ref. 19), the isolated condenser is assumed to exhaust at a rate of 1% per day, per Ref. 2, Appendix C.

However, per Ref. 2, Appendix C, footnote 2, forced flow pathways from the condenser must also be considered, such as un-isolated mechanical vacuum pumps or unprocessed air ejectors. These are evaluated as follows:

For Case 1 as per UFSAR Section 15.4.10.5, the main condenser mechanical vacuum pump is isolated following initiation of CRDA on Main Steam Line Radiation Monitors (MSLRM) high radiation signals. Therefore this path is not considered further. This is in accordance with the traditional CRDA scenarios and bounding accident considerations as defined in NEDO-31400A (Ref. 19).

For Case 2, where the condenser is not isolated from the reactor and the steam flow is sufficient for Steam Jet Air Ejector (SJAE) operation, the SJAE exhaust is processed by the charcoal delay beds in the Augmented Off-Gas System. While Ref. 2 does not require further analysis of this scenario, it is evaluated in this calculation as defined in Ref. 19, Scenario 2. The augmented off-gas system provides SJAE flow processing through charcoal delay beds which would eliminate iodine releases and greatly delay noble gas releases allowing for decay even with normal off-gas flow rates.

Finally, releases via steam flow to the turbine gland sealing system are considered, as has been done historically for this event, with all iodine and noble gases entering the gland seal condenser from the turbine seals released to the environment effectively immediately (well within 1/2 hour), without credit for any fission product deposition in the gland seal condenser.

2. METHODOLOGY AND ACCEPTANCE CRITERIA

2.1. General Description

In 1996 the Dresden Nuclear Station demonstrated that removal of the automatic MSIV isolation action following an MSLRM detection of high radiation was within regulatory practices. Exelon letter RS-01-183 (Ref. 13) indicated the acceptability of this for Extended Power Uprate (EPU) conditions. Now a CRDA, an event that would cause such radiation levels, will not lead to MSIV closure, and therefore cannot be credited in this analysis. However, as per the Dresden UFSAR Section 15.4.10.5 on Radiological Consequences of a CRDA, the main condenser's mechanical vacuum pump is isolated following the initiation of the CRDA, as the vacuum pump trips on MSLRM high radiation signals were not removed.

Following a CRDA, radioisotopes postulated to be released will be transported through the Main Steam Lines (MSLs) directly to the main steam condenser. With tripping of the MVPs by the MSLRMs, the release will be from condenser leakage (assumed at 1% per day) and Gland Sealing

CALCULATION NO. DRE02-0037	REV. NO. 001	PAGE NO. 4

Steam system leakage. The Gland Sealing Steam leakage is assumed, as historically done (per the analysis in References 11 and 12) and documented in the UFSAR, with the fraction of activity released from reactor coolant and transferred to the gland seal condenser as 0.0015. The activity is postulated to leak from the Turbine Building to the environment as an unfiltered ground release, corresponding to the MSIV leakage path used in the current AST LOCA calculations, with worst case X/Qs derived in Reference 8. The doses from either accident scenario should not exceed the acceptance criteria of the applicable regulatory guidance (Ref. 2).

A third scenario is for a CRDA assumed to occur during SJAE operation. In this Scenario, activity is released to a system of Charcoal Delay Beds, where Iodines and particulate are effectively removed and only delayed release of noble gas nuclides occurs. Although this release pathway (like the gland seal release) would be through the Station Chimney, for conservatism as was done for UFSAR Section 15.4.10.5, the release pathway is treated as a ground level release with higher X/Qs.

2.2. Core Source Term

For conservatism, the CRDA core source terms are those associated with 102% power, and for a reactor trip followed by an immediate restart. These source terms are per Reference 15.

2.3. Fuel Damage Assessment

The current design basis for fuel damage from a CRDA is not impacted by application of AST and is, therefore, unchanged. The fuel damage (number of rods with failed cladding and fuel melting) assumptions correspond to those of the Dresden UFSAR and the Extended Power Uprate described in the calculation of Reference 12.

2.4. Radioactivity Transport

Release fractions and transport fractions are per RG 1.183, Appendix C and Table 3, as shown in the spreadsheet in Attachment A to this calculation for both the main condenser and the gland seal condenser (where credit for fission product deposition is not taken).

2.5. Release Pathways

2.5.1. Turbine /Condenser 1% / day Leakage

Releases from the Turbine/Condenser are assumed to be at ground level without credit for dilution or holdup in the Turbine Building.

2.5.2. Steam Jet Air Ejector Discharge

When in operation the Steam Jet Air Ejectors discharge to the augmented off-gas system. This pathway is assessed in Attachment E, through the use of a spreadsheet crediting elimination of lodine releases and a delay of noble gas releases by the augmented off-gas system charcoal delay beds, per UFSAR Section 11.3.2.1.2.10. Although the releases would be through the Station Chimney, for conservatism they are assumed to be at ground level.

2.5.3. Gland Seal Condenser Release

For the Turbine Gland Seal Condenser release path, as per the analysis in References 11 and 12, the fraction of activity released from reactor coolant that is transferred to the gland seal condenser

CALCULATION NO. DRE02-0037 REV. NO. 001 PAGE NO. 5

is 0.0015. Although the releases would be through the Station Chimney, for conservatism they are assumed to be at ground level through the MSIV leakage path used in the current AST LOCA calculations.

2.6. Dose Conversion Factors

The revised Dose Conversion Factors (DCFs) from the U.S. Federal Guidance Report 11&12 (Ref. 17,18) are used for this analysis. The RADTRAD code inputs these values directly from its internal database, and when used in spreadsheet analyses they are input directly.

2.7. Control Room Dose Model

For the analysis performed by the RADTRAD code, the Dresden Unit 2&3 Control Room is modeled as a closed volume of 64,000 ft³. Although normal maximum flow into the CR is 2000 cfm + 10%, a Control Room changeover rate of 1 CR Volume per minute is used for conservatism and to allow for any unfiltered inleakage Flow into the CR is therefore assumed to be 64,000 CFM, and to balance the system for analytical purposes, an equal flow of clean air is considered to leave the CR. No credit is taking for any filtration of flows into the CR.

The CR $^{x}/_{Q}$'s have been determined in Reference 8. Worst-case ground level releases through the MSIV leakage path used in the current AST LOCA calculations are assumed. Having determined these dispersion factors, the total dose is modeled in RADTRAD 3.03 to determine the CR total dose throughout the duration of the accident. The methodologies significant to this analysis are the dose consequence analysis in NUREG/CR 6604 Section 2.3 (Ref. 5) and the Radioactive Decay Calculations, Section 2.4.3 (Ref. 5).

2.8. EAB and LPZ Dose Model

The EAB and LPZ $\frac{1}{2}$'s have been determined in Reference 8. Worst-case ground level releases through the MSIV leakage path used in the current AST LOCA calculations are assumed. The EAB and LPZ are located 800m and 8000m from the postulated release points. Because of the distance of these locations from the plant, the release is simplified to be all from one point for the duration of the accident. Having determined these dispersion factors, the total dose is modeled in RADTRAD 3.03 using the same RADTRAD analysis as used in determining the CR total dose.

2.9. Acceptance Criteria

Radiological doses resulting from a design basis CRDA for the control room operator and a person located at EAB or LPZ are to be less than the regulatory dose limits as given in Table 2.1.

Dose Type	Control Room (rem)	EAB and LPZ (rem)
TEDE Dose	5ª	6.25 ^b

Table	2.1.	Regulat	orv	Dose	Limits

Notes:

^a 10 CFR 50.67 (Ref. 10)

^b SRP 15.0.1 (Ref. 4), Reg. Guide 1.183 (Ref. 2)

Direct conformance with the relevant sections of the body of Regulatory Guide 1.183 (such as the Acceptance Criteria provided above) and all of the Assumptions in its Appendix C "Assumptions for Evaluating the Radiological Consequences of a BWR Rod Drop Accident" is provided by this analysis, as shown in the Conformance Matrix Table 2.2.

.

.

REV. NO. 001

PAGE NO. 6

.

Table 2.2: Conformance with RG 1.183 Appendix C (Control Rod Drop Accident)				
RG Section	RG Position	Dresden/Quad Cities Analysis	Comments	
1	Assumptions acceptable to the NRC staff regarding core inventory are provided in Regulatory Position 3 of this guide. For the rod drop accident, the release from the breached fuel is based on the estimate of the number of fuel rods breached and the assumption that 10% of the core inventory of the noble gases and iodines is in the fuel gap. The release attributed to fuel melting is based on the fraction of the fuel that reaches or exceeds the initiation temperature for fuel melting and on the assumption that 100% of the noble gases and 50% of the iodines contained in that fraction are released to the reactor coolant.	Conforms	100% of the noble gases and 50% of the iodines released from melted fuel. Other releases also based on Regulatory Position 3.	
2	If no or minimal fuel damage is postulated for the limiting event, the released activity should be the maximum coolant activity (typically 4 μ Ci/gm DE I-131) allowed by the technical specifications.	Conforms	Fuel damage is postulated. Therefore, coolant activity is neglected.	
3.1	The activity released from the fuel from either the gap or from fuel pellets is assumed to be instantaneously mixed in the reactor coolant within the pressure vessel.	Conforms		
3.2	Credit should not be assumed for partitioning in the pressure vessel or for removal by the steam separators.	Conforms		
3.3	Of the activity released from the reactor coolant within the pressure vessel, 100% of the noble gases, 10% of the iodine, and 1% of the remaining radionuclides are assumed to reach the turbine and condensers.	Conforms		
3.4	Of the activity that reaches the turbine and condenser, 100% of the noble gases, 10% of the iodine, and 1% of the particulate radionuclides are available for release to the environment. The turbine and condensers leak to the atmosphere as a ground-level release at a rate of 1% per day for a period of 24 hours, at which time the leakage is assumed to terminate. No credit should be assumed for dilution or holdup within the turbine building. Radioactive decay during holdup in the turbine and condenser may be assumed.	Conforms	Release rate of 1% per day for 24 hours. Decay is assumed in the condenser.	
3.5	In lieu of the transport assumptions provided in paragraphs 3.2 through	Conforms	Paragraphs 3.2 through 3.4	

REV. NO. 001

.

PAGE NO. 7

1

	Table 2.2: Conformance with RG 1.183 Appendix C (Control Rod Drop Accident)				
RG Section	RG Position	Dresden/Quad Cities Analysis	Comments		
	3.4 above, a more mechanistic analysis may be used on a case-by-case basis. Such analyses account for the quantity of contaminated steam carried from the pressure vessel to the turbine and condensers based on a review of the minimum transport time from the pressure vessel to the first main steam isolation (MSIV) and considers MSIV closure time.	-	above are utilized		
3.6	The iodine species released from the reactor coolant within the pressure vessel should be assumed to be 95% CsI as an aerosol, 4.85% elemental, and 0.15% organic. The release from the turbine and condenser should be assumed to be 97% elemental and 3% organic.	Conforms			
Foot- note 1	The activity assumed in the analysis should be based on the activity associated with the projected fuel damage or the maximum technical specification values, whichever maximizes the radiological consequences. In determining the dose equivalent I-131 (DE I-131), only the radioiodine associated with normal operations or iodine spikes should be included. Activity from projected fuel damage should not be included.	Conforms	Projected fuel damage is the limiting case.		
Foot- note 2	If there are forced flow paths from the turbine or condenser, such as unisolated motor vacuum pumps or unprocessed air ejectors, the leakage rate should be assumed to be the flow rate associated with the most limiting of these paths. Credit for collection and processing of releases, such as by off gas or standby gas treatment, will be considered on a case-by-case basis.	Conforms	Forced flow paths are considered and the most limiting path is determined.		

3. ASSUMPTIONS

- 1. Core inventory was based on a power level of 102% to account for uncertainty in the core power level.
- 2. An average power peaking factor of 1.7 per pin was assumed, as per Reference 14 (more conservative than UFSAR value of 1.5). 10% of the core inventory of noble gases and iodines are released from the fuel gap (Appendix C of Ref. 2). Release fractions of other nuclide groups contained in the fuel gap are detailed in Table 3 of Reg. Guide 1.183 (Ref. 2).
- 3. 0.77% of the fuel will melt during the CRDA (Ref. 19 and UFSAR Section 15.4.10.5). 100% of noble gases and 50% of the iodines contained in the melted fuel fraction are assumed to be released to the reactor coolant (Appendix C of Ref. 2). Fractions of other nuclides released from the melted fuel are used from Table 1 of Reg. Guide 1.183 (Ref. 2). Though these are described as LOCA values for fuel melt release, they are used to conservatively supplement for missing guidance in regards to the other nuclide groups.
- 4. The activity released from the fuel from either the gap or from fuel pellets is assumed to be instantaneously mixed with the reactor coolant within the pressure vessel (Ref. 2, 4).
- 5. 100% of all noble gases, 10% of the iodines, and 1% of remaining nuclides are transported to the turbine/condenser (Ref. 2, 4).
- 6. Of the activity that reaches the turbine and condenser, 100% of the noble gases, 10% of the iodine, and 1% of the particulate nuclides are available for release to the environment. (Appendix C of Ref. 2). However, for the gland seal condenser, it is assumed due to the forced flow pathway for releases that 100% of all of the activity that reaches this condenser are available for release to the environment.
- 7. All leakage from the main steam turbine condenser leaks to the atmosphere as a ground level release at a rate of 1% per day through the worst case LOCA MSIV release points, for a period of 24 hours (Ref. 2, 4).
- 8. The control room occupancy factor was assumed to be 1 because the duration of this analysis of the CRDA is 24 hours. Therefore the occupancy factor is essentially ignored.

4. DESIGN INPUT

4.1. ^x/_Q Calculations (Meteorology)

The CR $x_{l_{Q}}$ values input to RADTRAD were taken from ARCON96 results of Exelon (ComEd) Design Calculation DRE04-0030, Rev. 1. The $x_{l_{Q}}$ calculated by ARCON96 for the worst-case MSIV release point to the Control Room fresh air intake is used for the 1% per day condenser leakage.

The CR atmospheric relative concentrations used are as follows (Ref. 8):

 $x/_{Q} = 1.30E-03 \text{ sec/m}^{3}$ (0-2 hours) $x/_{Q} = 1.06E-03 \text{ sec/m}^{3}$ (2-8 hours) $x/_{Q} = 4.49E-04 \text{ sec/m}^{3}$ (8-24 hours)

The EAB and LPZ $\frac{1}{2}$ values input to RADTRAD were taken from PAVAN results of Exelon (ComEd) Design Calculation DRE04-0030, Rev. 1. They reflect the worst-case $\frac{1}{2}$ which are the MSIV release pathway values at ground-level. The EAB/LPZ atmospheric relative concentrations used are as follows (Ref. 8):

EAB $x/q = 2.51E-04 \text{ sec/m}^3$ (0-2 hours)

LPZ

 $x/_{Q} = 2.63E-05 \text{ sec/m}^{3}$ (0-2 hours) $x/_{Q} = 1.09E-05 \text{ sec/m}^{3}$ (2-8 hours) $x/_{Q} = 7.02E-06 \text{ sec/m}^{3}$ (8-24 hours)

4.2. Plant Data

٠	Power Level, (102% of 2957 to account for uncertainty) (Ref. 12)	3016 MWt
•	Radial Peaking Factor (Ref. 14)	1.7
•	Number of Failed Fuel Rods, bounding case (Ref. 7 and UFSAR Section 15.4.10.5, for bounding 7 x 7 fuel array	y) 850
•	Isotopic Release Fractions, as per Reg. Guide 1.183 (Ref. 2)	See Attachment A
•	Volume of primary system (MSL and dome) (Conservatively reduced from 8,431 ft ³) (Ref. 11)	5,000 ft ³
•	Vapor space volume of the condenser (UFSAR 15.4.10.5) (Ref. 3)	55,000 ft ³
•	Gland Seal Condenser Release Fraction (Ref. 11)	.0015

4.3. Control Room Data

•	Volume of Control Room Emergency Zone, ft ³ (Ref. 3, 7)	81,000
٠	Volume of Control Room Proper, ft ³ (Ref. 3, 7)	64,000
•	Control Room Normal Intake Flow, scfm	64,000

(Smaller Control Room volume is used, as the flow rate maximizes inhalation doses, and for interior cloud doses, the appropriate volume is the control room proper).

4.4. Source Terms

The AST values used in this analysis were derived using guidance outlined in Reg. Guide 1.183. A list of 60 core isotopic nuclides and their curie per megawatt activities were extracted from Appendix D of the GE task report No. GE-NE-A22-00103-64-01 (Ref. 15) for input into the RADTRAD "NIF" (see Attachment C). The release fractions associated with all of these nuclide groups, as detailed in Reg. Guide 1.183, were applied to their given groups in Attachment A, and subsequently input into the appropriate RADTRAD "RTF", as seen in Attachment D. RADTRAD uses these files combined with the power of 3016 MWt (102% power, to account for uncertainty) to develop the source terms for this CRDA.

5. **REFERENCES**

- 1. NUREG-1465, "Accident Source Terms for Light-Water Nuclear Power Plants", February 1995
- 2. USNRC Regulatory Guide 1.183, "Alternative Source Terms for Evaluating Design Basis Accidents at Nuclear Power Reactors", July 2000
- 3. Dresden Unit 2 & 3 UFSAR, Rev. 4.
- 4. USNRC SRP 15.0.1, Rev. 0, Radiological Consequences Using Alternate Source Terms.
- 5. NUREG/CR-6604, "RADTRAD: A Simplified Model for RADionuclide Transport and Removal And Dose Estimation", April1998, and Supplement 1, June 1999.
- 6. TID 14844, "Calculation of Distance Factors for Power and Test Reactor Sites", March, 1962.
- 7. Exelon (ComEd) Design Analysis DRE00-0028, Analytic Limit for MSLRM Reading Following a CRDA, Rev. 1.
- 8. Exelon (ComEd) Design Analysis DRE04-0030, Atmospheric Dispersion Factors (X/Qs) for Accident Release, Rev. 1.

9. Deleted

10. 10 CFR 50.67

- 11. Bechtel Power Corporation Design Calculation DR-357-M-004, "Control Rod Drop Accident/ MSLRM Removal", Rev. 0.
- 12. Exelon (ComEd) Design Analysis DRE00-0071, "Impact of Extended Power Uprate on Site Boundary and Control Room Doses for LOCA and Non-LOCA Events", Rev. 0.
- 13. Exelon Letter RS-01-183 to the USNRC, "Additional Radiation Dose Information Supporting the License Amendment Request to Permit Uprated Power Operation", Aug. 31, 2001.
- 14. NEDC-32868P, GE14 GESTAR Compliance Document
- 15. GE Task Report No. GE-NE-A22-00103-64-01, Rev. 0, Project Task Report: "Dresden and Quad Cities Asset Enhancement Program - Task T0802: Radiation Sources and Fission Products", August 2000.
- 16. Deleted
- 17. U.S. Federal Guidance Report No.11, "Limiting Values of Radionuclide Intake and Air Concentration and Dose Conversion Factors for Inhalation, Submersion, and Ingestion", 1988.
- 18. U.S. Federal Guidance Report No.12, "External Exposure to Radionuclides in Air, Water, and Soil", 1993.
- 19. NEDO-31400A Class I, "Safety Evaluation for Eliminating the BWR MSIV Closure Function and Scram Function of the MSLRM", October 1992

6. CALCULATIONS

6.1. Source Term Calculation

The source terms are calculated by RADTRAD, using input values of core activity (as a function of power), nuclide release fractions, and core power. For this analysis, a list of 60 core isotopic nuclides and their curie per megawatt activities were extracted from Appendix D of the GE task report No. GE-NE-A22-00103-64-01 (Ref. 15) for input into the RADTRAD "NIF" (see Attachment C). The AST release fractions associated with all of these nuclide groups are derived using guidance outlined in Reg. Guide 1.183, as applied in Attachment A. The final gap release and fuel melt release fraction calculated in that attachment, for each nuclide group, is then input into the appropriate RADTRAD "RTF", as seen in Attachment D. RADTRAD applies the input core power of 3016 MWt (102% power, to account for uncertainty) (Ref. 12) to these two input files to develop the core source term activities for this CRDA. Radioactive decay and daughter products are considered in RADTRAD, with this RADTRAD option turned "on".

6.2. Dose Calculations

The RADTRAD v. 3.03 computer code is used to determine Dresden 2&3 CRDA doses at the three dose points cited in Reg. Guide 1.183 (Ref. 2); the Exclusion Area Boundary (EAB), Low Population Zone (LPZ), and Control Room. RADTRAD is a simplified model of <u>RAD</u>ionuclide <u>Transport and Removal And Dose Estimation developed for the NRC and endorsed by the NRC as an acceptable methodology for reanalysis of the radiological consequences of design basis accidents.</u>

RADTRAD estimates the releases using the Reference 2 Alternate Source Term source terms and assumptions. The RADTRAD code uses a combination of tables and/or numerical models of source term reduction phenomena to determine the time-dependent dose at user-specified locations for a given accident scenario. The code system also provides the inventory, decay chain, and dose conversion factor tables needed for the dose calculation. The technical basis for the RADTRAD code is documented in Section 2 of NUREG/CR-6604 (Ref. 5).

Separate RADTRAD runs are made for the main condenser and the gland seal condenser leakages. This output is provided in Attachment B. The following is a parameter and descriptions listing of input into the RADTRAD models:

A. Compartments

- 1. Reactor Coolant This compartment represents the cooling water within the primary containment vessel.
 - a. Compartment type Other since it is not the environment or control room.
 - b. Volume 1 ft³ This nominal value, used to simplify input, is based on there being a fractional leak rate associated with this compartment.
 - c. Source term fraction 1.0 All of the source term is generated in the reactor coolant.
 - d. Compartment features none selected.
- 2. Condenser This compartment is the internal volume of the steam condenser.
 - a. Compartment type Other since it is not the environment or control room.
 - b. Volume $-55,000 \text{ ft}^3 \text{actual free volume.}$
 - c. Source term fraction -0.0
 - d. Compartment features none selected.

REV. NO. 001

PAGE NO. 13

3. Environment

a. Compartment type – Environment

- 4. Control Room
 - a. Compartment type Control Room
 - b. Volume $64,000 \text{ ft}^3 \text{Proper volume}.$
 - c. ---Source term fraction 0.0
 - d. Compartment features none selected.
- B. Transfer Pathways Main Condenser
 - 1. Filtered Flow, Reactor Coolant to Condenser
 - a. From Compartment 1 Reactor Coolant
 - b. To Compartment 2 Condenser
 - c. Transfer mechanism "Filter" selected
 - d. Filter Efficiency Panel Flow rate 275 cfm With the Reactor Coolant volume set to the nominal value of 1 ft³, this flow rate transfers 99% of the intended activity to the Condenser within 1 second.
 - e. Filter Efficiency Panel Filter efficiency is 0.0%, as no filtration is considered for this accident analysis.
 - f. Active Pathway Yes
 - 2. Filtered Flow, Condenser to Environment
 - a. From Compartment 2 Condenser
 - b. To Compartment 3 Environment
 - c. Transfer mechanism "Filter" selected -
 - d. Filter Efficiency Panel Flow rate 0.3819 cfm for 0.0-24 hrs This indicates the activity leaks from the Main Condenser at a rate of 1% per day for the duration of the accident.
 - e. Filter Efficiency Panel Filter efficiency is 0.0%, as no filtration is considered for this accident analysis.
 - f. Active Pathway Yes
 - 3. Filtered Flow, Environment to Control Room
 - a. From Compartment 3 Environment
 - b. To Compartment 4 Control Room
 - c. Transfer mechanism "Filter" selected -
 - d. Filter Efficiency Panel Flow rate 64,000 cfm Artificially high CR intake flowrate of one air change per minute, to conservatively allow for any unfiltered inleakage, for the duration of the accident.
 - e. Filter Efficiency Panel Filter efficiency is 0.0%, as no filtration is considered for this accident analysis.
 - f. Active Pathway Yes
 - 4. Filtered Flow, Control Room to Environment
 - a. From Compartment 4 Control Room
 - b. To Compartment 3 Environment
 - c. Transfer mechanism "Filter" selected -
 - d. Filter Efficiency Panel Flow rate 64,000 cfm for the duration of the accident.

	1 5 5 4 3 4 6 6 6 6	
I CATCULATION NO DRE02-0037	IREV NO 001	I PAGENO 1
CRECOLATION NO. DREDZ-0057	10.110.001	

e. Filter Efficiency Panel – Filter efficiency is entered as 100.0% iodine chemical for all time periods. This is the exit from the control room to the environment; the filtration prevents a double counting of the iodine release.

4

- f. Active Pathway Yes
- C. Transfer Pathways Gland Seal Condenser
 - 5. Filtered Flow, Reactor Coolant to Condenser
 - a From Compartment 1 Reactor Coolant
 - b To Compartment 2 Condenser
 - c Transfer mechanism "Filter" selected
 - d Filter Efficiency Panel Flow rate 275 cfm With the Reactor Coolant volume set to the nominal value of 1 ft³, this flow rate transfers 99% of the intended activity to the Condenser within 1 second.
 - e Filter Efficiency Panel Filter efficiency is 0.0%, as no filtration is considered for this accident analysis.
 - f Active Pathway Yes
 - 6. Filtered Flow, Environment to Control Room
 - a From Compartment 3 Environment
 - b To Compartment 4 Control Room
 - c Transfer mechanism "Filter" selected -
 - d Filter Efficiency Panel Flow rate 64,000 cfm Artificially high CR intake flowrate of one air change per minute, to conservatively allow for any unfiltered inleakage, for the duration of the accident.
 - e Filter Efficiency Panel Filter efficiency is 0.0%, as no filtration is considered for this accident analysis.
 - f Active Pathway Yes
 - 7. Filtered Flow, Control Room to Environment
 - a From Compartment 4 Control Room
 - b To Compartment 3 Environment
 - c Transfer mechanism "Filter" selected -
 - d Filter Efficiency Panel Flow rate 64,000 cfm for the duration of the accident.
 - Filter Efficiency Panel Filter efficiency is entered as 100.0% iodine chemical for all time periods. This is the exit from the control room to the environment; the filtration prevents a double counting of the iodine release.
 - f Active Pathway Yes
 - 8. Filtered Flow, Reactor Coolant to Environment
 - a. From Compartment 1 Reactor Coolant
 - b. To Compartment 3 Environment Through Gland Seal system
 - c. Transfer Mechanism "Filter" selected
 - d. Filter Efficiency Panel Flow Rate 0.4125 cfm 0.15% of the 275 cfm nominal value is chosen as the rate to evacuate activity from the coolant to the gland seal steam condenser, as described on sheet 13 of Reference 11.
 - e. Filter Efficiency Panel Filter efficiency is 0.0%, as no filtration is considered for this release path.
 - f. Active Pathway Yes
- D. Dose Locations

- 1. Exclusion Area Boundary
 - a. In Compartment 3 Environment
 - b. Breathing Rate Default not checked
 - c. x_{Q} –2.51E-04 sec/m³ for 0-2 hrs This represents the conservatively chosen MSIV LOCA release points.
 - d. Breathing Rate 3.47E-04 m³/sec this is the Reg. Guide 1.183 specified breathing
 - -----rate, with the traditional three digit accuracy (RADTRAD default). This value is entered from time 0 to the end of the accident.
- 2. Low Population Zone
 - a. In Compartment 2 Environment
 - b. Breathing Rate Default not checked
 - c. ^x/_Q –2.63E-05 sec/m³ for 0-2 hrs; 1.09E-05 sec/m³ for 2-8 hrs; 7.02E-06 sec/m³ for 8-24 hrs; These represent the conservatively chosen MSIV LOCA release points.
 - d. Breathing Rate 3.47E-04 m³/sec for 0-8 hrs; 1.75E-04 m³/sec for 8-24 hrs this is the Reg. Guide 1.183 specified breathing rate, with the traditional three digit accuracy (RADTRAD default), assuming a time dependent reduction.
- 3. Control Room
 - a. In Compartment 3 Control Room
 - b. Breathing Rate Default not checked
 - c. $x_{Q} = 1.30E-03$ sec/m³ for 0-2 hrs; 1.06E-03 sec/m³ for 2-8 hrs; and 4.49E-04 sec/m³ for 8-24 hrs These represent the conservatively chosen MSIV LOCA release points.
 - d. Breathing Rate 3.47E-04 m³/sec for 0-24 hrs this is the Reg. Guide 1.183 specified breathing rate, with the traditional three digit accuracy (RADTRAD default).
 - e. Occupancy Factor -1 For the duration of the accident.
- E. Source Term
 - a. The "Dres QDC Source Terms.nif" file [Attachment C] reflects the Dresden core activities, and is modified to reflect the "Alternate Source Term" activities provided by Reference 15.
 - b. The power level of 3016.00 MWt, as per Section 4.2 above, reflects a core at 102% power, accounting for uncertainty.
 - c. There is no credited delay in the release of activity.
 - d. The RADTRAD radioactive decay and daughter products option is turned "on".
 - e. The dre-qdc-crda.rft files [Attachment D] is designed to reflect gap activity fractions per RG 1.183, Appendix C, with one for the main condenser and one (without condenser fission product deposition credit) for the gland seal condenser.

The source terms, which are calculated in Section 6.1 above, are input as a separate RADTRAD "NIF" file. This file is included in Attachment C.

Washington Group International has pre-qualified RADTRAD for application to perform such calculations, as documented in the Computer Disclosure Sheet of Attachment F. The new design basis RADTRAD simulations utilized the design input parameters as provided in Section 4.

6.3. SJAE Release Pathway

The calculation of the dose consequence from the SJAE release pathway was performed using the spreadsheet in Attachment E. The SJAE Release Pathway dose is dependent only upon the noble gas alternate source term, because all iodine and particulate nuclides are eliminated by the charcoal delay beds. The initial core activity for each noble gas, calculated at 3016 MWt (Ref. 12),

ONT OTH A TRONTING DD DOG 0000	
$\Gamma^{*}\Delta \Gamma \Gamma^{*} \Gamma \Gamma \Delta \Gamma \Gamma \Gamma \Gamma \Lambda \Lambda$	
CALCULATION NO. DILLUZ-0037	I I AULINO. 10 I

is then multiplied by the total noble gas release fraction calculated in Attachment A. This activity is then decayed for the period of time that it is delayed in the charcoal beds:

$$\alpha = \alpha_o e^{-\lambda t}$$

where:

 α = nuclide activity after decay period (Ci) α_o = initial nuclide activity (Ci) e = exponential constant λ = decay constant (hours⁻¹) t = time of delay (hours)

It is important to note that the two noble gases in the source term of this plant, Krypton and Xenon, are characterized by different delay periods.

When the decayed activities are found, the dose conversion factors (DCF), dispersion factor $(x/_{Q})$, and (for the control room dose location) geometry factors are applied. The resulting dose is what is seen via the SJAE release pathway at each respective dose location following a CRDA. See Attachment E. This does not include the release associated with steam flow to the turbine gland sealing system, which is calculated separately as described in Section 6.2.

REV. NO. 001

7. SUMMARY AND CONCLUSIONS

Table 3 provides the Scenario 2 results from the RADTRAD code, as well as the prescribed dose acceptance criteria.

Table 7.1.	RADTRAD Anal	vsis Results and	Comparisons to	the Acceptance Criteria
		,		

	EAB	LPZ	CR
Prescribed Dose Limits (TEDE)/ Basis Document	6.25 rem/ RG 1.183	6.25 rem/ RG 1.183	5 rem/ 10CFR50.67
RADTRAD Analysis Results in Attachment B (main condenser leakage)	0.132 rem	0.0385 rem	3.00 rem
RADTRAD Analysis Results in Attachment B (gland seal condenser leakage)	0.263 rem	0.0276 rem	1.01 rem
SJAE Release from Attachment E	0.292 rem	0.0306 rem	0.0544 rem
Total Main and Gland Seal Condenser Leakage	0.395 rem	0.0661 rem	4.01 rem
Total Gland Seal Condenser Leakage and SJAE Release	0.555 rem	0.0582 rem	1.06 rem

All doses are acceptable.

CALCULATION NO. DRE02-0037 REV. NO. 001

OWNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL DESIGN 8. ANALYSIS

DESIGN ANALYSIS NO. DRE02-0037 REV: 1

		Yes	No	N/A
1.	Do assumptions have sufficient rationale?	Ľ		
2.	Are assumptions compatible with the way the plant is operated and with the licensing basis?			
3.	Do the design inputs have sufficient rationale?			
4.	Are design inputs correct and reasonable?			
5.	Are design inputs compatible with the way the plant is operated and with the licensing basis?	Ľ		
6.	Are Engineering Judgments clearly documented and justified?			
7.	Are Engineering Judgments compatible with the way the plant is operated and with the licensing basis?	ď		
8.	Do the results and conclusions satisfy the purpose and objective of the Design Analysis?			
9.	Are the results and conclusions compatible with the way the plant is operated and with the licensing basis?	ľ		
10.	Does the Design Analysis include the applicable design basis documentation?			
11.	Have any limitations on the use of the results been identified and transmitted to the appropriate organizations?	R		
12.	Are there any unverified assumptions?		Ľ	
13.	Do all unverified assumptions have a tracking and closure mechanism in place?			U
14.	Have all affected design analyses been documented on the Affected Documents List (ADL) for the associated Configuration Change?	ď		
15.	Do the sources of inputs and analysis methodology used meet current technical requirements and regulatory commitments? (If the input sources or analysis methodology are based on an out-of-date methodology or code, additional reconciliation may be required if the site has since committed to a more recent code)	Ľ		
16.	Have vendor supporting technical documents and references (including GE DRFs) been reviewed when necessary?	D2		
EXELO	N REVIEWER: [].MSCIST MARINE DATE: Print Sign	8/13	105	_

onstants						<u> </u>				·	
Value	<u> </u>		Description	· · · · ·		<u> </u> -,−	Basis		<u> </u>		
850			Failed fuel ro	ds - boundi	ng case	<u>} ─ ─</u> ──	DRE00-00	71/QDC-0000-I	v-1020		<u> </u> _
45612			Fuel rods in f	ull core	r <u> </u>		DRE00-007	71/QDC-0000-!	V-1020	<u>├</u>	t
0.018635		·	Fraction of ro	ds in core v	vith gap act	ivity release	850/45612				<u>├</u>
1.7		· · ·	Peaking facto	r		г <u>. </u>	NEDC-328	68P			
0.03168			Gap activity r	elease pote	ntial with p	eaking	1.7 x .0186	35		<u>├</u> ────	<u> </u>
0.0077		[Fraction of fu	el in failed r	ods assum	ed to melt	DRE00-00	71/QDC-0000-1	N-1020	<u>├───</u>	<u>├</u> ────
0.000244			Melted fuel a	tivity release	se potentia	with peaking	.03168 x .0	077		<u></u>	<u> </u>
										F	
				·		·					
						i					<u> </u>
		Fraction					Activity		<u>_</u>	;	,
Activity	Fraction	Available fo)r				Fraction				<u> </u>
Fraction	Released	Release	Duration (h):				Released	Duration (h):			
teleased	from	from	1.0000E-03				from	1.0000E-03			
rom Gap ¹	Vessel ²	Condense	Noble Gases				Melted Fuel	Noble Gases:		[
0.1	1	1	3.1680E-03	-			0.9	2.1954E-04			†
			lodine:					lodine:			
0.1	0.1	0.1	3.1680E-05				0.45	1.0977E-06			<u> </u>
			Cesium:					Cesium:		1	
0.12	0.01	0.01	3.8016E-07				0.2	4.8788E-09		1	
			Tellurium:					Tellurium:		· · · ·	
0.	0.01	0.01	0.0000E+00				0.05	1.2197E-09			
			Strontium:					Strontium:			
0	0.01	0.01	0.0000E+00				0.02	4.8788E-10			
			Barium:					Barium:			
0	0.01	0.01	0.0000E+00				0.02	4.8788E-10			
			Ruthenium:					Ruthenium:			
0	0.01	0.01	0.0000E+00				0.0025	6.0984E-11			
			Cerium:					Cerium:			
0	0.01	0.01	0.0000E+00				0.0005	1.2197E-11			
			Lanthanum:					Lanthanum:			
0	0.01	0.01	0.0000E+00		I	L	0.0002	4.8788E-12		L	
	Í	ļ			Ļ			·		l	
		L			<u> </u>	<u> </u>				<u> </u>	<u> </u>
	L	I							·		
	l		1		l	L				L	<u> </u>
From App	endix C, pa	aragraph 1.	(for Noble gas	es and lodi	ne) and Ta	ble 3 (for Ce	sium, an Al	kali Metal) of R	egulatory (Guide 1.183	
From App	endix C, pa	aragraph 3.3	3 of Regulatory	Guide 1.1	83						
From App	endix C, pa	aragraph 3.4	4 of Regulatory	Guide 1.1	83	· · ·				<u> </u>	[
From Rer	Guide 1 1	83 Table 1	Farly In-yess	el Release	Column w	ith 50% tota	I lodine rele	ase ner Annen	dix C nara	oraph 1	1

-

Constants	:								
Value	<u> </u>		Description				Basis		
850			Failed fuel rods - bo	unding case			DRE00-0071	/QDC-0000-N-1	020
45612		·	Fuet rods in full core				DRE00-0071	/QDC-0000-N-1	020
0.018635			Fraction of rods in c	ore with gap activit	v release potential		850/45612		<u> </u>
1.7			Peaking factor		í		NEDC-32868	3P	[
0.03168			Gap activity release	potential with peal	king		1.7 x .01863	5	
0.0077			Fraction of fuel in fa	iled rods assumed	to melt		DRE00-0071	/QDC-0000-N-1	020
0.000244	· ·		Melted fuel activity	release potential wi	th peaking		.03168 x .00	77	
		····	······································		°		· · · · · · · · · · · · · · · · · · ·		
			·						<u> </u>
		Fraction					Activity		
Activity	Fraction	Available for					Fraction		· ·
Fraction	Released	Release	Duration (h):	•			Released	Duration (h):	
Released	from	from	1.0000E-03				from	1.0000E-03	
rom Gap ¹	Vessel ²	Condenser ³	Noble Gases:				Melted Fuel	Noble Gases:	
0.1	1	1	3.1680E-03	· · · · · · · · · · · · · · · · · · ·	·		0.9	2.1954E-04	
			lodine:					lodine:	
0.1	0.1	.1	3.1680E-04				0.45	1.0977E-05	
			Ceslum:					Cesium:	
0.12	0.01	1	3.8016E-05	- <u></u>		-	0.2	4.8788E-07	
			Tellurium:					Tellurium:	
0	0.01	1	0.0000E+00	•			0.05	1.2197E-07	
			Strontium:					Strontium:	-
0	0.01	1	0.0000E+00			_	0.02	4.8788E-08	
			Barium:					Barium:	
0	0.01	1	0.0000E+00				0.02	4.8788E-08	
			Ruthenium:			•		Ruthenium:	
0	0.01	1	0.0000E+00	·····			0.0025	6.0984E-09	h
			Cerium:					Cerium:	
0	0.01	1	0.0000E+00				0.0005	1.2197E-09	-
			Lanthanum:		· · ·			Lanthanum:	
0	0.01	1	0.0000E+00	·			0.0002	4.8788E-10	
							<u>····</u>		
				·					
From App	endix C, pa	ragraph 1. (fo	r Noble gases and I	odine) and Table 3	(for Cesium, an Alka	ali Metal) of	Regulatory C	Suide 1.183	
From Apr	endix C. na	ragraph 3.3 o	f Regulatory Guide	1.183	,		/		ŀ
Without P	egulatory G	uide 1 183 P	aragraph 3.4 credit f	or no deposition in	the Gland Seal Con	denser for fr	med release	!	
maiourn	cyulatory c	1,100 PC	agaph 0.4 cieurn	or no deposition in	ine Siand Sear Colli	Jenser IOF N	1000 100830		l

CRDA AST RADTRA	1				1	1		I
								· · · · · · · · · · · · · · · · · · ·
Constants:		1					· · · · · · · · · · · · · · · · · · ·	
Value			Description		<u>_</u>		Basis	
850			Failed fuel rods - bounding case			— <u> </u>	DRE00-0071/QDC-0000-I	
45612			Fuel rods in full core				DRE00-0071/QDC-0000-I	
=A5/A6			Fraction of rods In core with gap activi				850/45612	
1.7		1	Peaking factor]	NEDC-32868P	
=A7*A8		· · · · · · · · · · · · · · · · · · ·	Gap activity release potential with pea				1.7 x .018635	
0.0077	•		Fraction of fuel in failed rods assumed				DRE00-0071/QDC-0000-I	1
=A9*A10			Melted fuel activity release potential w			· · · ·	.03168 x .0077	
							F	
	•						<u>_</u>	
								1
		Fraction			-	-	Activity	
Activity	Fraction	Available for					Fraction	
Fraction	Released	Release	Duration (h):				Released	Duration (h):
Released	from	from	0.001				from	0.001
from Gap	Vessel ²	Condenser	Noble Gases:		_		Melted Fuel	Noble Gases:
0.1	1	1	=A\$9*A20*B20*C20				=(1-A20)	=A\$11*H20*B20*C20
			lodine:					lodine:
0.1	0.1	1	=A\$9*A22*B22*C22			-	0.45	=A\$11*H22*B22*C22
		•	Cesium:		·			Cesium:
0.12	0.01	1	=A\$9*A24*B24*C24 -				0.2	=A\$11*H24*B24*C24
			Tellurium:					Tellurium:
0	0.01	1	=A\$9*A26*B26*C26	•			0.05	=A\$11*H26*B26*C26
			Strontium:					Strontium:
0	0.01	1	=A\$9*A28*B28*C28				0.02	=A\$11*H28*B28*C28
			Barlum:					Barium:
0	0.01	1	=A\$9*A30*B30*C30				0.02	=A\$11*H30*B30*C30
			Ruthenium:					Ruthenium:
0	0.01	1	=A\$9*A32*B32*C32				0.0025	=A\$11*H32*B32*C32
			Cerium:					Cerium:
0	0.01	1	=A\$9*A34*B34*C34				0.0005	=A\$11*H34*B34*C34
			Lanthanum:		<u> </u>			Lanthanum:
0	0.01	1	=A\$9*A36*B36*C36				0.0002	=A\$11*H36*B36*C36
	l							
					·	<u></u>		
J		· · · · · · · · · · · · · · · · · · ·	·			ļ		
·	[<u> </u>				l		
' From Appendix C, pa		<u> </u>						
From Appendix C, pa								
³ Without Regulatory C								
From Reg. Guide 1.1		· · · · · · · · · · · · · · · · · · ·				1	· · ·	1
to account for the 50%		<u> </u>						
	·		L			<u> </u>		

.

.

```
RADTRAD Version 3.03 (Spring 2001) run on 8/12/2005 at 20:55:26
 *****
 ****************
                  File information
 ***************
                   = P:\Users\Nuc\Exelon EOC\Discipline Files\Process\AST\Dresden &
Plant file
Quad Cities AST\DRE CRDA\DRE-CRDA (Gland Seal only) (1CR airchange per min.psf
                   = p:\users\nuc\exelon eoc\discipline files\process\ast\dresden &
 Inventory file
quad cities ast\dre crda\dres qdc source terms.nif
                  = p:\users\nuc\exelon eoc\discipline files\process\ast\dresden &
Release file
quad cities ast/dre crda/dre-qdc-crda-gland seal condenser.rft
Dose Conversion file = c:\program files\radtrad3-03\defaults\fgr11&12.inp
    #####
                  #####
                                    #####
                                                  #####
            ####
                          #
                             #
                                  #
                                           #
                                                #
                  #
                          #
                            ##
                                  #
                                           #
                                                #
                                                    #
    #
        #
                                    #
                                         #
                          #
                             Ħ
                                  #
                                           #
                                                ŧ
                                                    #
    #
        #
                                    #
                                         £
                                                    #
    #####
                          #
                             #
                                  ₽
                                    쁖쁖
                                           #
                                                ŧ
                  ####
                                                    #
                  #
                          #
                             #
                                  #
                                           #
                                                #
    #
                                                    #
                             #
                                                #
    #
                  #
                          #
                             #
                                                    Ŧ
    #
            ####
                  #
                          #
                                    #
                                            ####
Radtrad 3.03 4/15/2001
Dresden Units 263 CRDA with Gland Sealing Steam System Operation only (1CR airchange per
min)
Nuclide Inventory File:
p:\users\nuc\exelon eoc\discipline files\process\ast\dresden & quad cities ast\dre
crda/dres qdc source terms.nif
 Plant Power Level:
 3.0160E+03
Compartments:
  4
Compartment 1:
Reactor Coolant
  3
 1.0000E+00
  0
  0
  0
  0
  Ω
Compartment 2:
 Condenser
  3
 5.5000E+04
  0
  0
  0
  0
```

DRE02-0037, Rev. 1, Attachment B, Page B1 of B27

0 Compartment 3: Environment 2 0.0000E+00 0 0 0 0 0 Compartment 4: Control Room 1 6.4000E+04 0 0 0 0 0 Pathways: 5 Pathway 1: Reactor Coolant to condenser 1 2 2 Pathway 2: Condenser to environment 2 . 3 2 Pathway 3: Environment to Control Room 3 4 2 Pathway 4: Control Room to Environment 4 3 2 Pathway 5: Reactor Coolant to Environment 1 3 2 End of Plant Model File Scenario Description Name: Plant Model Filename: Source Term: 1 1.0000E+00 1 c:\program files\radtrad3-03\defaults\fgr11&12.inp p:\users\nuc\exelon eoc\discipline files\process\ast\dresden & quad cities ast\dre crda\dre-qdc-crda-gland_seal_condenser.rft

DRE02-0037, Rev. 1, Attachment B, Page B2 of B27

```
0.0000E+00
  0
                4.8500E-02
                              1.5000E-03
                                             1.0000E+00
  9.5000E-01
Overlying Pool:
  0
  0.0000E+00
  0
  0
  0
  0
Compartments:
  4
Compartment 1:
  0
  1
  0
  0
  0
  0
  0
  0
  0
Compartment 2:
  0
  1
  0
  0
  0
  0
  0
  0
  0
Compartment 3:
  0
  1
  0
  0
  0
  0
  0
  0
  0
Compartment 4:
  0
  1
  0
  0
  0
  0
  0
  0
  0
Pathways:
  5
Pathway 1:
  0
  0
```

DRE02-0037, Rev. 1, Attachment B, Page B3 of B27

0 0 1 3					
0.0000E+00 1.6670E-01 2.4000E+01 0 0 0 0 0 0 0 Pathway 2:	2.7500E+02 0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00 0.0000E+00	
0 0 0 0 0 1 2				•	
0.0000E+00 2.4000E+01 0 0 0 0	0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00	
Pathway 3: 0 0 0 0 0 1 2			•		
0.0000E+00 2.4000E+01 0 0 0 0 0	6.4000E+04 0.0000E+00	0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00	
Pathway 4: 0 0 0 0 0 1 2	·				
0.0000E+00 2.4000E+01 0	6.4000E+04 0.0000E+00	1.0000E+02 0.0000E+00	1.0000E+02 0.0000E+00	1.0000E+02 0.0000E+00	

DRE - Gland Seal

DRE02-0037, Rev. 1, Attachment B, Page B4 of B27



DRE02-0037, Rev. 1, Attachment B, Page B5 of B27

2.4000E+01 0.0000E+00 1 2 0.0000E+00 1.0000E+00 2.4000E+01 0.0000E+00 Effective Volume Location: 1 4 0.0000E+00 1.3000E-03 2.0000E+00 1.0600E-03 8.0000E+00 4.4900E-04 2.4000E+01 0.0000E+00 Simulation Parameters: 5 0.0000E+00 1.0000E-04 1.0000E-02 1.0000E-03 1.0000E-01 1.0000E-02 1.0000E+00 1.0000E+00 2.4000E+01 0.0000E+00 Output Filename: P:\Users\Nuc\Exelon EOC\Discipline Files\Process\AST\Dresden & Quad Cities AST\DRE CRDA\DRE-CRDA (Gland Seal only) (1CR airchange per min.o0 1 2 1 0 1

End of Scenario File

DRE02-0037, Rev. 1, Attachment B, Page B6 of B27

DRE - Gland Seal

RADTRAD Version 3.03 (Spring 2001) run on 8/12/2005 at 20:55:26 ***** Plant Description *** Number of Nuclides = 60Inventory Power = 1.0000E+00 MWth Plant Power Level = 3.0160E+03 MWth Number of compartments 4 Compartment information 1.0000E+00 Compartment number 1 (Source term fraction = Name: Reactor Coolant Compartment volume = 1.0000E+00 (Cubic feet) Compartment type is Normal Pathways into and out of compartment 1 Exit Pathway Number 1: Reactor Coolant to condenser Exit Pathway Number 5: Reactor Coolant to Environment Compartment number 2 Name: Condenser 5.5000E+04 (Cubic feet) Compartment volume = Compartment type is Normal Pathways into and out of compartment 2 Inlet Pathway Number 1: Reactor Coolant to condenser Exit'Pathway Number 2: Condenser to environment Compartment number 3 Name: Environment Compartment type is Environment Pathways into and out of compartment 3 Inlet Pathway Number 2: Condenser to environment Inlet Pathway Number 4: Control Room to Environment Inlet Pathway Number 5: Reactor Coolant to Environment Exit Pathway Number 3: Environment to Control Room Compartment number 4 Name: Control Room 6.4000E+04 (Cubic feet) Compartment volume = Compartment type is Control Room Pathways into and out of compartment 4 Inlet Pathway Number 3: Environment to Control Room Exit Pathway Number 4: Control Room to Environment Total number of pathways = 5

DRE02-0037, Rev. 1, Attachment B, Page B7 of B27

DRE - Gland Seal

**************************** RADTRAD Version 3.03 (Spring 2001) run on 8/12/2005 at 20:55:26 # # # # # ##### # ##### # # # # # # # # # # # Ħ # '# # # # # # # ##### # # # # # # # # # # # # # #### # # #### * * * * * Dose Output **** ***************** Detailed model information at time (H) =0.0010 EAB Doses: Time (h) =0.0010 Whole Body Thyroid TEDE 5.7988E-02 4.8202E+00 2.1780E-01 Delta dose (rem) Accumulated dose (rem) 5.7988E-02 4.8202E+00 2.1780E-01 LPZ Doses: Time (h) =0.0010 Whole Body Thyroid TEDE 6.0760E-03 5.0507E-01 2.2821E-02 Delta dose (rem) 6.0760E-03 5.0507E-01 2.2821E-02 Accumulated dose (rem) Control Room Doses: Time (h) = 0.0010Whole Body Thyroid TEDE Delta dose (rem) 3.0001E-04 6.9456E-01 2.3328E-02 Accumulated dose (rem) 3.0001E-04 6.9456E-01 2.3328E-02 Detailed model information at time (H) = 0.0020 EAB Doses: 0.0020 Thyroid TEDE Time (h) =Whole Body Delta dose (rem) 1.2770E-02 9.7304E-01 4.5063E-02 Accumulated dose (rem) 7.0758E-02 5.7933E+00 2.6286E-01 LPZ Doses: 0.0020 Whole Body TEDE Time (h) =Thyroid 1.3380E-03 1.0196E-01 4.7217E-03 Delta dose (rem) 7.4141E-03 6.0702E-01 Accumulated dose (rem) 2.7543E-02 Control Room Doses:

DRE02-0037, Rev. 1, Attachment B, Page B8 of B27

Thyroid Time (h) = 0.0020Whole Body TEDE Delta dose (rem) 7.2078E-04 1.6577E+00 5.5685E-02 Accumulated dose (rem) 1.0208E-03 2.3523E+00 7.9013E-02 Detailed model information at time (H) = 0.1667EAB Doses: Time (h) = 0.1667 Whole Body' Thyroid TEDE Delta dose (rem) 2.0644E-04 1.0776E-02 5.6606E-04 Accumulated dose (rem) 7.0964E-02 5.8040E+00 2.6343E-01 LPZ Doses: Time (h) = 0.1667Whole Body Thyroid TEDE Delta dose (rem) 2.1631E-05 1.1291E-03 5.9313E-05 Accumulated dose (rem) 7.4357E-03 6.0815E-01 2.7602E-02 Control Room Doses: Whole Body Time (h) = 0.1667Thyroid TEDE 1.2106E-02 2.7706E+01 9.3077E-01 Delta dose (rem) Accumulated dose (rem) 1.3127E-02 3.0058E+01 1.0098E+00 Detailed model information at time (H) = 2.0000 EAB Doses: Time (h) = 2.0000Whole Body Thyroid TEDE Delta dose (rem) 0.0000E+00 0.0000E+00 0.0000E+00 Accumulated dose (rem) 7.0964E-02 5.8040E+00 2.6343E-01 LPZ Doses: Time (h) = 2.0000Whole Body Thyroid TEDE Delta dose (rem) 0.0000E+00 0.0000E+00 0.0000E+00 Accumulated dose (rem) 7.4357E-03 6.0815E-01 2.7602E-02 Control Room Doses: Time (h) = 2.0000Whole Body Thyroid TEDE 6.0085E-07 1.4464E-03 4.8523E-05 Delta dose (rem) Accumulated dose (rem) 1.3128E-02 3.0059E+01 1.0098E+00 Detailed model information at time (H) = 8.0000 EAB Doses: Time (h) = 8.0000Whole Body Thyroid TEDE Delta dose (rem) 0.0000E+00 0.0000E+00 0.0000E+00 Accumulated dose (rem) 7.0964E-02 5.8040E+00 2.6343E-01 LPZ Doses: Thyroid Time (h) =8.0000 Whole Body TEDE 0.0000E+00 0.0000E+00 0.0000E+00 Delta dose (rem)

DRE02-0037, Rev. 1, Attachment B, Page B9 of B27

DRE – Gland Seal

Accumulated dose (rem) 7.4357E-03 6.0815E-01 2.7602E-02

Control Room Doses:

Time (h) = 8.0000 Whole Body . Thyroid TEDE Delta dose (rem) 1.7868E-54 6.9882E-51 2.3204E-52 Accumulated dose (rem) 1.3128E-02 3.0059E+01 1.0098E+00

Detailed model information at time (H) = 24.0000

EAB Doses:

Time (h) = 24.0000Whole BodyThyroidTEDEDelta dose (rem)0.0000E+000.0000E+000.0000E+00Accumulated dose (rem)7.0964E-025.8040E+002.6343E-01

LPZ Doses:

Time $(h) = 24.0000$	Whole Body	Thyroid	TEDE .
Delta dose (rem)	0.0000E+00	0.0000E+00	0.0000E+00
Accumulated dose (rem)	7.4357E-03	6.0815E-01	2.7602E-02

Control Room Doses:

Time $(h) = 24.0000$	Whole Body	Thyroid	TEDE
Delta dose (rem)	2.7947-211	2.9035-207	9.5487-209
Accumulated dose (rem)	1.3128E-02	3.0059E+01	1.0098E+00

411 .

************ I-131 Summary

****************	*****************
------------------	-------------------

•	Reactor Coolant	Condenser	Environment
Time (hr)	I-131 (Curies)	I-131 (Curies)	I-131 (Curies)
0.000	1.2669E+03	1.3208E+03	1.9812E+00
0.001	1.5672E+03	2.4293E+04	3.6440E+01
0.002	5.4302E+01	2.9196E+04	4.3794E+01
0.167	0.0000E+00	2.9233E+04	4.3876E+01
0.420	0.0000E+00	2.9206E+04	4.3876E+01
0.670	0.0000E+00	2.9180E+04	4.3876E+01
0.920	0.0000E+00	2.9154E+04	4.3876E+01
1.300	0.0000E+00	2.9114E+04	4.3876E+01
1.600	0.0000E+00	2.9083E+04	4.3876E+01
1.900	0.0000E+00	2.9051E+04	4.3876E+01
2.000	0.0000E+00	2.9041E+04	4.3876E+01
2.300	0.0000E+00	2.9010E+04	4.3876E+01
2.600	0.0000E+00	2.8979E+04	4.3876E+01
2.900	0.0000E+00	2.8947E+04	4.3876E+01
3.200	0.0000E+00	2.8916E+04	4.3876E+01
3.500	0.0000E+00	2.8885E+04	4.3876E+01
3.800	0.0000E+00	2.8854E+04	4.3876E+01
4.100	0.0000E+00	2.8823E+04	4.3876E+01
4.400	0.0000E+00	2.8792E+04	4.3876E+01
4.700	0.0000E+00	2.8761E+04	4.3876E+01
5.000	0.0000E+00	2.8730E+04	4.3876E+01

DRE02-0037, Rev. 1, Attachment B, Page B10 of B27

DRE – Gland Seal

		DRE – Gland Scar	
5.300	0.0000E+00	2.8699E+04	4.3876E+01
5.600	0.0000E+00	2.8668E+04	4.3876E+01
5.900	0.0000E+00	2.8637E+04	4.3876E+01
6.200	0.0000E+00	2.8606E+04	4.3876E+01
6.500	0.0000E+00	. 2.8575E+04	4.3876E+01
6.800	0.0000E+00	2.8545E+04	4.3876E+01
7.100	0.0000E+00	2.8514E+04	4.3876E+01
7.400	0.0000E+00	2.8483E+04	4.3876E+01
7.700	0.0000E+00	2.8452E+04	4.3876E+01
8.000	0.0000E+00	2.8422E+04	4.3876E+01
8.300	0.0000E+00	2.8391E+04	4.3876E+01
8.600	0.0000E+00	2.8361E+04	4.3876E+01
8.900	0.0000E+00	2.8330E+04	4.3876E+01
9.200	0.0000E+00	2.8300E+04	4.3876E+01
9.500	0.0000E+00 .	2.8269E+04	4.3876E+01
9.800	0.0000E+00	2.8239E+04	4.3876E+01
10.100	0.0000E+00	2.8208E+04	4.3876E+01
10.400	0.0000E+00	2.8178E+04	4.3876E+01
24.000	0.0000E+00	2.6834E+04	. 4.3876E+01
	Control Room		
Time (hr)	I-131 (Curies)		
0.000	7.7619E-02		
0.001	1.3911E+00		
0.002	1.5848E+00		
0.167	8.1077E-05		
0.420	2.0328E-11		
0.670	6.2128E-18		
0.920	1.8988E-24		
1.300	2.3764E-34		
1.600	3.6150E-42		
1.900	5.4990E-50		
2.000	1.3625E-52		
2.300	2.0726E-60		
2.600	3.1529E-68		
2.900	4.7961E-76		
3.200	7.2957E-84		
3.500	1.1098E-91		•
3.800	1.6882E-99		
4.100	2.5681-107		
4.400	3.9065-115	•	
4.700	5.9425-123	•	
5.000	9.0396-131		
5.300	1.3/51-138		
5.600	2.0918-146		•
5.900	3.1820-154	•	
0.200	4.0403-102		
6.500	1.1200.177		
0.0UU 7 100	1.1200-1//		
7.100	1./030-103		
7.400	2.3910-193		
1.700	J.9420-201 5 0073-200	· .	
0.000	0.1020-017		
0.300	9.1230-21/		
8.600	1.30/0-224		

8.900

9.200

2.1111-232

3.2113-240

DRE02-0037, Rev. 1, Attachment B, Page B11 of B27

9.500	4.8850-248
9.800	7.4309-256
10.100	1.1304-263
10.400	1.7195-271
24.000	0.0000E+00

	Ež	AB .	L	PZ	Control Room		
Time	Thyroid	TEDE	Thyroid	TEDE	Thyroid	TEDE	
(hr)	(rem)	(rem)	(rem)	(rem)	(rem)	(rem)	
0.000	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	
0.001	4.8202E+00	2.1780E-01	5.0507E-01	2.2821E-02	6.9456E-01	2.3328E-02	
0.002	5.7933E+00	2.6286E-01	6.0702E-01	2.7543E-02	2.3523E+00	7.9013E-02	
0.167	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0058E+01	1.0098E+00	
0.420	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
0.670	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
0.920	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
1.300	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
1.600	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
1.900	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
2.000	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
2.300	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
2.600	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
2.900	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
3.200	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
3.500	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
3.800	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
4.100	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
4.400	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
4.700	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
5.000	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
5.300	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
.5.600	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
5.900	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
6.200	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
6.500	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
6.800	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
7.100	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
7.400	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
7.700	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
8.000	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
8.300	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
8.600	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
8.900	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
9.200	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
9.500	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
9.800	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
10.100	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
10.400	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	
24.000	5.8040E+00	2.6343E-01	6.0815E-01	2.7602E-02	3.0059E+01	1.0098E+00	

Worst Two-Hour Doses

DRE02-0037, Rev. 1, Attachment B, Page B12 of B27

Time	Whole Body	Thyroid		TEDE
(hr)	(rem)	(rem)		(rem)
0.0	7.0964E-02	5.8040E+00	•	2.6343E-01

DRE02-0037, Rev. 1, Attachment B, Page B13 of B27

DRE - Gland Seal

********************************** ******************************* File information = P:\Users\Nuc\Exelon EOC\Discipline Files\Process\AST\Dresden & Plant file Quad Cities AST\DRE CRDA\DRE-CRDA_condenser_path (1CR airchange per min).psf = p:\users\nuc\exelon eoc\discipline files\process\ast\dresden & Inventory file quad cities ast\dre crda\dres qdc source terms.nif Release file = p:\users\nuc\exelon eoc\discipline files\process\ast\dresden & quad cities ast\dre crda\dre-qdc-crda-main condenser.rft Dose Conversion file = c:\program files\radtrad3-03\defaults\fgr11&12.inp ##### **** #### ##### # # # ##### # # # # ₽ # ## # # # # # # # # ł # # # # # # # # # ##### * * * * £ # # # # # # # # #### # ### Radtrad 3.03 4/15/2001 Dresden Units 2&3 CRDA with 1 percent per day condenser volume release rate (1CR airchange per min) Nuclide Inventory File: p:\users\nuc\exelon eoc\discipline files\process\ast\dresden & quad cities ast\dre crda/dres qdc source terms.nif Plant Power Level: 3.0160E+03 Compartments: 4 Compartment 1: Reactor Coolant 3 1.0000E+00 0 0 0 0 ٥ Compartment 2: Condenser 3 5.5000E+04 0 0 0

0 . .

DRE02-0037, Rev. 1, Attachment B, Page B14 of B27

```
0
Compartment 3:
Environment
  2
 0.0000E+00
   0
   0
   0
   0
   0
Compartment 4:
Control Room
  1
  6.4000E+04
  0
   0
   0
   0
   0
Pathways:
  5
Pathway 1:
Reactor Coolant to condenser
  1
  2
  2
Pathway 2:
Condenser to environment
   2
   3
  2
Pathway 3:
Environment to Control Room
   3
   4
   2
 Pathway 4:
Control Room to Environment
   4
   3
   2
Pathway 5:
Reactor Coolant to Environment
  1
   3
   2
End of Plant Model File
Scenario Description Name:
Plant Model Filename:
Source Term:
  1
       1.0000E+00
   1
c:\program files\radtrad3-03\defaults\fgr11&12.inp
p:\users\nuc\exelon eoc\discipline files\process\ast\dresden & quad cities ast\dre
crda\dre-qdc-crda-main_condenser.rft
```

DRE02-0037, Rev. 1, Attachment B, Page B16 of B27

0 0 1 3				
0.0000E+00 1.6670E-01 2.4000E+01 0 0 0 0 0	2.7500E+02 0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00 0.0000E+00
0 Pathway 2:	· .			
0 0 0 0 1	•			•
0.0000E+00 2.4000E+01 4.8000E+01 0 0 0 0 0	3.8190E-01 0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00 0.0000E+00
Pathway 3: 0 0 0 0 0 1 2				
0.0000E+00 4.8000E+01 0 0 0 0 0	6.4000E+04 0.0000E+00	0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00	0.0000E+00 0.0000E+00
0 Pathway 4: 0 0 0 0 1 2	·		· ·	
0.0000E+00 4.8000E+01	6.4000E+04 0.0000E+00	1.0000E+02 0.0000E+00	1.0000E+02 0.0000E+00	1.0000E+02 0.0000E+00

DRE - Gland Seal

DRE02-0037, Rev. 1, Attachment B, Page B17 of B27

0 0				
0 0				
0				
Pathway 5:				
0				
0		1		
0				
0				
2	۰			
0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00
2.4000E+01 0	0.0000000000	0.00002+00	0.00005+00	0.00001100
0				
0				
0				
0		•		
Dose Locations	5:			
Location 1: EAB				
3				
1 2				
0.0000E+00	2.5100E-04			
2.0000E+00	0.0000E+00			
3			•	
0.0000E+00	3.4700E-04			
8.0000E+00 2.4000E+01	1.7500E-04 0.0000E+00			
0				
Location 2:				
3				
1				
8 0.0000E+00	2.6300E-05			
2.0000E+00	1.0900E-05			
8.0000E+00	7.0200E-06			
2.8000E+01	1.0000E-12			
3.2000E+01	1.0000E-12			
4.0000E+01 4.8000E+01	1.0000E-12 0.0000E+00			
1				
4	3 47005-04			
8.0000E+00	1.7500E-04			
2.4000E+01	0.0000E+00			
4.8000E+01 0	0.0000E+00			
U -				

-

١

DRE – Gland Seal

Location 3: Control Room 4 0 1 3 0.0000E+00 3.4700E-04 2.4000E+01 3.4700E-04 0.0000E+00 4.8000E+01 1 3 0.0000E+00 1.0000E+00 2.4000E+01 6.0000E-01 4.800'0E+01 0.0000E+00 Effective Volume Location: 1 5 0.0000E+00 1.3000E-03 1.6670E-01 1.3000E-03 2.0000E+00 1.0600E-03 8.0000E+00 4.4900E-04 0.0000E+00 2.4000E+01 Simulation Parameters: 6 0.0000E+00 1.0000E-04 1.0000E-02 1.0000E-03 1.0000E-01 1.0000E-02 1.0000E+00 1.0000E+00 2.4000E+01 2.0000E+00 4.8000E+01 0.0000E+00 Output Filename: P:\Users\Nuc\Exelon EOC\Discipline Files\Process\AST\Dresden & Quad Cities AST\DRE CRDA\DRE-CRDA_condenser_path (1CR airchange per min).00 1 . 2

End of Scenario File

************** RADTRAD Version 3.03 (Spring 2001) run on 8/12/2005 at 20:51:24 **** Plant Description ********************** Number of Nuclides = 60Inventory Power = 1.0000E+00 MWth Plant Power Level = 3.0160E+03 MWth Number of compartments Compartment information Compartment number 1 (Source term fraction = 1.0000E+00 Name: Reactor Coolant Compartment volume = 1.0000E+00 (Cubic feet) Compartment type is Normal Pathways into and out of compartment 1 Exit Pathway Number 1: Reactor Coolant to condenser Exit Pathway Number 5: Reactor Coolant to Environment Compartment number 2 Name: Condenser Compartment volume = 5.5000E+04 (Cubic feet) Compartment type is Normal Pathways into and out of compartment 2 Inlet Pathway Number 1: Reactor Coolant to condenser Exit'Pathway Number 2: Condenser to environment Compartment number 3 Name: Environment Compartment type is Environment Pathways into and out of compartment 3 Inlet Pathway Number 2: Condenser to environment Inlet Pathway Number 4: Control Room to Environment Inlet Pathway Number 5: Reactor Coolant to Environment Exit Pathway Number 3: Environment to Control Room Compartment number 4 Name: Control Room Compartment volume = 6.4000E+04 (Cubic feet) Compartment type is Control Room Pathways into and out of compartment 4 Inlet Pathway Number 3: Environment to Control Room Exit Pathway Number 4: Control Room to Environment

Total number of pathways = 5

DRE02-0037, Rev. 1, Attachment B, Page B20 of B27

RADTRAD Version 3.03 (Spring 2001) run on 8/12/2005 at 20:51:24 ******************** ##### #### # ##### ##### 7 Ħ # ŧ Ħ # # # # # # # # # # # # # # Ħ # # # # # # # # ##### # # # # # ,# # # # Ħ # # # # # # # # Ħ # # # #### # #### # #### ***** Dose Output ***** Detailed model information at time (H) =0.0010 EAB Doses: Time (h) =0.0010 Whole Body Thyroid TEDE Delta dose (rem) 7.6067E-06 6.3233E-04 2.8571E-05 Accumulated dose (rem) 7.6067E-06 6.3233E-04 2.8571E-05 LPZ Doses: 0.0010 Thyroid Time (h) =Whole Body TEDE 7.9704E-07 6.6256E-05 2.9937E-06 Delta dose (rem) Accumulated dose (rem) 7.9704E-07 6.6256E-05 2.9937E-06 Control Room Doses: Time (h) =0.0010 Whole Body Thyroid TEDE 2.6552E-08 6.1473E-05 2.0647E-06 Delta dose (rem) Accumulated dose (rem) 2.6552E-08 6.1473E-05 2.0647E-06 Detailed model information at time (H) = 0.0020 EAB Doses: Time (h) =0.0020 Whole Body Thyroid TEDE 1.8887E-05 1.5506E-03 7.0293E-05 Delta dose (rem) Accumulated dose (rem) 2.6494E-05 2.1829E-03 9.8865E-05 LPZ Doses: 0.0020 Time (h) =Whole Body Thyroid TEDE 7.3654E-06 1.9790E-06 1.6247E-04 Delta dose (rem) Accumulated dose (rem) 2.7760E-06 2.2873E-04 1.0359E-05 Control Room Doses: DRE02-0037, Rev. 1, Attachment B, Page B21 of B27

Time (h) = 0.0020 Whole Body Thyroid TEDE Delta dose (rem) 1.8236E-07 4.2056E-04 1.4126E-05 Accumulated dose (rem) 2.0891E-07 4.8204E-04 1.6190E-05 Detailed model information at time (H) = 0.1667EAB Doses: -• ·- ·· · - -. . . Time (h) = 0.1667Whole Body Thyroid TEDE Delta dose (rem) 3.1333E-03 2.5891E-01 1.1713E-02 Accumulated dose (rem) 3.1598E-03 2.6109E-01 1.1812E-02 LPZ Doses: Whole Body Time (h) = 0.1667Thyroid TEDE Delta dose (rem) 3.2831E-04 2.7129E-02 1.2273E-03 Accumulated dose (rem) 3.3109E-04 2.7358E-02 1.2376E-03 Control Room Doses: Time (h) = 0.1667Whole Body Thyroid TEDE Delta dose (rem) 5.2716E-04 1.2159E+00 4.0818E-02 Accumulated dose (rem) 5.2737E-04 1.2164E+00 4.0834E-02 Detailed model information at time (H) = 2.0000 EAB Doses: Thyroid TEDE Time (h) = 2.0000Whole Body Delta dose (rem) 2.6341E-02 2.8346E+00 1.1994E-01 Accumulated dose (rem) 2.9501E-02 3.0957E+00 1.3175E-01 LPZ Doses: • Whole Body Time (h) = 2.0000Thyroid TEDE Delta dose (rem) 2.7600E-03 2.9702E-01 1.2567E-02 Accumulated dose (rem) 3.0911E-03 3.2437E-01 1.3805E-02 Control Room Doses: Time (h) = 2.0000Whole Body Thyroid TEDE Delta dose (rem) 4.8987E-03 1.4681E+01 4.8968E-01 Accumulated dose (rem) 5.4260E-03 1.5898E+01 5.3051E-01 Detailed model information at time (H) = -8.0000EAB Doses: Time (h) = 8.0000Whole Body Thyroid . TEDE Delta dose (rem) 0.0000E+00 0.0000E+00 0.0000E+00 Accumulated dose (rem) 2.9501E-02 3.0957E+00 1.3175E-01 LPZ Doses: Time (h) = 8.0000Whole Body Thyroid TEDE 1.7031E-03 3.8060E-01 1.4201E-02 Delta dose (rem)

DRE02-0037, Rev. 1, Attachment B, Page B22 of B27

Accumulated dose (rem) 4.7942E-03 7.0497E-01 2.8006E-02 Control Room Doses: Time (h) = 8.0000Whole Body . Thyroid TEDE 5.9660E-03 3.7086E+01 1.2238E+00 Delta dose (rem) Accumulated dose (rem) 1.1392E-02 5.2984E+01 1.7543E+00 Detailed model information at time (H) = 24.0000EAB Doses: Time (h) = 24.0000Thyroid Whole Body TEDE Delta dose (rem) 0.0000E+00 0.0000E+00 0.0000E+00 Accumulated dose (rem) 2.9501E-02 3.0957E+00 1.3175E-01 LPZ Doses: Time (h) = 24.0000Whole Body Thyroid TEDE Delta dose (rem) 9.3815E-04 2.9186E-01 1.0501E-02 Accumulated dose (rem) 5.7324E-03 9.9683E-01 3.8507E-02 Control Room Doses: Time (h) = 24.0000Whole Body Thyroid TEDE 2.1716E-03 3.7187E+01 1.2205E+00. Delta dose (rem) Accumulated dose (rem) 1.3564E-02 9.0171E+01 2.9749E+00 Detailed model information at time (H) = 28.0000 EAB Doses: Time (h) = 28.0000Whole Body Thyroid TEDE Delta dose (rem) 0.0000E+00 0.0000E+00 0.0000E+00 Accumulated dose (rem) 2.9501E-02 3.0957E+00 1.3175E-01 LPZ Doses: Time (h) = 28.0000Whole Body Thyroid TEDE Delta dose (rem) 0.0000E+00 0.0000E+00 0.0000E+00 Accumulated dose (rem) 5.7324E-03 9.9683E-01 3.8507E-02 Control Room Doses: Time (h) = 28.0000Whole Body Thyroid TEDE Delta dose (rem) 2.3543E-05 6.4007E-01 2.1009E-02 Accumulated dose (rem) 1.3587E-02 9.0811E+01 2.9959E+00 Detailed model information at time (H) = 32.0000EAB Doses: TEDE Time (h) = 32.0000Whole Body Thyroid 0.0000E+00 0.0000E+00 0.0000E+00 Delta dose (rem) Accumulated dose (rem) 2.9501E-02 3.0957E+00 1.3175E-01

LPZ Doses:

DRE02-0037, Rev. 1, Attachment B, Page B23 of B27

Time (h) = 32.0000 Whole Body Thyroid TEDE 0.0000E+00 0.0000E+00 0.0000E+00 Delta dose (rem) Accumulated dose (rem) 5.7324E-03 9.9683E-01 3.8507E-02 Control Room Doses: Time (h) = 32,0000 Whole Body Thyroid TEDE Delta dose (rem) 1.1869-109 3.6140-105 1.1869-106 Accumulated dose (rem) 1.3587E-02 9.0811E+01 2.9959E+00 Detailed model information at time (H) = 40.0000EAB Doses: Time (h) = 40.0000Whole BodyThyroidTEDEDelta dose (rem)0.0000E+000.0000E+000.0000E+00 Accumulated dose (rem) 2.9501E-02 3.0957E+00 1.3175E-01 LPZ Doses: Time (h) = 40.0000Whole BodyThyroidTEDEDelta dose (rem)0.0000E+000.0000E+000.0000E+00 Accumulated dose (rem) 5.7324E-03 9.9683E-01 3.8507E-02 Control Room Doses: Time (h) = 40.0000Whole Body Thyroid TEDE Delta dose (rem) 6.1296-214 2.0446-209 6.7202-211 Accumulated dose (rem) 1.3587E-02 9.0811E+01 2.9959E+00 Detailed model information at time (H) = 48.0000EAB Doses: Time (h) = 48.0000Whole Body Thyroid TEDE Delta dose (rem) 0.0000E+00 0.0000E+00 0.0000E+00 Accumulated dose (rem) 2.9501E-02 3.0957E+00 1.3175E-01 LPZ Doses: Time (h) = 48.0000Whole Body Thyroid TEDE Delta dose (rem) 0.0000E+00 0.0000E+00 0.0000E+00 Accumulated dose (rem) 5.7324E-03 9.9683E-01 3.8507E-02 Control Room Doses: Time (h) = 48.0000Whole Body Thyroid TEDE Delta dose (rem) 0.0000E+00 0.0000E+00 0.0000E+00 Accumulated dose (rem) 1.3587E-02 9.0811E+01 2.9959E+00 435 ********* I-131 Summary ****************

DRE02-0037, Rev. 1, Attachment B, Page B24 of B27

·

	Reactor Coolant	Condenser	Environment
Time (hr)	I-131 (Curies)	I-131 (Curies)	I-131 (Curies)
0.000	1.2681E+03	1.3216E+03	2.0576E-05
0.001	1.5695E+03	2.4327E+04	4.7803E-03
0.002	5.4388E+00	. 2.8562E+04	1.6503E-02
0.167	0.0000E+00	2.8548E+04	1.9760E+00
0.420	0.0000E+00	2.8519E+04	4.9872E+00
0.670	0.0000E+00	2.8491E+04	7.9560E+00
0.920	0.0000E+00	2.8462E+04	1.0922E+01
1.300	0,0000E+00	2.8419E+04	1.5424E+01
1,600	0.0000E+00	2.8385E+04	1.8973E+01
1,900	0.0000E+00	2.8351E+04	2.2518E+01
2,000	0.0000E+00	2.8339E+04	2.3699E+01
2.300	0.0000E+00	2.8305E+04	2.7238E+01
2 600	0 00005+00	2.8271E+04	3.0773E+01
2 900	0.00005+00	2 8237E+04	3 4304E+01
3 200	0.00005+00	2 8203E+04	3 78305+01
3 500	0.0000E+00	2.8169F+04	4 1352E+01
3 800	0.00002+00	2.01050,03	A 4870E+01
4 100	0.00005+00	2.01305-04	A 8384E+01
4.100	0.0000E+00	2.01025+04	5 18945+01
4.400	0.0000E+00		5.10945+01
4.700	0.0000E+00	2.80342+04	5.53996+01
5.000	0.0000E+00		5.8900E+01
5.300	0.0000E+00	2.79676+04	6.2397E+01
5.600	0.0000E+00	2.7933E+04	6.5890E+01
5.900	0.0000E+00	2.7900E+04	6.93792+01
6.200	0.0000E+00	2.7866E+04	7.2863E+01
6.500	0.0000E+00	2.7833E+04	7.6343E+U1
6.800 .	0.0000E+00	2.7799E+04	7.9819E+01
7.100	0.0000E+00	2.7766E+04	8.3291E+01
7.400	0.0000E+00	2.7732E+04	8.6/58E+01
7.700	0.0000E+00	2.7699E+04	9.0222E+01
8.000	0.0000E+00	2.7666E+04	9.3681E+01
8.300	0.0000E+00	2.7633E+04	9.7136E+01
8.600	0.0000E+00	2.7599E+04	1.0059E+02
8.900	0.0000E+00	2.7566E+04	1.0403E+02
9.200	0.0000E+00	2.7533E+04	1.0748E+02
9.500	0.0000E+00	2.7500E+04	1.1092E+02
9.800	0.0000E+00	2.7467E+04	1.1435E+02
10.100	0.0000E+00	2.7434E+04	1.1778E+02
10.400	0.0000E+00	2.7401E+04	1.2121E+02
24.000	0.0000E+00	2.5947E+04	2.7208E+02
28.000	0.0000E+00	2.5577E+04	2.7208E+02
32.000	0.0000E+00	2.5212E+04	2.7208E+02
40.000	0.0000E+00	2.4498E+04	2.7208E+02
48.000	0.0000E+00	2.3804E+04	2.7208E+02
	Control Room		
Time (hr)	I-131 (Curies)		
0.000	8.0663E-07		
0.001	1.8420E-04		
0.002	6.2038E-04		
0.167	7.7834E-03		
0.420	7.7759E-03		
0.670	7.7681E-03		
0.920	7.7603E-03		
1.300	7.7485E-03		

7.7603E-03 7.7485E-03 .

DRE02-0037, Rev. 1, Attachment B, Page B25 of B27

1 600	7 73025-03
1 000	7 72005-03
2 000	7 72695-03
2.000	C 2027E 02
2.300	0.29276-03
2.600	6.2851E-03
2.900	6.2776E-03
3.200	6.2700E-03
3.500	6.2625E-03
3.800	6.2550E-03
4.100	6.2475E-03
4.400	6.2400E-03
4.700	6.2325E-03
5.000	6.2250E-03
5.300	6.2175E-03
5.600	6.2100E-03.
5.900	6.2025E-03
6.200	6.1951E-03
6.500	6.1876E-03
6.800	6.1802E-03
7.100	6.1728E-03
7.400	6.1654E-03
7.700	6.1579E-03
8.000	6.1505E-03
8.300	2.6021E-03
8.600	2.5990E-03
8.900	2.5959E-03
9.200	2.5928E-03
9.500	2.5897E-03
9.800	2.5865E-03
10.100	2.5834E-03
10.400	2.5803E-03
24.000	2.4434E-03
28.000	1.4037-107
32.000	8.0642-212
40.000	0.0000E+00

0.0000E+00

48.000

LPZ EAB Control Room TEDE Time Thyroid TEDE Thyroid TEDE Thyroid (hr) · (rem) (rem) (rem) (rem) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.0000E+00 0.0000E+00 0.0000E+00 0.0000E+00 0.001 6.3233E-04 2.8571E-05 6.6256E-05 2.9937E-06 6.1473E-05 2.0647E-06 0.002 2.1829E-03 9.8865E-05 2.2873E-04 1.0359E-05 4.8204E-04 1.6190E-05 0.167 2.6109E-01 1.1812E-02 2.7358E-02 1.2376E-03 1.2164E+00 4.0834E-02 0.420 6.5782E-01 2.9453E-02 6.8927E-02 3.0861E-03 3.2712E+00 1.0970E-01 0.670 1.0477E+00 4.6456E-02 1.0978E-01 4.8677E-03 5.2903E+00 1.7724E-01 0.920 1.4359E+00 6.3096E-02 1.5045E-01 6.6112E-03 7.3008E+00 2.4437E-01 1.300 2.0231E+00 8.7834E-02 2.1199E-01 9.2033E-03 1.0343E+01 3.4578E-01 1.600 2.4843E+00 1.0690E-01 2.6031E-01 1.1201E-02 1.2731E+01 4.2528E-01 1.900 2.9432E+00 1.2560E-01 3.0839E-01 1.3160E-02 1.5108E+01 5.0428E-01 2.000 3.0957E+00 1.3175E-01 3.2437E-01 1.3805E-02 1.5898E+01 5.3051E-01 2.300 3.0957E+00 1.3175E-01 3.4418E-01 1.4598E-02 1.7897E+01 5.9686E-01 2.600 3.0957E+00 1.3175E-01 3.6390E-01 1.5378E-02 1.9814E+01 6.6043E-01

DRE02-0037, Rev. 1, Attachment B, Page B26 of B27

DRE – Gland Seal

2.90	3.0957E+00	1.3175E-01	3.8352E-01	1.6146E-02	2.1723E+01	7.2365E-01
3.20	3.0957E+00	1.3175E-01	4.0306E-01	1.6903E-02	2.3623E+01	7.8654E-01
3.50	3.0957E+00	1.3175E-01	4.2252E-01	1.7650E-02	2.5515E+01	8.4911E-01
3.80	0 3.0957E+00	1.3175E-01	4.4189E-01	1.8388E-02	2.7399E+01	9.1137E-01
4.10	3.0957E+00	1.3175E-01	4.6117E-01	1.9117E-02	2.9275E+01	9.7333E-01
4.40	3.0957E+00	1.3175E-01	4.8038E-01	1.9838E-02	3.1142E+01	1.0350E+00
4.70	0 3.0957E+00	1.3175E-01	4.9951E-01	2.0552E-02	3.3002E+01	1.0964E+00
5.00	3.0957E+00	1.3175E-01	5.1855E-01	2.1259E-02	3.4855E+01	1.1575E+00
5.30	0 3.0957E+00	1.3175E-01	5.3753E-01	2.1959E-02	3.6700E+01	1.2183E+00
5.60	0 3.0957E+00	1.3175E-01	5.5642E-01	2.2652E-02	3.8537E+01	1.2789E+00
5.90	0 3.0957E+00	1.3175E-01	5.7524E-01	2.3340E-02	4.0368E+01	1.3391E+00
6.20	0 3.0957E+00	1.3175E-01	5.9399E-01	2.4022E-02	4.2191E+01	1.3992E+00
6.50	0 3.0957E+00	1.3175E-01	6.1266E-01	2.4698E-02	4.4007E+01	1.4590E+00
6.80	0 3.0957E+00	1,3175E-01	6.3126E-01	2.5369E-02	4.5816E+01	1.5185E+00
7.10	0 3.0957E+00	1.3175E-01	6.4979E-01	2.6035E-02	4.7618E+01	1.5778E+00
7.40	3.0957E+00	1.3175E-01	6.6826E-01	2.6697E-02	4.9413E+01	1.6369E+00
7.70	0 3.0957E+00	1.3175E-01	6.8665E-01	2.7354E-02	5.1202E+01	1.6957E+00
8.00	0 3.0957E+00	1.3175E-01	7.0497E-01	2.8006E-02	5.2984E+01	1.7543E+00
8.30	0 3.0957E+00	1.3175E-01	7.1090E-01	2.8233E-02	5.3907E+01	1.7847E+00
8.60	0 3.0957E+00	1.3175E-01	7.1681E-01	2.8457E-02	5.4657E+01	1.8093E+00
8.90	0 3.0957E+00	1.3175E-01	7.2270E-01	2.8680E-02	5.5403E+01	1.8338E+00
9.20	3.0957E+00	1.3175E-01	7.2856E-01	2.8901E-02	5.6147E+01	1.8583E+00
9.50	0 3.0957E+00	1.3175E-01	7.3441E-01	2.9120E-02	5.6889E+01	1.8826E+00
9.80	0 3.0957E+00	1.3175E-01	7.4023E-01	2.9338E-02	5.7627E+01	1.9069E+00
10.10) 3.0957E+00	1.3175E-01	7.4604E-01	2.9554E-02	5.8363E+01	1.9311E+00
10.40	0 3.0957E+00	1.3175E-01	7.5182E-01	2.9769E-02	5.9097E+01	1.9552E+00
24.00	0 3.0957E+00	1.3175E-01	9.9683E-01	3.8507E-02	9.0171E+01	2.9749E+00
28.00	0 3.0957E+00	1.3175E-01	9.9683E-01	3.8507E-02	9.0811E+01	2.9959E+00
32.00	0 3.0957E+00	1.3175E-01	9.9,683E-01	3.8507E-02	9.0811E+01	2.9959E+00
40.00	0 3.0957E+00	1.3175E-01	9.9683E-01	3.8507E-02	9.0811E+01	2.9959E+00
48.00	0 3.0957E+00	1.3175E-01	9.9683E-01	3.8507E-02	9.0811E+01	2.9959E+00

EAB

Time	Whole Body	Thyroid	TEDE
(hr)	(rem)	(rem)	(rem)
0.0	2.9501E-02	3.0 <u>9</u> 57E+00	1.3175E-01

DRE02-0037, Rev. 1, Attachment B, Page B27 of B27

Nuclide Inventory Name: Source Document Calc. #GE-NE-A22-00103-64-01 Appendix D for Dresden and Quad Cities Power Level: 0.1000E+01 Nuclides: 60 Nuclide 001: Co-58 7 0.6117120000E+07 0.5800E+02 0.1529E+03 none 0.0000E+00 none 0.0000E+00 0.0000E+00 none Nuclide 002: Co-60 , 7 0.1663401096E+09 0.6000E+02 0.1830E+03 none 0.0000E+00 none 0.0000E+00 none 0.0000E+00 Nuclide 003: Kr-85 1 .0.3382974720E+09 0.8500E+02 4.3644E+02 none 0.0000E+00 none 0.0000E+00 none 0.0000E+00 ' Nuclide 004: Kr-85m 1 0.1612800000E+05 0.8500E+02 6.7720E+03 Kr-85 0.2100E+00 none 0.0000E+00 none 0.0000E+00 Nuclide 005: Kr-87 1 0.4578000000E+04 0.8700E+02 1.2910E+04 Rb-87 0.1000E+01 none 0.0000E+00 none 0.0000E+00 Nuclide 006: Kr-88 1 0.1022400000E+05 0.8800E+02 1.8150E+04 Rb-88 0.1000E+01

DRE02-0037, Rev. 1, Attachment C, Page 1 of 10

0.0000E+00 none 0.0000E+00 none Nuclide 007: Rb-86 3 0.1612224000E+07 0.8600E+02 7.096E+01 none 0.0000E+00 0.0000E+00 none 0.0000E+00 none Nuclide 008: Sr-89 5 0.4363200000E+07 0.8900E+02 2.4284E+04 none , 0.0000E+00 none 0.0000E+00 none 0.0000E+00 Nuclide 009: Sr-90 5 0.9189573120E+09 0.9000E+02 3.5283E+03 Y-90 0.1000E+01 0.0000E+00 none 0.0000E+00 none Nuclide 010: Sr-91 5 0.342000000E+05 0.9100E+02 3.0810E+04 Y-91m 0.5800E+00 Y-91 0.4200E+00 0.0000E+00 none Nuclide 011: Sr-92 5 0.975600000E+04 0.9200E+02 3.3620E+04 Y-92 0.1000E+01 none 0.0000E+00 0.0000E+00 none Nuclide 012: Y~90 9 0.230400000E+06 0.9000E+02 3.6249E+03 0.0000E+00 none none 0.0000E+00 none 0.0000E+00 Nuclide 013: Y-91 9

DRE02-0037, Rev. 1, Attachment C, Page 2 of 10

Dres QDC Source Terms for CRDA.nif

1

0.5055264000E+07 0.9100E+02 3.1549E+04 0.0000E+00 none 0.0000E+00 none 0.0000E+00 none Nuclide 014: Y-92 9 0.1274400000E+05 0.9200E+02 3.3767E+04 0.0000E+00 none 0.0000E+00 none none 0.0000E+00 Nuclide 015: Y-93 9 0.363600000E+05 0.9300E+02 3.9417E+04~ Zr-93 0.1000E+01 0.0000E+00 none 0.0000E+00 none Nuclide 016: Zr-95 9 0.5527872000E+07 0.9500E+02 4.4427E+04 Nb-95m 0.7000E-02 Nb-95 0.9900E+00 0.0000E+00 none Nuclide 017: Zr-97 9 0.608400000E+05 0.9700E+02 4.4971E+04 Nb-97m 0.9500E+00 Nb-97 0.5300E-01 none 0.0000E+00 Nuclide 018: Nb-95 9 0.3036960000E+07 0.9500E+02 4.4637E+04 0.0000E+00 none none 0.0000E+00 0.0000E+00 none Nuclide 019: Mo-99 7 0.2376000000E+06 0.9900E+02 5.1210E+04 Tc-99m 0.8800E+00 Tc-99 0.1200E+00

DRE02-0037, Rev. 1, Attachment C, Page 3 of 10

0.0000E+00 none Nuclide 020: Tc-99m 7 0.216720000E+05 0.9900E+02 4.4837E+04 Tc-99 0.1000E+01 none 0.0000E+00 0.0000E+00 none Nuclide 021: Ru-103 7 0.3393792000E+07 0.1030E+03 . 4.3107E+04 Rh-103m 0.1000E+01 none . 0.0000E+00 none 0.0000E+00 Nuclide 022: Ru-105 7 0.1598400000E+05 0.1050E+03 3.0337E+04 Rh-105 0.1000E+01 none 0.0000E+00 0.0000E+00 none Nuclide 023: Ru-106 7 0.3181248000E+08 0.1060E+03 1.8366E+04 Rh-106 0.1000E+01 0.0000E+00 none none 0.0000E+00 Nuclide 024: Rh-105 7 0.1272960000E+06 0.1050E+03 2.8824E+04 none 0.0000E+00 0.0000E+00 none none 0.0000E+00 Nuclide 025: Sb-127 4 0.3326400000E+06 0.1270E+03 2.9994E+03 Te-127m 0.1800E+00 0.8200E+00 Te-127 none 0.0000E+00 Nuclide 026: Sb-129 4 0.1555200000E+05

DRE02-0037, Rev. 1, Attachment C, Page 4 of 10

0.1290E+03 8.8770E+03 Te-129m 0.2200E+00 Te-129 0.7700E+00 0.0000E+00 none Nuclide 027: Te-127 4 0.336600000E+05 0.1270E+03 2.9857E+03 0.0000E+00 none 0.0000E+00 none 0.0000E+00 none Nuclide 028: . Te-127m 4 0.9417.600000E+07 0.1270E+03 4.0597E+02 Te-127 0.9800E+00 none 0.0000E+00 0.0000E+00 none Nuclide 029: Te-129 4 0.4176000000E+04 0.1290E+03 .8.7350E+03 I~129 0.1000E+01 0.0000E+00 none none 0.0000E+00 Nuclide 030: Te-129m 4 0.2903040000E+07 0.1290E+03 1.3004E+03 Te-129 0.6500E+00 I-129 0.3500E+00 0.0000E+00 none Nuclide 031: Te-131m 4 0.108000000E+06 0.1310E+03 3.9549E+03 Te-131 0.2200E+00 I-131 0.7800E+00 none 0.0000E+00 Nuclide 032: Te-132 4 0.2815200000E+06 0.1320E+03 3.8497E+04 I-132 0.1000E+01 none 0.0000E+00 none 0.0000E+00

DRE02-0037, Rev. 1, Attachment C, Page 5 of 10

Nuclide 033: 1-131 2 0.6946560000E+06 0.1310E+03 2.7104E+04 Xe-131m 0.1100E-01 none 0.0000E+00 none 0.0000E+00 Nuclide 034: I-132 2 0.828000000E+04 0.1320E+03 , 3.9136E+04 0.0000E+00 none 0.0000E+00 none 0.0000E+00 none Nuclide 035: I-133 2 0.7488000000E+05 0.1330E+03 5.5010E+04 Xe-133m 0.2900E-01 Xe-133 0.9700E+00 none 0.0000E+00 Nuclide 036: I-134 2 0.315600000E+04 0.1340E+03 6.0353E+04 none 0.0000E+00 none 0.0000E+00 none 0.0000E+00 Nuclide 037: I-135 2 0.2379600000E+05 0.1350E+03 5.1570E+04 Xe-135m 0.1500E+00 Xe-135 0.8500E+00 none 0.0000E+00 Nuclide 038: Xe-133 1 0.4531680000E+06 0.1330E+03 5.2821E+04 0.0000E+00 none none 0.0000E+00 none 0.0000E+00 Nuclide 039: Xe-135 1 0.3272400000E+05 0.1350E+03

DRE02-0037, Rev. 1, Attachment C, Page 6 of 10

```
2.1437E+04
Cs-135
         0.1000E+01
         0.0000E+00
none
         0.0000E+00
none
Nuclide 040:
Cs-134
  3
 0.6507177120E+08
 0.1340E+03
 8.0091E+03
         0.0000E+00
none
         0.0000E+00
none
         0.0000E+00
none
Nuclide 041:
Cs-136
  3
 0.1131840000E+07
 0.1360E+03
 2.3791E+03
none
         0.0000E+00
         0.0000E+00
none
         0.0000E+00
none
Nuclide 042:
Cs-137
  3
 0.9467280000E+09
 0.1370E+03
 4.9283E+03
Ba-137m 0.9500E+00
none
         0.0000E+00
         0.0000E+00
none
Nuclide 043:
Ba-139
  6
 0.4962000000E+04
 0.1390E+03
 4.8879E+04
none
         0.0000E+00
         0.0000E+00
none
         0.0000E+00
none
Nuclide 044:
Ba-140
  6
 0.1100736000E+07
 0.1400E+03
 4.7141E+04
La-140
         0.1000E+01
         0.0000E+00
none
         0.0000E+00
none
Nuclide 045:
La-140
  9
 0.1449792000E+06
 0.1400E+03
 5.0553E+04
none
         0.0000E+00
         0.0000E+00
none
none
         0.0000E+00
Nuclide 046:
```

DRE02-0037, Rev. 1, Attachment C, Page 7 of 10

La-141 9 0.1414800000E+05 0.1410E+03 4.4469E+04 Ce-141 0.1000E+01 none 0.0000E+00 none 0.0000E+00 Nuclide 047: La-142 9 0.555000000E+04 0.1420E+03 4.2864E+04 0.0000E+00 none 0.0000E+00 none none 0.0000E+00 Nuclide 048: Ce-141 8 0.2808086400E+07 0.1410E+03 4.4650E+04 none 0.0000E+00 none 0.0000E+00 none 0.0000E+00 Nuclide 049: Ce-143 . 8 0.1188000000E+06 0.1430E+03 4.1011E+04 0.1000E+01 Pr-143 none 0.0000E+00 none 0.0000E+00 Nuclide 050: Ce-144 8 0.2456352000E+08 0.1440E+03 3.6823E+04 Pr-144m 0.1800E-01 Pr-144 0.9800E+00 0.0000E+00 none Nuclide 051: Pr-143 9 0.1171584000E+07 0.1430E+03 3.9634E+04 none 0.0000E+00 none 0.0000E+00 none 0.0000E+00 Nuclide 052: Nd-147 9 0.9486720000E+06 0.1470E+03 1.7999E+04

DRE02-0037, Rev. 1, Attachment C, Page 8 of 10

Pm-147 0.1000E+01 none 0.0000E+00 none 0.0000E+00 Nuclide 053: Np-239 8 0.2034720000E+06 0.2390E+03 5.5866E+05 Pu-239 0.1000E+01 0.0000E+00 none none 0.0000E+00 Nuclide 054: Pu-238 . 8 0.2768863824E+10 0.2380E+03 1.7677E+02 U-234 0.1000E+01 0.0000E+00 none 0.0000E+00 none Nuclide 055: Pu-239 8 0.7594336440E+12 0.2390E+03 1.4743E+01 U-235 0.1000E+01 0.0000E+00 none none 0.0000E+00 Nuclide 056: Pu-240 8 0.2062920312E+12 0.2400E+03 . 2.0014E+01 U-236 0.1000E+01 none 0.0000E+00 none 0.0000E+00 Nuclide 057: Pu-241 8 0.4544294400E+09 0.2410E+03 6.6999E+03 U-237 0.2400E-04 Am-241 0.1000E+01 none 0.0000E+00 Nuclide 058: Am-241 9 0.1363919472E+11 0.2410E+03 9.8566E+00 Np-237 0.1000E+01 0.0000E+00 none 0.0000E+00 none Nuclide 059: Cm-242

DRE02-0037, Rev. 1, Attachment C, Page 9 of 10

```
9
 0.1406592000E+08
 0.2420E+03
 2.2847E+03
Pu-238
        0.1000E+01
none
         0.0000E+00
none
         0.0000E+00
Nuclide 060:
Cm-244
 9
 0.5715081360E+09
 0.2440E+03
1.6212E+02
Pu-240 0.1000E+01
         0.0000E+00
none
        0.0000E+00
none
End of Nuclear Inventory File
```

.

DRE02-0037, Rev. 1, Attachment C, Page 10 of 10

Release Fraction and Timing Name:							
Dresden and (Quad Cities •	-Gland Seal (Condenser				
Duration (h):	: Control H	Rod Drop Acc	ident				
0.0010D+00	0.0010D+00	0.0000D+00	0.0000D+00				
Noble Gases:							
3.1680E-03	2.1954E-04	0.0000D+00	0.0000D+00				
Iodine:							
3.1680E-04	1.0977E-05	0.0000E+00	0.0000E+00				
Cesium:		•					
3.8016E-05	4.8788E-07	0.0000E+00	0.0000E+00				
Tellurium:							
0.0000E+00	1.2197E-07	0.0000E+00	0.0000E+00				
Strontium:							
0.0000E+00	4.8788E-08	0.0000E+00	0.0000E+00				
Barium:							
0.0000E+00	4.8788E-08	0.0000E+00	0.0000E+00				
Ruthenium:							
0.0000E+00	6.0984E-09	0.0000E+00	0.0000E+00				
Cerium:	•						
0.0000E+00	1.2197E-09	0.0000E+00	0.0000E+00				
Lanthanum:							
0.0000E+00	4.8788E-10	0.0000E+00	0.0000E+00				
Non-Radioact:	ive Aerosols	(kg):					
0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00				
End of Releas	se File		•				

DRE02-0037, Rev. 1, Attachment D, Page D1 of D2

Release Fraction and Timing Name:							
Dresden and (Quad Cities •	-Main Conden:	ser				
Duration (h)	: Control H	Rod Drop Acc.	ident				
0.0010D+00	0.0010D+00	0.0000D+00	0.0000D+00				
Noble Gases:							
3.1680E-03	2.1954E-04	0.0000D+00	0.0000D+00				
Iodine:							
3.1680E-04	1.0977E-06	0.0000E+00	0.0000E+00				
Cesium:							
3.8016E-05	4.8788E-09	0.0000E+00	0.0000E+00				
Tellurium:							
0.0000E+00	1.2197E-09	0.0000E+00	0.0000E+00				
Strontium:							
0.0000E+00	4.8788E-10	0.0000E+00	0.0000E+00				
Barium:							
0.0000E+00	4.8788E-10	0.0000E+00	0.0000E+00				
Ruthenium:	•						
0.0000E+00	6.0984E-11	0.0000E+00	0.0000E+00				
Cerium:							
0.0000E+00	1.2197E-11	0.0000E+00	0.0000E+00				
Lanthanum:							
0.0000E+00	4.8788E-12	0.0000E+00	0.0000E+00				
Non-Radioact:	ive Aerosols	(kg):					
0.0000E+00	0.0000E+00	0.0000E+00	0.0000E+00				
End of Relea	se File						

_ . _

DRE02-0037, Rev. 1, Attachment D, Page D2 of D2

	A	В	С	D	E	F	G	н	1	J	K.	L
1						Core	Release	Initial Core		Decay	Release to	Release to
2				Half-Live	Nominal	Source	Fractions	Activity	Half-Live	Constant	Delay Bed	Environment
3	Nuclide	Isotope	Class	(seconds)	At. Wt.	CI/MW	0-0.5hr	(Ci)	(hours)	(hours) ⁻¹	(Ci)	(Ci)
4	003:	Kr-85	1	3.38E+08	85	4.3644E+02	0.05	1.32E+06	9.40E+04	7.38E-06	4.46E+03	4.46E+03
5	004:	Kr-85m	1	1.61E+04	85	6.7720E+03	0.05	2.04E+07	4.48E+00	1.55E-01	6.92E+04	3.44E+03
6	005:	Kr-87	1	4.58E+03	87	1.2910E+04	0.05	3.89E+07	1.27E+00	5.45E-01	1.32E+05	3.37E+00
7	006:	Kr-88	1	1.02E+04	88	1.8150E+04	0.05	5.47E+07	2.84E+00	2.44E-01	1.85E+05	1.63E+03
8	038:	Xe-133	1	4.53E+05	133	5.2821E+04	0.05	1.59E+08	1.26E+02	5.51E-03	5.40E+05	7.84E+04
9	039:	Xe-135	1	_3.27E+04	135	2.1437E+04	0.05	6.47E+07	9.09E+00	7.63E-02	2.19E+05	5.45E-07
10		·								· ·		·
11				L	L			<u> </u>			<u> </u>	
12	0.003388	=CRDA Noble (Gas Release	Fraction ³				-				
13	19.4	=Krypton Holdu	p in Delay B	ed (hrs) ⁴							•	
14	350.4	=Xenon Holdup	in Delay Be	d (hrs) ⁴								
15	2.51E-04	≈Worst Case E	AB X/Q (sec/	/m3)5							·	
16	2.63E-05	=Worst Case Li	PZ X/Q (sec/	m3)5								
17	1.30E-03	=Worst Case C	R X/Q (sec/n	n3)6								
18	3.59E-02	=Control Room	Geometry Fa	actor (Murphy	-Campe Base	d) ²						
19						· · · · · · · · · · · · · · · · · · ·						
20									j			
21		Release to										
22	-	Environment	DCF ¹	EAB Dose	LPZ Dose	CR Dose						
23	Isotope	(Ci)		(rem TEDE)	(rem TEDE)	(rem TEDE)	•					
24	Kr-85	4.46E+03	4.403E-04	4.93E-04	5.16E-05	9.16E-05			·			
25	Kr-85m	3.44E+03	2.768E-02	2.39E-02	2.50E-03	4.44E-03					[
26	Kr-87	3.37E+00	1.524E-01	1.29E-04	1.35E-05	2.40E-05						
27	Kr-88	1.63E+03	3.774E-01	1.54E-01	1.62E-02	2.87E-02	· ·					
28	Xe-133	7.84E+04	5.770E-03	1.14E-01	1.19E-02	2.11E-02						
29	Xe-135	5.45E-07	4.400E-02	6.02E-12	6.31E-13	1.12E-12						
30												
31		Total Dose (rem TEDE):	2.92E-01	3.06E-02	5.44E-02						
32	·			· · · · ·	l							
33					l		 					
34				l	l	·	L		L			
35	<u>'</u>	Dose Conversion	Factor (rem-r	n'/Curie-secon	d) from FGR 12	per Reg. Guid	e 1.183	l	· ·			
36	2	K.G. Murphy an	d K.W. Cam	pe, 13th AEC	Air Cleaning (Conference, "I	Nuclear Power Plant (Control Room				
37		Ventilation Syst	em Design fo	or Meeting Ge	neral Criterior	19", August	1974	<u> </u>	·			
38	3	Summation from	n Attachmen	t A	L							
39	4	Section 11.3 of	Dresden UF	SAR	l			· · ·		·		
40	5	Reference 8					•					
41	6	Reference 8										

.

r				<u> </u>	E		<u> </u>	<u>н</u>		<u> </u>	<u> </u>	
H	^		<u> </u>	·	<u>-</u>	Core	Relates	Initial Core	· · · ·	Decay	Release to	Release to
12				Half-Live	Nominat	Source	Fractions	Activity	Half-Live	Constant	Delay Bed	Environment
1	Nuclida	Isotope	Class	(seconds)	At We	CIAW	0.0 5hr	(CD)	(hours)	(hours)-1	(CD	(CD)
۲ă,	003.	Kr.85	1	338297472	85	438 442857142857	0.05	EF4"3016	=04/3600	=1 N(2)/14	=H4'SAS12	-K4 - FXP(- 14 - SAS13)
5	004:	Kr.85m	<u>i</u>	16128	85	6772	0.05	=E5*3016	=D5/3600	=LN(2)/15	=H5*\$A\$12	*K5'EXP(-J5'SA\$13)
6	005:	Kr-87	i	4578	87	12910	0.05	*F6*3016	=D6/3600	=LN(2)/16	=H6*\$A\$12	=K6*EXP(-J6*SAS13)
17	006:	Kr-88	li	10224	88	18150	0.05	=F7*3016	=D7/3600	=LN(2)17	=H7*\$A\$12	*K7*EXP(-J7*\$A\$13)
8	038:	Xe-133	1	453168	133	52821.4285714286	0.05	=F8*3016	=D8/3600	=LN(21/18	=H8*\$A\$12	=K8*EXP(-J8*SAS14)
9	039;	Xe-135	1	32724	135	21437.1428571429	0.05	=F9*3016	=D9/3600	=LN(2)/19	=H9*\$A\$12	=K9'EXP(-J9'SA\$14)
10								1				
11					<u> </u>	[1		
12	0.0033875701569762	=CRDA Noble Gas Release Fr						1			· ·	
13	19.4	=Krypton Holdup in Delay Bed						1			· · ·	
14	=14.6*24	=Xenon Holdup in Delay Bed ()						1	· · · · · ·			
15	0.000251	#Worst Case EAB X/Q (sec/m3		j				1	<u> </u>	·	t	
16	0.0000263	=Worst Case LPZ X/Q (sec/m3				[1				
17	0.0013	=Worst Case CR X/Q (sec/m3)									<u> </u>	
18	=(64000^0.338)/1173	=Control Room Geometry Fact			·	[····	I		1		
19					·	<u>†</u>				<u> .</u>		
20					· · · ·	l	[1	<u> </u>			<u> </u>
21		Release to		i	·				I			
22		Environment	DCF ¹	EAB Dose	LPZ Dose	CR Dose						
23	Isotope	(Ci)		(rem TEDE)	(rem TEDE)	(rem TEDE)					t	
24	Kr-85	r 14	0.0004403	*\$B24*\$A\$15*\$C24	=\$B24*\$A\$16*\$C24	=\$B24*\$A\$17*\$C24*\$A\$18		1		1	i	
25	Kr-85m	=15	0.027676	*\$B25*\$A\$15*\$C25	*\$B25*\$A\$16*\$C25	=\$B25*\$A\$17*\$C25*\$A\$18		<u> </u>				
26	Kr-87	#L6	0.15244	*\$B26*\$A\$15*\$C26	=\$826*\$A\$16*\$C26	=\$826*\$A\$17*\$C26*\$A\$18						
27	Kr-88	*L7	0.3774	=\$827*\$A\$15*\$C27	=\$827*\$A\$16*\$C27	=\$B27*\$A\$17*\$C27*\$A\$18						
28	Xe-133	=L8	0.00577	=\$B28*\$A\$15*\$C28	=\$B28*\$A\$16*\$C28	=\$828*\$A\$17*\$C28*\$A\$18		I			_	
29	Xe-135	et.9	0.044	=\$B29*\$A\$15*\$C29	*\$829*\$A\$16*\$C29	=\$B29*\$A\$17*\$C29*\$A\$18						
30					L			Ļ	<u> </u>	<u> </u>	<u> </u>	L
31		L	Total Dose (rem TEDE):	=SUM(D24:D29)	=SUM(E24:E29)	=SUM(F24:F29)		I	<u> </u>	I	<u> </u>	l
32					l			ļ	<u> </u>	I	I	
33					l	<u> </u>		L		I	I	
34		L			ļ	<u> </u>		<u> </u>	1	<u> </u>		
35	·'	Dose Conversion Factor (rem-m ³ /C	1	L	L	L	L	L	ļ	L	<u> </u>	L
36	2	K.G. Murphy and K.W. Campe,	, 13th AEC Air Cleaning Co	nference, "Nuclear Po	wer Plant Control Roo	m Ventilation System Design	for Meeting General (criterion 19",	L	I	L	
37		August 1974				_	·		<u> </u>	<u> </u>	I	I
38	· · · · · · · · · · · · · · · · · · ·	Summation from Attachment A			l	<u> </u>		 	L	ļ	I	
39	·'	Section 11.3 of Dresden UFSA	l	L	<u> </u>	<u></u>	I	I		I		
40	· · · · · · · · · · · · · · · · · · ·	Reference 8							L			
41	•	Reference 8									1	

.

-

. *

CALCULATION NO. DRE02-0037, Attachment F

.

.

.

RE	٧.	NO.	1	
----	----	-----	---	--

PAGE NO. F-1

Computer Disclosure Sheet Discipline <u>Nuclear</u>								
Client: Exelon Corporation Project: Dresden Units 2&3 C	RDA AST		Date: Job No.	August, 2005	•			
Program(s) used Attachment A spreadsheet Attachment E spreadsheet	Rev No. N/A N/A	Rev Date N/A N/A			Calculation Set No.: DRE02-0037, Rev. 1 Status [] Prelim. [X] Final [] Void			
WGI Prequalification [] Yes [X] No								
Run No.	Description:							
Analysis Description: Spreadsheet used to perform dose assessments for CRDA, as described in calculation.								
The attached computer output has been reviewed, the input data checked, And the results approved for release. Input criteria for this analysis were established.								
By:	On: August 2005							
Run by: H. Rothstein Hand Arothstein								
Checked by: P. Reichert F. Kushit								
Approved by: H. Rothstein	Hould Motoka	~						
Remarks: This spreadsheet is applied in a straight-forward manner and was hand checked. The Attachments include the spreadsheets in both normal and formula display mode and therefore is completely documented.								

.

CALCULATION NO. DRE02-0037, Attachment F

/

.

.

		_		 _
REV.	NO.	1	_	

PAGE NO. F-2

.

Computer Disclosure Sheet Discipline <u>Nuclear</u>							
Client: Exelon Corpo Project: Dresden Unit	pration s 2&3 CRDA AST	Date: Job No.	August 2005				
Program(s) used:	Rev No.	Rev Date	Calc	ulation Set No.: DRE02-0037, Rev. 0			
RADTRAD 3.03 Runs in Att. RADTRAD 3.03 NIF File in A RADTRAD 3.03 RFT File in	B 0 Att. C 0 Att. D 0	January 2003 (Preo January 2003 January 2003	ualification Date)	Status [] Prelim. [X] Final			
WGI Prequalification [X] Yes [] No							
Run No.	Description:						
Analysis Description: RADTRAD output files, where applied to calculations of CRDA dose assessments, as described in calculation.							
The attached computer output has been reviewed, the input data checked, And the results approved for release. Input criteria for this analysis were established.							
By:	On: August 2005	i					
Run by: H. Rothstein	Hould Protate	<					
Checked by: P. Reichert	P. Ruihot)					
Approved by: H. Rothstein	Hund Rotte	\sim					
Remarks: The RADTRAD computer code is applied in a manner fitting its intended purpose, and well within its operating parameters. All outputs were hand checked. Attachments C & D include the Nuclide Information File and Release Fraction and Timing File used by the RADTRAD code and generated specifically for the Dresden Nuclear Power Station. Both were also hand checked for accuracy.							