

August 31, 2005

LICENSEE: Nuclear Management Company, LLC

FACILITY: Monticello Nuclear Generating Plant

SUBJECT: SUMMARY OF A TELEPHONE CONFERENCE CALL HELD ON AUGUST 15, 2005, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION (NRC) AND NUCLEAR MANAGEMENT COMPANY, LLC, CONCERNING INFORMATION PERTAINING TO THE MONTICELLO NUCLEAR GENERATING PLANT LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Nuclear Management Company, LLC (NMC) held a telephone conference on August 15, 2005, to discuss and clarify the applicant's responses to questions raised during the Aging Management Program (AMP) audit which were provided in a letter dated August 11, 2005, concerning the Monticello Nuclear Generating Plant license renewal application. The conference call was useful in clarifying the intent of the staff's question. On the basis of the discussion, the applicant plans to submit a written response.

Enclosure 1 provides a listing of the meeting participants. Enclosure 2 contains a listing of the issues discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

*/RA/*

Daniel J. Merzke, Project Manager  
License Renewal Section A  
License Renewal and Environmental Impacts Program  
Division of Regulatory Improvement Programs  
Office of Nuclear Reactor Regulation

Docket No.: 50-263

Enclosures: As stated

cc w/encls: See next page

August 31, 2005

LICENSEE: Nuclear Management Company, LLC

FACILITY: Monticello Nuclear Generating Plant

SUBJECT: SUMMARY OF A TELEPHONE CONFERENCE CALL HELD ON AUGUST 15, 2005, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION (NRC) AND NUCLEAR MANAGEMENT COMPANY, LLC, CONCERNING INFORMATION PERTAINING TO THE MONTICELLO NUCLEAR GENERATING PLANT LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Nuclear Management Company, LLC (NMC) held a telephone conference on August 15, 2005, to discuss and clarify the applicant's responses to questions raised during the Aging Management Program (AMP) audit which were provided in a letter dated August 11, 2005 concerning the Monticello Nuclear Generating Plant license renewal application. The conference call was useful in clarifying the intent of the staff's question. On the basis of the discussion, the applicant plans to submit a written response.

Enclosure 1 provides a listing of the meeting participants. Enclosure 2 contains a listing of the issues discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

*/RA/*

Daniel J. Merzke, Project Manager  
License Renewal Section A  
License Renewal and Environmental Impacts Program  
Division of Regulatory Improvement Programs  
Office of Nuclear Reactor Regulation

Docket No.: 50-263

Enclosures: As stated

cc w/encls: See next page

DISTRIBUTION: See next page

**ADAMS Accession No.: ML052430782**

DOCUMENT NAME: E:\Filenet\ML052430782.wpd

OFFICE	PM:RLEP	LA:RLEP	SC:RLEP
NAME	DMerzke	YEdmonds	SLee
DATE	8/31/05	8/31/05	8/31/05

OFFICIAL RECORD COPY

Monticello Nuclear Generating Plant

cc:

Jonathan Rogoff, Esquire  
Vice President, Counsel & Secretary  
Nuclear Management Company, LLC  
700 First Street  
Hudson, WI 54016

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
2807 W. County Road 75  
Monticello, MN 55362

Manager, Regulatory Affairs  
Monticello Nuclear Generating Plant  
Nuclear Management Company, LLC  
2807 West County Road 75  
Monticello, MN 55362-9637

Robert Nelson, President  
Minnesota Environmental Control  
Citizens Association (MECCA)  
1051 South McKnight Road  
St. Paul, MN 55119

Commissioner  
Minnesota Pollution Control Agency  
520 Lafayette Road  
St. Paul, MN 55155-4194

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60532-4351

Commissioner  
Minnesota Department of Health  
717 Delaware Street, S. E.  
Minneapolis, MN 55440

Douglas M. Gruber, Auditor/Treasurer  
Wright County Government Center  
10 NW Second Street  
Buffalo, MN 55313

Commissioner  
Minnesota Department of Commerce  
85 7th Place East, Suite 500  
St. Paul, MN 55101-2198

Manager - Environmental Protection Division  
Minnesota Attorney General's Office  
445 Minnesota St., Suite 900  
St. Paul, MN 55101-2127

John Paul Cowan  
Executive Vice President & Chief Nuclear  
Officer  
Nuclear Management Company, LLC  
700 First Street  
Hudson, WI 54016

Nuclear Asset Manager  
Xcel Energy, Inc.  
414 Nicollet Mall, R.S. 8  
Minneapolis, MN 55401

Mr. James Ross  
Nuclear Energy Institute  
1776 I Street, NW, Suite 400  
Washington, DC 20006-3708

Patrick Burke  
License Renewal Project Manager  
Monticello Nuclear Generating Plant  
Nuclear Management Company, LLC  
2807 West County Road 75  
Monticello, MN 55362-9637

Mr. Douglas F. Johnson  
Director, Plant Life Cycle Issues  
Nuclear Management Company, LLC  
700 First Street  
Hudson, WI 54016

Monticello Nuclear Generating Plant

cc:

David R. Lewis  
Pillsbury Winthrop Shaw Pittman, LLP  
2300 N Street, NW  
Washington, DC 20037-1122

Mr. George Crocker  
North American Water Office  
P.O. Box 174  
Lake Elmo, MN 55042

DISTRIBUTION: Summary of telecon on 8/15/05, re: RAI for review of Monticello LRA, Dated:  
August 31, 2005

**ADAMS Accession No.: ML052430782**

**HARD COPY**

RLEP RF

**E-MAIL:**

RidsNrrDrip

RidsNrrDe

G. Bagchi

K. Manoly

W. Bateman

J. Calvo

R. Jenkins

J. Fair

RidsNrrDssa

RidsNrrDipm

D. Thatcher

R. Pettis

G. Galletti

C. Li

K. Winsberg (RidsOgcMailCenter)

R. Weisman

M. Mayfield

A. Murphy

S. Smith (srs3)

S. Duraiswamy

Y. L. (Renee) Li

RLEP Staff

-----

L. Raghavan

L. Padovan

A. Stone, RIII

B. Burgess, RIII

P. Loughheed, RIII

R. Orlikowski, RIII

T. Mensah

OPA

**LIST OF PARTICIPANTS FOR TELEPHONE CONFERENCE CALL  
TO DISCUSS THE MONTICELLO NUCLEAR GENERATING PLANT  
LICENSE RENEWAL APPLICATION  
AUGUST 15, 2005**

**Participants**

Daniel Merzke  
Peter Wen  
Mark Lintz  
Greg Cranston  
Joe Pairitz  
Bill O'Brien  
Dave Sexton  
Bob Jackson

**Affiliations**

U.S. Nuclear Regulatory Commission (NRC)  
NRC  
NRC  
NRC  
Nuclear Management Company, LLC (NMC)  
NMC  
NMC  
Advanced Technologies and Laboratories International, Inc. (ATL)

**MONTICELLO NUCLEAR GENERATING PLANT  
LICENSE RENEWAL APPLICATION**

**AUGUST 15, 2005**

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Nuclear Management Company, LLC (NMC) held a telephone conference call on August 15, 2005, to discuss and clarify the applicant's responses to questions raised during the Aging Management Program (AMP) audit which were provided in a letter dated August 11, 2005, concerning the Monticello Nuclear Generating Plant license renewal application (LRA). The following issues were discussed during the telephone conference call.

1. The applicant was asked to provide justification for using Risk-Informed In-Service Inspection (RI-ISI) as an acceptable exception to the GALL Report for the boiling-water reactor (BWR) Stress Cracking Corrosion, BWR Vessel Internals, and Primary Containment In-Service Inspection Aging Management Programs.

**Discussion:** The applicant indicated that the question is clear.

2. The applicant was asked to provide a docketed response to Question 3.4-06 from the Aging Management Review (AMR) audit regarding aging management of the main condenser components.

**Discussion:** The applicant indicated that the question is clear.