

مترجعون والمراجع والمراجع

A Duke Energy Company

GARY R. PETERSON Vice President McGuire Nuclear Station

Duke Power MG01VP / 12700 Hagers Ferry Road Huntersville, NC 28078-9340

704 875 5333 704 875 4809 fax grpeters@duke-energy.com

August 22, 2005

U. S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555-0001

Subject: Duke Energy Corporation McGuire Nuclear Station Unit 1 Docket No. 50-369 Relief Request (RR) 05-MN-01

Pursuant to 10 CFR 50.55a(a)(3), Duke requests approval to use alternatives to Section XI of the ASME Boiler and Pressure Vessel Code. Compliance with the specified requirements of this section would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety. However, the proposed alternatives will provide an acceptable level of quality and safety. Specific details are described in the attached relief requests.

Questions on this matter should be directed to Norman T. Simms, McGuire Regulatory Compliance, at (704) 875-4685.

Sincerely,

G.R. Peterson

Attachment

U.S. Nuclear Regulatory Commission August 22, 2005

cc w/attachment:

Mr. W.D. Travers Regional Administrator, Region II U. S. Nuclear Regulatory Commission Atlanta Federal Center 61 Forsyth Street, SW, Suite 23T85 Atlanta, Georgia 30303

Mr. S.E. Peters, Project Manager (addressee only)
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
One White Flint North, Mail Stop 08 G9
11555 Rockville Pike
Rockville, MD 20852-2738

Mr. J.B. Brady Senior NRC Resident Inspector McGuire Nuclear Station

ATTACHMENT

•

.

、 、

.

Relief Request 05-MN-001

Proposed Relief in Accordance with 10 CFR 50.55a(g)(5)(iii), Inservice Inspection Impracticality Duke Energy Corporation McGuire Nuclear Station – Unit 1 (EOC-16) Third 10-Year Interval – Inservice Inspection Plan Interval Start Date= December 1, 2001 Interval End Date= December 1, 2011 ASME Section XI Code – 1995 Edition with 1996 Addenda and *Westinghouse Owner's Group (WCAP-14572) Code Case N-460 is applicable Examination Dates October 11, 2002-April 12, 2004

•

:

| | I. | 11. | III. | IV. & V. | VI. | VII. | VIII. |
|----------------|-------------------------------------|--|--|--|---|--|--|
| List Number | Limited Area/Weld I.D. Number | System / Component for Which Relief is Requested: Area or Weld to be Examined | Code Requirement from Which Relief is Requested: 100% Exam Volume Coverage Exam Category Item No. Fig. No. Limitation Percentage | Impracticality/ Burden Caused by Compliance | Proposed Alternate Examinations or Testing | Implementation Schedule and Duration | Justification for Granting Relief |
| 1. | IPZR-12 | NC System Pressurizer Spray Nozzle to Upper Head | Exam Category B-D Item No. B03.1 10.002 Fig. IWB-2500-7 (b) 73.6% Volume Coverage (COVERAGE LIMITATION) | See Paragraph "A" See Attachment I Pages 1-23 | See Paragraph "G". | See Paragraph "N". | See Paragraph "H" See Attachment I Pages 1-23 |
| 2. | 1PZR-15 | NC System Pressurizer SafetyNozzle to Upper Head | Exam Category B-D Item No. B03.110.005 Fig. IWB-2500-7(b) 73.6% Volume Coverage (COVERAGE LIMITATION) | See Paragraph "A" See Attachment 1 Pages 1-23 | See Paragraph "G". | See Paragraph "N". | See Paragraph "H" See Attachment 1 Pages 1-23 |
| 3. | 1PZR-16 | NC System Pressurizer Relief Nozzle to Upper Head | Exam Category B-D Item No. B03.110.006 Fig. IWB-2500-7(b) 73.6% Volume Coverage (COVERAGE LIMITATION) | See Paragraph "A" See Attachment 1 Pages 1-23 | See Paragraph "G". | See Paragraph "N". | See Paragraph "H" See Attachment 1 Pages 1-23 |
| 4. | IRCPA-8-1 | NV System Reciprocating Charging Pump Accumulator Flange to Shell | Exam Category C-A Item No. C01.010.090 Fig. IWC-2500-1 74.4% Volume Coverage (COVERAGE LIMITATION) | See Paragraph "B" See Attachment 2 Pages 1-6 | See Paragraph "G". | See Paragraph "N". | See Paragraph "I" See Attachment 2 Pages 1-6 |
| 5. | I ASWINJF-1 | NV System Seal Water Injection Filter 1A Shell to Upper Flange | Exam Category C-A Item No. C01.010.100 Fig. IWC-2500-1 64.4% Volume Coverage (COVERAGE LIMITATION) | See Paragraph "C" See Attachment 3 Pages 1-5 | See Paragraph "G". | See Paragraph "N". | See Paragraph "J" See Attachment 3 Pages 1-5 |

Request Relief 05-MN-001 Page 2 of 10

| | Ι. | II. | 111. | IV. & V. | VI. | VII. | VIII. |
|----------------|-------------------------------------|--|--|---|---|--|---|
| List Number | Limited Area/Weld I.D. Number | System / Component for Which Relief is Requested: Area or Weld to be Examined | Code Requirement from Which Relief is Requested: 100% Exam Volume Coverage Exam Category Item No. Fig. No. Limitation Percentage | Impracticality Burden Caused by Compliance | Proposed Alternate Examinations or Testing | Implementation Schedule and Duration | Justification for Granting Relief |
| 6. | IELDHX-HD- FLG | NV System Excess Letdown Heat Exchanger Head to Flange | Exam Category C-A Item No. C01.020.021 Fig. IWC-2500-1 79.8% Volume Coverage (COVERAGE LIMITATION) | See Paragraph "D" See Attachment 4 Pages 1-11 | See Paragraph "G". | See Paragraph "N". | See Paragraph "K" See Attachment 4 Pages 1-11 |
| 7. | IRCPA-10-1 | NV System Reciprocating Charging Pump Accumulator Shell to Head | Exam Category C-A Item No. C01.020.080 Fig. IWC-2500-1 71.1% Volume Coverage (COVERAGE LIMITATION) | See Paragraph "E" See Attachment 5 Pages 1-6 | See Paragraph "G". | See Paragraph "N". | See Paragraph "L" See Attachment 5 Pages 1-6 |
| 8. | INVP888-1 | NV System Reducer to Pipe | Exam Category R-A (Table 4.1-1) Item No. R01.011.150 Fig. IWB-2500-8 (c) & Note 1 35.6% Volume Coverage (COVERAGE LIMITATION) | See Paragraph "F" See Attachment 6 Pages 1-5 | See Paragraph "G". | See Paragraph "N". | See Paragraph "M" See Attachment 6 Pages 1-3 |

*Piping Welds examined under the RI-ISI Program developed in accordance with methodology contained in the Westinghouse Owner's Group (WOG) Topical Report, WCAP-14572, Revision 1-NPA and Request for Relief 01-005 approved by SER, dated June 12, 2002.

IV. & V. Impracticality/Burden caused by Code Compliance

Paragraph A: (The Pressurizer Spray, Safety and Relief Nozzles are carbon steel. The diameter of the Spray Nozzle is 12.750 inches with a wall thickness of 1.900 inches. The diameter of the Safety and Relief Nozzles is 15.00 inches with a wall thickness of 1.900 inches.)

During the ultrasonic examination of these welds, 100% coverage of the required examination volume could not be obtained. Coverage was limited because of the proximity of the nozzle blend radius to the weld, which prevented axial scanning from the nozzle side. The amount of coverage reported presents the aggregate coverage from all scans performed on the weld and base material. The weld volume was scanned using 45-degree and 60-degree shear waves and straight beam longitudinal waves. The 45-degree beam covered 88% of the weld and 62% of the base material; the 60-degree beam covered 78% of the weld and 54% of the base material and the straight beam covered 100% of the weld and 58% of the base material. In order to achieve more coverage, the welds would have to be redesigned to allow scanning from both sides of the weld, which is impractical. There were no recordable indications found during the inspection of these welds.

Paragraph B: (The Reciprocating Charging Pump Accumulator Flange to Shell weld is stainless steel. The diameter of this weld is 6.660 with a wall thickness of .495 inches.)

During the ultrasonic examination of the shell to flange weld, 100% coverage of the required examination volume could not be obtained. Coverage was limited because of the proximity of the flange taper to the weld, which prevented scanning from four directions. The amount of coverage reported presents the aggregate coverage from all scans performed on the weld and base material. The weld volume was scanned using 45-degree shear waves supplemented by 60-degree longitudinal waves. The 45-degree beam covered 72% of the required examination volume in four orthogonal directions. The 60-degree beam covered 8% from one axial direction. In order to achieve more coverage, the weld would have to be redesigned to eliminate the flange taper, which is impractical. There were no recordable indications found during the inspection of this weld.

Paragraph C: (The Seal Water Injection Filter 1A Shell to Upper Flange is stainless steel. The diameter of this weld is 4.000 inches with a wall thickness of .438 inches.

During the ultrasonic examination of the shell to flange weld, 100% coverage of the required examination volume could not be obtained. Coverage was limited because of the proximity of the flange taper to the weld, which prevented scanning from four directions. The amount of coverage reported presents the aggregate coverage from all scans performed on the weld and base material. The weld volume was scanned using 45-degree shear waves supplemented by 60-degree longitudinal waves. The 45-degree beam covered 63% of the required examination volume in four orthogonal directions. The 60-degree beam covered 3% from one axial direction.

In order to achieve more coverage, the weld would have to be redesigned to eliminate the flange taper, which is impractical. There were no recordable indications found during the inspection of this weld.

Paragraph D: (The Excess Letdown Heat Exchanger Head to Flange is stainless steel-carbon steel. The diameter of this weld is 9.500 inches with a wall thickness of .750 inches.

During the ultrasonic examination of the head to flange weld, 100% coverage could not be obtained. Coverage was limited because of the proximity of the flange taper to the weld, which prevented scanning from four directions. The amount of coverage reported presents the aggregate coverage from all scans performed on the weld and base material. The weld volume was scanned using 45-degree shear waves supplemented by 45-degree longitudinal waves. The 45-degree shear wave covered 51% of the required examination volume in four orthogonal directions. The 45-degree longitudinal wave covered 28% from one axial direction. In order to achieve more coverage, the weld would have to be redesigned to eliminate the flange taper, which is impractical. There were no recordable indications found during the inspection of this weld.

Paragraph E: (The Reciprocating Charging Pump Accumulator Shell to Head Weld is stainless steel. The diameter of this weld is 6.660 inches with a wall thickness of .495 inches.

During the ultrasonic examination of the shell to head weld, 100% coverage of the required examination volume could not be obtained. Coverage was limited because of the proximity of the flange taper to the weld, which prevented scanning from four directions. The amount of coverage reported presents the aggregate coverage from all scans performed on the weld and base material. The weld volume was scanned using 45-degree shear waves supplemented by 60-degree longitudinal waves. The 45-degree shear wave covered 67% of the required examination volume in four orthogonal directions. The 60-degree longitudinal wave covered 12% from one axial direction. In order to achieve more coverage, the weld would have to be redesigned to eliminate the head taper, which is impractical. There were no recordable indications found during the inspection of this weld.

Paragraph F: (The reducer to pipe material is stainless steel. The diameter of this weld is 2.000 inches with a wall thickness of .344 inches.)

During the ultrasonic examination of this weld, 100% coverage of the required examination volume could not be obtained. Coverage was limited because of the proximity of the reducer and it's taper to a socket weld at an adjacent valve, which prevented scanning from four directions. The amount of coverage reported presents the aggregate coverage from all scans performed on the weld and base material. The required volume was scanned using 45-degree, 60-degree shear waves and 70-degree shear waves. The 45-degree beam covered 50% of the volume in two circumferential directions. The 60-degree beam covered 42% of the volume in one axial

direction from the reducer side of the weld. The 70-degree shear wave covered 17.4% of the volume from one axial direction from the reducer side of the weld but was not included in the percent of coverage because of the requirements in 10CFR50.55a(b)(2)(xv)(A)(2). In order to achieve more coverage, the weld would have to be redesigned to allow scanning from both sides of the weld, which is impractical. There were no recordable indications found during the inspection of this weld.

VI. <u>Proposed Alternate Examinations or Testing</u>

Paragraph G:

The scheduled 10-year code examination was performed on the referenced area/welds and it resulted in the noted limited coverage of the required ultrasonic volume. No additional examinations are planned for the area/weld during the current inspection interval.

VII. Implementation Schedule and Duration

Paragraph N:

The scheduled 10-year code examination was performed on the referenced area/welds and it resulted in the noted limited coverage of the required ultrasonic volume. No additional examinations are planned for the area/weld during the current inspection interval.

VIII. Justification for Granting Relief

Paragraph H:

Ultrasonic examination of these welds for item B03.110 was conducted using personnel, qualified in accordance with ASME Section XI, Appendix VII. The examinations were also performed in accordance with the requirements of ASME Section V, Article 4 with the additional requirements of ASME Section XI, Appendix I.

The Pressurizer Nozzle to Upper Head Welds are limited due to single sided access caused by their nozzle geometry. In order to achieve more coverage, the nozzles would have to be redesigned to allow access from both sides. Therefore, the 100% volumetric examination is impractical for this weld. During the examination of these welds, techniques were utilized to obtain maximum possible coverage.

These welds are located on the upper head of the pressurizer and are not part of the reactor pressure vessel. These welds are not exposed to significant neutron fluence and are not prone to negative material property changes (i.e., embrittlement) associated with neutron bombardment. The McGuire Nuclear Station Unit 1 Pressurizer was fabricated by Westinghouse and is free from unacceptable fabrication defects. Westinghouse performed rigorous state-of-the-art inspections following fabrication to ensure no significant flaws existed. If a leak were to occur at any of the welds in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at any of these welds would result in the following:

- a) Increased containment humidity. This parameter is indicated in the control room and this is monitored periodically by Operations and also the Containment Ventilation System Engineer.
- b) Increased Pressurizer enclosure temperature. This parameter is continuously monitored by Operations via an Operator Aid Computer (OAC) alarm, and this is periodically monitored by the System Engineer.
- c) Increased input into the Ventilation Unit Condensate Drain Tank (VUCDT). This parameter is monitored continuously by Operations via an OAC alarm and also periodically by the Liquid Radwaste System Engineer and Reactor Coolant System Engineer.
- d) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of the reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage specification in Technical Specification 3.4.13.1 is 1 gpm.
- e) Other indicators such as containment radiation monitors EMF-38, 39 and 40, monitor the containment floor and equipment sump levels.

Note: The above parameters would be used to identify a leak in the pressurizer enclosure or containment, but could not specifically identify the exact source of the leakage. A containment entry would be required to identify the exact source of the leakage.

Also, a containment walkdown is performed when the unit reaches Mode 3 (full temperature/pressure) during the unit shutdown and startup for each refueling outage. This walkdown should identify any leak at the weld in question.

No additional B03.110 welds were scheduled during this outage. No additional surface or volumetric NDE examinations were performed on these welds.

Paragraph I:

Ultrasonic examination of this weld for item C01.010 was conducted using personnel, qualified in accordance with ASME Section XI, Appendix VII. The examination was also performed in accordance with the requirements of ASME Section XI, Appendix III with the additional requirements of ASME Section XI, Appendix I. This weld is located on the NV System Reciprocating Charging Pump Accumulator and it is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at this weld would result in the following:

- a) Abnormal Volume Control Tank (VCT) level trends and/or unexpected auto make-ups.
- b) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of the reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage specification in Technical Specification 3.4.13.1 is 1 gpm.

c) Increase in ND/NS Sump inputs. This parameter is monitored periodically by the Liquid Radwaste System Engineer.

Also, operators perform surveillance once per shift during daily rounds of the room containing the Reciprocating Charging Pump Accumulator. This surveillance should identify any leak at the weld in question.

No additional C01.010 welds were scheduled for the Reciprocating Charging Pump Accumulator this outage. No additional surface or volumetric NDE examinations were performed on this weld.

Paragraph J:

Ultrasonic examination of this weld for item C01.010 was conducted using personnel, qualified in accordance with ASME Section XI, Appendix VII. The examination was also performed in accordance with the requirements of ASME Section XI, Appendix III with the additional requirements of ASME Section XI, Appendix I. This weld is located on the Seal Water Injection Filter and is not exposed to significant neutron fluence and it is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at this weld would result in the following:

- a) Abnormal Volume Control Tank (VCT) level trends and/or unexpected auto make-ups.
- b) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of the reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage specification in Technical Specification 3.4.13.1 is 1 gpm.
- c) Increase in ND/NS Sump inputs. This parameter is monitored periodically by the Liquid Radwaste System Engineer.

One additional NDE ultrasonic examination was performed on the Seal Water Injection Filter 1A, Item Number C01.010.101 shell to lower flange weld. The results from this examination were acceptable with 90% coverage. No additional surface or volumetric NDE examinations were performed on this weld.

Paragraph K:

Ultrasonic examination of this weld for item C01.020 was conducted using personnel, qualified in accordance with ASME Section XI, Appendix VII. The examination was also performed in accordance with the requirements of ASME Section XI, Appendix III with the additional requirements of ASME Section XI, Appendix I. This weld is located on the Excess Letdown Heat Exchanger and is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at this weld would result in the following:

- a) Increased containment humidity. This parameter is indicated in the control room and it is monitored periodically by Operations and the Containment Ventilation System Engineer.
- b) Increased input into the VUCDT. This parameter is monitored continuously by Operations via an OAC alarm and also periodically by the Liquid Radwaste System Engineer and Reactor Coolant System Engineer.
- c) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage specification in Technical Specification 3.4.13.1 is 1 gpm.
- d) Other indicators such as containment radiation monitors EMF-38, 39 and 40 monitor the containment floor and equipment sump levels.

Note: The above parameters would be used to identify a leak in the containment, but could not specifically identify this weld as the source of leakage. A containment entry would be required to identify the exact source of the leak.

Also, a containment walkdown is performed when the unit reaches Mode 3 (full temperature/pressure) during the unit shutdown and startup for each refueling outage. This walkdown should identify any leak at the weld in question.

One additional NDE ultrasonic examination was performed on the (Excess Letdown Heat Exchanger, Item Number C01.020.020 shell to head weld. The results from this examination were acceptable with 100% coverage. No additional surface or volumetric NDE examinations were performed on this weld.

Paragraph L:

Ultrasonic examination of this weld for item C01.020 was conducted using personnel, qualified in accordance with ASME Section XI, Appendix VII. The examinations were also performed in accordance with the requirements of ASME Section XI, Appendix III with the additional requirements of ASME Section XI, Appendix I. This weld is located on the NV System Reciprocating Charging Pump Accumulator and is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Enginerring evaluation. A leak at this weld would result in the following:

- a) Abnormal Volume Control Tank (VCT) level trends and/or unexpected auto make-ups.
- b) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of the reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage specification in Technical Specification 3.4.13.1 is 1 gpm.
- c) Increase in ND/NS Sump inputs. This parameter is monitored periodically by the Liquid Radwaste System Engineer.

Also, operators perform surveillance once per shift during daily rounds of the room containing the Reciprocating Charging Pump Accumulator. This surveillance should identify any leak at the weld in question.

No additional C01.020 welds were scheduled for the Reciprocating Charging Pump Accumulator this outage. No additional surface or volumetric NDE examinations were performed on this weld.

Paragraph M:

Ultrasonic examination of this weld for item R01.011 was conducted using personnel, procedures and equipment qualified in accordance with ASME Section XI, Appendix VIII, Supplement 2. This weld is located on the outlet side of the 1A Seal Water Injection Filter Outlet Isolation Valve (1NV-494) and it is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. A leak at this weld would result in the following.

- a) Abnormal Volume Control Tank (VCT) level trends and/or unexpected auto make-ups.
- b) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of the reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage specification in Technical Specifications 3.4.13.1 is 1 gpm.
- c) Increase in ND/NS Sump inputs. This parameter is monitored periodically by the Liquid Radwaste System Engineer.

Two additional NDE ultrasonic examinations were performed on 2.00" diameter, .344 wall thickness welds in the NV System. The results from these examinations were acceptable with 100% coverage.

IX. <u>Other Information</u>

Jim McArdle (Principal UT NDE Level III Examiner) provided Sections III., IV., V. and part of Section VIII.

Ed Hyland, Bryan Meyer, Harry Vanpelt, Jack Knost and Andrew McGuire (MNS Systems Engineers) provided parts of Section VIII.

Gary Underwood (Sponsor) compiled the remaining sections of this relief request.

| Sponsored By: Jany Und | Date Date | 7-25-05 |
|---------------------------|--|-----------------|
| Approved By: <u>L. Le</u> | vin Phyne Date | 7/28/05 |
| Attachment 1 | UT Examination Data B03.110.002, B03.110.005 | and B03.110.006 |
| Attachment 2 | UT Examination Data C01.010.090 | |
| Attachment 3 | UT Examination Data C01.010.100 | |
| Attachment 4 | UT Examination Data C01.020.021 | |
| Attachment 5 | UT Examination Data C01.020.080 | |
| Attachment 6 | UT Examination Data R01.011.150 | |

-

| | DUKE POWER COMPA | |
|---|--|---|
| · · · · · · · · · · · · · · · · · · · | UNIT: 1 STATUS: AS HANDFACTURED CERTIFICATION LETTER NO. AUTHORITY: ENGR. LTR. NO. | SPDN: ROPCPR R. # DUKE-2964 R. \$. HOWRD P/SA-5885 P |
| a a (3) (3) (3) (3) (3) (3) (4) (5) (5) (7) | | A DOM REVISED FOR MOTH 11437 IMAN NG REVISED FOR MOTH 11437 IMAN NG REVISED FOR MOTH 11437 |
| $\frac{1}{1}$ | | OA CONDITION 1 MCM 1201.01-0171 001 |
| S. D. NO. DAPT-1471 CONTRACT AND A CONTRACT AND A | 0. <u>CH-12884</u> <u>CURE POVER</u> NO. <u>1471</u> R NO. <u>1471</u> | Vestinghouse Electric Corporation TAMPA DIVISION TAMPA FLA. MAMANUK MESSIMICAN 1880 CU. MT.) THE GITTIN & LONG, VELD SCAN DECEMBRICATION THE GITTIN ALLONG, VELD SCAN DECEMBRICATION THE GITTING ALLONG |

.



Ł



| Sit | e/Unit: M | /icGuire / | 01 | _ | Procedu | re:NDE-640 |) | 0 | utage No.: <u>N</u> | IN1EOC16 |
|---------------------------|------------|-----------------|-------------|-----------------|-----------------------------|------------------------|------------|--------|---------------------|---------------|
| Summa | ry No.: | B03.11 | 0.002 | Procedure Rev.: | | ev.:2 | | ਰ | JT-04-081 | |
| Work | scope: _ | 15 | | - | - Work Order No.: | | 98577763 | | Page: 1 | of |
| Code: Sec | tion XI, 1 | 995 thru 1996 | Addenda | Cat./Item | : <u>B-D/B3.110.2</u> | Location: | | | N/A | |
|)rawing No.: | | MCM 120 | 1.01-170 | | Description: Circui | mferential - Nozzle to | Upper Head | | | |
| ystem ID: | | | | | | | | | | |
| omponent ID: | B03.110 | 0.002 /1PZR-12 | | | | Size/Length: | <u>N/A</u> | Thick | ness/Diameter: | 1.9" / 12.75" |
| mitations: | Yes - Se | ee Limitation o | alculations | attached to | Report no. UT-04-080 | St | art Time: | 1030 | Finish Time: | 1035 |
| Examination S | urface: | Inside 🔲 | Outside | ⇒ 🗹 | Surface Condition: | AS GROUND | | | | |
| Lo Location: | | 9.2.3 | V | Vo Location: | Centerline of Weld | Couplant: | ULTRAG | EL 11 | Batch No.: | 00325 |
| Temp. Tool M | fg.: | FISHER | | Serial No.: | MCNDE 27218 | Surface Temp. | :69 | °F. | | |
| Cal. Report No | o.: | | | , | CAL-04-142 | ÷ | | | | |
| Angle Used | 0 | 45 45T | 60 60 |)T |] | | | | | |
| Scanning dB | 38.8 | | | | | | | | | |
| ndication(s): | Yes [|] No 🗹 | | | - Scan Coverage: Upstrea | m 🔲 🛛 Downstream 🗹 |] cw 🗹 | ccw [| | |
| Comments: | | | | | | | | | | |
| FC 03-20 | | | | | | | | | | |
| | | | | | | | | | | |
| Results: | Acce | ent 🕢 Rei | ect 🗔 | | | | | | | |
| Percent Of Co | verage C | btained > 90% | <u>No -</u> | 73.6% | Reviewed Previous Da | ta: <u>Yes</u> | | | <u>-</u> | |
| xaminer L | evel II | | Sign | ature | Date Revie | ewer | | Signat | ure | Date |
| esor, James | н | - | mulf! | Barr_ | 3/14/2004 Jay / | A Eaton Level III | - Chit | | · | 3/16/2004 |
| xaminer l Bener Winfre | .evel II | 51 | Sign | ature | Date Site I | Review | ψN | Signat | ure | Date |
| ther L | evel II | later | / Sign | ature | Date ANII | Review | | Signat | ure | Date |
| obernusz, Te | rry | len | 1 hole | mou | 3/14/2004 | | _ | allel | my a | 7-18-04 |
| | | <u> </u> | | | / | | | 1 | | <u></u> |





UT Vessel Examination

.

| Site/U | Jnit: McGuire / | 01 | | Pro | ocedure: | NDE-820 | | C | Dutage No.: | MN | IEOC16 | ; |
|---|---------------------------|----------------|------------------------|--|------------------------------|---------------|------------|-------------|-------------|---------------|-------------|--|
| Summary N | No.: B0 | 3.110.002 | | Procedu | re Rev.: | 1 | | 1 | Report No.: | UT | -04-080 | |
| Worksco | ope: | ISI | | Work Or | der No.: | 98577763 | | | Page: | 1 | oř | 2 |
| Code: Section | n XI, 1995 thru 1 | 1996 Addend | laCat./Item | n:B-D/B3.11 | 0.2 | Location: | | | N/A | | | |
| Drawing No.: | МСМ | 1201.01-170 |) | Description: | Circumferential | - Nozzle to L | Jpper Head | | | | | |
| iystem ID: | | <u> </u> | | <u></u> | | | ··· | | | | | |
| omponent ID: B | 03.110.002 /1PZ | R-12 | | | S | ize/Length: | N/A | Thic | kness/Diame | ter: <u>1</u> | .9" / 12. | .75" |
| imitations: Ye | es - See attache | d Limitation | Report | | | Sta | rt Time: | 1047 | Finish Tir | ne: | 1114 | |
| Examination Surf | face: Inside | | itside 🔽 | Surface Cond | ition: AS GROL | IND | | | | | | |
| Lo Location: | 9.2.3 | | Wo Location: | Centerline of V | <u>Veld</u> Co | uplant: | ULTRAGE | <u>L 11</u> | Batch No. | : | _00325 | <u>; </u> |
| Temp. Tool Mfg.: | FISH | ER | Serial No.: | MCNDE 272 | <u>18</u> Su | face Temp.: | 69 | °F | | | | |
| Cal. Report No.: | | | | CAL-04-143, CAL-04- | 144 | | | | | | | |
| Angle Used | 0 45 4 | 5T 60 | 60T | 1 | : | | | | | | | |
| Scanning dB | 58.7 | 58.7 64.8 | 64.8 | | | | | | | | | |
| Indication(s): | Yes 🔲 No 🔽 |] | | Scan Coverage: Up | ostream 🔲 🛛 Do | wnstream 🗹 | cw 🗹 | ccw | | | | |
| Comments: | | | | | | | | | | | | |
| FC 03-29, 03-31 | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| Results: | Accept 🔽 | Reiect | Info 🗖 | | | | | | | | | |
| Percent Of Cover | rage Obtained > | 90%: | <u>No 73.6%</u> | Reviewed Previou | us Data: | Yes | - 1 | | ······ | | | |
| | | | Signature | Date | Reviewer | | | Signa | ature | | | Date |
| xaminer Lev | vel 11 | | Signature | | I CONCI | | | | | | | |
| xaminer Lev lesor, James H. | /el | Junes | Allen | 3/14/2004 | Jay A Eaton L | evel III | -hl | Š | | | 3/1 | 16/2004 |
| xaminer Lev Resor, James H. xaminer Lev .eeper, Winfred (| /el /el c. / | Junes Vei l | Signature Signature | 3/14/2004 Date 3/14/2004 | Jay A Eaton L Site Review | evel III | -M | Signa | ature | | 31' | 16/2004 Date |
| Examiner Lev Resor, James H. Examiner Lev Leeper, Winfred (Other Lev | /el /el C. // | Junes Vinfo | Signature Signature | 3/14/2004 Date 3/14/2004 Date | Jay A Eaton L Site Review | evel lil | | Signa | ature | | <u>3</u>]· | 16/2004 Date |



Limitation Record

| Ŋ | Site/Unit: | McGuire / | 01 | Procedure: | NDE-820 | Outage No.: | M | 11EOC | 216 |
|-------|--------------------|-----------|-------|-----------------|----------|-------------|---|--------|-----|
| 2 4 | Summary No.: | B03.11 | 0.002 | Procedure Rev.: | 11 | Report No.: | ហ | Г-04-0 | 80 |
| Z L | Workscope: | ISI | | Work Order No.: | 98577763 | Page: | 2 | of | 2 |
| -92-1 | Description of Lir | nitation: | | | | | | | |

Limited due to Nozzle Configuration. Aggregate coverage = 89% (weld) + 58.1% (Base metal) = 147.1 / 2 = 73.6% See attached

.

.

THESE CALCULATIONS ALSO APPLY TO BO3. 110.005 \$ BO3. 110.006

. .

Sketch of Limitation:

,

Limitations removal requirements: N/A

Radiation field: N/A

| Hadiation field | 1: N/A | _ | | | | ۸ | | |
|-----------------|----------|----|---------------|-----------|-----------------------|------------|-----------|-----------|
| Examiner | Level | 11 | Signature | Date | Reviewer | $ \land $ | Signature | Date |
| Resor, Jam | es H. | | Jouthen | 3/14/2004 | Jay A Eaton Level III | -m | κ | 3/16/2004 |
| Examiner | Level | 11 | Signalure | Date | Site Review | | Signature | Date |
| Leeper, Wi | nfred C. | | Ven Deen | 3/14/2004 | | 1. | | |
| Ither | Level | 11 | Signature | Date | ANII Review | 6 | Signature | Date |
| Kobernusz, | , Terry | | Cerry hoberno | 3/14/2004 | - | Nit | Clein 3.1 | 8-04 |
| | | | | J | R le | ui3/22/64- | γ | - 1 |

| C Energ | IY . | UT | | ATTACHMENT TO UT-04. | | | | |
|----------------|------------------|-----------------------|-----------|-------------------------|---------------------------|---------|------------------|--|
| Site/Unit: | McGuire / | 01 Procedure: NDE-820 | | Outage | No.: MN1EOC1 | | | |
| Summary No.: | B03.110.0 | 002 | Procedure | Rev.: | 1 | Report | No.: UT-04-08 | |
| Workscope: | ISI | | Work Orde | er No.: | 98577763 | P | age: dof | |
| <u>0 deg P</u> | anar | | | _ | | | 98310 | |
| Scan | 100.000 | % Length X | 100.000 | % volur | ne of length / $100 = $ _ | 100.000 | % total for 0 de | |
| <u>45 deg</u> | | | | | | | | |
| Scan | 100.000 | % Length X | 100.000 | % volur | ne of length / 100 = _ | 100.000 | % total for Scar | |
| Scan | 2100.000 | % Length X | 54.300 | % volur | ne of length / $100 = $ _ | 54.300 | % total for Scar | |
| Scan | 3 100.000 | % Length X | 100.000 | % volur | ne of length / $100 = $ | 100.000 | % total for Scar | |
| Scan | 4100.000 | % Length X | 100.000 | % volur | ne of length / 100 = _ | 100.000 | % total for Scar | |
| Add | totals and divid | le by # scans = | 88.575 | % total fo | r 45 deg | | | |
| <u>Other d</u> | <u>60 60 pa</u> | | | | | | | |
| Scan | 100.000 | % Length X | 98.600 | % volur | ne of length / $100 = $ _ | 98.600 | % total for Scar | |
| Scan | 2100.000 | % Length X | 18.500 | % volur | ne of length / $100 = $ _ | 18.500 | % total for Sca | |
| Scan | 3 | % Length X | 98.400 | % volur | ne of length / $100 = $ _ | 98.400 | % total for Scar | |
| Scan | 4 | % Length X | 98.400 | % volur | ne of length / $100 = $ _ | 98.400 | % total for Scar | |
| bbA | totals and divid | de by # scans = | 78.475 | % total fo | r <u>60</u> deg | | | |

Add totals for each angle and scan required and divide by # of angles to determine;

89.017 % Total for complete exam

Note:

Supplemental coverage may be achieved by use of other angles / methods. When used, the coverage for volume not obtained with angles as noted above shall be calculated and added to the total to provide the percent total for the complete examination.

WELD

| Site Field Supervisor: | Date: 3/16/04 | Ner 12 - 70 - 70 - 71 - 71 - 71 - 71 - 71 - 71 |
|------------------------|---------------|--|
| | | |

| Co Energy | | ŬT | Examinations | s - Vessels | ATT | АСНМЕЛТ-Т Л-04-036 |
|----------------------------|--------------------------------|---|---|--|--|--------------------------|
| Site/Unit: Mc | Guire / | 01 | Procedure: | NDE-820 | Outage No.: | MN1EOC16 |
| Summary No.: | B03.110 | 002 | Procedure Rev.: | 1 | Report No.: | UT-04-080 |
| Workscope: | 1SI | | Work Order No.: | 98577763 | Page: | BZ of 15 |
| <u>0 deg Plan</u> | ar | | | | | QC 3/16/04 |
| Scan | 100.000 | % Length X | 58,200% vol | ume of length / 100 = | <u>58.200</u> % | total for 0 deg |
| <u>45 deg</u> | | | | | | |
| Scan 1 | 100.000 | % Length X | 86.600 % vol | ume of length / $100 = $ | 86.600 % | total for Scan 1 |
| Scan 2 | 100.000 | % Length X | % vol | ume of length / 100 = | <u>45.000</u> % | total for Scan 2 |
| Scan 3 | 100.000 | % Length X | 58.200% vol | ume of length / 100 = | <u> 58.200 </u> % | total for Scan 3 |
| Scan 4 | 100.000 | % Length X | 58.200 % volu | ume of length / 100 = | 58.200 % | total for Scan 4 |
| Scan 1 Scan 2 | 100.000 | % Length X% Length X | 82.600 % volu | ume of length / $100 =$ | <u>82.600</u> % | total for Scan 1 |
| Scan 3 | 100.000 | | % vol | $m_{\rm e}$ of length (100 - | 70 | total for Soon 0 |
| Coor 4 | | | % voit | | % | Iotal for Scan 3 |
| Add to | als and divid | % Length X de by # scans = | % void % total f | or <u>60</u> deg | 55.200% | ioiai ior Scan 4 |
| Percent co | mplete cove | rage | | | | |
| Add totals f | or each angle | e and scan required | and divide by # of ang | les to determine; | | |
| 58.083 | % Total for | complete exam | BASE | METAL | | |
| Supplemen | lal coverage Ih angles as i | may be achieved by noted above shall b | / use of other angles / i e calculated and added | methods. When used, t d to the total to provide t | he coverage for vo he percent total for | lume not the complete |
| obtained wi examination | | \cap | | | · - | - ALDE |

RR = 05-110-001

ATT.1 page7.23



ATT.1 Page 8.23





KK. 02-UM. 001 ATT. 1 page 10-23 ٠. B03,110,00 Z PRESSURIZER - MASHI NOZZLE HEAD TD 45° FROM 52 - WELT $1.7'' \times 2.8'' = 2.38/4.38 \times 100 = 54.3\%$... 5Z NOZZLE SI HEAD . ATTACHMENT TO UT-04-080 PAGE 6 DF 15 III 3/16/04. R/144 3122/00



KK 02-111 --- 1 ATT. 1 Page 12-23



RK 05-HN-001 ATT-1 prog 13-23











RR OD-MN----

ATT. 1 page 18.23





Ret 5. NN-001 ATT-1 page 20-23

.



| Summary No: B03.110.005 Procedure Rev.: 2 Report No.: UT-04-083 Workscope: 151 Work Order No.: 98577763 Page: 1 of 1 Code: Section XI, 1995 thm 1996 Addenda Cat./Item: B-D/153.110.5 Location: N/A Drawing No:: MCM 120.10170 Description: Circumferential - Nozzle to Upper Head N/A Tackness/Diameter: 1.8° / 15.0° Component ID: B3.110.005 /1FZR-15 Size/Length: N/A Tackness/Diameter: 1.8° / 15.0° Limitations: Yes - See Limitation calculations attached to Report no. UT-04-080 Start Time: 1025 Finish Time: 1040 Examination Surface: Inside Outside G/ Surface Condition: AS GROUND 00325 00325 Lo Location: 9.2.3 Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 00325 Temp. Tool Mig: FISHER Serial No.: MCNDE 27218 Surface Temp.: 69 *F Cal. Report No.: CAL-04-142 Angle Used | Si | te/Unit: | McGuire / | 01 | - | Pr | ocedure: | NDE-640 | | (| Outage No.: <u>M</u> | N1EOC16 | |
|---|----------------|-----------|--|---------------|-------------------|------------------------|--------------|---------------------|--|-------------|----------------------|-----------|--------|
| Workscope: ISI Work Order No.: 98577763 Page: 1 of 1 Code: Section XI, 1995 thru 1996 Addenda Cat./Item: B-D/B3.110.5 Location: N/A Drawing No.: MCM 1201.01-170 Description: Circumferential - Nozzle to Upper Head System ID: Component ID: B03.110.005 /IPZR-15 Size/Length: N/A Thickness/Diameter: 1.9° / 15.0° Linitations: Yes - See Linitation calculations attached to Report no. UT-04-080 Start Time: 1033 Finish Time: 1040 Examination Surface: Inside Outside Q Surface Condition: AS GROUND 00325 00325 Lo Location: 9.2.3 Wo Location: Canter/Ine of Weld Couplant: ULTRAGEL II Batch No.: 00325 Temp. Tool Mg: FISHER Serial No.: MCNDE 27218 Surface Temp.: 69 'F Cal. Report No.: CAL-04-142 Surface Temp.: 69 'F Cal. Report No.: CAL 04-142 Surface Temp.: 69 'F Canments: | Summa | ry No.: | B03.11 | 0.005 | _ | Procedu | ure Rev.: | 2 | | | Report No.: | T-04-083 | |
| Code: Section XI, 1995 thru 1996 Addenda Cat./ltem: B-//B3.110.5 Location: N/A Drawing No.: MCM 1201.01-170 Description: Circumferential - Nozzle to Upper Head Size/Length: N/A Thickness/Diameter: 1.9" / 15.0" Component ID: B03.110.055 /1PZR-15 Size/Length: N/A Thickness/Diameter: 1.9" / 15.0" Limitations: Yes - See Limitation calculations attached to Report no. UT-04-080 Start Time: 1035 Finish Time: 1040 Examination Surface: Instide Outside G Surface Condition: AS GROUND 00325 Lo Localion: 9.2.3 Wo Location: Centerline of Weld Couplent: ULTRAGEL II Batch No.: 00325 Temp. Tool Mfg: FISHER Serial No.: MCNDE 27218 Surface Temp.: 69 "F Cal. Report No.: | Work | (scope: | | | - Work Order No.: | | | 98577763 | | | Page: 1 | of | 1 |
| Drawing No.: MGM 1201.01-170 Description: Circumferential - Nozzle to Upper Head System ID: | Code: Sec | tion XI, | 1995 thru 1996 | Addenda | Cat./Item | :B-D/B3.1 ⁻ | 10.5 | Location: | | | N/A | | |
| System ID: Component ID: 503.110.005 /1PZR-15 Size/Length: N/A Thickness/Diameter: 1.9" / 15.0" Limitations: Yes - See Limitation calculations attached to Report no. UT-04-080 Start Time: 1035 Finish Time: 1040 Examination Surface: Inside Outside S Surface Condition: AS GROUND Surface Condition: AS GROUND 003225 Lo Location: 9.2.3 Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 00325 Temp. Tool Mfg: FISHER Serial No.: MCNDE 27218 Surface Temp.: 69 "F Cal. Report No.: 00325 Cal. Report No.: CAL-04-142 Couplant: Surface Temp.: 69 "F CCW S CCW S Comments: Fros No S Scan Coverage: Upstream Downstream S CW S CCW S Comments: FC 03-20 Start Ime Jinfo Signature Signature Signature Percent Of Coverage Obtained > 90%: No - 73.6% Reviewed Previous Data: Yes Signature Signature Signature Examiner Level II Signature Date Signature Signature Signature Signature Examiner Level II Signature Date< | Drawing No.: | | MCM 120 | 1.01-170 | | Description: | Circumferer | ntial - Nozzle to U | pper Head | | <u></u> | | |
| Component ID: B03,110.005 /1PZR-15 Size/Length: N/A Thickness/Diameter: 1.9" / 15.0" Limitations: Yes - See Limitation calculations attached to Report no. UT-04-080 Start Time: 1035 Finish Time: 1040 Examination Surface: Inside Outside Ø Surface Condition: AS GROUND Lo Location: 9.2.3 Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 00325 Temp. Tool Mfg: FiSHER Serial No.: MCNDE 27218 Surface Temp.: 69 *F Cal. Report No: | System ID: | | | | | <u></u> | | | | | | | |
| Limitations: Yes - See Limitation calculations attached to Report no. UT-04-080 Start Time: 1035 Finish Time: 1040 Examination Surface: Inside Outside Surface Condition: AS GROUND Outside Outside Outside Surface Condition: As GROUND Lo Location: 9.2.3 Wo Location: Centerline of Weid Couplant: ULTRAGEL II Batch No.: 00325 Temp. Tool Mig: FISHER Serial No.: MCNDE 27218 Surface Temp.: 63 *F Cal. Report No.: CAL-04-142 Cal.ede-142 Surface Cowerage: Upstream Downstream CW M CW M CW M CW M Start Time: 1040 45 45T 60 60T Scanning dB Start Surface Temp.: 63 *F Cal. Report No.: CAL-04-142 Cowerage: Upstream Downstream CW M CW M CW M CW M Indication(s): Yes No Ø Scan Coverage: Upstream Downstream CW M CW M Signature Date Results: Accept Ø Reject I Info Peretent Of Coverage Obtained > 90%: No -73.6 | Component ID: | B03.11 | 0.005 /1PZR-15 | | | | | Size/Length: | N/A | Thic | kness/Diameter: | 1.9" / 15 | .0" |
| Examination Surface: Inside Outside Surface Condition: AS GROUND Lo Location: 9.2.3 Wo Location: Centerline of Weid Couplant: ULTRAGEL II Batch No.: 00325 Temp. Tool Mig.: FISHER Serial No.: MCNDE 27218 Surface Temp.: 69 *F Cal. Report No.: CAL-04-142 Angle Used 0 45 45T 60 60T Scanning dB 38.8 1 1 1 Indication(s): Yes No Ø Scan Coverage: Upstream Downstream Ø CW Ø CCW Ø Comments: FC 03-20 Results: Accept Ø Reject Info | Limitations: | Yes - S | ee Limitation o | alculations | attached to | Report no. UT-04-08 | 0 | Star | t Time: | 1035 | Finish Time: | 1040 | |
| Lo Location: 9.2.3 Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 00325 Temp. Tool Mfg.: FISHER Serial No.: MCNDE 27218 Surface Temp.: 69 *F Cal. Report No.: | Examination S | Surface: | Inside 🔲 | Outside | | Surface Cond | lition: AS G | ROUND | ······································ | | | | |
| Temp. Tool Mig.: FISHER Serial No.: MCNDE 27218 Surface Temp.: 69 *F Cal. Report No.: | Lo Location: | | 9.2.3 | w | /o Location: | Centerline of V | Neld | Couplant: | ULTRAGE | <u>L II</u> | Batch No.: | 00325 | |
| Cal. Report No.: CAL-04-142 Angle Used 0 45 45T 60 60T Scanning dB 38.8 1 1 1 Indication(s): Yes No Ø Scan Coverage: Upstream Downstream Ø CW Ø CCW Ø Comments: FC 03-20 Results: Accept Ø Reject Info | Temp. Tool M | lfg.: | FISHER | / | Serial No .: | MCNDE 272 | 18 | Surface Temp.: | 69 | *F | | | |
| Angle Used 0 45 45T 60 60T Scanning dB 38.8 1 1 1 Indication(s): Yes No Ø Scan Coverage: Upstream Downstream Ø CW Ø CCW Ø Comments: FC 03-20 Results: Accept Ø Reject Info | Cal. Report N | o.: | | | | CAL-04-142 | | ······ | | | | | |
| Scanning dB 38.8 | Angle Used | 0 | 45 45T | 60 60 | т | 1 | | | | | | | |
| Indication(s): Yes No Ø Scan Coverage: Upstream Downstream Ø CW Ø CCW Ø Comments: FC 03-20 Results: Accept Ø Reject Info | Scanning dB | 38.8 | | | | | | | | | | | |
| Comments: FC 03-20 Results: Accept Ø Reject Info Percent Of Coverage Obtained > 90%: No - 73.6% Reviewed Previous Data: Yes Examiner Level II Signature Date Resor, James H. Signature Signature Date Signature Date Signature Date Signature Date Signature Date Signature Date Other Level II Vinter C. Vinter Control Signature Date Milt Review Signature Date ANII Review Signature J/8-04 | Indication(s): | Yes [| No 🗹 | | | Scan Coverage: Up | ostream 🔲 | Downstream 🗹 | cw 🗹 | ccw | | | |
| FC 03-20 Results: Accept P Reject Info Percent Of Coverage Obtained > 90%: No - 73.6% Reviewed Previous Data: Yes Examiner Level II Signature Date Reviewer Accept Minter Signature Date Reviewer Signature Date Examiner Level II Signature Date Signature Date Examiner Level II Signature Date Signature Date Cherry Level II Signature Date Signature Date Coherry Level II Signature Signature Date Other Level II Signature Date ANII Review Signature Date Kobernusz, Terry Grupper Winfred C. Signature Signature Date ANII Review Signature Date ANII Review Signature Date ANII Review Signature Trance | Comments: | | | | | | | | | | | | |
| Results: Accept P Reject Info Percent Of Coverage Obtained > 90%: No - 73.6% Reviewed Previous Data: Yes Examiner Level Signature Date Reviewer Resor, James H. Journal of the standard | FC 03-20 | | | | | | | | | | | | |
| Results: Accept I Reject I Info I Percent Of Coverage Obtained > 90%: No - 73.6% Reviewed Previous Data: Yes Examiner Level II Signature Date Reviewer Resor, James H. Connuctification 3/14/2004 Jay A Eaton Level III Signature Date Examiner Level II Connuctification Date Signature Date Other Level II Signature Date 3/14/2004 Signature Date Other Level II Signature Date 3/14/2004 Mil Review Signature Date Kobernusz, Terry Gray Mursury 3/14/2004 Mil Review Signature Date | , | | | | | | | | | | | | |
| Percent Of Coverage Obtained > 90%: No - 73.6% Reviewed Previous Data: Yes Examiner Level II Signature Date Signature Date Resor, James H. Image: March 100 and 114/2004 Jay A Eaton Level III Signature Date Examiner Level II Image: March 100 and 114/2004 Date Site Review Signature Date Cher Level II Signature Date Site Review Signature Date Other Level II Signature Date ANII Review Signature Date Kobernusz, Terry Grup Muran 3/14/2004 Mark 2004 Mark 2004 Mark 2004 | Results: | Acc | ept 🔽 Rej | ect 🔲 | Info 🔲 | | | | | | | | |
| Examiner Level II Signature Date Reviewer Signature Date Resor, James H. Image: Margin and the signature 3/14/2004 Jay A Eaton Level III Signature Date 3/16/2004 Examiner Level II Signature Date Site Review Signature Date Leeper, Winfred C. Signature Date Site Review Signature Date Other Level II Signature Date ANII Review Signature Date Kobernusz, Terry Granture 3/14/2004 Signature Date ANII Review Signature Date | Percent Of Co | overage (| Obtained > 90% | <u>No - 7</u> | /3.6% | Reviewed Previo | us Data: | Yes | | | | | |
| Resor, James H. June 447 3/14/2004 Jay A Eaton Level III June 447 3/16/2004 Examiner Level II Signature Date Sile Review Signature Date Leeper, Winfred C. User and a few and a f | Examiner | Level II | | Signa | ature | Date | Reviewer | | () | Signa | ature | | Date |
| Leeper, Winfred C. User Contraction Date Signature Date Other Level II Signature Date ANII Review Signature Date Kobernusz, Terry Erry Wolung 3/14/2004 3/14/2004 Signature Date | Resor, James | H. | Jon | metel 2 | | 3/14/2004 | Jay A Eato | | | | | 3/1 | 6/2004 |
| Other Level II Signature Date ANII Review Signature Date Kobernusz, Terry Grup Kolunsury 3/14/2004 | Leeper, Winfre | ed C. | Win | \mathcal{D} | | 3/14/2004 | ONG LEAIGM | | 11 | Signa | | | |
| Novernosz, reny why whish 3/14/2004 Moglin - 5-18-04 | Other | Level II | - Contraction of the second se | Signa | ature | · Date | ANII Review | / | | (S) | ature | | Date |
| | Kobernusz, 16 | y | eng/a | Juna | <u></u> | 3/14/2004 | | <u> </u> | | Mag | Ken . | -18-1 | 24 |

RR*05-MN-001. ATT-1 page 21-23

5000

٠



Ì.

| Sit | e/Unit: | McGuire | 1 | 01 | | | | | Proc | edure: | N |)E-820 | | | (| Outage No |).: <u> </u> | <u>4N1</u> | EOC | 6 |
|----------------|-------------------|-----------|--------------|-----------|-----------------|---------------|-------|--------------|-----------------|--------------------|-------------|---------|----------|----------------|------|-----------|--------------|------------|-------------|-----------|
| Summa | ry No.: | 1 | B03.110 | .005 | | | | Pro | ocedure | e Rev.: | | 1 | | | | Report No | ».: | UT- | 04-08 | 5 |
| Work | scope: | | ISI | - | | | | Wo | rk Orde | er No.: | 98 | 577763 | | _ | - | Pag | e: <u>1</u> | <u> </u> | of _ | 1 |
| Code: Sec | tion XI, | 1995 thr | u 1996 / | Addend | a | Cat./Iten | n: | B-D/E | B3.110 | .5 | Loc | ation: | | | | N/A | | | | |
| Drawing No.: | | мс | M 1201 | .01-170 | | | _ | Descriptio | on: <u>Ci</u> r | rcumferen | tial - Nozz | le to U | pper He | ad | | | | | | |
| System ID: | | | | | | | | | _ | | | | | | | | | | | |
| Component ID: | B03.11 | 0.005 /11 | PZR-15 | | | | | | | | Size/Le | ngth: _ | N/A | <u> </u> | Thic | kness/Dia | meter: | : _1 | .9"/1 | 5.0" |
| Limitations: | Yes • S | See Limit | tation ca | alculatio | ons atta | ched to | Repo | rt no. UT-04 | 4-080 | | | Star | t Time: | 1 | 053 | - Finist | Time: | · | 112 | 0 |
| Examination S | Surface: | Insic | ie 📋 | Ou | tside 🔽 |] | | Surface (| Conditi | ion: <u>AS G</u> i | ROUND | | | | | | | | | |
| Lo Location: | | 9.2 | 2.3 | | WoL | ocation: | | Centerline | <u>e of We</u> | eld | Couplant | | ULTR | AGEL | 1 | Batch | No.: _ | | _003; | 25 |
| Temp. Tool M | fg.: | FI | SHER_ | | Se | rial No.: | | MCNDE | <u>: 27218</u> | 3 | Surface T | emp.: | 6 | 9 | •F | | | | | |
| Cal. Report No | o.: | | | | | | CAL-0 | 04-143, CAL | <u>04-14</u> | 14 | | | | | | | | | | |
| Angle Used | 0 | 45 | 45T | 60 | 60T | [|] | | | | | | | | | | | • | | |
| Scanning dB | | 58.7 | 58.7 | 64.8 | 64.8 | | | | | | | | | | | | | | | |
| Indication(s): | Yes [| No | \mathbf{N} | | | | Scar | n Coverage: | Upst | tream 🗌 | Downstre | am 🗹 | CM | | CCW | | | | | |
| Comments: | | | | | | | | | | | | | | | | | | | | |
| FC 03-29, 03- | 31 | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| Results: | Acc | ept 🔽 | Reie | ect 🗖 | Inf | ю П | | | | | | | | | | | | | | |
| Percent Of Co | verage | Obtained | > 90%: | <u></u> N | o - 73.6 | | - | Reviewed Pr | revious | : Data: | Ye | 3 | <u> </u> | | | <u> </u> | <u></u> | , | | |
| Examiner | | | | | Signatur | ·• | | r | Date | Reviewer | ····· | | | | Sign | aturo | | | | Date |
| Resor, James | -стог п Н. | \leq | For | wt | Sin | | | 3/14/2 | 2004 J | ay A Eato | n Level II | | (| γV | | | | | 3 | /16/2004 |
| Examiner I | Level ed C. | 1 | | A. | Signatur | 6 | | C 3/14/2 | Date S | Site Review | , | | | - | Sign | ature | | | | Date |
| Other I | evel II | $-\omega$ | wa. | 21 | Signatur | .6 | | E | Jate A | NII Reviev | / | | | | Sign | att the A | ~ | | | Date |
| Kobernusz, Te | rry | Les. | m | 14l | na | | | 3/14/2 | :004 | | | | | | مك | n V | en | 3~ | <u>18-C</u> | <i>94</i> |
| | | (| \bigcirc | | $\overline{\ }$ | \mathcal{I} | | | | | | | | | | Ľ | | | | |



| Site/U Summary N Worksco | Site/Unit: McGuire / 01 Summary No.: B03.110.006 Workscope: ISI | | Procedure: Procedure Rev.: Work Order No.: | | NDE-640 2 98577763 | | Outage No.: Report No.: Page: | | MN1EOC16 UT-04-087 1 of 1 | | | |
|---|---|-------------------------------------|--|---|--|---|-------------------------------------|----------------|---------------------------------|-------------------|-------------------|--|
| Code: Section Drawing No.: | XI, 1995 thru 1996 MCM 1201 | Addenda Ca 1.01-170 | it./Item: | B-D/B3.11 Description: C | 0.6 Circumfere | Location: ntlal - Nozzle to U | pper Head | | N/A | | | |
| Component ID: B0 Limitations: Ye | 3.110.006 /1PZR-16 s - See Limitation c | alculations attach | ned to R | Report no. UT-04-080 |) | Size/Length:Star | N/A t Time: | Thic 1040 | kness/Diameter Finish Time | : <u>1.9</u> : | " / 15.0" 1045 | |
| Examination Surfa Lo Location: Temp. Tool Mfg.: Cal. Report No.: Angle Used Scanning dB Indication(s): Comments: FC 03-20 | ace: Inside 9.2.3 FISHER 0 45 45 45T 38.8 | Outside 🗹 Wo Loc Seria | ation: | Surface Condi Centerline of V MCNDE 2721 CAL-04-142 Scan Coverage: Up | ition: <u>AS G</u> Veld 18 stream | Couplant: Surface Temp.: Downstream | ULTRAGE | L II *F | Batch No.: | 0 | 0325 | |
| Results: Percent Of Cover Examiner Leve Resor, James H. | Accept Rej age Obtained > 90%: | ect Info No - 73.6% Signature | | Reviewed Previou Date 3/14/2004 | us Data: Reviewer Jay A Eato | Yes on Level III | | Sign | ature | | Date 3/16/2004 | |
| Examiner Leve Leeper, Winfred C Other Leve Kobernusz, Terry | | Signature | <u>,</u> | Date 3/14/2004 Date 3/14/2004 | Site Review | w | | Signi | ature | 18- | Date | |



UT Vessel Examination

.

| | Site/U | nit: <u>M</u> | cGuire | 1 | 01 | | | P | rocedure: | NDE-820 |) | (| Dutage No.: | MN | I1EOC | 16 |
|-------------|--------------|---------------|-----------|------------|----------|-----------|--------------|---------------------|---------------------------------------|--------------------|------------|-------|--------------|------------------|---------|-----------|
| Sur | mmary N | lo.: _ | 1 | 303.110 | .006 | | | Proced | lure Rev.: | 1 | | | Report No.: | רט | r-04-01 | 38 |
| \V | Worksco | pe: | | ISI | | | | Work C |)rder No.: | 9857776 | 3 | | Page: | 1 | of | 1 |
| Code: | Section | XI, 1 | 995 thr | u 1996 . | Addenc | la | Cat./Item | n:B-D/B3.1 | 110.6 | Location: | | | N/A | | | |
| Drawing No | o.: | | мс | M 1201 | .01-170 |) | | Description: | Circumferen | tial - Nozzle to I | Jpper Head | | | | | |
| System ID: | : | | | | | | | | | | | | | | | |
| Componen | nt ID: BO | 3.110 | .006 /11 | PZR-16 | | | | | · · · · · · · · · · · · · · · · · · · | Size/Length: | N/A | Thic | kness/Diamet | er: | 1.9"/ | 15.0" |
| Limitations | s: <u>Ye</u> | s - Se | e Limit | ation c | alculati | ons atta | ched to | Report no. UT-04-08 | 30 | Sta | rt Time: | 1059 | Finish Tim | 1 0 : | 11 | 26 |
| Examinat | tion Surfa | ace: | Insid | le 🗌 | Ot | itside 🔽 | | Surface Con | dition: AS GF | ROUND | | | | | | |
| Lo Locatio | on: | | 9,2 | .3 | | _ Wol | ocation: | Centerline of | Weld | Couplant: | ULTRAGE | L [] | Batch No.: | · | 003 | 25 |
| Temp. To | ool Mfg.: | | FI | SHER | | _ Se | rial No.: | MCNDE 27 | 218 | Surface Temp.: | 69 | •F | | | | |
| Cal. Repo | ort No.: | | | | | <u></u> | | CAL-04-143, CAL-04 | -144 | | | | | | | |
| Angle Use | ed [| ō | 45 | 45T | 60 | 60T | | 1 | | | | | | | | |
| Scanning | dB | | 58.7 | 58.7 | 64.8 | 64.8 | | | | ` | | | | | | |
| Indication | ה(s): א | /es 🗖 | No | N | | | | Scan Coverage: U | pstream 🔲 | Downstream 🗹 | cw 🗹 | ccw | | | | |
| Comment | its: | | | | | | | | | | | | | | | |
| FC 03-29 | , 03-31 | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| Posuite: | | A.c.c. | | Pol | oct 🗂 | Inf | ~ — | | | | | | | | | |
| Results. | | Acce | | | | | о (_] " | | | | | 1 | | | | |
| | Di Covera | age O | | > 90%: | ^ | 10 - 73.6 | <u>%</u> | Reviewed Previo | bus Data: | Yes | | | | | | |
| Examiner | Leve | el II | | | | Signatyr | e | Date | Reviewer | | 711 | Signa | lture | | | Date |
| Resor, Jar | mes H. | | 6 | | 111/ | 4 | <u>~</u> | 3/14/2004 | Jay A Eaton | Level III | A | | > | | ; | 3/16/2004 |
| Leeper, W | linfred C | a 11 : | 1 | C - | l, k | | • | 3/14/2004 | Sile Review | | 11 | Signa | IUre | | | Date |
| Other | Leve | 11 | /, | Ť | 2 | Signatur | e | Date | ANII Review | | | Signa | iture | ~ | | Date |
| Kobernus | z, Terry | | <u>(e</u> | n | 20 | uno | m | 3/14/2004 | <u> </u> | | | Alle | <u></u> | <u> </u> | 18 | -04 |
| | | | | \bigcirc | , | | \checkmark | , | | | | | | | | |



ATT. 2 Page 1-6

RR 05-AN-001





UT Vessel Examination

.

.

| Site/Unit: McGuire / 01 | | | Pr | rocedure: | NDE-330 | | Ou | tage No.: | MN1EC | C16 | | |
|-----------------------------|----------------|------------|-------------|-------------------|---------------------------|--------------|--------------------|---------------------|--------------|-------------|------------------|-----------|
| Summary | / No.: | CO | 1.010.090 | | Procedu | ure Rev.: | 0 | | Re | eport No.: | UT-04- | 039 |
| Works | cope: _ | | ISI | | Work O | rder No.: | 98577988 | | | Page: | <u>1</u> of | |
| Code: Secti | on XI, 1 | 995 thru 1 | 996 Adden | da Cat./It | em:C-A/C1.1 | 0.90 | Location: | | | N/A | | |
| Drawing No.: | | МСМ | 1201.04-19 | 7 | Description: | Circumferen | tial - Flange to S | Shell | | ··· | | |
| System ID: | | | | | | - | | | | | | |
| Component ID: | C01.010 | .090 /1RC | PA-8-1 | | | | Size/Length: | N/A | Thickr | ess/Diamet | er: <u>.49</u> 5 | 5/ 6.660 |
| Limitations: | Yes-See | Attached | Limitation | Report | | | Sta | rt Time: | 0950 | Finish Tim | e: | 1008 |
| Examination Su | rface: | Inside | | utside 🔽 | Surface Conc | dition: AS G | ROUND | | | | | |
| Lo Location: | | 9.2.1 | | Wo Locatio | n: <u>Centerline of </u> | Weld | Couplant: | ULTRAGE | <u>:L 11</u> | Batch No .: | 0 | 0325 |
| Temp. Tool Mfg | ı∷ | FISH | ER | Serial N | D.:MCNDE 272 | 218 | Surface Temp.: | 68 | °F | | | |
| Cal. Report No. | : | ··· | <u>.</u> | CAL | -04-084, CAL-04-085, C | AL-04-086 | | | | | | |
| Angle Used | 0 | 45 4 | 15T 60 | 60T 60 | - 1 | | | | | | | |
| Scanning dB | | 54 | 55 | 64 | | | | | | | | |
| Indication(s): | Yes 🗌 | No 🔽 |] | | Scan Coverage: Up | pstream 门 | Downstream 🗹 | cw⊵ | ccw |] | | |
| Comments: | | | | | | | | | | | | |
| Scanned at ref | ference | DB due to | signal to i | noise ratio | | | | | | | | |
| | | | | | | | | | | | | |
| Results: | Acce | pt 🗹 | Reject 🔲 | Info 🔲 | <u></u> | | | | 1 | | | |
| Percent Of Cov | erage O | btained > | 90%: | <u>No - 74.4%</u> | Reviewed Previo | ous Data: | Yes | - | | | • | |
| Examiner Le | evel | | , /. | Signatore | Date | Reviewer | | $\overline{\Delta}$ | Signatu | ire | | Date |
| Leeper, Winfred | <u> 1 C.</u> | | Ulen | hal be | <u>e</u> <u>2/24/2004</u> | Jay A Eato | n Level III | -m | | | | 2/26/2004 |
| Examiner Le Jordan, Joey | evei | | | oignature | Date 2/24/2004 | Site Review | | 11 | Signatu | ILE | | Date |
| Other Le | evel N// | 4 | | Signature | Date | ANII Review | Al Dein | | Signatu | 1re 3-8-0 | y | Date |
| | | | | | ······ | | - pr - l | | | | | |

Puke Energy

_ -

Determination of Percent Coverage for UT Examinations - Pipe

| 3 | Site/Unit: | McGuire / 01 | Procedure: | NDE-330 | Outage No.: | MN | I1EOC | >16 | |
|-----|-------------|--------------|-----------------|----------|-------------|----|--------|--------|--|
| o s | ummary No.: | C01.010.090 | Procedure Rev.: | 0 | Report No.: | ហ | r-04-0 |)4-039 | |
| - | Workscope: | ISI | Work Order No.: | 98577988 | Page: | 2 | of | 4 | |

<u>45 deg</u>

| Scan 1 | 100.000 | % Length X | 81.700 | \sim % volume of length / 100 = _ | 81.700 | % total for Scan 1 |
|--------|---------|----------------|--------|--|--------|--------------------|
| Scan 2 | 100.000 | _ % Length X _ | 68.300 | % volume of length / 100 = | 68.300 | % total for Scan 2 |
| Scan 3 | 100.000 | _ % Length X _ | 69.500 | \sim % volume of length / 100 = \sim | 69.500 | % total for Scan 3 |
| Scan 4 | 100.000 | % Length X | 69.500 | % volume of length / 100 = _ | 69.500 | % total for Scan 4 |

Add totals and divide by # scans = 72.250 % total for 45 deg

Other deg - 60 (to be used for supplemental scans)

The data to be listed below is for coverage that was not obtained with the 45 deg scans.

| Scan 1 | 100.000 % Leng | th X 8.500 | % volume of length / 100 = | 8.500 | % total for Scan 1 |
|--------|----------------|------------|----------------------------|---------|--------------------|
| Scan 2 | % Leng | th X | % volume of length / 100 = | | % total for Scan 2 |
| Scan 3 | % Leng | th X | % volume of length / 100 = | | % total for Scan 3 |
| Scan 4 | % Leng | th X | % volume of length / 100 = | • | % total for Scan 4 |

Percent complete coverage

Add totals for each scan required and divide by # of scans to determine;

% Total for complete exam 74.375 Site Field Supervisor: TT

Lindon Broch Date:



Limitation Record

| Site/Unit: McG | iulre / 01 | Procedure: | NDE-330 | Outage No.: MN1EOC16 |
|---------------------------------------|----------------|-------------------------|----------------|----------------------------|
| Summary No.: | C01.010.090 | Procedure Rev.: | 0 | Report No.: UT-04-039 |
| Workscope: | 151 | Work Order No.: | 98577988 | Page: <u>3</u> of <u>4</u> |
| Description of Limitatio | on: | | | • |
| Limited due to flange | | | | |
| | SHELL-51 | | FLA. | JKE-SZ |
| | • | , | | |
| | | | | |
| Sketch of Limitation: | ····· | XIIVIX | T. | an and |
| | | | 45" | 7000 S1 = 81.770 |
| | <u> </u> | <u> </u> | | |
| | | | | |
| | | | | - |
| · | | | | |
| | | 777 X7 17 | The side | 10-10 67 - 1836 |
| | | | 45 | PROM 36 - 00.370 |
| | | | // | |
| | | | | |
| | | | | |
| · | | | | |
| | · | KV//// | 45 | $cw \in ccw = 19.5\%$ |
| | | | 15 | |
| | | | | · |
| | | 1 | | |
| | | | | |
| | | TTTT | | |
| | | | 1. 60L | SUPPLEMENTAL = 90.2 |
| | <u></u> | <u> </u> | <u></u> | |
| • | | | • | |
| Radiation field: N/A | SEE PAKE | 4 OF 4 FOR | 2 CALCUL | ATTOPS. |
| Examinar Loval | u Signaturo | Data Roviewa | * | L Signature Date |
| Leeper, Winfred C. | II Signature | 2/24/2004 Jay A E | aton Level III | 2/26/2004 |
| Examiner Lovel | II Signalure | Date Site Rev | iew | Signature Date |
| Other Level | N/A Signature | 2/24/2004 Date ANII Boy | | Signature Date |
| | IVA - Ognature | | Allei | ~ 3-9-0 |
| · · · · · · · · · · · · · · · · · · · | <u> </u> | | - Cont | F-1 (100) |
| | | | | Charle |



Supplemental Report

| | 6 | | | | Report No.: | UT-04-039 |
|----------|---------|------------|-----------------------------------|-----|-----------------------------------|-----------------|
| - NH- OO | s Su | mmary No.: | C01.010.090 | | | of |
| in | ሲ | Examiner: | Leeper, Winfred C. Markel ALevel: | 11 | Reviewer: Jay A Eaton Level III M | Date: 2/26/2004 |
| ۴ ۲ | ц. 2 | Examiner: | Jordan, Joey | u | Site Review: | Date: |
| ď | ¥ | Other: | N/A Level: | N/A | ANII Review: | Date: 3- 6-04 |

Comments:

Total Exam Area = $(1.65 \times 0.495) + (0.2 \times 0.05 / 2) = 0.82$ sq. in.

Percent of Coverage:

45° shear from S1 = $(1.1 + 1.6/2) \times 0.495 = 0.67/0.82 \times 100 = 81.7\%$

45° shear from S2 =((1.15 + 0.65 / 2) x 0.495) + (0.4 x 0.55 / 2) = $0.56 / 0.82 \times 100 = 68.3\%$

45° shear CW & CCW = 1.15 x 0.495 = 0.57 / 0.82 x 100 = 69.5%

60°L supplemental = (0.2 x 1.65) + ((1.1 + 1.65 / 2) x 0.295) = 0.74 / 0.82 x 100 = 90.2%

Additional coverage with 60°L = 90.2% - 81.7% (45° shear) = 8.5%.



RR 05-MU-001 ATT.2 Page G.6



UT Vessel Examination

..

| Site/Unit: Summary No.: Workscope: | McGuire / 0 <u>C01.010.09</u> <u>· ISI</u> | 01 0 | Procedure Procedure Rev. Work Order No | e: NDE-330 .: 0 .: 98577988 | ······· | Outage No.: Report No.: Page: | MN1 UT-1 | EOC16 04-046 of <u>1</u> | • |
|--|--|------------------------|--|-----------------------------------|--------------|-------------------------------------|-------------|--------------------------------|------------------|
| Code: Section XI, | 1995 thru 1996 Add | ienda Cat./item: | C-A/C1.10.90 | Location: | | N/A | | | |
| Drawing No.: | MCM 1201.04 | -197 | Description: Circum | ferential - Flange to Sh | ell | | | | |
| System ID: | | | | | | | | | |
| Component ID: C01.0 | 10.090 /1RCPA-8-1 | | | Size/Length: | <u>N/A</u> T | hickness/Diamet | er: | 195/6.660" | |
| Limitations: Yes-S | ee Limitation Repor | t no. Ut-04-39 sheets | 2,3 & 4. | Start * | Time:0850 | Finish Tim | ne: | 0853 | |
| Examination Surface: | Inside 📋 | Outside 🔽 | Surface Condition: | | | | | | • |
| Lo Location: | 9.2.1 | Wo Location: | Centerline of Weld | Couplant: | ULTRAGEL II | Batch No.: | | 00325 | • |
| Temp. Tool Mfg.: | FISHER | Serial No.: _ | : MCNDE 27218 | Surface Temp.: | <u>68</u> *F | | | | |
| Cal. Report No.: | | | CAL-04-090 | | | | | | |
| Angle Used 0 Scanning dB | 45 45T 6 54 | 60 60T | Scan Coverage: Upstream | | cw□ cr | w m | | | |
| Comments: | | | | | | | | | |
| Scanned at Reference | ce DB due to signal | to noise ratio - Scanr | ed upstream for additiona | al coverage | | | | | |
| Results: Acc | cept 🔽 Reject | 🗋 Info 🗍 | <u></u> | | | | | | |
| Percent Of Coverage | Obtained > 90%: | <u>No - 74.4%</u> | Reviewed Previous Data | a: <u>Yes</u> | | | | | |
| Examiner Level Leeper, Winfred C. | 1 Way | Signature | Date Review 2/25/2004 Jay A | ver Eaton Level III | - Hesi | gnature | | Date 2/26/2004 | - - - |
| Examiner Level Jordan, Joey | | Signature | Date Site R 2/25/2004 | eview | Si | gnature | | Date | ديجي آ |
| Other Level N/A | N/A | Signature | Date ANII R | review Alfle | si | gnature | 3-6 | Date | ; 3 ^k |

RR 05-HN-GOL ATT. 3 Page 1-5



RR 05-MN-001 ATT-3 page 2-5

.



| Site/Unit: McGuire / 01 | Procedure: | NDE-330 | Outage No.:N | INIEOC16 |
|--|--------------------------------------|-------------------------------|--------------------|-----------|
| Summary No.: C01.010.100 | : Procedure Rev.: | 0 | Report No.: | UT-04-041 |
| Workscope: ISI | Work Order No.: | 98577988 | Page: _1 | of |
| Code: Section XI, 1995 thru 1996 Addenda Cat./I | tem: <u>C-A/C1.10.100</u> | Location: | N/A | |
| Drawing No.: MCM 1201.04-27 | Description: Circumfere | ntial - Shell to Upper Flange | 9 | |
| | | | Thickness/Diameter | 420/4 07 |
| Component ID: | | Size/Length: N/A | | .438/4.0 |
| Limitations: Yes-See Attached Limitation Report | | Start Time: | 0955 Finish Time: | 1010 |
| Examination Surface: Inside 🗌 Outside 🗹 | Surface Condition: AS | SROUND | | |
| Lo Location: 9.2.1 Wo Location | on: <u>Centerline of Weld</u> | Couplant: ULTRAG | ELII Batch No.: | 00325 |
| Temp. Tool Mfg.: FISHER Serial N | o.:MCNDE 27218 | Surface Temp.:86_ | •F | |
| Cal. Report No.: CAI | -04-087, CAL-04-088, CAL-04-089 | · | | |
| Angle Used 0 45 45T 60 60T 60 | L | | | |
| Scanning dB 50 58 6 ⁴ | 1 | | | |
| Indication(s): Yes 🗔 No 🔽 | Scan Coverage: Upstream | Downstream 🗂 🛛 CW 🔽 | | |
| | | | | |
| Comments: | | | | |
| Scanning DB less than reference + 14 to obtain 2:1 sig | nal to noise ratio on all three scan | S | | |
| · | | | | |
| Results: Accept 🗹 Reject 🔲 Info 🗌 | | | | |
| Percent Of Coverage Obtained > 90%: No - 64.4% | Reviewed Previous Data: | Yes | | |
| Examiner Level II Signature | Date Reviewer | <u>/</u> | Signature | Date |
| Weaver, Marion T. Manon T. Weaver | 2/25/2004 Jay A Eat | on Level III UT | | 3/2/2004 |
| Examiner Level II Signature | Date Site Revie | w IV | Signature | Date |
| Other Level N/A Signature | Date ANII Revie | W Pha: | Signature | Date |
| N/A | | aplen | 5-0-09 | |



-

-

Determination of Percent Coverage for UT Examinations - Pipe

| ~ | Site/Unit: | McGuire / | 01 | Procedu | re: NDE-330 | Outage N | o.: MN1EOC | 216 |
|------------|---------------|--|---------------------|--------------------------|------------------------------|-----------|--|------|
| <u>୪</u> ଲ | Summary No.: | C01.010. | 100 | Procedure Re | v.: 0 | Report N | lo.: UT-04-0 | 41 |
| Zan | Workscope: | ISI | | Work Order N | o.: 98577988 | Paç | je: 2 of | 4 |
| T of | | | | | | | ······································ | |
| 50 | | | | | | | | |
| "AH | 15 deg | | | | | | | |
| ¢r⊀ | <u>Scan</u> 1 | 100.000 | % Length Y | 63 200 | % volume of length / 100 - | 63 200 | % total for So: | n 1 |
| | Ocan | | | | | | - | |
| | Scan 2 | 2 100.000 | % Length X | 67.600 | % volume of length / $100 =$ | 67.600 | - % total for Sca | in 2 |
| | Scan 3 | 3 100.000 | % Length X | 61.800 | % volume of length / 100 = | 61.800 | _% total for Sca | in 3 |
| | Scan 4 | 100.000 | % Length X | 61.800 | % volume of length / 100 = | 61.800 | % total for Sca | ın 4 |
| | | | | | | | | |
| | | Add totals and | d divide by # sca | ns = 63.600 | % total for 45 deg | | | |
| | | | | | • | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | Other de | eg - 60 | _ (to be used for | supplemental sc | ans) | | | |
| | The data | to be listed belo | w is for coverage | that was not obta | ained with the 45 deg scans. | | | |
| | | | | | | | | |
| | Scan 1 | | % Length X | | % volume of length / 100 = | | % total for Sc | an 1 |
| | Scan 2 | 2 100.000 | % Length X | 3.000 | _ % volume of length / 100 = | 3.000 | % total for Sc | an 2 |
| | Scan 3 | 3 | % Length X | <u></u> | % volume of length / 100 = | | % total for Sc | an 3 |
| | Scan 4 | L | % Length X | | % volume of length / 100 = | | % total for Sc | an 4 |
| | | | | <u> </u> | - | <u>_,</u> | | |
| | Percent | complete cover | rage | | | | | |
| | A dd toto | la far anab anna | rosuirod os d divid | la hu il af anna ti | e determiner | | | |
| | Audiola | is for each scan | | le by # of scans in I | o determine; | | | |
| | 64.350 | ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~ | complete exam | | | | | |
| | | | () | | | | | |
| | Site Fiel | d Supervisor: | th | KI | Date: | 3204 | | |
| | | | | V | | | Ð | |
| | | | v. | | | ř. | (n) | |
| | | | | | | 11/1/1/20 | ARRA | |
| | | | | | | <u> </u> | 71-1-4 | |
| | | | | | | | J-F-C | 'Y |

| Dide Energy. | |
|-----------------|--|
|-----------------|--|

Limitation Record

| 5-5 | Site/Unit: McG | uire / 01 | Procee | jure:N | IDE-330 | Outage No.: | MN1 | EOC16 | |
|------------|-------------------------------------|---------------|------------------------|---------------------------|----------|-------------|------------|--------|------------|
| de | Summary No.: | C01.010.100 | Procedure I | Rev.: | 0 | Report No.: | <u>UT-</u> | 04-041 | |
| Ř | Workscope: | ISI | Work Order | No.: 9 | 8577988 | Page: | 3 | of | _ |
| <u>м</u> 1 | Description of Limitation | n: | | | | • | | | |
| Ė | Limited due to Flange | configuration | | | | | | | |
| ~ | | | | | | | | | |
| | | | | | CILEU | . 67 | | | |
| | OPPI | e thanke - | | | 570 | 6-56 | | | |
| | | | i | • | | | | | |
| | | | MIX | -477 | | | | | 2 |
| | | | | $\langle \rangle \rangle$ | 45 517 | EAR FROM S | 51 - | 65.6 | > |
| | | <u> </u> | | | <u>_</u> | •• • •• • | • | | - |
| | | | 1 | | | | | | |
| | | | | | | | | | |
| | | | D vdv | ~~~ | | | | | 9 |
| | | | | | 45° 514 | ear from ? | 52= | 67.6 | 0 ľ |
| | | | | <u>\._\</u> | | | | - | - |
| | | ۰. | | | | | | | |
| | | - | | | | | | | |
| | | | The set | | | ···· · · · | | | 3, |
| | | | | \sim | 45° SHEA | n. cwęcci | <i>w</i> = | 61.8 | 5/. |
| | | | n | | | | | | - |
| | | | l T | , | | | | | |
| | | | | | | | | | |
| | • | | 1 John | | . 0 | ••••••••• | | • | ۰, د |
| | | | | | 60 SUPF | lemestal p | romsi | 2 = 70 | صا. |
| | | | | | | | · | | - |
| | Badiation field: N/A | | ALE HOE | 4 For | CALCOU | ingus | | | |
| | | SEEF | | | | | | D | ate |
| | Examiner Level Weaver, Marlon T. | II Signa | ture Date 2/25/2004 | Jay A Eaton | | | | 312/2 | 004 |
| | Examiner Level | II Signa | ture Date | Site Review | | Signature | | D | ate |
| | Jordan, Joey | NUA Signa | 2/25/2004 ture Date | ANII Review | | Signature | 2 | D | ate |
| | N/A | N/A 775igha | | | | Bain | 3-8. | vy_ | |
| | L | | | | | · C R | 2.0109 | / | |
| | | | | | | _ | 517 | | |

| 6 | Puta | 9 97 . | Suppleme | ental Report | | | | |
|------|--------------|----------------------------|------------|---------------|-------------------|------------|---------|----|
| N S | | | | | Report No.: | <u> </u> | 04-041 | |
| 38 | > | | | | Page: | | of | |
| E & | Summary No.: | C01.010.100 | | | | | | |
| jon. | Examiner: | Weaver, Marion T. May V. W | Level: II | Reviewer: Jay | A Eaton Level III | | 3/2/200 | 14 |
| SE E | Examiner: | Jordan, Joey | loyel: II | Site Review: | | Date: | | |
| | Other: | N/A | Level: N/A | ANII Review: | allerin | _ Date: | 28-0 | νų |

Comments:

Total Examination Area = $(1.5 \times 0.438) + ((0.1 \times 0.5) / 2) = 0.68$ sq. in.

. 45° shear from S1 = ((0.7 + 0.35 / 2) x 0.438) + ((0.25 + 0.55 / 2) x 0.5) = 0.43 / 0.68 x 100 = 63.2%

45° shear from S2 = ((0.75 + 1.25 / 2) x 0.438) + (0.25 x 0.2 / 2) = 0.46 / 0.68 x 100 = 67.6%

45° shear CW & CCW = $(0.7 \times 0.438) + ((0.3 + 0.1 / 2) \times 0.55) = 0.42 / 0.68 \times 100 \approx 61.8\%$

60°L supplemental = (0.7 + 1.5 / 2) x 0.438 = 0.48 / 0.68 x 100 = 70.6%

Additional coverage with 60°L = 70.6% - 67.6% = 3%

122 124/24







UT Base Met Lamination

| Summary No.: C01.020.021 Procedure Rev.: 2 Report No.: UT-04-095 Code: ISI Work Order No.: 98578064 Page: 1 d 2 Code: Section XI, 1996 Addenda Cat./Item: C-ACI.20.21 Location: NA Drawing No.: MC-ISIN-1554-01.02 Description: Circumferential - Head to Flange NA Component ID: C01.020.021 //ELDHX-HD-FLG Size/Length: 9.5° SS/CS Thickness/Diameter: 0.75° Unitations: No Size/Length: 9.5° SS/CS Thickness/Diameter: 0.75° Unitations: No Size/Length: 9.5° SS/CS Thickness/Diameter: 0.75° Unitations: No Canterline of Weld Couplant: ULTRAGEL II Batch No.: 01225 Temp. Tool MG: Estamination SWrifese: No MCOBE 77220 Surface Temp.: 70 °F Scanning dB: 01225 Cal. Report No: CAL-04-155 Cal. Popelion Two Remarks Popelion Two Remarks 01225 N | | Site/ | Unit: <u>McGu</u> | ire / | 01 | | | | | Procedu | ure: | N | DE-640 | | | Outage No.: MM | NIEOC16 |
|--|-----------------|---------------------|-------------------|--|-------------------|----------|------------|----------|-----------------|------------------------|---------------------|-----------------|-----------|---------------|-------------|---------------------------------------|--|
| Workscope: ISI Work Order No.: 98578064 Page: 1 of 2 Code: Section XI, 1995 thru 1996 Addenda Cat./Item: C-A/C1.20.21 Location: N/A Drawing No.: MC-ISIN-1554-01.02 Description: Circumferential - Head to Flange N/A System ID: NV Code: Size/Longth: 9.5' SS/CS Thickness/Diameter: 0.75' Consolition: No Size/Longth: 9.5' SS/CS Thickness/Diameter: 0.75' Umitations: No Size/Longth: 9.5' SS/CS Thickness/Diameter: 0.75' Linitations: Top of Heat Exchanger Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 01225 Cal. Report No: CAL04-156 Colosin Max Position Max Position Two Remarks Remarks No Back Wai Full Screen 11 W1 W2 MP LA W1 W2 MP Coursents Figure 100* Initial Section XI Examination Perecent Of | | Summary | No.: | C01.0 | 20.021 | | | | Proc | edure R | ev.: | | 2 | | | Report No.: U | T-04-095 |
| Code: Section XI, 1935 thru 1996 Addenda Cat./Item: C-A/C1.20.21 Location: N/A Drawing No.: MC-ISIN-1554-01.02 Description: Circumferential - Head to Flange Size/Length: 9.5* 5S/CS Thickness/Diameter: 0.75* System ID: NV Size/Length: 9.5* 5S/CS Thickness/Diameter: 0.75* Unitations: No Size/Length: 9.5* 5S/CS Thickness/Diameter: 0.75* Lo Location: Top of Heat Exchanger Wo Location: Centerline of Weld Couplant: ULTRAGEL // Batch No.: 01225 Cal. Report No: FISHER Serial No: MCNDE 27220 Surface Temp.: 70 *F Scanning dB: • Cal. Report No: Cal-Od-155 Cal-Od-155 F Scanning dB: • • • • • Position Nax Position Two Remarks N N No Back Wat Full Screen L1 W1 W2 MP L2 W1 W2 MP N N No . Controon to the full Scient Na With W2 MP L2 W1 W2 MP | | Worksc | ope: | | SI | | | | Work | Order N | No.: | 98 | 578064 | , | | Page: 1 | of <u>2</u> |
| Drawing No.: MC-ISIN-1554-01.02 Description: Circumferential - Head to Flange System ID: NV Component ID: CO1.02.021 / IELDHX-HD-FLG Size/Length: 9.5° SS/CS Thickness/Diameter: 0.75° Limitations: No Start Time: 1041 Finish Time: 1049 Examination Surface: Inside Outside Ø Surface Condition: AS GROUND Linitations: 0.75° Lo Location: Top of Heat Exchanger Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No:: 01225 Temp. Tool Mig: FISHEFI Serial No: MOLDE 27220 Surface Temp; 70 °F Scanning dB: Cal. Report No: CAL-04-155 Examination Position Two Remarks Remarks NRI Viti Screen L1 W1 W2 MP L2 W1 W2 MP NRI Ind | Code: | Section | n XI, 1995 tł | hru 1996 | Addend | a | Cat./It | em: | C-A/ | C1.20.2 | 1 | Loc | ation: | | | N/A | |
| System ID: NV Component ID: C01/020.021 / FELDHX-HD-FLG Size/Length: 9.5° SS/CS Thickness/Diameler: 0.75° Linitations: No Start Time: 1041 Finish Time: 1049 Examination Surface: Instact Exchanger Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 01225 Temp. Tool Mg: FISHER Sofial No: MoNDE 27220 Surface Temp.: 70 °F Scanning dB; • Cal. Report No: CAL-04-156 | Drawing | j No.: | N | IC-ISIN- | 1554-01. | 02 | | D | escription | n: Circu | Imferent | - lal - Head | i to Flan | ge | | | |
| Component ID: 001.020.021 /1ELDHX-HD-FLG Size/Length: 9.5" SS/CS Thickness/Diameter: 0.75" Limitations: No Start Time: 1041 Finish Time: 1049 Examination Surface: Inside Outside Ø Surface Condition: AS GROUND 01225 Lo Location: Top of Heat Exchanger Wo Location: Center/line of Weld Couplant: ULTRAGEL II Batch No.: 01225 Call. Report No: Call-Od-156 MCNDE 27220 Surface Temp: 70 "F Scanning dB: - Ind Uos % Amplitude Position Two Report No.: 01225 Ind Uos % Position Two Remarks Remarks Remarks NRI Uos M W1 W2 MP L2 W1 W2 MP NRI Uos Size/Longth: Info Initial Section XI Examination Results: Accept Ø Reviewed Previous Data: No Signature Date Signature Signature Signature Signature Signature Signature Signature Signature Date Signature | System | | / | | | | | | | | | | | | | | |
| Limitations: No Start Time: 1041 Finish Time: 1049 Examination Surface: Inside Outside Surface Condition: As GROUND Outside Outside Outside Surface Condition: As GROUND Lo Localion: | Compor | nent ID: C | 01.020.021 / | 1ELDHX | HD-FLO | ; | | | | | | Size/Le | ngth: 9 | .5" SS/C | <u>s</u> TI | hickness/Diameter: | 0.75" |
| Examination Surface: Inside Outside S Surface Condition: AS GROUND Lo Location: Top of Heat Exchanger Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 01225 Temp. Tool Mig.: FISHER Serial No.: MCNDE 27220 Surface Temp.: 70 °F Scanning dB: • Cal. Report No.: CAL-04-156 CAL-04-156 Image: Cal. Position Max Position Two Remarks Remarks Ind. Loss % Amphitude Position One Position Max Position Two Remarks NRI Li W1 W2 MP L2 W1 W2 MP Comments: FC 03-20, *42.0 Db on Flange side - CS & 32.0 Db on the Head side -SS. Results: Accept S Reviewed Previous Data: No Percent Of Coverage Obtained > 90%: Yes - 100% Reviewed Previous Data: No Signature Date Brown, Thomas Signature Date 3/16/2004 Jay A Eaton Level III Signature Date MA WA Signature Date ANIt Review Signature <t< td=""><td>Limitatio</td><td>ons: <u>No</u></td><td><u> </u></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>-<u></u></td><td><u> </u></td><td>Start</td><td>Time:</td><td>1041</td><td>Finish Time:</td><td>1049</td></t<> | Limitatio | ons: <u>No</u> | <u> </u> | | | | | | | | - <u></u> | <u> </u> | Start | Time: | 1041 | Finish Time: | 1049 |
| Lo Location: Top of Heat Exchanger We Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 01225 Temp. Tool Mig.: FISHER Serial No.: MCNDE 27220 Surface Temp.: 70 °F Scanning dB: | Examir | nation Surfa | ace: Ins | side 🗔 | Ou | tside 🔽 | | s | urface Co | ondition: | AS GR | OUND | | | | | <u> </u> |
| Temp. Tool Mig: FISHER Serial No.: MCNDE 27220 Surface Temp.: 70 °F Scanning dB: | Lo Loc | ation: | Top of Hea | at Excha | nger | Wold | cation: | Ce | nterline o | of Weld | | Couplant: | | ULTRAGI | EL 11 | Batch No.: | 01225 |
| CAL-04-156 Ind. % Amplitude Position One Position Max Position Two No. Back Wall Full Screen L1 W1 W2 MP L2 W1 W2 MP NRI Image: Streen L1 W1 W2 MP L2 W1 W2 MP Image: Streen L1 W1 W2 MP L2 W1 W2 MP Image: Streen L1 W1 W2 MP L2 W1 W2 MP Image: Streen L1 W1 W2 MP L2 W1 W2 MP Image: Streen L1 W1 W2 MP L2 W1 W2 MP Image: Streen L1 W1 W2 MP L2 W1 W2 MP Image: Streen Image: Stre | Temp. | Tool Mfg.: | F | FISHER | | Ser | ial No.: _ | | MCNDE 2 | 7220 | | Surface T | emp.: | 70 | °F | Scanning dE | 3: |
| Ind. % Amplitude Position One Position Max Position Two No. Back Wall Full Screen L1 W1 W2 MP LM W1 W2 MP L2 W1 W2 MP NRI Image: Screen L1 W1 W2 MP L2 W1 W2 MP NRI Image: Screen L1 W1 W2 MP L2 W1 W2 MP Image: Screen L1 W1 W2 MP L2 W1 W2 MP Image: Screen L1 W1 W2 MP L2 W1 W2 MP Image: Screen L1 W1 W2 MP L3 M1 MP Image: Screen L1 L1 L4 | Cal. Re | eport No.: | | | | | CAL-04 | -156 | | | | | · | | | · · · · · · · · · · · · · · · · · · · | <u> </u> |
| No. Back Wall Full Screen L1 W1 W2 MP LM W1 W2 MP L2 W1 W2 MP Image: MP MP L2 W1 W2 MP MP Image: MP MP L2 W1 W2 MP MP Image: MP MP L2 W1 W2 MP Image: MP MP L2 W1 W2 MP Image: | Ind. | % | Amplitude % | | Positio | on One | | | Positio | on Max | | | Positi | ion Two | | Barnard | /e |
| NRI Image: Signature | No. | Back Wall | 70 Full Screen | L1 | W1 | W2 | MP | LM | W1 | W2 | MP | 12 | W1 | W2 | MP | nonan | |
| Comments: FC 03-20, *42.0 Db on Flange side - CS & 32.0 Db on the Head side -SS. Results: Accept Ø Reject I Info I Initial Section XI Examination Percent Of Coverage Obtained > 90%: Yes - 100% Reviewed Previous Data: No Examiner Level II Brown, Thomas Signature Joint Signature Jife/2004 Jay A Eaton Level II Signature Moss, Gary J. Moss Other Level N/A Signature Date ANII Reviewer Signature NA Signature | NRI | | | | | | | | | | | | | | | | |
| Comments: FC 03-20, *42.0 Db on Flange slde - CS & 32.0 Db on the Head slde -SS. Results: Accept [2] Reject [] Inflo [] Initial Section XI Examination Percent Of Coverage Obtained > 90%: Yes - 100% Reviewed Previous Data: No Examiner Level II Signature Date Accept [2] Signature Date Brown, Thomas Date 3/16/2004 Jay A Eaton Level III Signature Date Moss, Gary J. Moss 3/16/2004 Date Signature Date NA Signature Date ANII Reviewith Signature Date | | | | | | | | | | | | | | | | · | |
| Comments: FC 03-20, *42.0 Db on Flange side - CS & 32.0 Db on the Head side -SS. Results: Accept P Reject Info Info Reviewed Previous Data: No Percent Of Coverage Obtained > 90%: Yes - 100% Reviewed Previous Data: No Examiner Level II Signature Date Brown, Thomas 3/16/2004 Jay A Eaton Level III Signature Date Moss, Gary J. Moss 3/16/2004 Signature Date VA Signature Date ANII Reviewit Signature Date N/A Signature Date ANII Reviewit Signature Jaz 22/04 | | | | | | | | | | | | | | | | | |
| Comments: FC 03-20, *42.0 Db on Flange side - CS & 32.0 Db on the Head side -SS. Results: Accept Ø Reject Info Info Reviewed Previous Data: Percent Of Coverage Obtained > 90%: Yes - 100% Reviewed Previous Data: No Examiner Level II Brown, Thomas Jingature Date Reviewed Jingature Date Signature Date Signature Date Signature Date Signature Date Signature Date Signature Date Moss, Gary J. Monthan Signature N/A Signature Date ANII Review N/A Signature | | | | | · · | | | | | | ļ | <u> </u> | | | | | |
| Comments: FC 03-20, *42.0 Db on Flange side - CS & 32.0 Db on the Head side -SS. Results: Accept Ø Reject Info Info Reviewed Previous Data: No Percent Of Coverage Obtained > 90%: Yes - 100% Reviewed Previous Data: No Examiner Level II Brown, Thomas Signature Date 3/16/2004 Jay A Eaton Level III Signature Moss, Gary J. Date Moss, Gary J. Signature N/A Signature | | | | ĺ | | l | | | | | | | | | | | |
| Results: Accept Ø Reject I Info I Initial Section XI Examination Percent Of Coverage Obtained > 90%: Yes - 100% Reviewed Previous Data: No Examiner Level II Signature Date Reviewer Signature Date Brown, Thomas Date Blog 3/16/2004 Jay A Eaton Level III Signature Date Examiner Level VII Signature Date Site Review Signature Date Moss, Gary J. Moss Signature Date Site Review Signature Date N/A V/A Signature Date ANII Reviewit F Signature Date Signature | Comm | ents: FC | 03-20, *42.0 | 0 Db on l | Flange s | lde - CS | & 32.0 D | b on the | e Head si | de -SS. | | | · | • | | | |
| Hesoits: Accept M Heject I Initial Section Al Examination Percent Of Coverage Obtained > 90%: Yes - 100% Reviewed Previous Data: No Examiner Level II Signature Date Reviewer Signature Date Brown, Thomas Dow Date Signature Date Signature Date Brown, Thomas Dow Signature Date Signature Date Signature Date Moss, Gary J. Mark Signature Date Signature Date Signature Date Moss, Gary J. Mark Signature Date ANII Reviewl Signature Date N/A N/A Signature Date ANII Reviewl Function of the signature Date | Decult | | Assest 🗔 | Rai | oot [7] | Info | - | Initia | Contion | VI Evan | ninetior | | | | | | |
| Percent of coverage obtained > 90%. Test = 100% However Previous Data. However Signature Date Examiner Level II Signature Date Reviewer Signature Date Brown, Thomas Date 3/16/2004 Jay A Eaton Level III Signature Date Examiner Level II Signature Date Site Review Signature Date Moss, Gary J. Signature Date Site Review Signature Date Other Level N/A Signature Date ANII Review Signature Date N/A V/A Signature Date ANII Review Signature Date | Boroon | s. A Of Cover | | 19 1 - 00% | | - 100% | | Bovie | wod Pro | | innation | No | | - <u></u> | | | |
| Examiner Level II Signature Date Reviewer Signature Date Brown, Thomas Date 3/16/2004 Jay A Eaton Level III Mossion Signature Jay A Eaton Level III Jay A Eaton Level | | | | | | - 100 /8 | | | | | | | | = A | | | |
| Examiner Level II Signature Date Site Review Signature Date Moss, Gary J. Jan Moss 3/16/2004 Jane Jane Jane Jane Jane Other Level N/A Signature Date ANII Review/ Signature Date N/A VA Jane Jane Jane Jane Jane | Examin Brown | ier Lev . Thomas | | - 7 | .Я., | Signatur | 9 | | . Da 3/16/20 | ate Rev 104 Jav | /lewer / A Eatoi | n Level II | 1 | \mathcal{L} | NAL SH | gnature | Date 3/19/2004 |
| Moss, Gary J. Day /// Signature 3/16/2004 Other Level N/A Signature Date ANII Review F. Signature Date 3/ N/A Jerone F. Juan 3/22/04 | Examin | ner Lev | rel() 11, | Zni | <u> & va</u> | Signatur | | | D | ate Site | Review | | | | SI | gnature | Date |
| N/A Signature Date ANIT Heview F. Juan 3/22/04 | Moss, | Gary J. | Dan | <u>, </u> | 072 | Classie | | | 3/16/20 | 04 | Deuter | <u>A</u> | | / | / | | |
| | N/A | Lev | rei N/A | / | | Signatur | B | | Di | | I Meview | her not | ا رور | F / | 51 | | |
| | L | | | | | | · • | | | | 1 | prod k | / | | | | ······································ |





RR" 05-MH-001 ATT. 4 Page 4-1)

.



| Site/Un | it: McGulre / 01 | _ | Procedure: | NDE-330 | Outage No.: | MN1EOC16 |
|--------------------|--------------------------------|-------------------|-------------------------|-------------------------------|--|-----------------|
| Summary No | D.: C01.020.021 | _ | Procedure Rev.: | 1 | Report No.: | UT-04-096 |
| Workscop | e:ISI | - | Work Order No.: | 98578064 | Page: | 10f |
| Code: Section | XI, 1995 thru 1996 Addenda | Cat./Item: | C-A/C1.20.21 | Location: | N/A | |
| Drawing No.: | MC-ISIN-1554-01.02 | | Description: Circumfe | erential - Head to Flange | | |
| System ID: NV | | | | | | |
| Component ID: C01 | .020.021 /1ELDHX-HD-FLG | | | Size/Length: 9.5"SS/C | S Thickness/Diame | er: 0.75" |
| Limitations: Yes | - See attached limitation repo | orts | | Start Time: | 1100 Finish Tir | ne: <u>1156</u> |
| Examination Surfac | ce: Inside 🗌 Outside | | Surface Condition: A | S GROUND | ······································ | |
| Lo Location: | Top of Heat Exchanger V | /o Location: | Centerline of Weld | Couplant:ULTRAG | GEL II Batch No.: | 01225 |
| Temp. Tool Mfg.: | FISHER | Serial No.: | MCNDE 27220 | Surface Temp.:70_ | ٦• | |
| Cal. Report No.: | ······ | CAL-04-157, | CAL-04-158, CAL-04-1 | 59 | ···· | |
| Angle Used | 0 45 45T 60 60 | T 45L | | | | |
| Scanning dB | • • | 63 | | | | |
| Indication(s): Ye | es 🗋 No 🗹 | Scan | Coverage: Upstream | 🛛 Downstream 🗹 🛛 CW 🖥 | | |
| Comments: | | | | | | |
| Scanning Db with | 45° = 54.1, 56.0 Db with the 4 | 5°T CS & SS side: | s. 45°L scanned @ Ref. | due to signal to noise ratio. | | |
| | | | | | | |
| Results: | Accept 🗹 Reject 🗌 | Info 🗌 🛛 İr | itial Section XI Examin | ation | <u> </u> | |
| Percent Of Covera | ge Obtained > 90%:No - | 79.8% F | Reviewed Previous Data: | No | | |
| Examiner Level | II Sigr | ature | Date Review | er (h) | Signature | Date |
| Brown, Thomas | Comp due | oturo | 3/16/2004 Jay A E | | Signatura | 3/19/2004 |
| Moss, Gary J. | "Man / Man | | 3/16/2004 | | Signature | |
| Other Level | N/A / Sigr | ature | Date ANII Re | view F | Signature | Z 27 04 |
| L | | | (| y | - process | |

| | Purke Energ | Ŋ. | | Limitation Rec | ord | | | | |
|--------|----------------|-----------|-------|-----------------|----------|-------------|---|--------|-----|
| n b | Site/Unit: | McGuire / | 01 | Procedure: | NDE-330 | Outage No.: | м | 11EOC | :16 |
| 5 | Summary No.: | C01.02 | 0.021 | Procedure Rev.: | 1 | Report No.: | ហ | r-04-0 | 96 |
| r | Workscope: | IS | ä | Work Order No.: | 98578064 | Page: | 2 | of | 8 |

Description of Limitation:

See attached calculations.

Sketch of Limitation:

.

Limitations removal requirements: N/A

| Radiation field: N/A | | | | | 1 | |
|------------------------------------|-----------|-------------------|------------------------------|------|-------------|-------------------|
| Examiner Level II Brown, Thomas | Signature | Date 3/16/2004 | Reviewer Jay A Eaton Leve | | Signature | Date 3/19/2004 |
| Examiner Level () Moss, Gary J. | Signature | Date 3/16/2004 | Site Review | 1 | Signature | Date |
|)ther Level N/A | Signature | Date | ANII Review | me F | - Signature | 3/27/24 |
| | | | 0 | | 7 | R 23/25/104 |

.



28# 05-MN-001

Determination of Percent Coverage for UT Examinations - Pipe

| , | Site/Unit: | McGuire / 01 | Procedure: | NDE-330 | Outage No.: | MN | IEOC | :16 | _ |
|---|--------------|--------------|-----------------|----------|-------------|----|-------|-----|---|
| | Summary No.: | C01.020.021 | Procedure Rev.: | 1 | Report No.: | UT | -04-0 | 96 | _ |
| , | Workscope: | ISI | Work Order No.: | 98578064 | Page: | 3 | of . | 8 | - |

<u>45 deg</u>

| Scan 1 | 51.600 | % Length X | 100.000 | _ % volume of length / 100 = _ | 51.600 | % total for Scan 1 |
|--------|--------|----------------|---------|--|--------|--------------------|
| Scan 2 | 51.600 | _% Length X _ | 100.000 | % volume of length / 100 = | 51.600 | % total for Scan 2 |
| Scan 3 | 51.600 | _ % Length X _ | 100.000 | \sim % volume of length / 100 = \sim | 51.600 | % total for Scan 3 |
| Scan 4 | 51.600 | _ % Length X _ | 100.000 | % volume of length / 100 = | 51.600 | % total for Scan 4 |

Add totals and divide by # scans = 51.600 % total for 45 deg

Other deg - 45 (to be used for supplemental scans)

The data to be listed below is for coverage that was not obtained with the 45 deg scans.

| Scan 1 | 48.400 | % Length X | 79.100 | % volume of length / 100 = | 38.284 | % total for Scan 1 |
|--------|--------|------------|--------|----------------------------|--------|--------------------|
| Scan 2 | 48.400 | % Length X | 37.300 | % volume of length / 100 = | 18.053 | % total for Scan 2 |
| Scan 3 | 48.400 | % Length X | 58.200 | % volume of length / 100 = | 28.169 | % total for Scan 3 |
| Scan 4 | 48.400 | % Length X | 58.200 | % volume of length / 100 = | 28.169 | % total for Scan 4 |

Percent complete coverage

Add totals for each scan required and divide by # of scans to determine;

79.769 % Total for complete exam TT Site Field Supervisor:

Date: 31904 ____

Acri 114

RR 05-MK-001 ATT: 4 Page 7-11

| DUKE POWER C | OMPANY | | UT-04-096 |
|--|--------------------------|---------------------------------------|---------------|
| ISI LIMITATION | | | |
| Component/Weld ID: <u>IELDHX-HD-FLL</u> Item No: | <u>COI.020.02</u> 1 | remarks: | |
| ☑ NO SCAN SURFACE | DUE T | D VENT PIPE. | |
| LIMITED SCAN | | | |
| FROM L 27.0" to L 30.25" INCHES FRO | MW0 + .35 to BEYOND | | |
| ANGLE: 0 0 45 0 60 other FRC | M DEG to DEG | | |
| V NO SCAN SURFACE | BEAM DIRECTION | DUE TO | INLET |
| LIMITED SCAN | 1 🗌 2 🔽 cw 🗹 ccw | CONNEC | nal |
| FROM L 0.5" to L 4.0" INCHES FRO | MWO + 0.9" to BEYOND | | |
| ANGLE: 0 2 45 2 60 other FRC | M DEG to DEG | | |
| MO SCAN SURFACE | BEAM DIRECTION | DUE TO | OUTLET |
| LIMITED SCAN | 1 🛛 2 🗹 cw 🗹 ccw | CONNEC | TOL |
| FROM L 11.75" to L 16.25" INCHES FRO | MWO + 0.9 to BEYDD | · · · · · · · · · · · · · · · · · · · | |
| ANGLE: 0 45 60 other FRC | M DEG to DEG | | |
| NO SCAN SURFACE | BEAM DIRECTION | DUE TO | DRAND PIPE |
| LIMITED SCAN | 1 🗌 2 🗹 cw 🗹 ccw | | |
| FROM L 16.75 to L 18.25" INCHES FRO | MWO +.35" to BEYOND | Sketch(s) | attached |
| ANGLE: 0 0 45 0 60 other FRO | M DEG to DEG | yes | 🗌 No |
| Prepared By: Jan Mon Level | Date: 3.16.04 Shee | t <u>4</u> of | <u></u> |
| Reviewed By: ALL JIL Date: 3/21 | oy Authorized Inspectof. | re Ffw | Date: 3 29 04 |

:

RR# 05-111 - 201 ATT: 4 7-20 2-11

:

. .



TUTAL AREA OF INTEREST $(.75" \times 1.75") + (\frac{.5 \times .1}{7}) = 1.34 \text{ iv}^2$ % OF WELD WITH 100% SCAN FROM 52 30,5" - TOTAL LENGTH - 3.75" - VENT PIPE - 4.0" = INET - 5,0" = OUTLET - Z.O." = DRAID PIPE 15,75" + 30.5" × 100 = 51.6%

UT.04-096 PALE 5 OF 8 ME TT 3/19/04

Rfu

7]25/04

RR 05-NN-001

1

INER/OUTLET VENT/DRAIN PIPE HEAD-SZ UPSTREAM 90 COVERAKE 45° FROM SI C LIMITATIONS $1.34 \text{ in}^2 - (.75'' \times .75'') = 1.06 \text{ in}^2$ $1.06/1.34 \times 100 = 79.1\%$

UT-04-096 PAKE 10 OFB QUE TI 3/19/0 R/64 31.25/04



:

-



07-04-096 PALE MOFB 8/25/04 亚 3/19/2

.:

-.*

ITEM # CO1.020.021



NUT-04-096 PALE BOF B 3/25/14 Off TI 3/19/0'

11

. .

75025

RR 05-MM-001



.



÷

Duke Energy.

•

÷

| Site/U Summary N | Init: <u>McGuire /</u> No.: C01.0 20 | 0.080 | Procedure: _ Procedure Rev.: : | NDE-330 0 | Outage No.: _ Report No.: | MN1EOC16 UT-04-040 |
|---|---|--|--|--|------------------------------------|---|
| Worksco | pe: ISI | | Work Order No.: | 98577988 | Page: | 1 of 4 |
| Code: Section Drawing No.: System ID: | n XI, 1995 thru 1996 . MCM 120 ⁻ | Addenda Cat./Item: 1.04-197 | C-A/C1.20.80 Description: Circumfere | Location: | N/A | |
| Component ID: CC Limitations: Ye | 01.020.080 /1RCPA-1 es-See Attached Lim | 0-1 Itation Report | | Size/Length: N/A Start Time: | Thickness/Diame | ter: <u>.495 / 6.660</u> me: <u>1008</u> |
| Examination Surfa | ece: Inside 9.2.1 FISHER 0 45 45T 0 45 45T 54 55 Yes No rence DB due to sign Accent | Outside Wo Location: | Surface Condition: AS C Centerline of Weld MCNDE 27218 084, CAL-04-085, CAL-04-086 Scan Coverage: Upstream | Couplant: ULTRAC Surface Temp.: 68 Downstream ☑ CW ☑ | <u>BEL II</u> Batch No.: °F | . 00325 |
| Percent Of Covera | age Obtained > 90%: | <u>No - 71.1%</u> | Reviewed Previous Data: | Yes | | |
| Examiner Leve Leeper, Winfred C Examiner Leve Jordan, Joey Other Leve | el II :. // el II el N/A | Signature Signature Signature Signature | Date Reviewer 2/24/2004 Jay A Eato Date Site Review 2/24/2004 1 Date ANII Review | v Carbonia | Signature Signature | Date 2/26/2004 Date 32 Date |

Puke Energy.

Determination of Percent Coverage for UT Examinations - Pipe

| Site/Unit: | McGuire / | 01 | Proced | ure: | NDE-330 | Outage N | lo.: MN1EOC16 |
|--|---|--|---|--|--|----------|--|
| Summary No.: | C01.020. | 080 | Procedure R | ev.: | 0 | Report N | lo.: UT-04-040 |
| Workscope: | ISI | | Work Order I | No.: | 98577988 | _ Pa | ge: <u>2</u> of <u>4</u> |
| | | | | | | | |
| <u>45 deg</u> | | | | | | | |
| Scan | 1 100.000 | % Length X | 51.300 | % volume of | length / 100 = | 51.300 | _% total for Scan 1 |
| Scan | 2 100.000 | % Length X | 77.500 | % volume of | length / 100 = | 77.500 | % total for Scan 2 |
| Scan | 3 100.000 | % Length X | 71.500 | % volume of | length / 100 = | 71.500 | _% total for Scan 3 |
| Scan | 4 100.000 | % Length X | 71.500 | % volume of | length / 100 = | 71.500 | % total for Scan 4 |
| | | | | | | | |
| <u>Other d</u> The data | eg - 60 a to be listed belo | _ (to be used for w is for coverage | supplemental s that was not ob | cans) tained with the | e 45 deg scans. | | |
| <u>Other d</u> The data Scan | eg - <u>60</u> a to be listed belo | _ (to be used for w is for coverage % Length X | supplemental s that was not ob | cans) tained with the | e 45 deg scans. of length / 100 = | | % total for Scan 1 |
| <u>Other d</u> The data Scan Scan 2 | eg - 60 a to be listed belo 1 2100.000 | (to be used for w is for coverage % Length X % Length X | supplemental s that was not ob 12.500 | cans) tained with the % volume of % volume of | e 45 deg scans. of length / 100 = _ of length / 100 = _ | 12.500 | % total for Scan 2 |
| <u>Other d</u> The data Scan a Scan a Scan a | eg - 60 a to be listed belo 1 2100.000 3 | (to be used for w is for coverage % Length X % Length X | supplemental s that was not ob 12.500 | cans) tained with the % volume of % volume of % volume of | e 45 deg scans. of length / 100 = $\frac{1}{2}$ of length / 100 = $\frac{1}{2}$ of length / 100 = $\frac{1}{2}$ | 12.500 | % total for Scan % total for Scan 2 % total for Scan 3 |
| <u>Other d</u> The data Scan Scan Scan | eg - 60 a to be listed belo 1 2100.000 3 4 | (to be used for w is for coverage % Length X % Length X % Length X | supplemental s that was not ob 12.500 | cans) tained with the % volume of % volume of % volume of % volume of | e 45 deg scans. of length / $100 =$ of length / $100 =$ of length / $100 =$ of length / $100 =$ of length / $100 =$ | 12.500 | % total for Scan % total for Scan % total for Scan % total for Scan |

Limitation Record 02-NN-001 Site/Unit: McGuire / Procedure: NDE-330 Outage No .: MN1EOC16 01 Summary No.: C01.020.080 Procedure Rev.: 0 Report No .: UT-04-040 Workscope: ISI Work Order No.: 98577988 Page: 3 of S RR^H ATT-5 **Description of Limitation:** 9/2/26 Limited due to head configuration SHELL - 52 HEAD-51 Sketch of Limitation: 45° FROM 51 = 51.3% 45° FROM 52 = 77.5% 45° CWZ CCW = 71.25% 60° L SUPPLEMENTAL = 90% PALEE 4 OF 4 CALCULATIONS FOR SEE Radiation field: N/A Date Examiner Level II Signature Date Reviewer Signature Leeper, Winfred C. 2/26/2004 2/24/2004 Jay A Eaton Level III Lovel II Signature Date Examiner gnaturo Date Site Review Jordan, Joey 2/24/2004 Date ther Level N/A Signature Date **ANII Review** Signature 3-8-04 N/A 1/25/04

| JUN-WI | Purka Enoi | 9 979. |
|--------|---------------|-------------|
| ប៉ូល | Summary No.: | <u>C01.</u> |
| シビ | Examiner: | Leep |
| 5 | Examiner: | Jord |

Supplemental Report

| | | | | | Report No .: | UT | UT-04-040 | | |
|------------|---------------------------------------|-----|--------------|------------------|--------------|-------|-----------|------|--|
| | | | | | Page: | 4 | of | 4 | |
| Summary No | : C01.020.080 | | | | | | | | |
| Examine | : Leeper, Winfred C. // with ?? evel: | II | Reviewer: | Jay A Eaton Leve | IN ATE | Date: | 2/26 | 2004 | |
| Examine | : Jordan, Joey evel: | 11 | Site Review: | | | Date: | | | |
| Othe | : N/A Level: | N/A | ANII Review: | - Offee | Ľ~ | Date: | 3-8 | -0¥ | |

6 3- 19/2

Comments:

Total Exam Area = (1.6 x 0.495) + (0.25 x 0.1 / 2) = 0.8 sq in.

45° shear from S1 = $(1.05 + 0.6/2) \times 0.495 = 0.41/0.8 \times 100 = 51.3\%$

45° shear from S2 = $(1.0 + 1.5 / 2) \times 0.495 = 0.62 / 0.8 \times 100 = 77.5\%$

45° shear CW & CCW = 1.15 x 0.495 = 0.57 / 0.8 x 100 = 71.25%

• • •

60°L supplemental from S2 = (0.2 x 1.6) + (1.1 + 1.6 / 2 x 0.295) = 0.72 / 0.8 x 100 = 90%

Additional coverage gained with 60°L = 90% - 77.5% (coverage with 45°) = 12.5%





| Site/Unit: McGuire / 01 | | | Procedure: | | | NDE-330 | | 0 | MN1E | EOC16 | | | | | |
|-------------------------|----------|-----------|------------|-----------|-------------------|-------------------|----------------------|----------------|---------------------|-----------|--------------|---------------|------|----------|-----|
| Summa | ary No.: | (| C01.020 | .080 | | _ Procedure Rev.: | | 0 | | R | leport No.: | UT-04 | -047 | | |
| Work | scope: | | ISI | | | | Work C | order No.: | 98577988 | l | | Page: | | | |
| Code: Sec | tion XI, | 1995 thr | u 1996 A | Addend | a | Cat./Item | n: C-A/C1.2 | 0.80 | Location: | | | N/A | | | _ |
| rawing No.: | | м | CM 1201 | .04-197 | | _ | Description: | ;Circumferer | ntial - Shell to He | ad . | | | | | _ |
| ystem ID: | | | | | | | | | | | | | | | _ |
| omponent ID: | C01.02 | 0.080 /11 | RCPA-1 | 0-1 | | | | | Size/Length: | N/A | Thick | ness/Diameter | .49 | 5/6.660" | _ |
| imitations: | Yes-Se | e Limita | tion Rep | oort no. | UT-04-4 | 0 page 2 | 2, 3 and 4 | | Sta | irt Time: | 0853 | Finish Time | · | 0856 | _ |
| Examination S | urface: | Insic | le 🗍 | Ou | itside 🔽 | | Surface Con | dition: AS G | ROUND | | | | | | |
| Lo Location: | <u> </u> | 9.2 | .1 | | Wo Lo | ocation: | Centerline of | Weld | Couplant: | ULTRAG | <u>EL II</u> | Batch No.: _ | | 0325 | |
| Temp. Tool Mi | fg.: | FI | SHER | | . Se | rial No.: | MCNDE 272 | 18 | Surface Temp.: | 68 | *F | | | | |
| Cal. Report No | o.: | | | | <u> </u> | | CAL-04-090 | | · | | <u>-</u> - | | | | |
| Angle Used | 0 | 45 | 45T | 60 | 60T | | 1 | | | | | | | | |
| Scanning dB | | 54 | | | | |] | | | | | | | | |
| Indication(s): | Yes [| No | | 4 | L | | Scan Coverage: U | pstream 🗹 | Downstream 🗌 | cw□ | ccw [| ב | | | |
| Comments: | | | | | | | | | | | | | | | |
| Scanned at R | leferenc | e DB due | e to sign | nal to no | oise ratio | - Scann | ned upstream for add | litional cover | age | | | | | | |
| | | | | | | | | | | | | | | | |
| Results: | Acc | ept 🔽 | Reje | ect 📋 | Info | | | | | | | | | | |
| Percent Of Co | verage C | btained : | .90%: | <u></u> | <u>io - 71.19</u> | <u>/</u> | Reviewed Previou | us Data: | Yes | - | | · | | | _ |
| xaminer I | Level II | | 1 1 | <u> </u> | Signature | 1 | Date | Reviewer | | | Signat | Jre | | Da | ate |
| eeper, Winfre | | | <u>lik</u> | 1 sec | | en- | 2/25/2004 | Jay A Eator | Level III | -MV | | <u></u> | | 2/26/20 | 104 |
| ordan, Joev | revei | | | | Signature | 1 | 2/25/2004 | Sile Keview | | 11 | Signati | Ire | | Da | ate |
| Dther I | Level N | /A | | ay 7 | Signature | | Date | ANII Review | and in | <u></u> | Signatı 7 | | | D; | ate |
| · | | | | | | | | l | - Jun year | <u> </u> | | | | | |

RR 05-MN-001 ATT. 6 Page 1-3

. .

x 35 32



UT Pipe Weid Examination

| Site/Unit: M | | McGuire / | 01 | | Pro | ocedure: | NDE-600 |) | _ | Outage No.: | MN | 11EOC1 | 6 |
|----------------|-------------------|------------------|---------------|--|------------------|--------------|---------------|-------------|--------------|------------------|----------------|---------|----------|
| Summ | nary No.: | R01.01 | 1.150 | | Procedure Rev.: | | 15 | | | Report No.: | บา | r-04-04 | 3 |
| Wo | rkscope: | | | | Work Or | der No.: | 9857798 | 8 | - | Page: | 1 | of _ | 3 |
| Code: Sec | ction XI, | 1995 thru 1996 / | Addenda | Cat./Item: | /R1.11.1 | 50 | Location: | | | | | | |
| Drawing No.: | | MCFI-1N | /175 | | Description: F | Reducer to F | Pipe | | | | | | |
| System ID: | NV | | · · · · | | | | | | | | | | |
| Component ID: | R01.01 | 1.150 /1NVP888 | 1 | | | | Size/Length: | <u>N/A</u> | Th | ickness/Diam | eter: _ | .344/ | 2.0 |
| Limitations: | Yes • s | ee attached Ilmi | tation report | | | <u>_</u> | St | art Time: _ | 0928 | Finish T | ^{me:} | 093 | 8 |
| Examination | Surface: | Inside 🗌 | Outside 🗹 | | Surface Cond | lition: AS G | ROUND | ····· | | | | | |
| Lo Location: | <u></u> | 9.1.1.4 | Wo L | ocation: | Centerline of V | Weld | Couplant: | ULTRA | | Batch No | .: | 0122 | 25 |
| Temp. Tool N | lfg.: | FISHER_ | Se | rial No.: | MCNDE 272 | 17 | Surface Temp. | . 81 | ٩° | | | | |
| Cal. Report N | lo.: | | CAL-04-09 | 2, CAL-04-09 | 3, CAL-04-094 | | | | | | | | |
| Angle Used | 0 | 45 45T | 60 70 | | | | , | | | | | | |
| Scanning dB | | 50.0 | 48.5 52.0 | | | | | | | | | | |
| Indication(s): | Yes | | | Sca | n Coverage: Up | ostream 🔽 | Downstream | ı cw | | | | | |
| Commonio | | | | | | | | | | | | | |
| Comments. | | | | | | | | | | | | | |
| Results: | Accept 💽 |] Reject |] Info [| | NITIAL ISI EXAM | INATION | | | | | | | |
| Percent Of Co | overage C | btained > 90%: | No-35.6% | <u> </u> | Reviewed Previou | ıs Data: | No | - } | | | | | |
| Examiner | Level II | | Signature | e | Date | Reviewer | | | Sig | nature | | | Date |
| Zimmerman, I | David K. | | Janil K. | 3 | 2/25/2004 | Jay A Eato | n Level III | -Mr | | | | 2 | /26/2004 |
| Leeper, Winfr | Level ed C. | | | | 2/25/2004 | Sile rieview | i i | 13 | Sig | nature | | | Date |
| Other N/A | Level N | /Α | Signatur | e la | Date | ANII Review | V | 4 | Sig Recei | nature - 3-6- | -04 | | Date |
| | | | | | | | | - | <i>ν</i> ι | | | | |

Determination of Percent Coverage for UT Examinations - Pipe

| 50 NN | Energ | 9 7 . | L | UT Examinat | | | | | |
|-------|-------------------------|--------------|-------|-----------------|----------|-------------|-----------|----|---|
| 5.1 | Site/Unit: McGuire / 01 | | | Procedure: | NDE-600 | Outage No.: | MN1EOC16 | | |
| 0 0 | Summary No.: | R01.01 | 1.150 | Procedure Rev.: | 15 | Report No.: | UT-04-048 | | |
| ARK | Workscope: | 15 | t | Work Order No.: | 98577988 | Page: | 2 | of | 3 |

<u>45 deg</u>

| Scan 1 | | _% Length X | | % volume of length / 100 = | % total for Scan 1 | |
|--------|---------|-------------|--------|------------------------------|--------------------|--------------------|
| Scan 2 | | % Length X | | % volume of length / $100 =$ | <u> </u> | % total for Scan 2 |
| Scan 3 | 100.000 | % Length X | 50.000 | % volume of length / $100 =$ | 50.000 | % total for Scan 3 |
| Scan 4 | 100.000 | % Length X | 50.000 | % volume of length / $100 =$ | 50.000 | % total for Scan 4 |

Add totals and divide by # scans = 50.000 % total for 45 deg

Other deg - 60 (to be used for supplemental scans)

The data to be listed below is for coverage that was not obtained with the 45 deg scans.

| Scan 1 | 100.000 | _ % Length X | 42.500 | \sim % volume of length / 100 = | 42.500 | % total for Scan 1 |
|--------|----------|--------------|--------|-----------------------------------|--------|--------------------|
| Scan 2 | 100.000 | _% Length X | 0.000 | \sim % volume of length / 100 = | 0.000 | % total for Scan 2 |
| Scan 3 | . | _ % Length X | | % volume of length / 100 = | | % total for Scan 3 |
| Scan 4 | | _ % Length X | | _ % volume of length / 100 = | · | % total for Scan 4 |

Percent complete coverage

Add totals for each scan required and divide by # of scans to determine;

35.625 % Total for complete exam

Site Field Supervisor:

Daviel KZ Date: 02/25/04 gc 2/26/1

NOTE: 70° SHEAR SCAN NOT ENCLUDED EN PERCENT CONERAGE DUE TO REQUIREMENTS OF INCER 50.550(b)(Z)(XV)(A)(Z). BEST EFFORT SCAN WITH 70° SHEAK OBTAINED 17.4° COVER EN ODE AVIAL DIRECTION.



Limitation Record

| Site/Unit: McGuire / 01 | | Procedure: | Procedure: NDE-600 | | MN1EOC16 | | | | |
|-------------------------|---------|------------|--------------------|----------|-------------|-----------|----|---|--|
| Summary No.: | R01.011 | 1.150 | Procedure Rev.: | 15 | Report No.: | UT-04-048 | | | |
| Workscope: | ISI | | Work Order No.: | 98577988 | Page: | 3 | of | 3 | |

Description of Limitation:

Valve 494/socket weld attaching to butt weld between pipe and reducer

Sketch of Limitation:

$$\begin{aligned} & \text{IOTAL AREA: .115in $\times 1.0in = .115in^{2}} \\ & \text{LOO'SUEAR CONSELATE: } (\frac{.40it.45in}{2}).115in = .0049in^{2}} \\ & \text{LIISin^{2} $\times 100 = .42.5^{9}} \\ & \text{LIISin^{2} $\times 100 = .42.5^{9}} \\ & \text{LIISin^{2} $\times 100 = .50^{9}} \\ & \text{LIISin^{2} $\times 100 = .50^{9}$$

