

August 29, 2005

Bill Eaton, BWRVIP Chairman
Entergy Operations, Inc.
Echelon One
1340 Echelon Parkway
Jackson, MS 39213-8202

SUBJECT: NRC APPROVAL LETTER OF BWRVIP-42-A, "BWR VESSEL AND
INTERNALS PROJECT BOILING WATER REACTOR LOW PRESSURE
COOLANT INJECTION AND FLAW EVALUATION GUIDELINES"

Dear Mr. Eaton:

By letter dated March 30, 2005, the Boiling Water Reactor Vessel and Internals Project (BWRVIP) submitted Proprietary Report BWRVIP-42-A, "BWR Vessel and Internals Project Boiling Water Reactor Low Pressure Coolant Injection and Flaw Evaluation Guidelines," for NRC staff review.

The BWRVIP-42-A report provides generic guidelines on inspection and flaw evaluation of low pressure coolant injection (LPCI) couplings. The BWRVIP took into consideration degradation susceptibility, degradation mechanisms, loads, and inspection strategies for LPCI couplings in the BWRVIP-42-A guidelines. The intent of the report is provide inspection and flaw evaluation guidance to BWRVIP members that can be used to assure adequate BWR LPCI coupling integrity when meeting the specified acceptance criteria.

The BWRVIP-42-A report presents a compilation of information from several sources: the subject proprietary report, BWRVIP responses to NRC staff requests for additional information (RAIs) regarding the subject report, and the NRC staff's final safety evaluation (SE) dated January 9, 2001.

The NRC staff has reviewed the information in the BWRVIP-42-A report and has found that the report accurately incorporates all of the relevant information in the documents noted above to support NRC staff approval of the report. The staff found that minimal technical changes were made in the production of the BWRVIP-42-A report. The first revision was with respect to Open Item 3.3.4 of the staff's SE on the BWRVIP-03 report, "Reactor Pressure Vessel and Internals Examination Guidelines." The staff required that "all BWRVIP inspection and evaluation guidelines be revised to replace Core Spray VT-1 (CSVT-1) and modified visual testing (MVT-1) by enhanced visual testing (EVT-1), VT-1, or VT-3. In addition, EVT-1 is to be specified as the primary technique when fine, tight IGSCC is a primary concern. In all other locations, VT-1 or VT-3 will be used as appropriate." Therefore, in response to this open item, the BWRVIP revised Section 3.3 and Table 3-1, to replace "MVT-1" with "EVT-1." The staff found that the BWRVIP adequately revised the applicable sections of the BWRVIP-42-A report to address Open Item 3.3.4 of the BWRVIP-03 report.

B. Eaton

-2-

The second revision was with respect to the deletion of Section 3.7, "Reporting of Inspection Requirements," of the BWRVIP-42-A report. The BWRVIP determined that all reporting requirements would be removed from the BWRVIP-42-A report since they are already contained in the BWRVIP-94 report, "Program Implementation Guide." The staff found this acceptable because all reporting requirements for inspection and evaluation guidelines are adequately included in the BWRVIP-94 report.

Also, the staff noted that a couple of minor clarifications were made in the report. The staff confirmed that the clarifications did not impact the technical aspects of the report.

Based on the discussion above, the staff has determined that the BWRVIP-42-A report is acceptable. Please contact Meena Khanna of my staff at (301) 415-2150 if you have any further questions regarding this subject.

Sincerely,

/(RA by M. Mitchell for W. Bateman)/

William H. Bateman, Chief
Materials and Chemical Engineering Branch
Division of Engineering
Office of Nuclear Reactor Regulation

Attachment: As stated

cc: See next page

The second revision was with respect to the deletion of Section 3.7, "Reporting of Inspection Requirements," of the BWRVIP-42-A report. The BWRVIP determined that all reporting requirements would be removed from the BWRVIP-42-A report since they are already contained in the BWRVIP-94 report, "Program Implementation Guide." The staff found this acceptable because all reporting requirements for inspection and evaluation guidelines are adequately included in the BWRVIP-94 report.

Also, the staff noted that a couple of minor clarifications were made in the report. The staff confirmed that the clarifications did not impact the technical aspects of the report.

Based on the discussion above, the staff has determined that the BWRVIP-42-A report is acceptable. Please contact Meena Khanna of my staff at (301) 415-2150 if you have any further questions regarding this subject.

Sincerely,

/(RA by M. Mitchell for W. Bateman)/

William H. Bateman, Chief
Materials and Chemical Engineering Branch
Division of Engineering
Office of Nuclear Reactor Regulation

Attachment: As stated

cc: See next page

Distribution:

- EMCB R/F
- EMCB A
- AHiser
- ALee
- CE Moyer
- WCullen
- RLorson, R1
- MLesser, R2
- DHills, R3

Accession No.: ML052490557

INDICATE IN BOX: "C"=COPY W/O ATTACHMENT/ENCLOSURE, "E"=COPY W/ATT/ENCL, "N"=NO COPY

| | | | | | | |
|--------|------------|---|------------|---|------------|---|
| OFFICE | EMCB:DE | E | EMCB:DE | E | EMCB:DE | E |
| NAME | MKhanna | | MMitchell | | WHBateman | |
| DATE | 08/26/2005 | | 08/29/2005 | | 08/29/2005 | |

OFFICIAL RECORD COPY

CC:

Tom Mulford, EPRI BWRVIP
Integration Manager
Raj Pathania, EPRI BWRVIP
Mitigation Manager
Ken Wolfe, EPRI BWRVIP
Repair Manager
Larry Steinert, EPRI BWRVIP
Electric Power Research Institute
P.O. Box 10412
3412 Hillview Ave.
Palo Alto, CA 94303

Robert Carter, EPRI BWRVIP
Assessment Manager
Greg Selby, EPRI BWRVIP
Inspection Manager
EPRI NDE Center
P.O. Box 217097
1300 W. T. Harris Blvd.
Charlotte, NC 28221

George Inch, Technical Chairman
BWRVIP Assessment Committee
Constellation Nuclear
Nine Mile Point Nuclear Station (M/S ESB-1)
348 Lake Road
Lycoming, NY 13093

Denver Atwood, Chairman
BWRVIP Repair Focus Group
Southern Nuclear Operating Co.
Post Office Box 1295
40 Inverness Center Parkway (M/S B031)
Birmingham, AL 35242-4809

Jeff Goldstein, Technical Chairman
BWRVIP Mitigation Committee
Entergy Nuclear NE
440 Hamilton Ave. (M/S K-WPO-11c)
White Plains, NY 10601

Charles J. Wirtz, Chairman
BWRVIP Inspection Focus Group
FirstEnergy Corp.
Perry Nuclear Power Plant (M/S A250)
10 Center Road
Perry, OH 44081

Amir Shahkarami
BWRVIP Executive Oversight Committee Member
Exelon Corporation
4300 Winfield Road
Warrenville, IL 60555-4012

Robin Dyle, Technical Chairman
BWRVIP Integration Committee
Southern Nuclear Operating Co.
42 Inverness Center Parkway (M/S B234)
Birmingham, AL 35242-4809

Al Wrape, Executive Chairman
BWRVIP Assessment Committee
PPL Susquehanna, LLC
2 N. 9th St.
Allentown, PA 18101-1139

H. Lewis Sumner, Executive Chairman
BWRVIP Mitigation Committee
Vice President, Hatch Project
Southern Nuclear Operating Co.
M/S BIN B051, P.O. BOX 1295
40 Inverness Center Parkway
Birmingham, AL 35242-4809

Rick Libra
BWRVIP Executive Oversight Committee Member
DTE Energy
6400 N Dixie Hwy (M/S 280 OBA)
Newport, MI 48166-9726