

3.7 PLANT SYSTEMS

3.7.9 Nuclear Services Seawater System

LCO 3.7.9 Two Nuclear Services Seawater System trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One Nuclear Services Seawater System train inoperable.	A.1 Restore Nuclear Services Seawater System train to OPERABLE status.	72 hours
B. Required Action and associated Completion Time not met.	B.1 Be in Mode 3	6 hours
	<u>AND</u> B.2 Be in Mode 5.	36 hours

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. (continued)	B.3.1 Determine OPERABLE EDG is not inoperable due to common cause failure.	24 hours
	<u>OR</u>	
	B.3.2 Perform SR 3.8.1.2 for OPERABLE EDG.	24 hours
	<u>AND</u>	
	B.4 Restore EDG to OPERABLE status	72 Hours
		<u>AND</u>
		6 days from discovery of failure to meet LCO
		<u>OR</u>
		14 days if alternate AC power is available
		<u>AND</u>
		17 days from discovery of failure to meet LCO

(continued)