

CLINTON POWER STATION

Job Performance Measure

Complete a CPS 3006.01C007,
Control Rod Withdrawal Checklist – Mode 3

JPM Number: 30060117LAF01

Revision Number: 00

Date:

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Approved By:	_____	_____
	Training Department	Date

**Clinton Power Station
Job Performance Measure (JPM)**

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating and terminating cues are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure:
- Current Procedure Rev. _____ Date: _____
- Procedure Rev. Referenced _____ Date: _____
- If the Current Procedure Rev. and the Procedure Rev. Referenced are different then revise the JPM.
- _____ 9. Pilot test the JPM:
- a. verify cues both verbal and visual are free of conflict, and
- b. ensure performance time is accurate.
- _____ 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor

Date

SME/Instructor

Date

SME/Instructor

Date

JPM Number: 30060117LAF01

**Clinton Power Station
Job Performance Measure (JPM)**

Revision Record (Summary)

Revision	Date	Description
00		New JPM

JPM Number: 30060117LAF01

Clinton Power Station Job Performance Measure (JPM)

Operator's Name: _____

Job Title: ☐ NLO ☐ RO ☐ SRO ☐ STA ☐ SRO Cert

JPM Title: Complete a CPS No. 3006.01C007, Control Rod Withdrawal Checklist – Mode 3

JPM Number: 30060117LAN01

Revision Number:00

Task Number and Title: 300601.17, Perform Control Rod Withdrawal Checklist – Mode 3.

K/A System	K/A Number	Importance (RO/SRO)	
Generic	2.1.23	3.9	4.0

Suggested Testing Environment: Simulator

Actual Testing Environment: ☐ Simulator ☐ Plant ☐ Control Room

Testing Method: ☐ Simulate **Faulted/Alternate Path:** ☒ Yes ☐ No
☒ Perform **SRO Only:** ☐ Yes ☒ No

Time Critical: ☐ Yes ☒ No

Estimated Time to Complete: 20 minutes **Actual Time Used:** _____ minutes

References: CPS No. 3006.01C007, Control Rod Withdrawal Checklist – Mode 3, Rev. 4c

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against the standards contained in this JPM, and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ Date: _____

**Clinton Power Station
Job Performance Measure (JPM)**

READ TO THE OPERATOR

I will explain the initial conditions, which step(s) to simulate or discuss, and provide the initiating cues. When you complete the task successfully, the objective of this Job Performance Measure will be satisfied.

SIMULATOR SETUP CONDITIONS

- IC-83 on the ILT_EXAM_JPM_LOAD, or any IC setup with the plant in Mode 3 and the Mode Switch in the Refuel position. **Do not remove the key from the Mode Switch.**

TASK STANDARDS:

- CPS No. 3006.01C007 is completed correctly.

TOOLS, EQUIPMENT, OTHER SPECIAL REQUIREMENTS:

- Copy of CPS No. 3006.01C007, Control Rod Withdrawal Checklist – Mode 3 with Sections A & B complete.
- CPS No. 9000.01, CONTROL ROOM SURVEILLANCE LOG , Rev 034 A
- CPS No. 9000.01D001, CONTROL ROOM SURVEILLANCE LOG - MODE 1, 2, 3 DATA SHEET Rev 049 D

PROCEDURAL/REFERENCES:

- CPS No. 3006.01C007, Control Rod Withdrawal Checklist – Mode 3, Rev. 4c
- CPS No. 9000.01, CONTROL ROOM SURVEILLANCE LOG , Rev 034 A
- CPS No. 9000.01D001, CONTROL ROOM SURVEILLANCE LOG - MODE 1, 2, 3 DATA SHEET Rev 049 D

EVALUATOR INSTRUCTIONS:

- Amplifying cues are provided within the JPM steps.
- All pre-job briefings are completed.

**Clinton Power Station
Job Performance Measure (JPM)**

INITIAL CONDITIONS AND INITIATING CUE:

The plant is in Mode 3 and it is desired to perform control rod withdrawals. CPS No. 3006.01C007, Control Rod Withdrawal Checklist – Mode 3, has been started in preparation for withdrawing the first rod (24-29).

The CRS directs you to initiate Table 1 of CPS No. 3006.01C007 by performing Section C steps 1 through 4.

Day 1 is today's date, and the time is 0110.

NOTE TO EVALUATOR

When the Initiating Cue has been read by the student and acknowledged, provide a MARKED UP copy of the following procedure to the student.

- CPS No. 3006.01C007, Control Rod Withdrawal Checklist – Mode 3 with Sections A & B complete.

START TIME: _____

**Clinton Power Station
Job Performance Measure (JPM)**

PERFORMANCE INFORMATION

Critical steps are denoted with an asterisk (*) to the left of the step number and appear in BOLDED letters. Failure to meet the standards for a critical step constitutes failure of the Job Performance Measure. The sequence of steps is assumed unless denoted in the comments section of the JPM.

PERFORMANCE STEPS

CPS No. 3006.01C007 Control Rod Withdrawal Checklist – Mode 3

1. Enters today's date under Day 1 of Table 1

Standard: Today's date is entered under Day 1 of Table 1.

Cue: None, self revealing

Comments

SAT ☐ UNSAT ☐ Comment Number _____

2. 2.a)1)
Operator conducts an IRM channel check.

Standard: IRM channel check is completed satisfactorily using DCS indications and/or P678 charts, and the operator initials the appropriate block.

Cue: If operator asks, provide IRM Backpanel Readings Cue Sheet. Provide CPS 9000.01D001. Provide CPS 9000.01 if asked for.

Comments

SAT ☐ UNSAT ☐ Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

3. 2.a)2)

Operator conducts a SDV level ATM channel check.

Standard: SDV level ATM channel check is completed satisfactorily, and the operator initials the appropriate block.

Cue: Provide the SDV level RPS ATM Cue Sheet. Provide CPS 9000.01D001. Provide CPS 9000.01 if asked for.

Comments

SAT ☐

UNSAT ☐

Comment Number _____

4. 2.a)3)

Verify that all surveillances in Section B are current.

Standard: Operator verifies that all surveillances are current, and initials the appropriate block.

Cue: Dates indicate that all surveillances are current.

Comments

SAT ☐

UNSAT ☐

Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

5. 2.a)4)

If the control rod has been withdrawn for 7 days, then insert it at least one notch, and verify accumulator pressure is ≥ 1550 psig.

Standard: No action required.

Cue: None, self revealing

Comments

SAT ☐

UNSAT ☐

Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

6. 2.b)

Verify all other control rods in a 5 by 5 array centered on the control rod being withdrawn are disarmed.

Standard: Block should be marked NA, because Steps 2.a)1 thru 4) are being met.

Cue:

Comments If the operator checks this, no other rods are disarmed.

SAT ☐

UNSAT ☐

Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

	Faulted Step	
--	--------------	--

***7. 3.**

Verify the Reactor Mode Switch is locked in the REFUEL position.

Standard: Operator identifies that the key is still in the Mode Switch, and notifies the CRS.
The operator does not initial the appropriate block until the key has been removed.
Key may be placed in the Key Locker.

Cue: Acknowledge the report and tell the operator to remove the key and continue with the task.
Take the key from the operator, and notify the operator that the key will be placed in the Key Locker.

Comments To be "Locked in the REFUEL position" the reactor mode switch key must be removed from the console per ITS B 3.9.2, SR 3.9.2.1.

SAT ☐ UNSAT ☐ Comment Number _____

8. 4.

Verify all control rods , other than the control rod being withdrawn, are fully inserted.

Standard: Operator verifies that all the control rods are inserted, and initials the appropriate block.

Cue:

Comments

SAT ☐ UNSAT ☐ Comment Number _____

JPM Number: 30060117LAF01

**Clinton Power Station
Job Performance Measure (JPM)**

TERMINATING CUES:

The key has been removed from the Mode Switch and Section C, Steps 1 through 4 of CPS No. 3006.01C007 have been completed.

STOP TIME: _____

**Clinton Power Station
Job Performance Measure (JPM)**

INITIAL CONDITIONS AND INITIATING CUE:

The plant is in Mode 3 and it is desired to perform control rod withdrawals. CPS No. 3006.01C007, Control Rod Withdrawal Checklist – Mode 3, has been started in preparation for withdrawing the first rod (24-29).

The CRS directs you to initiate Table 1 of CPS No. 3006.01C007 by performing Section C steps 1 through 4.

Day 1 is today's date, and the time is 0110.

JPM Number: 30060117LAF01

**Clinton Power Station
Job Performance Measure (JPM)**

**IRM Backpanel Readings
(Cue Sheet for JPM Step 2 if needed)**

A	6
E	5
C	6
G	5
B	6
F	6
D	5
H	5

JPM Number: 30060117LAF01

**Clinton Power Station
Job Performance Measure (JPM)**

**SDV Level RPS ATM Readings
(Cue Sheet for JPM Step 3 if needed)**

1C11-N601A	0”
1C11-N601B	-1”
1C11-N601C	-0.5”
1C11-N601D	-0.25”

CLINTON POWER STATION

Job Performance Measure

Verify Conditions Are Met to Enter Mode 2 From Mode 1

JPM Number: 30060106LAF01

Revision Number: 00

Date:

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Approved By:	_____	_____
	Training Department	Date

**Clinton Power Station
Job Performance Measure (JPM)**

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating and terminating cues are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure:
- Current Procedure Rev. _____ Date: _____
- Procedure Rev. Referenced _____ Date: _____
- If the Current Procedure Rev. and the Procedure Rev. Referenced are different then revise the JPM.
- _____ 9. Pilot test the JPM:
- a. verify cues both verbal and visual are free of conflict, and
- b. ensure performance time is accurate.
- _____ 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor

Date

SME/Instructor

Date

SME/Instructor

Date

JPM Number: 30060106LAF01

**Clinton Power Station
Job Performance Measure (JPM)**

Revision Record (Summary)

Revision	Date	Description
00		New format and numbering convention, revalidated. This replaces JPM 300601.06. Revision number reset to 0.

JPM Number: 30060106LAF01

Clinton Power Station Job Performance Measure (JPM)

Operator's Name: _____

Job Title: ☐ NLO ☐ RO ☐ SRO ☐ STA ☐ SRO Cert

JPM Title: Verify Conditions Are Met to Enter Mode 2 From Mode 1

JPM Number: 30060106LAF01

Revision Number:00

Task Number and Title: 300601.06, Complete Control Room actions to perform Shifting Reactor Mode Switch to START & HOT STBY.

K/A System	K/A Number	Importance (RO/SRO)	
Generic	2.1.31	4.2	3.9

Suggested Testing Environment: Simulator

Actual Testing Environment: ☐ Simulator ☐ Plant ☐ Control Room

Testing Method: ☐ Simulate **Faulted/Alternate Path:** ☒ Yes ☐ No
☒ Perform **SRO Only:** ☐ Yes ☒ No

Time Critical: ☐ Yes ☒ No

Estimated Time to Complete: 20 minutes Actual Time Used: _____ minutes

References: CPS No. 3006.01 Unit Shutdown Rev 33a

CPS No. 9000.06D001, HEATUP/COOLDOWN, INSERVICE LEAK & HYDROSTATIC TESTING 30 MINUTE TEMPERATURE LOG Rev 30a

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against the standards contained in this JPM, and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name:_____ (Print)

Evaluator's Signature: _____ Date: _____

JPM Number: 30060106LAF01

**Clinton Power Station
Job Performance Measure (JPM)**

**Clinton Power Station
Job Performance Measure (JPM)**

READ TO THE OPERATOR

I will explain the initial conditions, which step(s) to simulate or discuss, and provide the initiating cues. When you complete the task successfully, the objective of this Job Performance Measure will be satisfied.

SIMULATOR SETUP CONDITIONS

IC-86 on the ILT_EXAM_JPM_LOAD or any other IC with the following conditions:

- Power level at 8%.
- APRM C failed to 4% power.
- MOV Test Prep Switches for DW Clg and Chill Wtr (5050) and SSW System Div 3 (5064) in TEST.
- Keys in 4 other MOV Test Prep Switches with switches in “NORM”

TASK STANDARDS:

- Completes applicable steps of CPS 3006.01 Unit Shutdown, Section 8.6 & 8.4.7.5.
- Determines that the mode change should not be performed.

TOOLS, EQUIPMENT, OTHER SPECIAL REQUIREMENTS:

- Marked up copy of CPS 3006.01, completed to step 8.6 with the exception of step 8.4.7.5.
- Copy of CPS 3006.01, Appendix C.
- Copy of CPS 9000.06D001

PROCEDURAL/REFERENCES:

- CPS 3006.01, Unit Shutdown, Rev. 33a

EVALUATOR INSTRUCTIONS:

- Amplifying cues are provided within the JPM steps.
- All pre-job briefings are completed.

JPM Number: 30060106LAF01

**Clinton Power Station
Job Performance Measure (JPM)**

INITIAL CONDITIONS AND INITIATING CUE:

A plant shutdown is in progress. You are directed to verify conditions are met to enter Mode 2 IAW CPS 3006.01, Unit Shutdown.

NOTE TO EVALUATOR

When the Initiating Cue has been read by the student and acknowledged, provide a MARKED UP copy of the following procedure to the student.

- CPS 3006.01, completed to step 8.6 with the exception of step 8.4.7.5.
- CPS 3006.01, Appendix C.
- CPS 90005.01D001.

START TIME: _____

**Clinton Power Station
Job Performance Measure (JPM)**

PERFORMANCE INFORMATION

Critical steps are denoted with an asterisk (*) to the left of the step number and appear in BOLDED letters. Failure to meet the standards for a critical step constitutes failure of the Job Performance Measure. The sequence of steps is assumed unless denoted in the comments section of the JPM.

PERFORMANCE STEPS

8.6 Shifting Reactor Mode Switch To Start & Hot Stby

1. 8.6.1.1
Section 8.4 completed as appropriate.

Standard: Operator checks CPS 3006.01 Section 8.4 and determines that 8.4.7.5. has not been initialed. Reports to the CRS.

Cue: Acknowledge the report as CRS and, if necessary, direct the operator to perform 8.4.7.5.

Comments

SAT ☐

UNSAT ☐

Comment Number _____

Clinton Power Station
Job Performance Measure (JPM)

	Faulted Step	
--	---------------------	--

***2. 8.4.7.5**

Verify IRM/APRM overlap is achieved.

- ☞ Overlap between IRMs and APRMs exist when sufficient (4 channels per ITS LCO 3.3.1.1 Table functions) IRMs and APRMs concurrently have on-scale readings such that the transition between MODE 1 and MODE 2 can be made without either APRM downscale rod block (5% RTP), or IRM upscale rod block (108/125 full scale).

- Standard:
- Operator determines that APRM C is giving a downscale rod block and step 8.4.7.5. is not satisfied.
 - Operator reports to the CRS that APRM C is reading 4% and has a Downscale Rod Block.

Cue: As the CRS, acknowledge report. If necessary, direct operator to complete Section 8.6 to determine if there are any other problems.

Comments

SAT ☐

UNSAT ☐

Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

	Faulted Step	
--	--------------	--

***3. 8.6.1.2**

**Verify/place MOV TEST PREP switches in NORMAL.
[Listed on Appendix C]**

Standard:

- Operator checks Appendix C and verifies completed entries and identifies switches on section 5050 & 5064 have not been checked.
- Operator determines that switches for DW Clg & Chill Wtr and SSW System Div 3 are in TEST, and places switches in NORMAL.

Cue:

If report is made about switches being in TEST, acknowledge report as CRS. If necessary direct the operator to place the switches in Normal.
If asked, the MSIV Leakage Control MOV TPS are in “NORMAL” (Backpanel)

Comments

SAT ☐

UNSAT ☐

Comment Number _____

4. 8.6.1.3.

Prepare for use during cooldown CPS 9000.06D001, Heatup/Cooldown, Inservice Leak and Hydrostatic Testing 30 Minute Temperature Log.

Standard:

Operator reviews CPS 9000.06D001 and fills in appropriate blocks.

Cue:

Provide a copy of CPS 9000.06D001.

Comments

SAT ☐

UNSAT ☐

Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

NOTE

APRM rod blocks will occur at $\leq 5\%$ with mode switch in RUN.

5. 8.6.2

Insert control rods per the specified sequence to decrease reactor power to ~6 - 8%.

Standard: Operator verifies that power is ~6 - 8%.

Cue: None

Comments

SAT ☐

UNSAT ☐

Comment Number _____

6. 8.6.3.1

Verify IRM/APRM Overlap completed per 8.4.7.

Standard: Actions per this step should have been identified in step 1, and completed in step 2 of this JPM. If the actions were not completed earlier then they should be completed now. Refer to Step 2 for standard

Cue: None

Comments

SAT ☐

UNSAT ☐

Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

7. 8.6.3.2

Adjust IRM Range Switches so all operable IRMs read on scale (preferred 15 – 75)

Standard: Operator verifies that all operable IRMs are reading on scale and are in the range of 15 – 75.

Cue: None

Comments

SAT ☐

UNSAT ☐

Comment Number _____

TERMINATING CUES:

The operator determines the Mode change should not be made.

STOP TIME: _____

JPM Number: 30060106LAF01

**Clinton Power Station
Job Performance Measure (JPM)**

INITIAL CONDITIONS AND INITIATING CUE:

A plant shutdown is in progress. You are directed to verify conditions are met to enter Mode 2 IAW CPS 3006.01, Unit Shutdown.

CLINTON POWER STATION

Job Performance Measure

Perform a Jet Pump Operability Test per CPS No. 9041.01

JPM Number: 90410101LAN01

Revision Number: 00

Date:

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Approved By:	_____	_____
	Training Department	Date

**Clinton Power Station
Job Performance Measure (JPM)**

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating and terminating cues are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure:
- Current Procedure Rev. _____ Date: _____
- Procedure Rev. Referenced _____ Date: _____
- If the Current Procedure Rev. and the Procedure Rev. Referenced are different then revise the JPM.
- _____ 9. Pilot test the JPM:
- a. verify cues both verbal and visual are free of conflict, and
- b. ensure performance time is accurate.
- _____ 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor

Date

SME/Instructor

Date

SME/Instructor

Date

JPM Number: 90410101LAN01

**Clinton Power Station
Job Performance Measure (JPM)**

Revision Record (Summary)

Revision	Date	Description
00		New format and numbering convention, revalidated. This replaces JPM 012202J005. Revision number reset to 0.

JPM Number: 90410101LAN01

**Clinton Power Station
Job Performance Measure (JPM)**

Operator's Name: _____

Job Title: ☐ NLO ☐ RO ☐ SRO ☐ STA ☐ SRO Cert

JPM Title: Perform a Jet Pump Operability Test per CPS No. 9041.01

JPM Number: 90410101LAN01

Revision Number:03

Task Number and Title: 904101.01, Perform the Jet Pump Operability Test

K/A System	K/A Number	Importance (RO/SRO)	
Generic	2.2.12	3.0	3.4

Suggested Testing Environment: Any

Actual Testing Environment:☐ Simulator ☐ Plant ☐ Control Room

Testing Method: ☐ Simulate **Alternate Path:** ☐ Yes ☒ No
 ☒ Perform **SRO Only:** ☐ Yes ☒ No

Time Critical: ☐ Yes ☒ No

Estimated Time to Complete: 40 minutes Actual Time Used: _____ minutes

References: CPS No. 9041.01, Jet Pump Operability Test, Rev. 36
 CPS No. 9041.01D001, Jet Pump Operability Test Data Sheet, Rev. 34

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against the standards contained in this JPM, and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ Date: _____

**Clinton Power Station
Job Performance Measure (JPM)**

READ TO THE OPERATOR

I will explain the initial conditions, which step(s) to perform, simulate or discuss, and provide the initiating cues. When you complete the task successfully, the objective of this Job Performance Measure will be satisfied.

SIMULATOR SET-UP CONDITIONS

- None

TASK STANDARDS:

- CPS No. 9041.01, Jet Pump Operability Test, has been completed satisfactorily.

TOOLS, EQUIPMENT, OTHER SPECIAL REQUIREMENTS:

- Calculator

PROCEDURAL/REFERENCES:

- CPS No. 9041.01, Jet Pump Operability Test, Rev 36
- CPS No. 9041.01D001, Jet Pump Operability Test Data Sheet, Rev. 34

EVALUATOR INSTRUCTIONS:

- Preference is to perform JPM on the simulator, but may also be performed in the Main Control Room with the plant at or near 90% power (ie>70%), and Reactor Recirc in 2 loop operation.

JPM Number: 90410101LAN01

**Clinton Power Station
Job Performance Measure (JPM)**

INITIAL CONDITIONS AND INITIATING CUE:

You are the extra RO and the CRS has directed you to perform CPS No. 9041.01, Jet Pump Operability Test, using the supplied CPS No. 9041.01, Jet Pump Operability Test and CPS 9041.01D001, Jet Pump Operability Test Data Sheet.

The computerized method of performing CPS No. 9041.01 is not available at this time.

APRM calibrations are NOT in progress.

NOTE TO EVALUATOR

When the Initiating Cue has been read by the student and acknowledged, provide the following to the student.

- CPS No. 9041.01, Jet Pump Operability Test, Rev 36
- CPS No. 9041.01D001, Jet Pump Operability Test Data Sheet, Rev. 34
- Calculator

START TIME: _____

**Clinton Power Station
Job Performance Measure (JPM)**

PERFORMANCE INFORMATION

Critical steps are denoted with an asterisk (*) to the left of the step number and appear in BOLDED letters. Failure to meet the standards for a critical step constitutes failure of the Job Performance Measure. The sequence of steps is assumed unless denoted in the comments section of the JPM.

PERFORMANCE STEPS

5.0 Prerequisites

1. 5.1, Recirculation System Status
 - 5.1.1 Initial
 - 5.1.1.1.1) Loop flow mismatch maintained within 5% of rated core flow (4.225 mlbm/hr) when effective core flow is \geq 70% of rated core flow (59.15 mlbm/hr),
 - 5.2 (Record) Record Rx power using OD-3, 3D Monicore, or APRM indication
 - 5.3 (Initial) Notify SMngt of test start, and log Time and Date.

- Standard:
- Checks the following squares for:
5.1.1.1.1), 5.2, & 5.3
 - 5.1.1 Initials the 9041.01D001
 - 5.2 Documents power on the 9041.01D001

Cue: Report that authorization has been granted
 Report that logging information will be done by the B operator.

Comments This is a passive surveillance but if performed in the MCR obtain permission to access the information from the various locations.

SAT ☐ UNSAT ☐ Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

NOTE

During two-loop (single-loop) operation, steps pertaining to single-loop (two-loop) operation should have N/A in initial or data blanks.

If APRM calibrations are in progress, DCS computer points for RR Flow may be invalid. Check alternate data sources to verify values.

***2 8.1.1**

(Record) Use computer points B33DA013 (Loop A) and B33DA014 (Loop B) to determine operating Recirculation Loop A and/or B Flow in GPM.

Standard: Record Recirc Loop A and/or B flows on CPS No. 9041.01D001

Cue: Provide Data Sheet for Section 8.1 and 8.2

Comments Recirc Loop Drive Flows on DCS display 4A use computer points B33-DA013 and B33-DA014.

SAT ☐ UNSAT ☐ Comment Number _____

***3. 8.1.2**

(Record) Use computer points B33-DA009 (FCV 1B33-F060A) and B33-DA010 (FCV 1B33-F060B) to determine operating Recirculation FCV position.

Standard: Record positions of FCV's B33-F060A and B33-F060B on CPS N0. 9041.01D001.

Cue: If performed in the Simulator, RVDT is selected for both FCVs.

Comments F060A and F060B valve positions on DCS display 4A use computer points B33-DA009 and B33-DA010.
If performed in the MCR ensure permission is granted to open 1H13-P634.

SAT ☐ UNSAT ☐ Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

***4. 8.1.3**

Determine the Established Recirculation Loop and/or B flow using step 8.1.3.2 as follows:

IF RR Pumps for TWO LOOP operation are in fast speed,

THEN Use Figure 1a (1b) and Recirc FCV A (B) position from step 8.1.2 (x-axis value) to determine Established Recirc Loop A (B) Flow (y-axis value).

Standard: Determine Established Recirc Loop A and B Flows and record on CPS No. 9041.01D001.

Cue:

Comments The valves should be between:
A 29100 – 29200
B 29100 – 29200

SAT ☐ UNSAT ☐ Comment Number _____

***5. 8.1.4**

(Record) For each operating Recirc Loop A and/or B, calculate the % deviation of the indicated loop flow from the established loop flow using the data sheet formula.

Standard: Calculate percent deviation for both loops and record on CPS No. 9041.01D001.

Cue:

Comments

SAT ☐ UNSAT ☐ Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

8.2 Indicated Total Core Flow versus Established Total Core Flow

***6. 8.2.1**

(Record) Use computer point B33NA001 to determine Indicated Total Core Flow.

Standard: Record total Jet Pump Flow on CPS No. 9041.01D001.

Cue:

Comments Total Core Flow on DCS display 4A uses computer point B33-NA001.

SAT ☐

UNSAT ☐

Comment Number

7. 8.2.2

(Record) Calculate the Total Recirc Flow, sum of Loop A and B Flow from step 8.1.1 using the data sheet formula.

Standard: Calculate and record Total Recirc Flow on CPS No. 9041.01D001

Cue:

Comments

SAT ☐

UNSAT ☐

Comment Number

**Clinton Power Station
Job Performance Measure (JPM)**

***8. 8.2.3**

(Record) Determine and record the Established Total Core Flow value per 8.2.3.1 or 8.2.3.2 below.

1. For TWO LOOP operation, using Figure 2a and the Total Recirc Flow from step 8.2.2 as the x-axis value, determine the Established Total Core Flow.

Standard: Determine and record the Established Total Core Flow on CPS No. 9041.01D001.

Cue:

Comments

SAT ☐

UNSAT ☐

Comment Number

***9. 8.2.4**

(Record) Calculate the percent deviation in Total Core Flow from Established Core Flow using the data sheet formula.

Standard: Calculate and record percent deviation on CPS No. 9041.01D001.

Cue: If asked, engineering judgement is not being used.

Comments

SAT ☐

UNSAT ☐

Comment Number

**Clinton Power Station
Job Performance Measure (JPM)**

8.3 Indicated Jet Pump Flow/dP Versus Established Jet Pump Flow/dP

***10. 8.3.1**

(Record) Using computer points B33NA009 - 028, or P619 indications, record for each jet pump for the operating loops, the indicated diffuser-to-lower plenum Jet Pump flow or Jet Pump dP.

Standard: Record Jet Pump Flows using computer points on CPS No. 9041.01D001

Cue: Provide Data Sheet for Section 8.3

Comments

SAT ☐

UNSAT ☐

Comment Number

**Clinton Power Station
Job Performance Measure (JPM)**

NOTE

For TWO LOOP operation, if the results of steps 8.1.4 and 8.2.4 are acceptable, the surveillance results are acceptable, and steps 8.3.2, 8.3.3, 8.3.4 may be omitted (N/A'd).

For SINGLE LOOP operation, these steps should be performed for the operating jet pumps, but acceptance criteria has not been established.

11. 8.3.2

(Record) Calculate the Average Jet Pump Flow for each recirc loop using Formula #1 or Average Jet Pump dP (P619 dP meter scales are in %) for each recirc loop using Formula #2.

Standard: Not required due to steps 8.1.4 and 8.2.4 are acceptable Steps 8.3.2, 8.3.3, 8.3.4 may be omitted

Cue:

Comments

SAT ☐

UNSAT ☐

Comment Number

**Clinton Power Station
Job Performance Measure (JPM)**

12. 8.4

(Initial) If an Engineering evaluation was performed, are jet pumps
OPERABLE.

Standard: Engineering evaluation is not performed

Cue:

Comments Step can be NA'd

SAT ☐

UNSAT ☐

Comment Number

13. 8.5

(Initial) Notify SMngt at test completion.

Standard: Notify SMngt at test completion.

Cue: Acknowledge completion.

Comments The student will need to provide procedure and D001.

SAT ☐

UNSAT ☐

Comment Number

TERMINATING CUES:

CPS No. 9041.01, Jet Pump Operability Test, completed satisfactorily.

STOP TIME: _____

JPM Number: 90410101LAN01

**Clinton Power Station
Job Performance Measure (JPM)**

Data for Section 8.1 and 8.2

	Reactor Power	96%
	INDICATED Loop A Flow	31429
	INDICATED Loop B Flow	32006
B33-DA009	B33-F060A Recirc FCV Position	RVDT 58%
B33-DA010	B33-F060B Recirc FCV Position	RVDT 59%
B33NA001	Indicated Total Core Flow	75.6

**Clinton Power Station
Job Performance Measure (JPM)**

Jet Pump Flow for Section 8.3

Jet Pump Number	
JP 1	3.96
JP 2	3.96
JP 3	3.70
JP 4	3.74
JP 5	3.77
JP 6	3.78
JP 7	3.70
JP 8	3.73
JP 9	3.70
JP 10	3.63
JP 11	4.10
JP 12	4.10
JP 13	3.86
JP 14	3.85
JP 15	3.99
JP 16	3.91
JP 17	3.86
JP 18	3.81
JP 19	3.80
JP 20	3.80

JPM Number: 90410101LAN01

**Clinton Power Station
Job Performance Measure (JPM)**

Initiating Cue

You are the extra RO and the CRS has directed you to perform CPS No. 9041.01, Jet Pump Operability Test, using the supplied CPS No. 9041.01, Jet Pump Operability Test and CPS 9041.01D001, Jet Pump Operability Test Data Sheet.

The computerized method of performing CPS No. 9041.01 is not available at this time.

APRM calibrations are NOT in progress.

CLINTON POWER STATION

Job Performance Measure

Determine Expected Dose Operator
Would Receive While Performing an LLRT

JPM Number: 99555501NAN01

Revision Number: 00

Date:

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Approved By:	_____	_____
	Training Department	Date

**Clinton Power Station
Job Performance Measure (JPM)**

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating and terminating cues are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure:
- Current Procedure Rev. _____ Date: _____
- Procedure Rev. Referenced _____ Date: _____
- If the Current Procedure Rev. and the Procedure Rev. Referenced are different then revise the JPM.
- _____ 9. Pilot test the JPM:
- a. verify cues both verbal and visual are free of conflict, and
- b. ensure performance time is accurate.
- _____ 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor

Date

SME/Instructor

Date

SME/Instructor

Date

JPM Number: 99555501NAN01

**Clinton Power Station
Job Performance Measure (JPM)**

Revision Record (Summary)

Revision	Date	Description
00		New format and numbering convention, revalidated. This replaces JPM 033299J006. Revision number reset to 0.

JPM Number: 99555501NAN01

**Clinton Power Station
Job Performance Measure (JPM)**

Operator's Name: _____

Job Title: ☐ NLO ☐ RO ☐ SRO ☐ STA ☐ SRO Cert

JPM Title: Determine Expected Dose Operator Would Receive While Performing LLRT

JPM Number: 99555501NAN01

Revision Number:00

Task Number and Title:995555.01, Complete in-plant radiological practices for High Radiation Zone

K/A System	K/A Number	Importance (RO/SRO)	
Generic	2.3.10	2.9	3.3

Suggested Testing Environment:Any

Actual Testing Environment: ☐ Simulator ☐ Plant ☐ Control Room

Testing Method: ☐ Simulate **Alternate Path:** ☐ Yes ☒ No
 ☒ Perform **SRO Only:** ☐ Yes ☒ No

Time Critical: ☐ Yes ☒ No

Estimated Time to Complete: 10 minutes **Actual Time Used:** _____ minutes

References: CPS No. RP-AA-203, Exposure Control and Authorization, Rev. 2

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against the standards contained in this JPM, and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name:_____ (Print)

Evaluator's Signature:_____ Date:_____

**Clinton Power Station
Job Performance Measure (JPM)**

READ TO THE OPERATOR

I will explain the initial conditions, which step(s) to simulate or discuss, and provide the initiating cues. When you complete the task successfully, the objective of this Job Performance Measure will be satisfied.

TASK STANDARDS:

- Expected dose is determined and operators, who would not exceed their dose limit, are selected.

TOOLS, EQUIPMENT, OTHER SPECIAL REQUIREMENTS:

- Radiation survey map of the Containment Steam Tunnel
- Simplified drawing of penetration 1MC-061
- RP-AA-203, Exposure Control and Authorization
- Calculator

PROCEDURAL/REFERENCES:

- CPS No. RP-AA-203, Exposure Control and Authorization, Rev. 2

EVALUATOR INSTRUCTIONS:

- Amplifying cues are provided within the JPM steps.
- All pre-job briefings are completed.

**Clinton Power Station
Job Performance Measure (JPM)**

INITIAL CONDITIONS AND INITIATING CUE:

You are part of a team that is responsible for performing LLRTs during a refueling outage. You have been given the responsibility to set up for a test on RWCU LLRT 1MC-061. This will require you and one other member of your team to perform tasks in the Containment Steam Tunnel approximately 30cm from 1G33-F053. The tasks are estimated to take 90 minutes to complete.

The SRO in charge of the LLRTs has asked you to determine the following:

- Expected dose that you would receive.
- Which members of the team could assist you without requiring a Dose Level Extension Form.

The following is a list of LLRT Team Members and their exposure history.

Name	Annual TEDE Dose: Non ROG	Annual TEDE Dose: Mid West ROG	Annual TEDE Dose: Clinton Station
John	0 mrem	245 mrem	1547 mrem
Tim	261 mrem	89 mrem	1319 mrem
Paul	154 mrem	0 mrem	1625 mrem

NOTE TO EVALUATOR

When the Initiating Cue has been read by the student and acknowledged, provide the following to the student.

- Radiation survey map of the Containment Steam Tunnel
- Simplified drawing of penetration 1MC-061
- RP-AA-203
- Calculator

START TIME: _____

**Clinton Power Station
Job Performance Measure (JPM)**

PERFORMANCE INFORMATION

Critical steps are denoted with an asterisk (*) to the left of the step number and appear in BOLDED letters. Failure to meet the standards for a critical step constitutes failure of the Job Performance Measure. The sequence of steps is assumed unless denoted in the comments section of the JPM.

PERFORMANCE STEPS

1. Locates survey map of the Containment Steam Tunnel

Standard: Describes the locations where survey maps can be found.

Cue: When operator describes where survey maps are located, provide him with a copy of the Containment Steam Tunnel map.

Comments Survey maps may be found in the following locations:

- Service Building entrance to the RCA
- R & S line near the Maintenance Area
- Radiation Protection Desk
- Access Control Point

SAT ☐

UNSAT ☐

Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

2. Determines the Dose Rate near 1G33-F053

Standard: Dose Rate determined to be 200 mr/hr @ 30 cm from valve 1G33-F053, and/or 150 mr/hr in the area around 1G33-F053.

Cue: None

Comments

SAT ☐

UNSAT ☐

Comment Number _____

- *3. Calculates expected dose.**

Standard: Expected dose calculated to be:

- 300 mrem if the 200 mr/hr rate is used.
- 225 mrem if the 150 mr/hr rate is used.

Cue: None

Comments

SAT ☐

UNSAT ☐

Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

***4 Determines which operators could assist without requiring a Dose Level Extension Form.**

Standard: Operator determines that Tim could assist.

Cue: None

Comments: The Admin Limit that would require a Dose Level Extension Form is 2000 mr/yr.

Name	Annual TEDE Dose: Non ROG	Annual TEDE Dose: MWROG	Annual TEDE Dose:CPS	Total Received @ 225 mrem
John	0 mrem	245 mrem	1547 mrem	2017
Tim	261 mrem	89 mrem	1319 mrem	1894
Paul	154 mrem	0 mrem	1625 mrem	2004

Name	Annual TEDE Dose: Non ROG	Annual TEDE Dose: MWROG	Annual TEDE Dose:CPS	Total Received @ 300 mrem
John	0 mrem	245 mrem	1547 mrem	2092
Tim	261 mrem	89 mrem	1319 mrem	1969
Paul	154 mrem	0 mrem	1625 mrem	2079

SAT ☐

UNSAT ☐

Comment Number _____

TERMINATING CUES:

Operator(s) has been named to assist in the LLRT tasks.

STOP TIME: _____

**Clinton Power Station
Job Performance Measure (JPM)**

INITIAL CONDITIONS AND INITIATING CUE:

You are part of a team that is responsible for performing LLRTs during a refueling outage. You have been given the responsibility to set up for a test on RWCU LLRT 1MC-061. This will require you and one other member of your team to perform tasks in the Containment Steam Tunnel approximately 30cm from 1G33-F053. The tasks are estimated to take 90 minutes to complete.

The SRO in charge of the LLRTs has asked you to determine the following:

- Expected dose that you would receive.
- Which members of the team could assist you without requiring a Dose Level Extension Form.

The following is a list of LLRT Team Members and their exposure history.

Name	Annual TEDE Dose: Non ROG	Annual TEDE Dose: Mid West ROG	Annual TEDE Dose: Clinton Station
John	0 mrem	245 mrem	1547 mrem
Tim	261 mrem	89 mrem	1319 mrem
Paul	154 mrem	0 mrem	1625 mrem

CLINTON POWER STATION

Job Performance Measure

Verify Conditions are met to Enter Mode 2

JPM Number: 30010101SAN01

Revision Number: 00

Date:

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Approved By:	_____	_____
	Training Department	Date

**Clinton Power Station
Job Performance Measure (JPM)**

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating and terminating cues are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure:
- Current Procedure Rev. _____ Date: _____
- Procedure Rev. Referenced _____ Date: _____
- If the Current Procedure Rev. and the Procedure Rev. Referenced are different then revise the JPM.
- _____ 9. Pilot test the JPM:
- a. verify cues both verbal and visual are free of conflict, and
- b. ensure performance time is accurate.
- _____ 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor

Date

SME/Instructor

Date

SME/Instructor

Date

JPM Number: 30010101SAN01

**Clinton Power Station
Job Performance Measure (JPM)**

Revision Record (Summary)

Revision	Date	Description
00		New format and numbering convention, revalidated. This replaces JPM 300101.0101. Revision number reset to 0.

JPM Number: 30010101SAN01

**Clinton Power Station
Job Performance Measure (JPM)**

Operator's Name: _____

Job Title: ☐ NLO ☐ RO ☐ SRO ☐ STA ☐ SRO Cert

JPM Title: Verify Conditions are met to Enter Mode 2

JPM Number: 30010101SAN01

Revision Number:00

Task Number and Title: 300101.01, Complete Control Room actions to perform preparation for startup and approach to critical.

K/A System	K/A Number	Importance (RO/SRO)	
Generic	2.1.31	4.2	3.9

Suggested Testing Environment: Any

Actual Testing Environment: ☐ Simulator ☐ Plant ☐ Control Room

Testing Method: ☐ Simulate **Faulted/Alternate Path:** ☐ Yes ☒ No
 ☒ Perform **SRO Only:** ☒ Yes ☐ No

Time Critical: ☐ Yes ☒ No

Estimated Time to Complete: 30 minutes Actual Time Used: _____ minutes

References: CPS 3001.01, Approach to Critical, Rev. 24A
 CPS 3001.01C001, Preparation for Startup Checklist, Rev. 17
 CPS 3001.01C002, Mode 2 Checklist, Rev. 15B

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against the standards contained in this JPM, and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ Date: _____

**Clinton Power Station
Job Performance Measure (JPM)**

READ TO THE OPERATOR

I will explain the initial conditions, which step(s) to simulate or discuss, and provide the initiating cues. When you complete the task successfully, the objective of this Job Performance Measure will be satisfied.

No equipment or controls will be manipulated during this evaluation, only **Simulated** Actions will occur.

SIMULATOR SET-UP CONDITIONS

- None

TASK STANDARDS:

- Does not enter Mode 2 due to discrepancies not in compliance with Technical Specification.

TOOLS, EQUIPMENT, OTHER SPECIAL REQUIREMENTS:

- Copy of completed CPS 3001.01, Approach to Critical, Rev. 24A
- Copy of completed CPS 3001.01C001, Preparation for Startup Checklist, Rev. 17
- Copy of completed CPS 3001.01C002, Mode 2 Checklist, Rev. 15B

PROCEDURAL/REFERENCES:

- CPS 3001.01, Approach to Critical, Rev. 24A
- CPS 3001.01C001, Preparation for Startup Checklist, Rev. 17
- CPS 3001.01C002, Mode 2 Checklist, Rev. 15B

EVALUATOR INSTRUCTIONS:

- Present the completed copy of CPS 3001.01, CPS 3001.01C001, and CPS 3001.01C002 to the operator when the Initiating Cue is presented.
- Amplifying cues are provided within the JPM steps.

**Clinton Power Station
Job Performance Measure (JPM)**

INITIAL CONDITIONS AND INITIATING CUE:

You have taken the shift as the CRS in Mode 4. Review the procedures CPS 3001.01, Approach to Critical, CPS 3001.01C001, Preparation for Startup Checklist, CPS 3001.01C002, Mode 2 Checklist, and identify any actions required to support placing the plant into Mode 2.

NOTE TO EVALUATOR

When the Initiating Cue has been read by the student and acknowledged, provide a MARKED UP copy of the following procedures to the student.

- Copy of completed CPS 3001.01, Approach to Critical, Rev. 24A
- Copy of completed CPS 3001.01C001, Preparation for Startup Checklist, Rev. 17
- Copy of completed CPS 3001.01C002, Mode 2 Checklist, Rev. 15B

START TIME: _____

**Clinton Power Station
Job Performance Measure (JPM)**

PERFORMANCE INFORMATION

Critical steps are denoted with an asterisk (*) to the left of the step number and appear in **BOLDED** letters. Failure to meet the standards for a critical step constitutes failure of the Job Performance Measure. The sequence of steps is assumed unless denoted in the comments section of the JPM.

PERFORMANCE STEPS

1. Reviews:
 - 1) CPS 3001.01 Approach to Critical
 - 2) CPS 3001.01C001, Preparation for Startup Checklist
 - 3) CPS 3001.01C002, Mode 2 Checklist

Standard: Operator begins review of completed:

- 1) CPS 3001.01 Approach to Critical
- 2) CPS 3001.01C001, Preparation for Startup Checklist
- 3) CPS 3001.01C002, Mode 2 Checklist

Cue: None

Comments

SAT ☐

UNSAT ☐

Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

2. RCIC Inoperable

Standard: Operator recognizes that RCIC Inoperability does not impact plant startup, LCO 3.5.3. and N/A's Step 9.10 of CPS 3001.01C001.

Cue: None

Comments Not required to be Operable until 150 psig.

SAT ☐ UNSAT ☐ Comment Number _____

***3. RHR B NOT in Standby**

Standard: Operator identifies that RHR B must be placed in Standby to enter Mode 2.

Cue: None

Comments RHR B NOT in Standby does not satisfy LCOs for ECCS, Containment Spray, and Suppression Pool Cooling:
ITS 3.5.1 Action A.1
ITS 3.6.1.7 Action A.1
ITS 3.6.2.3 Action A.1
LCO 3.0.4 requires the LCO to be met for mode change.

SAT UNSAT Comment Number

JPM Number: 30010101SAN01

**Clinton Power Station
Job Performance Measure (JPM)**

***4. RHR B Test Prep Switch in TEST**

Standard: Operator identifies that RHR B Test Prep Switch must be in NORMAL.

Cue: None

Comments ORM 2.5.2 Action 3.5.2 NOT satisfied.

SAT

UNSAT

Comment Number

TERMINATING CUES:

Does not enter Mode 2 due to discrepancies.

STOP TIME: _____

JPM Number: 30010101SAN01

**Clinton Power Station
Job Performance Measure (JPM)**

Initiating Cue

You have taken the shift as the CRS in Mode 4. Review the procedures CPS 3001.01, Approach to Critical, CPS 3001.01C001, Preparation for Startup Checklist, CPS 3001.01C002, Mode 2 Checklist, and identify any actions required to support placing the plant into Mode 2.

CLINTON POWER STATION

Job Performance Measure

Review and Approve a Jet Pump Operability Test

JPM Number: 90410101SAF01

Revision Number: 00

Date:

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Approved By:	_____	_____
	Training Department	Date

**Clinton Power Station
Job Performance Measure (JPM)**

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating and terminating cues are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure:
- Current Procedure Rev. _____ Date: _____
- Procedure Rev. Referenced _____ Date: _____
- If the Current Procedure Rev. and the Procedure Rev. Referenced are different then revise the JPM.
- _____ 9. Pilot test the JPM:
- a. verify cues both verbal and visual are free of conflict, and
- b. ensure performance time is accurate.
- _____ 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor

Date

SME/Instructor

Date

SME/Instructor

Date

JPM Number: 90410101SAF01

**Clinton Power Station
Job Performance Measure (JPM)**

Revision Record (Summary)

Revision	Date	Description
00		New format and numbering convention, revalidated. This replaces JPM 033342J001. Revision number reset to 0.

JPM Number: 90410101SAF01

**Clinton Power Station
Job Performance Measure (JPM)**

Operator's Name: _____

Job Title: ☐ NLO ☐ RO ☐ SRO ☐ STA ☐ SRO Cert

JPM Title: Review and Approve a Jet Pump Operability Test

JPM Number: 90410101SAF01

Revision Number:00

Task Number and Title: 904101.01, Perform the Jet Pump Operability Test

K/A System	K/A Number	Importance (RO/SRO)	
Generic	2.2.12	3.0	3.4

Suggested Testing Environment: Any

Actual Testing Environment:☐ Simulator ☐ Plant ☐ Control Room

Testing Method: ☐ Simulate **Alternate Path:** ☒ Yes ☐ No
 ☒ Perform **SRO Only:** ☒ Yes ☐ No

Time Critical: ☐ Yes ☒ No

Estimated Time to Complete: 25 minutes Actual Time Used: _____ minutes

References: CPS No. 9041.01, Jet Pump Operability Test, Rev. 36
 CPS No. 9041.01D001, Jet Pump Operability Test Data Sheet, Rev. 34

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against the standards contained in this JPM, and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ Date: _____

**Clinton Power Station
Job Performance Measure (JPM)**

READ TO THE OPERATOR

I will explain the initial conditions, which step(s) to perform, simulate or discuss, and provide the initiating cues. When you complete the task successfully, the objective of this Job Performance Measure will be satisfied.

SIMULATOR SET-UP CONDITIONS

- None

TASK STANDARDS:

- CPS No. 9041.01, Jet Pump Operability Test, has been reviewed satisfactorily.

TOOLS, EQUIPMENT, OTHER SPECIAL REQUIREMENTS:

- Completed copy of CPS 9041.01, Jet Pump Operability Test
- Completed copy of CPS 9041.01D001, Jet Pump Operability Test Data Sheet that contains calculation error at step 8.1.4. Do not complete section 8.3.2-4 based on the assumption that sections 8.1.4 and 8.2.4 are satisfactory.
- Calculator

PROCEDURAL/REFERENCES:

- CPS 9041.01, Jet Pump Operability Test, Rev. 36
- CPS 9041.01D001, Jet Pump Operability Test Data Sheet, Rev. 34

EVALUATOR INSTRUCTIONS:

- Amplifying cues are provided within the JPM steps.

JPM Number: 90410101SAF01

**Clinton Power Station
Job Performance Measure (JPM)**

INITIAL CONDITIONS AND INITIATING CUE:

Review the supplied CPS 9041.01, Jet Pump Operability Test and CPS 9041.01D001, Jet Pump Operability Test Data Sheet for acceptability.

NOTE TO EVALUATOR

When the Initiating Cue has been read by the student and acknowledged, provide the following to the student.

- Completed copy of CPS 9041.01, Jet Pump Operability Test
- Completed copy of CPS 9041.01D001, Jet Pump Operability Test Data Sheet that contains calculation error at step 8.1.4. Do not complete section 8.3.2-4 based on the assumption that sections 8.1.4 and 8.2.4 are satisfactory.
- Calculator

START TIME: _____

**Clinton Power Station
Job Performance Measure (JPM)**

PERFORMANCE INFORMATION

Critical steps are denoted with an asterisk (*) to the left of the step number and appear in BOLDED letters. Failure to meet the standards for a critical step constitutes failure of the Job Performance Measure. The sequence of steps is assumed unless denoted in the comments section of the JPM.

PERFORMANCE STEPS

5.0 Prerequisites

1. Reviews Section 5, PREREQUISITES, to determine if proper blocks are filled out.
 - 5.1, Recirculation System Status
 - 5.1.1 Initial
 - 5.1.1.1.1) Loop flow mismatch maintained within 5% of rated core flow (4.225 mlbm/hr) when effective core flow is $\geq 70\%$ of rated core flow (59.15 mlbm/hr),
 - 5.2 (Record) Record Rx power using OD-3, 3D Monicore, or APRM indication
 - 5.3 (Initial) Notify SMngt of test start, and log Time and Date.

Standard: Determines that all the proper squares are complete.

Cue: None

Comments

SAT ☐

UNSAT ☐

Comment Number _____

Clinton Power Station
Job Performance Measure (JPM)

Faulted Step

- 8.1 Indicated Recirc Loop Flow versus Established Loop Flow based on FCV Position
☞ Procedure may be performed via Appendix A: Performance of Computerized CPS 9041.01D001, Refer to 2.1.7. criteria.

***2. Reviews Section 8.1 to determine if it is completed correctly.**

Standard: Determines that Step 8.1.4 has been incorrectly calculated for Recirc Loop B and that the correct "Loop Flow % Deviation" for Recirc Loop B would be outside the Acceptance Value.

Cue: If operator immediately wants to return the document to the originator request that he complete the review to determine if there are any other problems.

Comments B Loop Flow % Deviation should actually be 11.2%

SAT ☐

UNSAT ☐

Comment Number _____

8.2 Indicated Total Core Flow versus Established Total Core Flow

3. Reviews Section 8.2 to determine if it is completed correctly.

Standard: Determines that Step 8.2.4 has been completed correctly.

Cue: None

Comments

SAT ☐

UNSAT ☐

Comment Number

**Clinton Power Station
Job Performance Measure (JPM)**

8.2 Indicated Jet Pump Flow/dP versus Established Jet Pump Flow/dP

4. Reviews Section 8.3.1 to determine if it is completed correctly.

(Record) Using computer points B33NA009 – 028, or P619 indications, record for each jet pump for the operating loops, the indicated diffuser-to-lower plenum Jet Pump flow or Jet Pump dP.

Standard: Determines that Step 8.3.1 is completed correctly.

Cue: None

Comments

SAT ☐

UNSAT ☐

Comment Number

**Clinton Power Station
Job Performance Measure (JPM)**

NOTE

For TWO LOOP operation, if the results of steps 8.1.4 and 8.2.4 are acceptable, the surveillance results are acceptable, and steps 8.3.2, 8.3.3, 8.3.4 may be omitted (N/A'd).

For SINGLE LOOP operation, these steps should be performed for the operating jet pumps, but acceptance criteria has not been established.

***5. Reviews Steps 8.3.2, 8.3.3, and 8.3.4 to determine if they have been completed correctly.**

Standard: Determines from NOTE preceeding Step 8.3.2 that because Step 8.1.4 is not within the Acceptance Value, Steps 8.3.2, 8.3.3, 8.3.4 need to be completed.

Cue: If operator wants to return the document to the originator request that he complete the review to determine if there are any other problems.

Comments

SAT ☐ UNSAT ☐ Comment Number

6. Reviews Step 8.4, to determine if it has been completed correctly.

Standard: Determines that Step 8.4 was completed correctly.

Cue: None

Comments Step may be N/A'd

SAT ☐ UNSAT ☐ Comment Number

**Clinton Power Station
Job Performance Measure (JPM)**

7. Reviews Steps 8.5 to determine if it has been completed correctly.

Standard: Determines that Step 8.5 was completed correctly.

Cue: None

Comments

SAT ☐

UNSAT ☐

Comment Number

***8. Signs for Review and Approval**

Standard: Determines that because Step 8.1.4 was completed incorrectly and Steps 8.3.2, 8.3.3, and 8.3.4 are not completed, CPS 9041.01D001 should **not** be signed.

Cue: None

Comments

SAT ☐

UNSAT ☐

Comment Number

JPM Number: 90410101SAF01

**Clinton Power Station
Job Performance Measure (JPM)**

TERMINATING CUES:

Problems with CPS 9041.01, Jet Pump Operability Test, have been identified and test is not signed off.

STOP TIME: _____

JPM Number: 90410101SAF01

**Clinton Power Station
Job Performance Measure (JPM)**

Initiating Cue

Review the supplied CPS 9041.01, Jet Pump Operability Test and CPS 9041.01D001, Jet Pump Operability Test Data Sheet for acceptability.

CLINTON POWER STATION

Job Performance Measure

Redirect Worker in a High Radiation Area

JPM Number: 99555501SAN01

Revision Number: 00

Date:

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Approved By:	_____	_____
	Training Department	Date

**Clinton Power Station
Job Performance Measure (JPM)**

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating and terminating cues are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure:
- Current Procedure Rev. _____ Date: _____
- Procedure Rev. Referenced _____ Date: _____
- If the Current Procedure Rev. and the Procedure Rev. Referenced are different then revise the JPM.
- _____ 9. Pilot test the JPM:
- a. verify cues both verbal and visual are free of conflict, and
- b. ensure performance time is accurate.
- _____ 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor

Date

SME/Instructor

Date

SME/Instructor

Date

JPM Number: 99555501SAN01

**Clinton Power Station
Job Performance Measure (JPM)**

Revision Record (Summary)

Revision	Date	Description
00		New format and numbering convention, revalidated. This replaces JPM 995555.0103. Revision number reset to 0.

JPM Number: 99555501SAN01

**Clinton Power Station
Job Performance Measure (JPM)**

Operator's Name: _____

Job Title: ☐ NLO ☐ RO ☐ SRO ☐ STA ☐ SRO Cert

JPM Title: Redirect Worker in a High Radiation Area

JPM Number: 99555501SAN01

Revision Number:01

Task Number and Title: 995555.01, Perform radiological practices for High Radiation Zone

K/A System	K/A Number	Importance (RO/SRO)	
Generic	2.3.10		3.3

Suggested Testing Environment: Any, Simulator is preferred

Actual Testing Environment: ☐ Simulator ☐ Plant ☐ Control Room

Testing Method: ☐ Simulate **Faulted/Alternate Path:** ☐ Yes ☒ No
 ☒ Perform **SRO Only:** ☒ Yes ☐ No

Time Critical: ☐ Yes ☒ No

Estimated Time to Complete: 15 minutes Actual Time Used: _____ minutes

References: RP-AA-460, Controls for High and Very High Radiation Areas, Rev. 7
 RP-AA-400, ALARA Program, Rev. 3

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against the standards contained in this JPM, and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ Date: _____

**Clinton Power Station
Job Performance Measure (JPM)**

READ TO THE OPERATOR

I will explain the initial conditions, which step(s) to perform, simulate or discuss, and provide the initiating cues. When you complete the task successfully, the objective of this Job Performance Measure will be satisfied.

TASK STANDARDS:

The NLO is waiting in a low dose area.

TOOLS, EQUIPMENT, OTHER SPECIAL REQUIREMENTS:

- Copy of Aux Bldg Steam Tunnel Survey Map

PROCEDURAL/REFERENCES:

- RP-AA 460, Controls for High and Very High Radiation Areas, Rev. 7
- RP-AA-400, ALARA Program, Rev. 3

EVALUATOR INSTRUCTIONS:

- Amplifying cues are provided within the JPM steps.
- All pre-job briefings are completed.

JPM Number: 99555501SAN01

**Clinton Power Station
Job Performance Measure (JPM)**

INITIAL CONDITIONS AND INITIATING CUE:

1. The Unit is shutdown, you are the CRS.
2. An NLO is in the Aux Bldg Steam Tunnel to perform valve manipulations for feedwater flow trouble shooting.
3. You have just directed the NLO to CLOSE 1FW042A "Rx Feedwater Flow Inst Root"
4. Respond to reports from the NLO.

START TIME: _____

**Clinton Power Station
Job Performance Measure (JPM)**

PERFORMANCE INFORMATION

Critical steps are denoted with an asterisk (*) to the left of the step number and appear in BOLDED letters. Failure to meet the standards for a critical step constitutes failure of the Job Performance Measure. The sequence of steps is assumed unless denoted in the comments section of the JPM.

PERFORMANCE STEPS

RP-AA-460, Controls for High and Very High Radiation Areas

4.1.2.2, Only RP personnel are authorized to alter the position of radiological boundaries or barricades associated with a HRA/LHRA/VHRA.

-
1. RP barricade blocks access to valve.

Standard: Does not allow the NLO to move the barricade.

Cue: As the NLO report that there is a roped off area with a radiation sign and a swing gate with a light on it. Requests permission to move the rope to be able to access the 1FW042A valve.

Comments

SAT ☐

UNSAT ☐

Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

Note

May direct the performance of step 3 before step 2

***2 Directs RP to move barricade.**

Standard: Contacts RP or directs NLO to contact RP to have barricade moved.

Cue:

- As the NLO report that RP will not be able to move the barricade until after shift turnover in 30 minutes.
- If the CRS contacts RP then above report should come from RP.

Comments

SAT ☐

UNSAT ☐

Comment Number _____

RP-AA-400, ALARA Program

3.10.1 ENSURE that department personnel comply with ALARA Program procedures and requirements.

***3. Directs NLO to low dose area.**

Standard: Has NLO go to low dose area and/or exit Locked High Radiation Area

Cue: When operator gives direction to the NLO give the CRS the survey map of Aux Bldg Steam Tunnel and have him determine the "Low Dose Area".

Comments

SAT ☐

UNSAT ☐

Comment Number _____

TERMINATING CUES:

The NLO is waiting in a low dose area.

STOP TIME: _____

**Clinton Power Station
Job Performance Measure (JPM)**

Initiating Cue

1. The Unit is shutdown, you are the CRS.
2. An NLO is in the Aux Bldg Steam Tunnel to perform valve manipulations for feedwater flow trouble shooting.
3. You have just directed the NLO to CLOSE 1FW042A “Rx Feedwater Flow Inst Root”
4. Respond to reports from the NLO.

CLINTON POWER STATION

Job Performance Measure

Complete a NARS Form and Make the Required Notifications

JPM Number: 99999924SAN01

Revision Number: 00

Date:

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Approved By:	_____	_____
	Training Department	Date

**Clinton Power Station
Job Performance Measure (JPM)**

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating and terminating cues are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure:
- Current Procedure Rev. _____ Date: _____
- Procedure Rev. Referenced _____ Date: _____
- If the Current Procedure Rev. and the Procedure Rev. Referenced are different then revise the JPM.
- _____ 9. Pilot test the JPM:
- a. verify cues both verbal and visual are free of conflict, and
- b. ensure performance time is accurate.
- _____ 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor

Date

SME/Instructor

Date

SME/Instructor

Date

JPM Number: 99999924SAN01

**Clinton Power Station
Job Performance Measure (JPM)**

Revision Record (Summary)

Revision	Date	Description
00		New format and numbering convention, revalidated. This replaces JPM 999999.24. Revision number reset to 0.

JPM Number: 99999924SAN01

**Clinton Power Station
Job Performance Measure (JPM)**

Operator's Name: _____

Job Title: ☐ NLO ☐ RO ☐ SRO ☐ STA ☐ SRO Cert

JPM Title: Complete a NARS Form and Make the Required Notifications

JPM Number: 99999924SAN01

Revision Number:00

Task Number and Title: 999999.24, Preparation of Notification Form

K/A System	K/A Number	Importance (RO/SRO)	
Generic	2.4.38	2.2	4.0

Suggested Testing Environment: Any

Actual Testing Environment: ☐ Simulator ☐ Plant ☐ Control Room

Testing Method: ☐ Simulate **Faulted/Alternate Path:** ☐ Yes ☒ No
 ☒ Perform **SRO Only:** ☒ Yes ☐ No

Time Critical: ☒ Yes ☐ No

Estimated Time to Complete: 30 minutes

Actual Time Used: _____ minutes

References: EP-AA-1003, Radiological Emergency Plan Annex for Clinton Station, Rev. 6
 EP-AA-111, Emergency Classification and Protective Action
 Recommendations, Rev. 10
 EP-AA-111-F-07, Clinton Plant Based PAR Flowchart, Rev B
 EP-MW-114-100, Midwest Region Offsite Notifications, Rev. 5

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The operator's performance was evaluated against the standards contained in this JPM, and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ Date: _____

**Clinton Power Station
Job Performance Measure (JPM)**

READ TO THE OPERATOR

I will explain the initial conditions, which step(s) to simulate or discuss, and provide the initiating cues. When you complete the task successfully, the objective of this Job Performance Measure will be satisfied.

No equipment or controls will be manipulated during this evaluation, only **Simulated** Actions will occur.

SIMULATOR SET-UP CONDITIONS

- None

TASK STANDARDS:

- NARS Form is filled out correctly and Notifications made within the required time.

TOOLS, EQUIPMENT, OTHER SPECIAL REQUIREMENTS:

- A copy of FG1 (Page CL 3-25) and Fission Product Barrier Matrix (Page CL 3-8) from EP-AA-1003, Radiological Emergency Plan Annex for Clinton Station
- A copy of EP-AA-111, Emergency Classification and Protective Action Recommendations
- A copy of EP-AA-111-F-07, Clinton Plant Based PAR Flowchart
- A copy of EP-MW-114-100, Midwest Region Offsite Notifications
- EP-MW-114-100-F-01, Nuclear Accident Reporting System (NARS) Form

PROCEDURAL/REFERENCES:

- EP-AA-1003, Radiological Emergency Plan Annex for Clinton Station, Rev. 6
- EP-AA-111, Emergency Classification and Protective Action Recommendations, Rev. 10
- EP-AA-111-F-07, Clinton Plant Based PAR Flowchart, Rev B
- EP-MW-114-100, Midwest Region Offsite Notifications, Rev. 5

EVALUATOR INSTRUCTIONS:

- Amplifying cues are provided within the JPM steps.

**Clinton Power Station
Job Performance Measure (JPM)**

INITIAL CONDITIONS AND INITIATING CUE:

You are the Shift Manager.

A LOCA has occurred in the plant.

RPV Level is less than –187 inches.

Containment Pressure is 15 psig.

The inboard and outboard MSIVs on the D Main Steam Line have failed to shut manually.

Wind direction is varying between 280 and 284 degrees

Wind speed is 10 mph.

No release of radioactive materials has occurred.

An EAL initial classification of General Emergency as EAL FG1 has just been declared.

You are to complete the NARS Form, EP-MW-114-100-F-01, and make the required notifications.
Report when the task is complete. **This JPM is time critical.**

NOTE TO EVALUATOR

When the Initiating Cue has been read by the student and acknowledged, provide a copy of the following procedures to the student.

- A copy of FG1 (Page CL 3-25) and Fission Product Barrier Matrix (Page CL 3-8) from EP-AA-1003, Radiological Emergency Plan Annex for Clinton Station
- EP-AA-111, Emergency Classification and Protective Action Recommendations
- EP-AA-111-F-07, Clinton Plant Based PAR Flowchart
- EP-MW-114-100, Midwest Region Offsite Notifications
- EP-MW-114-100-F-01, Nuclear Accident Reporting System (NARS) Form

START TIME: _____

**Clinton Power Station
Job Performance Measure (JPM)**

PERFORMANCE INFORMATION

Critical steps are denoted with an asterisk (*) to the left of the step number and appear in BOLDED letters. Failure to meet the standards for a critical step constitutes failure of the Job Performance Measure. The sequence of steps is assumed unless denoted in the comments section of the JPM.

PERFORMANCE STEPS

1. UTILITY MESSAGE NO. _____

Standard: 1

Cue: None

Comments **START TIME FOR NEXT SECTION: _____ (Time Critical)**
(Same as JPM Start Time)

SAT ☐ UNSAT ☐ Comment Number _____

2. STATE MESSAGE NO. _____

Standard: N/A

Cue: None

Comments

SAT ☐ UNSAT ☐ Comment Number _____

**Clinton Power Station
Job Performance Measure (JPM)**

-
3. 1. STATUS
[A] ACTUAL
[B] DRILL/EXERCISE

Standard: Either

Cue: None

Comments

SAT	UNSAT	Comment Number
-----	-------	----------------

-
- *4. 2. STATION
[A] BRAIDWOOD [C] CLINTON [E] LASALLE [G] ZION
[B] BYRON [D] DRESDEN [F] QUAD CITIES

Standard: [C] CLINTON

Cue: None

Comments

SAT	UNSAT	Comment Number
-----	-------	----------------

**Clinton Power Station
Job Performance Measure (JPM)**

-
- *5. 3. ONSITE CONDITION**
[A] UNUSUAL EVENT
[B] ALERT
[C] SITE AREA EMERGENCY
[D] GENERAL EMERGENCY
[E] RECOVERY
[F] TERMINATED

Standard: [D] GENERAL EMERGENCY

Cue: None

Comments

SAT	UNSAT	Comment Number
-----	-------	----------------

-
- | | |
|--|-----------------------------------|
| *6. 4. <u>ACCIDENT CLASSIFIED</u> | <u>ACCIDENT TERMINATED</u> |
| TIME (3[A-E]): _____ | TIME (3[F]): _____ |
| DATE (3[A-E]): _____ | DATE (3[F]): _____ |
| EAL#: _____ | |

Standard: ACCIDENT CLASSIFIED
Present Date and Time when Cue was acknowledged.
EAL#: FG1

ACCIDENT TERMINATED
Time and Date: N/A

Cue: None

Comments

SAT	UNSAT	Comment Number
-----	-------	----------------

Clinton Power Station Job Performance Measure (JPM)

*7. 5. RELEASE STATUS 6.

[A] NONE ←→

[B] OCCURRING ←→

[C] TERMINATED ←→

Standard: [A] NONE

Cue: None

Comments

SAT

UNSAT

Comment Number

***8. 6. TYPE OF RELEASE**
[A] NOT APPLICABLE
[B] GASEOUS
[C] LIQUID

Standard: [A] NOT APPLICABLE

Cue: None

Comments

SAT

UNSAT

Comment Number

**Clinton Power Station
Job Performance Measure (JPM)**

***9. 7. WIND DIR**

(DEGREES FROM)

Standard: 280 – 284
(DEGREES FROM)

Cue: None

Comments Operator May just indicate 280

SAT	UNSAT	Comment Number
-----	-------	----------------

***10. 8. WIND SPEED**
[A] METERS/SEC: _____
[B] MILES/HR: _____

Standard: 9. WIND SPEED
[A] METERS/SEC: _____
[B] MILES/HR: 10

Cue: None

Comments

SAT	UNSAT	Comment Number
-----	-------	----------------

**Clinton Power Station
Job Performance Measure (JPM)**

***11. 9. RECOMMENDED ACTIONS**

UTILITY RECOMMENDATION

[A] NONE (UE, Alert, and SAE Only)

------(GE Only)-----

[B] SHELTER ILLINOIS SUB AREAS:_____

AND ADVISE REMAINDER OF THE EPZ TO MONITOR LOCAL RADIO STATIONS

[C] SHELTER IOWA SUB AREAS:_____

AND ADVISE REMAINDER OF THE EPZ TO MONITOR LOCAL RADIO STATIONS

[D] EVACUATE ILLINOIS SUB AREAS:_____

AND ADVISE REMAINDER OF THE EPZ TO MONITOR LOCAL RADIO STATIONS

[E] SHELTER IOWA SUB AREAS:_____

AND ADVISE REMAINDER OF THE EPZ TO MONITOR LOCAL RADIO STATIONS

Standard: Determines Protective Action Recommendation using EP-AA-111 & EP-AA-111-F-07

[D] EVACUATE ILLINOIS SUB AREAS: 1, 3, 4

AND ADVISE REMAINDER OF THE EPZ TO MONITOR LOCAL RADIO STATIONS

Cue: None

Comments Given wind speed encompasses 2 sectors.

SAT

UNSAT

Comment Number

12. 10. ADDITIONAL INFORMATION

Standard: None

Cue: None

Comments

SAT

UNSAT

Comment Number

**Clinton Power Station
Job Performance Measure (JPM)**

***13. MAKE THE NOTIFICATION**

Standard: Dial NARS Code 36

Cue: You receive a “beep” and the following agencies respond as on line:
Illinois EMA
DeWitt Co. Sheriff
Illinois REAC
DeWitt Co. EOC

Comments

SAT

UNSAT

Comment Number

***14. CONDUCT A ROLL CALL**

Standard: Checks off each agency as they respond.

Cue: Acknowledge each agency on line.

Comments May be done in conjunction with step 13.

SAT

UNSAT

Comment Number

**Clinton Power Station
Job Performance Measure (JPM)**

***15. FILL IN TIME AND DATE OF ROLL CALL**

Standard: Time and Date of Roll Call is filled in on Page 2 of the NARS Form.

Cue: None

Comments **STOP TIME FOR TIME CRITICAL PORTION OF JPM: _____**
(<15 Minutes)

SAT

UNSAT

Comment Number

***16. READ THE NARS MESSAGE**

Standard: Message is correctly read

Cue: Acknowledge the message

Comments Compare with provided Answer Key

SAT

UNSAT

Comment Number

**Clinton Power Station
Job Performance Measure (JPM)**

17. 11. TRANSMITTED BY:

Standard: Completes Block 11. with Name. Phone Number Calling from, and Time/Date.

Cue: None

Comments

SAT

UNSAT

Comment Number

18. 12. RECEIVED BY:

Standard: Asks for name of the IEMA representative and enters information on the NARS Form

Cue: Give the operator the name "Ken Evans"

Comments

SAT

UNSAT

Comment Number

**Clinton Power Station
Job Performance Measure (JPM)**

19. REPEAT THE ROLL CALL

Standard: Operator checks off each agency as they respond

Cue: Respond as roll is called.

Comments

SAT

UNSAT

Comment Number

20. ASK if there are any questions about the information provided.

Standard: Answers any questions.

Cue: None

Comments

SAT

UNSAT

Comment Number

21. STATE "NARS communication is complete."

Standard: States that NARS communication is complete.

Cue: None

Comments

SAT

UNSAT

Comment Number

JPM Number: 99999924SAN01

**Clinton Power Station
Job Performance Measure (JPM)**

TERMINATING CUES:

NARS Form is correctly filled out and Notification is made within the required time.

STOP TIME: _____

**Clinton Power Station
Job Performance Measure (JPM)**

Initiating Cue

You are the Shift Manager.

A LOCA has occurred in the plant.

RPV Level is less than –187 inches.

Containment Pressure is 15 psig.

The inboard and outboard MSIVs on the D Main Steam Line have failed to shut manually.

Wind direction is varying between 280 and 284 degrees

Wind speed is 10 mph.

No release of radioactive materials has occurred.

An EAL initial classification of General Emergency as EAL FG1 has just been declared.

You are to complete the NARS Form, EP-MW-114-100-F-01, and make the required notifications.

Report when the task is complete. **This JPM is time critical.**