

From: "NELSON, Alan" <apn@nei.org>  
To: "Nader Mamish" <NLM@nrc.gov>  
Date: 9/7/05 2:16PM  
Subject: RE: Fwd: UCS comments following emergency preparedness meeting

A couple thoughts:

- 1) Security Based EALs: The security based EALs are designed to supplement the existing set. The scenario described in the letter would still be driven as far as a GE if the radiological release were to exceed PAGs. Changing the definition of the vital area would add little other than a concurrent EAL situation.
- 2) Expedited NRC notification: I believe that the NRC should be notified within 15 minutes of classification (as discussed by the offsite agencies).
- 4) Informed Consent for Exposure to Bullets: How would we capture the statistical health effects and brief personnel in this instance?
- 5) ERO Augmentation: Was this a question?
- 6) Drill and Exercise Program: Drills and exercises are opportunities for both training and evaluation. The level of simulation while extensive does not provide the actual conditions of a real event. Trying to equate the consequences of a drill and that of an actual event are therefore not productive or practical. The ROP/CAP processes are working as evidenced in the performance indicators over the past several years.
- 7) SAE PARs: I agree, don't change them from what the State already has in place.
- 8) Spent Fuel Pool ERDS Points: Level and temp would be good.
- 9) Back-up siren power: Since sirens are a warning to go listen for information (not all siren systems are exclusively used for nuclear plant events), a wide scale power outage scenario would have many people without phone, TV or radio to do so. While back-up power is good, it is nothing more than one of several potential redundancies to help improve an already strong system.

-----Original Message-----

From: Nader Mamish [mailto:NLM@nrc.gov]  
Sent: Wednesday, September 07, 2005 10:18 AM  
To: NELSON, Alan  
Subject: FYI: Fwd: UCS comments following emergency preparedness meeting

FYI

This electronic message transmission contains information from the Nuclear Energy Institute, Inc. The information is intended solely for the use of the addressee and its use by any other person is not authorized. If you are not the intended recipient, you have received this communication in error, and any review, use, disclosure, copying or distribution of the contents of this communication is strictly prohibited. If you have received this electronic transmission in error, please notify the sender immediately by

---

telephone or by electronic mail and permanently delete the original message.

**Mail Envelope Properties (431F2E8A.039 : 10 : 4153)**

**Subject:** RE: Fwd: UCS comments following emergency preparedness meeting  
**Creation Date:** 9/7/05 2:16PM  
**From:** "NELSON, Alan" <apn@nei.org>  
**Created By:** apn@nei.org

**Recipients**

nrc.gov  
twf2\_po.TWFN\_DO  
NLM (Nader Mamish)

**Post Office**  
twf2\_po.TWFN\_DO

**Route**  
nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	2431	09/07/05 02:16PM
Mime.822	4339	

**Options**

**Expiration Date:** None  
**Priority:** Standard  
**Reply Requested:** No  
**Return Notification:** None

**Concealed Subject:** No  
**Security:** Standard