

From: <Tony_Banks@dom.com>
To: "Jack Cushing" <JXC9@nrc.gov>
Date: 9/15/05 8:24AM
Subject: Table 3.1-9

----- Forwarded by Tony Banks/NUC/VANCPower on 09/15/2005 08:22 AM -----

(See attached file: ER Table 3.1-9.doc)

CONFIDENTIALITY NOTICE: This electronic message contains information which may be legally confidential and/or privileged and does not in any case represent a firm ENERGY COMMODITY bid or offer relating thereto which binds the sender without an additional express written confirmation to that effect. The information is intended solely for the individual or entity named above and access by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution, or use of the contents of this information is prohibited and may be unlawful. If you have received this electronic transmission in error, please reply immediately to the sender that you have received the message in error, and delete it. Thank you.

Mail Envelope Properties (432967EE.956 : 4 : 43350)

Subject: Table 3.1-9
Creation Date: 9/15/05 8:23AM
From: <Tony_Banks@dom.com>

Created By: Tony_Banks@dom.com

Recipients

nrc.gov
owf4_po.OWFN_DO
JXC9 (Jack Cushing)

Post Office
owf4_po.OWFN_DO

Route
nrc.gov

Files	Size	Date & Time
MESSAGE	912	09/15/05 08:23AM
ER Table 3.1-9.doc	78848	
Mime.822	110355	

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard

Table 3.1-9 ESP Site Characteristics and Design Parameters

Item	Single Unit/Group Value [Second Unit/Group Value]	Description and References
Part 1 - Site Characteristics		
Normal Plant Heat Sink		
<ul style="list-style-type: none"> • Maximum Inlet Temperature Condenser/Heat Exchanger • Evaporation Rate 	<p>95°F (Unit 3 only)</p> <p>12,600 gpm, average, at 96% capacity factor (13,000 gpm, average, at full-load operation)</p>	<ul style="list-style-type: none"> • Item 2 of Table 3.1-1 • Maximum water temperature at condenser and heat exchanger inlet • Item 2.2.1 of Table 3.1-1 • Refer to Section 3.4.1.3.2. • Site-specific expected average rates of water lost by evaporation from Lake Anna, at 96% capacity factor and full load operation, as a result of heat rejection to the WHTF at the specified cooling water flow rate and cooling water temperature rise of 18°F. • Item 2.5.4.1 of Table 3.1-1 • Refer to Section 5.2.1.2; Tables 3.3-1 & 5.2-1; Figure 3.3-1.
Atmospheric Dispersion (χ/Q) (Accident)		
<ul style="list-style-type: none"> • EAB • LPZ 	<p>3.34E-5 sec/m³ [Same for 2nd unit/group]</p> <p>2.17E-6 sec/m³ [Same for 2nd unit/group]</p>	<ul style="list-style-type: none"> • Atmospheric dispersion coefficients used to estimate dose consequences of accident airborne releases. • Item 9.1 of Table 3.1-1 • Refer to Section 2.7.5; Tables 2.7-11 & 2.7-12.
Gaseous Effluents Dispersion, Deposition (Annual Average)		
<ul style="list-style-type: none"> • Atmospheric Dispersion (χ/Q) • Ground Deposition (D/Q) 	<p>χ/Q values in Table 2.7-14 [Same for 2nd unit/group]</p> <p>D/Q values in Table 2.7-14 [Same for 2nd unit/group]</p>	<ul style="list-style-type: none"> • Item 9.2 of Table 3.1-1 • The atmospheric dispersion coefficients used to estimate dose consequences of normal airborne releases. • Refer to Section 2.7.6; Table 2.7-14. • The ground deposition coefficients used to estimate dose consequences of normal airborne releases. • Refer to Section 2.7.6; Table 2.7-14.
Dose Consequences		
<ul style="list-style-type: none"> • Normal 	<p>10 CFR 20, 10 CFR 50 Appendix I, and 40 CFR 190 dose limits [Same for 2nd unit/group]</p>	<ul style="list-style-type: none"> • Item 9.3 of Table 3.1-1 • Radiological dose consequences due to gaseous releases from normal operation of the plant. • Item 9.3.1 of Table 3.1-1 • Refer to Section 5.4.3; Tables 5.4-10 & 5.4-11.

Item	Single Unit/Group Value [Second Unit/Group Value]	Description and References
<ul style="list-style-type: none"> • Post-Accident 	10 CFR 50.34(a)(1) and 10 CFR 100 dose limits [Same for 2nd unit/group]	<ul style="list-style-type: none"> • Radiological dose consequences due to gaseous releases from postulated plant accidents. • Item 9.3.2 of Table 3.1-1 • Refer to Sections 7.1.2 & 7.1.4.

Part 1 - Site Characteristics (continued)

<ul style="list-style-type: none"> • Minimum Distance to Site Boundary 	2854.9 ft [Same for 2nd unit/group]	<ul style="list-style-type: none"> • Minimum lateral distance from the ESP Plant Parameter Envelope boundaries to the Exclusion Area Boundary • Item 9.4.4 of Table 3.1-1 • Refer to Figure 3.1-3.
Liquid Radwaste System		<ul style="list-style-type: none"> • Item 10 of Table 3.1-1
<ul style="list-style-type: none"> • Normal Dose Consequences 	10 CFR 50 Appendix I, 10 CFR 20, and 40 CFR 190 dose limits [Same for 2nd unit/group]	<ul style="list-style-type: none"> • The radiological dose consequences due to liquid effluent releases from normal operation of the plant. • Item 10.1.1 of Table 3.1-1 • Refer to Section 5.4.3; Tables 5.4-10 & 5.4-11.
Population Density		
<ul style="list-style-type: none"> • Population density at the time of initial site approval and within about 5 years thereafter 	Population density meets the guidance of RS-002, Section 2.1.3 for RG 4.7, Regulatory Position C.4 [Both units/groups]	<ul style="list-style-type: none"> • At the time of initial site approval and within about 5 years hereafter, the population densities, including weighted transient population, averaged over any radial distance out to 20 miles (cumulative population at a distance divided by the circular area at that distance), would not exceed 500 persons per square mile. • Refer to Section 2.5.1.5; Figure 2.5-13.
<ul style="list-style-type: none"> • Population density at the time of initial operation 	Population density meets the guidance of RS-002, Section 2.1.3 [Both units/groups]	<ul style="list-style-type: none"> • The population densities, including weighted transient population, averaged over any radial distance out to 30 miles (cumulative population at a distance divided by the area at that distance), would not exceed 500 persons per square mile at the time of initial operation. • Refer to Section 2.5.1.5; Figure 2.5-13.
<ul style="list-style-type: none"> • Population density over the lifetime of the new units until 2065 	Population density meets the guidance of RS-002, Section 2.1.3 [Both units/groups]	<ul style="list-style-type: none"> • The population densities, including weighted transient population, averaged over any radial distance out to 30 miles (cumulative population at a distance divided by the area at that distance), would not exceed 1000 persons per square mile over the lifetime of new units. • Refer to Section 2.5.1.5; Figure 2.5-13.

Item	Single Unit/Group Value [Second Unit/Group Value]	Description and References
Population Center Distance	10 CFR 100.21(b) Meets requirement [Both units/groups]	<ul style="list-style-type: none"> The distance from the ESP plant parameter envelope to the nearest boundary of a densely populated center containing more than about 25,000 residents is not less than one and one-third times the distance from the ESP plant parameter envelope to the outer boundary of the LPZ. Refer to Section 2.5.1.2.

Part 1 - Site Characteristics (continued)

Exclusion Area Boundary (EAB)	10 CFR 100.21(a) Meets requirement [Both units/groups]	<ul style="list-style-type: none"> The exclusion area boundary is the perimeter of a 5000-ft-radius circle from the center of the abandoned Unit 3 containment. Refer to Sections 2.7.5, 2.7.6, 3.1.5, 4.1.1, 4.4.1.3, 5.1.1, 5.3.3.2.3, 5.3.4, 5.3.4.2, 5.4.1.3, 5.4.2.2, 5.5.1.3, 5.8.1.1, 5.8.1.2, 5.8.1.4, 5.8.3.1, 7.1.2, 7.1.4; Tables 2.7-10, 2.7-11, 2.7-14, 4.4-2, 7.1-1, 7.1-2, 7.1-4, 7.1-6, 7.1-8, 7.1-10, 7.1-11, 7.1-13, 7.1-15, 7.1-17, 7.1-19, 7.1-20, 7.1-22, 7.1-24, 7.1-26 & 7.1-28; Figures 1.1-1 & 2.1-2.
Low Population Zone (LPZ)	10 CFR 100.21(a) Meets requirement [Both units/groups]	<ul style="list-style-type: none"> The LPZ is a 6-mile-radius circle centered at the Unit 1 containment building. Refer to Sections 2.7.5, 2.7.6, 5.8.3.1, 7.1.2, 7.1.4; Tables 2.7-12, 7.1-1, 7.1-2, 7.1-4, 7.1-6, 7.1-8, 7.1-10, 7.1-11, 7.1-13, 7.1-15, 7.1-17, 7.1-19, 7.1-20, 7.1-22, 7.1-24, 7.1-26 & 7.1-28.

Part 2 - Design Parameters

Structure Height	≤ 234 ft [Same for 2nd unit/group]	<ul style="list-style-type: none"> The height from finished grade to the top of the tallest power block structure, excluding cooling towers Item 1.1.1 of Table 3.1-1 Refer to Sections 2.7.5, 3.1.2.2 & 6.4.1.1.
Structure Foundation Embedment	≤ 140 ft [Same for 2nd unit/group]	<ul style="list-style-type: none"> The depth from finished grade to the bottom of the basemat for the most deeply embedded power block structure Item 1.1.2 of Table 3.1-1 Refer to Section 4.2.1.2.
Normal Plant Heat Sink		<ul style="list-style-type: none"> Item 2 of Table 3.1-1
<ul style="list-style-type: none"> Condenser / Heat Exchanger Duty 	≤ 9.7 E9 Btu/hr [Additional 9.7 E9 Btu/hr for 2nd unit/group]	<ul style="list-style-type: none"> Waste heat rejected from the main condenser and the auxiliary heat exchangers during normal plant operation at full station load Item 2.2.2 of Table 3.1-1 Refer to Sections 3.4.1.1, 3.4.1.3, 3.4.2.3, 5.3.2.1, 5.3.2.1.2.
<ul style="list-style-type: none"> Unit 3 Once-Through Cooling 		<ul style="list-style-type: none"> Item 2.5 of Table 3.1-1

Item	Single Unit/Group Value [Second Unit/Group Value]	Description and References
Cooling Water Flow Rate	1,140,000 gpm	<ul style="list-style-type: none"> • Total cooling water flow rate through the condenser at specified heat rejection rate and temperature rise of 18°F. • Item 2.5.2 of Table 3.1-1 • Refer to Sections 3.4.1.1, 3.4.2.1, 3.4.2.2, 5.2.1.1, 5.2.2.1.2, 5.3.1, 5.3.1.1, 5.3.1.1.2, 5.3.2.1.2 & 5.3.2.1.3; Table 3.3-1; Figure 3.3-1.

Part 2 - Design Parameters (continued)

Heat Rejection Rate	≤ 9.7 E9 Btu/hr	<ul style="list-style-type: none"> • The expected maximum heat rejection rate to the WHTF, during normal operation at full station load • Item 2.5.5 of Table 3.1-1 • Refer to Sections 3.4.1.1, 3.4.1.3.1, 3.4.2.3, 5.3.2.1 & 5.3.2.1.2.
Cooling Water Discharge Temperature	113°F	<ul style="list-style-type: none"> • Site-specific bounding value based on a maximum inlet temperature of 95°F and a condenser temperature rise of 18°F at full flow condition • Item 2.5.1.1 of Table 3.1-1 • Refer to Sections 3.4.1.1, 3.4.2.2, 3.4.2.3, 5.2.2.1.2 & 5.3.2.1.2.
<ul style="list-style-type: none"> • Unit 4 Dry Cooling Towers 		
Evaporation Rate	None or negligible (on the order of 1 gpm, average)	<ul style="list-style-type: none"> • The expected rate at which water is lost by evaporation from the cooling water system • Refer to Sections 1.1.4, 2.3.1.1, 3.1.5, 3.3.1, 3.4.1.1, 5.2.1, 5.2.2.1.2, 5.3.3.1 & 5.3.3.2.1; Table 3.3-2; Figure 3.3-2.
Height	≤ 150 ft	<ul style="list-style-type: none"> • The vertical height above finished grade of the cooling towers • Refer to Sections 3.1.2.2, 5.3.3.2.4 & 5.8.1.5.
Makeup Flow Rate	None or negligible (on the order of 1 gpm, average)	<ul style="list-style-type: none"> • The expected rate of removal of water from Lake Anna to replace evaporative water losses from the cooling water system • Refer to Sections 2.3.1.1, 2.3.3.1, 3.3.1, 3.4.1.1, 3.4.2.1, 5.2.1, 5.2.1.1, 5.2.1.4, 5.3.1, 5.3.1.1, 5.3.1.2.2 & 5.3.3.1; Table 3.3-2; Figure 3.3-2.
Noise	< 60 – 65 dbA at EAB	<ul style="list-style-type: none"> • Maximum expected sound level produced by operation of the cooling towers • Refer to Sections 3.1.5, 5.3.3.2.3, 5.3.4.2 & 5.8.1.2.
Heat Rejection Rate	≤ 9.7 E9 Btu/hr	<ul style="list-style-type: none"> • Waste heat rejected to the atmosphere from the cooling water system, during normal plant operation at full station load • Refer to Sections 3.4.1.1, 3.4.1.3.1 & 3.4.2.3.

Part 2 - Design Parameters (continued)

Item	Single Unit/Group Value [Second Unit/Group Value]	Description and References
Ultimate Heat Sink Mechanical Draft Cooling Towers		<ul style="list-style-type: none"> • Item 3 of Table 3.1-1 • Item 3.3 of Table 3.1-1
• Blowdown Constituents and Concentrations	Values in Table 3.1-1 [Same for 2nd unit/group]	<ul style="list-style-type: none"> • The maximum expected concentrations for anticipated constituents in the UHS blowdown to the WHTF • Item 3.3.3 of Table 3.1-1 • Refer to Section 5.5.1.1.
• Blowdown Flow Rate	144 gpm expected, 850 gpm maximum [288 gpm expected, 1700 gpm maximum]	<ul style="list-style-type: none"> • The normal expected and maximum flow rate of the blowdown stream from the UHS system to the WHTF • Item 3.3.4 of Table 3.1-1 • Refer to Sections 3.4.1.2, 3.4.2.2 & 5.3.2.1; Tables 3.3-1 & 3.3-2; Figures 3.3-1 & 3.3-2.
• Evaporation Rate	411 gpm normal, 850 gpm shutdown [822 gpm normal, 1700 gpm shutdown]	<ul style="list-style-type: none"> • The expected (and maximum) rate at which water is lost by evaporation from the UHS system • Item 3.3.7 of Table 3.1-1 • Refer to Section 3.4.1.2; Tables 3.3-1 & 3.3-2; Figures 3.3-1 & 3.3-2.
• Height	≤ 60 ft [Same for 2nd unit/group]	<ul style="list-style-type: none"> • The vertical height above finished grade of mechanical draft cooling towers associated with the UHS system. • Item 3.3.8 of Table 3.1-1 • Refer to Section 3.1.5.
• Maximum Consumption of Raw Water	850 gpm, nominal [1700 gpm]	<ul style="list-style-type: none"> • The expected maximum short-term consumptive use of water from Lake Anna by the UHS system (evaporation and drift losses) • Item 3.3.14 of Table 3.1-1 • Refer to Tables 3.3-1 & 3.3-2; Figures 3.3-1 & 3.3-2.
• Monthly Average Consumption of Raw Water	411 gpm [822 gpm]	<ul style="list-style-type: none"> • The expected normal operating consumption of water from Lake Anna by the UHS system (evaporation and drift losses) • Item 3.3.15 of Table 3.1-1 • Refer to Tables 3.3-1 & 3.3-2; Figures 3.3-1 & 3.3-2.
Release Point		
• Elevation	Ground Level	<ul style="list-style-type: none"> • The elevation above finished grade of the release point for routine operational and accident sequence releases • Item 9.4 of Table 3.1-1

Part 2 - Design Parameters (continued)

Source Term		<ul style="list-style-type: none"> • Item 9.5 of Table 3.1-1
• Gaseous (Normal)	Values in Table 5.4-7 (maximum values) [Double values in Table 5.4- 7]	<ul style="list-style-type: none"> • The annual activity, by isotope, contained in routine plant airborne effluent streams • Item 9.5.1 of Table 3.1-1 • Refer to Section 5.4.2.2; Table 5.4-7.

Item	Single Unit/Group Value [Second Unit/Group Value]	Description and References
<ul style="list-style-type: none"> • Gaseous (Post-Accident) 	Values in Section 7.1 tables (maximum values) [Same for 2nd unit/group]	<ul style="list-style-type: none"> • The activity, by isotope, contained in post-accident airborne effluents • Item 9.5.2 of Table 3.1-1 • Refer to Section 7.1.4; Tables 7.1-3, 7.1-5, 7.1-7, 7.1-9, 7.1-12, 7.1-14, 7.1-16, 7.1-18, 7.1-21, 7.1-23, 7.1-25 & 7.1-27.
<ul style="list-style-type: none"> • Tritium 	3530 Ci/y [7060 Ci/yr] (maximum values)	<ul style="list-style-type: none"> • The annual activity of tritium contained in routine plant airborne effluent streams • Item 9.5.3 of Table 3.1-1 • Refer to Section 5.4.2.2; Table 5.4-7.
Liquid Radwaste System		
<ul style="list-style-type: none"> • Release Point Dilution Factor 	10 (minimum) [Same for 2nd unit/group]	<ul style="list-style-type: none"> • Item 10 of Table 3.1-1 • The ratio of liquid potentially radioactive effluent streams to liquid non-radioactive effluent streams from plant systems to the WHTF through the discharge canal used for NAPS Units 1 and 2 • Refer to Section 5.4.1.1; Table 5.4-1.
<ul style="list-style-type: none"> • Liquid 	Values in Table 5.4-6 (maximum values) [Double the values in Table 5.4-6]	<ul style="list-style-type: none"> • The annual activity, by isotope, contained in routine plant liquid effluent streams • Item 10.3.1 of Table 3.1-1 • Refer to Section 5.4.2.1; Table 5.4-6.
<ul style="list-style-type: none"> • Tritium 	≤ 3100 Ci/yr [≤ 6200 Ci/yr]	<ul style="list-style-type: none"> • The annual activity of tritium contained in routine plant liquid effluent streams • Item 10.3.2 of Table 3.1-1 • Refer to Section 5.4.2.1; Table 5.4-6.
Solid Radwaste System		
<ul style="list-style-type: none"> • Activity 	≤ 2700 Ci/yr [≤ 5400 Ci/yr]	<ul style="list-style-type: none"> • Item 11 of Table 3.1-1 • The annual activity contained in solid radioactive wastes generated during routine plant operations • Item 11.2.1 of Table 3.1-1 • Refer to Section 3.5.3.
<ul style="list-style-type: none"> • Volume 	≤ 9041 cu ft/yr [$\leq 18,646$ cu ft/yr]	<ul style="list-style-type: none"> • The expected volume of solid radioactive wastes generated during routine plant operations • Item 11.2.2 of Table 3.1-1 • Refer to Section 3.5.3.

Part 2 - Design Parameters (continued)

Plant Characteristics		
<ul style="list-style-type: none"> • Acreage 	Approximately 128.5 acres [Both units/groups]	<ul style="list-style-type: none"> • Item 16 of Table 3.1-1 • Approximate area on the NAPS site that would be affected on a long-term basis as a result of additional permanent facilities • Item 16.2 of Table 3.1-1 • Refer to Section 4.1.1.4.

Item	Single Unit/Group Value [Second Unit/Group Value]	Description and References
<ul style="list-style-type: none"> • Megawatts Thermal 	<ul style="list-style-type: none"> ≤ 4300 MWt [≤ 8600 MWt] 	<ul style="list-style-type: none"> • The thermal power generated by one unit (may be the total of several modules) • Item 16.3 of Table 3.1-1 • Refer to Sections 1.1.3, 3.1.2.2, 3.2.1, 3.8.1 & 7.1.4; Table 3.8-1.
<ul style="list-style-type: none"> • Plant Population – Operation 	<ul style="list-style-type: none"> Approximately 720 permanent employees [Both units/groups] 	<ul style="list-style-type: none"> • Anticipated number of new employees that would be required for operation of the new units • Item 16.5.1 of Table 3.1-1 • Refer to Sections 2.5.2, 5.8.2 & 5.8.2.2.
<ul style="list-style-type: none"> • Plant Population – Refueling / Major Maintenance 	<ul style="list-style-type: none"> Approximately 700–1,000 temporary workers during planned outages [Same for 2nd unit/group] 	<ul style="list-style-type: none"> • Anticipated number of additional workers onsite during planned outages of the new units • Item 16.5.2 of Table 3.1-1 • Refer to Sections 2.5.2 & 5.8.2.1.2.
<ul style="list-style-type: none"> • Plant Population – Construction 	<ul style="list-style-type: none"> 5,000 people maximum [simultaneous construction] 	<ul style="list-style-type: none"> • Peak workforce of 5,000 for construction of both new units/groups • Item 17.4.1 of Table 3.1-1 • Refer to Sections 2.5.2, 4.4.2, 4.4.2.2.1, 4.5.4, 5.8.2.2 & 5.8.2.2.2.
<ul style="list-style-type: none"> • Maximum Fuel Enrichment for Light-Water-Cooled Reactors 	<ul style="list-style-type: none"> 5% [Same for 2nd unit/group] 	<ul style="list-style-type: none"> • Concentration of U-235 in fuel • Refer to Sections 3.2.1 & 3.8; Table 3.8-1.
<ul style="list-style-type: none"> • Maximum Fuel Burn-up for Light-Water-Cooled Reactors 	<ul style="list-style-type: none"> 62,000 MWd/MTU [Same for 2nd unit/group] 	<ul style="list-style-type: none"> • The value derived by calculating the reactor thermal power multiplied by the time of irradiation divided by fuel mass (expressed as megawatt-days per metric ton of irradiated fuel) • Refer to Sections 3.2.1 & 3.8; Table 3.8-1.
<ul style="list-style-type: none"> • Maximum Fuel Enrichment for Gas-Cooled Reactors 	<ul style="list-style-type: none"> 19.8% [Same for 2nd unit/group] 	<ul style="list-style-type: none"> • Concentration of U-235 in fuel • Refer to Sections 3.2.1 & 3.8; Table 3.8-2.
<ul style="list-style-type: none"> • Maximum Fuel Burn-up for Gas-Cooled Reactors 	<ul style="list-style-type: none"> 133,000 MWd/MTU [Same for 2nd unit/group] 	<ul style="list-style-type: none"> • The value derived by calculating the reactor thermal power multiplied by the time of irradiation divided by fuel mass (expressed as megawatt-days per metric ton of irradiated fuel) • Refer to Sections 3.2.1 & 3.8; Table 3.8-2.