Official Transcript of Proceedings ACRST- 3322

NUCLEAR REGULATORY COMMISSION

Title:

Advisory Committee on Reactor Safeguards

Plant Operations and Fire Protection

Subcommittees Region II Visit

Docket Number:

(not applicable)

PROCESS USING ADAMS TEMPLATE: ACRS/ACNW-005

SISP - REVIEW COMPLETE

Location:

Atlanta, Georgia

Date:

Thursday, August 25, 2005

Work Order No.:

NRC-549

Pages 1-138

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

ACRS OFFICE COPY
RETAIN FOR THE LIFE OF THE COMMITTEE

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

August 25, 2005

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on August 25, 2005, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1	UNITED STATES OF AMERICA
2	NUCLEAR REGULATORY COMMISSION
3	+ + + +
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
5	PLANT OPERATIONS AND
6	FIRE PROTECTION SUBCOMMITTEES
7	REGION II VISIT
8	+ + + +
9	Thursday, August 25, 2005
10	8:30 a.m.
11	+ + + +
12	• Conference Room 24T20
13	Sam Nunn Federal Center
14	61 Forsyth Street, N.W.
15	Atlanta, Georgia
16	PANEL MEMBERS:
17	JOHN D. SIEBER, Chairman
18	VICTOR H. RANSOM, ACRS
19	GRAHAM B. WALLIS, ACRS
20	DANA A. POWERS, ACRS
21	THOMAS J. KRESS, ACRS
22	RICHARD S. DENNING, ACRS
23	MARIO V. BONACA, ACRS
24	WILLIAM J. SHACK, ACRS
25	, ·
	NEAL D. CDOSS

1	-	2
1	STAFF:	
2	RALPH CARUSO, ACRS Staff	
3	ASHOK C. THADANI, ACRS Staff	
4	JOHN T. LARKINS, ACRS Staff	
5	W. BILL TRAVERS, NRC Region II	
6	VICTOR M. McCREE, NRC Region II	
7	JOE SHEA, NRC Region II	
8		
9		
10		
11	•	
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		
- 1		

I-N-D-E-X

2	AGENDA ITEM PAGE
3	Inspection Staff Succession Planning
4	(V. McCree, RII; J. Shea, RII) 4
5	Recent Greater than Green Inspection Findings
6	Oconee 95002: White Finds on staffing the
7	Safe Shutdown Facility (SSF) in the event of
8	a fire and the SSF Pressurizer Heater adequacy
9	(B. Schin, RII)
10	Sequoyah 95001: White Finding on binding of
11	the 1A RHR Electrical Breaker
12	(S. Freeman, RII)
13	SDP Timeliness/Fire Protection Issues 101
14	(C. Payne, RII)
15	Closing Remarks
16	(W. Travers, RII; J. Sieber, ACRS)
17	Adjourn
18	
19	
20	
21	
22	
23	
24	
25	

P-R-O-C-E-E-D-I-N-G-S

MR. SIEBER: This is a continuation of the ACRS meeting with Region II personnel, and the portion of the ACRS that are here today are the Pant Operations Subcommittee and the Fire Protection Subcommittee which comprises the bulk of ACRS members, so there's only a couple that are absent.

I would welcome Bill Travers, as he has welcomed me, and as an old friend, and I would report to you that your team did an excellent job yesterday in their presentation. It was very efficient and forthright, and for me, and I'm sure the rest of the members, I gained confidence in the agency's ability to handle the issues that come forward from licensees, and particularly some challenging applications that lie before us right now.

And that was one of the purposes of our visit was to get a handle on TBA's applications for Browns Ferry for license renewal, extended power uprate, combined with the restart activity which looks almost like starting a new plant.

And so I think that will be a challenge of for both the region and the headquarters staff and for us to understand it and be able to separate the issues and combine them in a way that will allow us to make

good decisions.

And so I thank you on behalf of the subcommittees for the work that the region is doing in that regard, and since they visit us from time to time at White Flint and report their findings to us, I've always had that confidence in Region II personnel. I also read the website that has your inspection reports.

I would point out that our agenda calls for us to conclude by something like 12:15 today, and for me, my next two days of travel must work like clockwork. I'm going to Montana but I have to pick up my wife and mother-in-law on the East Coast to accompany them out there, and every connection looks to me like a bad one, and so I have to leave promptly, and in the event that we aren't done, I don't want to cut short any of the discussion that will go on. I would ask Dr. Powers to take my place to conclude the meeting.

So with that, I'd like to ask Dr. Travers to give us a little introduction.

DR. TRAVERS: Thanks, Chairman Jack. It's great to see you. Glad the ACRS could come to Region II. It is a good organization and I'm glad you've had the benefit of some of the presentations yesterday.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

I'm sorry I couldn't be here for the first half of the first day that you were able to take advantage of some of the information developing here at Region II.

There are a lot of challenges in Region II and obviously a lot of challenges within the agency, and the Southeast seems to be the targeted area for some of the projects, probably not unsurprisingly, that are being developed, and so we're extremely interested in being ready and prepared for the new work.

But the fundamental job that we have on a continuing basis is safety inspection at both nuclear power plants and all of the fuel cycle facilities across the country that are organized under Region II. And that's the reason I was out in Washington at Framatone Richmond yesterday to accompany Commissioner Jaczko, and for the first time myself have the advantage of that tour.

We certainly look forward in the future, as we have in the past, to working with ACRS. You are also obviously going to be challenged on some of this new work as it develops, if it develops, and so we'll need to assure that we have the same kind of good coordination and interaction with ACRS as we pursue these matters.

There's a lot on the plate, and I think today's first discussion actually, that Vic McCree is going to lead us through, will underscore the challenge we have in the most important element as I see it, and that the personnel, the people side of NRC programs.

NRC, in my sense, has always been effective largely or most importantly as a function of the people that work here, and so that's not going to change. Any organization is really defined by its personnel and the people that work.

I've been lucky enough to work in enough jobs to see NRC in a broad scope fashion, and I can tell you my experience here in Region II reinforces my view, a similar one I think that you share, that we're very fortunate to have a very professional team here at NRC.

But again, welcome, glad you could come.

MR. SIEBER: Thank you.

MR. McCREE: As Bill has indicated, and certainly made it very clear to the management team, our people are our greatest asset. So the management team, including myself in the Division of Reactor Safety and Joe in the Division of Reactor Projects, spend a considerable amount of time and effort focused

on identifying our needs, our skill needs, where we are, recruiting, hiring, developing, and putting in place an environment that's enriching enough and focused enough that people feel like staying here. We focus on retention.

But I wanted to take a while to talk about Joe and I, our use of the Strategic Workforce Plan, something that we've engaged in for the last two years, as well as our recruiting philosophy and strategy; the use of the Division of Reactor Projects Resident Inspector succession Plan which Joe is going to speak, as well as the Division of Reactor Safety Skills Matrix, both of which, again, are tools to help us to the end of getting good people onboard; and then talk about staff development training and end with just an overview of demographics that help drive what we do.

The Strategic Workforce Plan is, as you may be aware, an agency initiative of several years ago to address our current and long-term successor planning needs. All staff have to use that web-based tool to enter their skills and their knowledge.

Management looks at it to confirm their skill and knowledge level. We use it to determine where we recruit, how extensively we recruit, and it

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

also facilitates the technical Training Center's development of the training program that all of our staff have to take advantage of.

Using that tool does help to increase our efficiency and effectiveness. Prior to that, while we made it work, it was certainly less efficient than it is now. So it's a very helpful tool for us to use the Strategic Workforce Plan.

Next slide, please. Our recruiting philosophy and strategy. We've learned over the years that we have benefitted in Region II when we attempt to target folks who have some connection to the South, to the Southeast. We've targeted our recruiting efforts primarily to southern universities, as well as other locations in the South, and that's really helped us in terms of identifying people and also retaining them. When they have a connection to the geography, they tend to want to come and they tend to want to stay. So that's helped us tremendously.

We've used tailored vacancy announcements, specifically -- and I know Joe is going to speak to this -- we've tried to target our vacancy announcements so that we get the people that we want to apply for jobs.

As an example, in our Resident Inspector

NEAL R. GROSS

Program, about five years ago we were hiring people for the position that they would occupy once they joined us, as a project engineer, for example, when we really wanted those people to develop to become residents. changed the title of that So 6 7 announcement so that it was a Resident Inspector

Candidate Development Program and were able to draw in the operations-oriented people rather than the project management experience that we were getting under that previous posting. That's helped us significantly.

Again, we have targeted universities in the South, in the Southeast, such as Georgia Tech, Virginia Tech, NC State.

When you target them, what MR. WALLIS: sort of response do you find that you get from these universities?

The response that we get is MS. DMcCREE: a very positive one. We've identified what we call fact, across the agency we've champions. In identified champions for specific universities. We go and visit the different schools and departments that we're targeting, Nuclear Engineering departments at Georgia Tech and NC State, South Carolina State, and others.

1

2

3

4

5

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	DR. TRAVERS: Graham, just as an
2	example Georgia Tech is just four stops up, we live
3	next door about six months ago we had a group of
4	students come over and I think we've actually gotten
5	some fair interest from the group. We spent the day
6	with them, had the chance to interact with them and
7	some of the different disciplines.
8	MS. McCREE: It's the student chapter of
9	the American Nuclear society.
10	MR. McCREE: In fact, several of our
11	relatively new hires were members of the group that
12	came over and hosted and talked with.
13	MR. WALLIS: When they actually get hired,
14	that's when you really learn something.
15	DR. TRAVERS: We have quite a few Georgia
16	Tech on line.
17	MR. WALLIS: Because students will flirt
18	with all kinds of potential employers but when you
19	actually hire them, that's when you actually learn
20	something.
21	DR. TRAVERS: In fact, one of them told
22	me, Well, MIT is really the Georgia Tech of the
23	Northeast.
24	MR. WALLIS: You mean it's been corrupted
25	in the same way.

(General laughter.)

MR. McCREE: One of the strategies that we use, as well, is certainly using our internship and co-op opportunities to get potential new hires onboard so that they can see what we do, whether it's what they want to do, and we certainly have an opportunity as well to see what they're capable of.

And using the co-op strategy, in particular, helps us because it's easier and more efficient for us to hire potential new hires when we bring them in as co-ops and have them here for one or two summers, and we've used that very successfully over the last few years.

MR. McCREE: Next slide, please.

MR. SHEA: Let me take a couple of minutes to talk about the structure to the Inspection Program, and that's the context in which we look to make sure we have the right folks with the right qualifications to successfully accomplish that.

The NRC's entire Operating Reactor Inspection Program is outlined at the highest level in our inspection manual, Chapter 2515, and that outlines the entire Inspection Program: Supplemental, Baseline, Special Inspection programs, and in there indicates that it's imperative that those inspections

be conducted by qualified inspectors and then points to our qualification procedure.

That manual chapter for Operating Reactors is manual Chapter 1245, and that details the levels of qualification, the basic and final qualification, as well as refresher training and continuing education expectations for inspectors.

In the context, all of the training programs are oriented toward establishing really four critical elements that a good inspector needs to have, and that's they understand the legal foundation for acting as an inspector in a regulatory framework, that they have a detailed knowledge of the technology that they're inspecting, and that gets down to whether that's the NSSS specific training or just the generic aspects of pumps and valves or diesel generators and that sort of thing which are generic to the power reactors.

It drives toward making sure the inspectors have good inspection techniques, that is, their ability to gather data, analyze it, and assess it against the regulatory structure, and that's with making sure that they have good ability to assess that in a fundamental safety sense.

And finally, the training program makes

NEAL R. GROSS

what's 1 sure that inspectors have critical, 2 communication, the ability to communicate what they 3 see in the field to the licensee, back to management, 4 back to headquarters. MR. WALLIS: Can I ask you about this, you 5 said they learn about the regulatory structure. 6 7 MR. SHEA: Yes, sir. 8 MR. WALLIS: They must be smarter than 9 some of us. Some of us have been on this committee for 10 10-12 years and we're still trying to figure out some 11 of the details of the regulatory structure. Maybe 12 these guys pick it up quicker. How long does it take for them to really get familiar with the regulatory 13 structure? 14 15 MR. SHEA: The expectations for someone who comes in at maybe an early mid-career entry is two 16 17 years to achieve final qualifications, so they can pick up basic qualifications in 6 to 8 months. 18 19 MR. WALLIS: This is a full-time job, so 20 it is taking quite a while. MR. SHEA: Yes, it does. 21 22 MR. POWERS: Based on my observation, it's They're counting the minutes 23 a grind for two years. till the time they get through it. I teach R-800 for 24 25 this and I get them about a third to two-thirds of the

way through, and they're looking for the end. 1 Especially your course, I 2 MR. WALLIS: 3 should think. MR. POWERS: My course is so much fun. Of 4 5 course, it's rigorous and demanding but it's lots of fun. 6 (General laughter.) 7 MR. McCREE: Actually, it's a very sought-8 9 after course. MR. SHEA: But clearly, that's a challenge 10 in part to ensure that it becomes not as much of a 11 12 grind as it perhaps can be, but we make sure that we're giving them real-time assignments that will give 13 14 them practical application, even while they're going 15 through the qualification process. MR. WALLIS: Do you get any attrition? Do 16 they find that after a year that they don't like it? 17 The answer is no. 18 MR. McCREE: No. 19 MR. WALLIS: That's a good sign. We haven't lost any during 20 MR. McCREE: the training process. We've had some leave after --21 22 and these are new hires right out of college -- we've had just a couple leave from this region. I think our 23 attrition rate is less than some of our counterparts 24 in the other regions and headquarters, and I'd like to 25

1 attribute that to the fact that most of our new hires have co-op'd with us beforehand, so they have a much 2 3 better understanding of what they're getting into rather than someone who we just bring in right out of 4 school. 5 And again, we try not to do that with our 6 new hires. Mid career, it's a little bit different, 7 8 they're more mature, if you will, more experienced, 9 and have a much better idea of what they're getting 10 into. 11 MR. POWERS: My observation is that when 12 you pair a new hire with a mentor of some maturity and there's a good working relationship there, it breeds 13 an enthusiasm. 14 MR. McCREE: Indeed. 15 MR. POWERS: I can tell who is doing that 16 17 in the classes I teach because their enthusiasm and 18 curiosity levels are just much, much higher. 19 One of our early lessons MR. McCREE: learned too -- because most of our new hires are in 20 21 the Division of Reactor Safety, new hires meaning 22 right out of college -- is that we try not to bring 23 them in one at a time because we want them to have a peer group, if you would. 24 25 In fact, early on we called them Pride

Α

Group 1, Pride Group 2 because we bring in several, three or four new hires, and it really helps with their own synergy, at their own level, and it has helped us to retain them and move them along. couple actually have gone into the Resident Program after about three or four years. DR. TRAVERS: When we think of attrition, there is one element that we're thinking about currently, and that is some of the new jobs that are likely to be created in headquarters as a function of some of the new work that is being done. So we're actually incorporating into our philosophy of looking for people for training some notion that we'll probably lose some folks, and that's not just Region II, but the regions collectively will lose some folks as some of those jobs appear to be attractive in our MSS workshops. MR. LARKINS: Is that Traditionally the regions have served as the feeder group for a lot of headquarters jobs when they reached the journeyman level, GG-13, 14, as they look for promotions and stuff, and with the challenges you're being confronted with and the need for expertise. IT's been more of DR. TRAVERS:

challenge in Region I, and as real estate prices go up

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

concern?

1	in Washington.
2	(General laughter.)
3	DR. TRAVERS: But it is.
4	MR. McCREE: It's happened, I think it's
5	good for the agency to have that movement of
6	operations field experience to headquarters. We're
7	mindful of that and try to plan for it by populating
8	staff with people who can fall in behind them and do
9	what we need to do.
10	But it is a challenge, and what Bill is
11	alluding to is the fact that the Program Office has
12	allotted us additional FTEs to recognize the
13	likelihood that there will be opportunities
14	. MR. LARKINS: But as you said, as real
15	estate prices get higher, there's less movement.
16	MR. SIEBER: Washington is a good place to
17	move away from.
18	DR. TRAVERS: Amen.
19	(General laughter.)
20	MR. RANSOM: Do you put the training
21	materials together here? I presume you have training
22	materials that you use. Right?
23	MR. SHEA: Yes.
24	MR. RANSOM: I'd personally be interested
25	in getting a copy of that.
ĺ	NEAL D. ODOOG

1 MR. SHEA: The training course program is 2 fairly extensive and all oriented toward supporting 3 qualification of the inspectors. classroom training offered both in headquarters and 4 5 here in the region, and again, some of the attributes about the legal foundation of regulatory structure, 6 7 the technology and inspector techniques are offered in 8 both places. Part of the qualification process, 9 there's probably 10 to 15 courses that an individual 10 needs to go through, and that material is here and in 11 headquarters. 12 MR. RANSOM: You haven't put together a text or something with this material? 13 It would not be a single 14 15 binder, if you will. Some is online, but we can get 16 the representative elements of it. 17 (General talking.) MR. McCREE: I think what would be useful 18 19 is to look at the manual chapter itself, manual 20 chapter 1245 which has several attachments that describe what the qualification program is all about. 21 22 It tells a person what you have to do to become basic 23 certified and furthermore, what you have to do to complete full qualification. 24 25 That's a relatively new development and it

1 was updated about three years ago, so I think that 2 would be a very useful thing. 3 MR. WALLIS: So we understand it's tough material, but nobody flunks out, or do some people 4 fail? 5 Well, if that happens, then 6 MR. McCREE: 7 we have failed. 8 MR. WALLIS: I presume it's very well, you 9 select them so well. MR. McCREE: We have had inspectors who 10 11 have, for example, not passed one of the series 12 courses. MR. WALLIS: They go back and do it again? 13 MR. McCREE: What we do is we tutor that 14 15 individual and send them back and have them do it again, that's correct. And we've had a lot of success 16 with that, the second time around. But we've not had 17 anyone fail to become fully qualified, it just may 18 take a little bit more time. 19 And then the culmination of 20 MR. SHEA: that final qualification process is the qualification 21 22 board in which there are seasoned inspectors and 23 management assessing the full range of knowledge of that person before they put him out in the field, so 24 25 it's that board's responsibility.

MR. WALLIS: I remember about TMI there was some public criticism of the process where people sort of marginally would fail and eventually be reprocessed and marginally get through and so on. I'm sure that is no longer the case?

MR. McCREE: We try to invest on the front-end to make sure that people that we hire are very capable. We've been very fortunate in terms of our new hiring, in terms of grade point average and certainly their college experience, that they're very solid academically. In fact, many of our hires not only have an undergraduate degree but they have a master's degree before coming in.

With respect to our mid-career people, we interview then extensively, do very thorough reference checks, and have been very fortunate in terms of the quality and experience base of folks we've hired.

Again, even in the resident program, within the last five years we've put a major push on because a number of our residents have been hired in headquarters. We've been very successful with hiring individuals that are SRO licensed, shift technical advisors, shift supervisors who are fatigued with working shift work and have always thought about being a regulator, and this is just the right time for them

in their career, and we have a number who are out 1 2 there in the field right now. 3 MR. SIEBER: It's been my experience that training person involved in the 4 the and 5 development of resident inspectors is the senior resident at the plant site. 6 7 MR. McCREE: Exactly. MR. SIEBER: And that performs the check 8 9 on the quality of the reports that are written and also day-to-day tutoring. 10 MR. SHEA: That's right, and in fact, once 11 12 a person receives a basic level of qualification after six months, then they can be assigned to a site, and 13 in that context we would look where are the sites 14 15 where we have the most seasoned senior residents and look to pair those newer basic-qualified folks with 16 17 some of those more seasoned folks and get that 18 exchange that way. 19 MR. SIEBER: I guess the flip side of that 20 is the biggest mistake you can make as managers is to make somebody a senior resident who really doesn't 21 22 have all these qualities and attributes because some 23 of them are not the kinds of things that you can readily measure. 24 25 It has to do with personality, it has to

1 do with attitude, it has to do with drive, and I have 2 seen a lot of good resident inspectors in my career 3 become so because the senior resident was a very knowledgeable person with a lot of leadership skills. 4 5 MR. McCREE: We've tried not to make those kinds of mistakes, and we've had the benefit, we 6 7 mentioned, of experience level. Each year in NRR 8 sends to the commission a paper called Resident 9 Inspector Demographics, and if you look at that paper, 10 historically Region II has benefitted from having the most experienced inspectors, senior residents as well 11 as residents, in terms of time on a site, past 12 experience in the technical field, whether a shipyard 13 or within the industry. 14 15 So we have had that luxury, if you would, of having had experience to pass along to our new 16 17 resident inspectors. 18 MR. KRESS: But of your new hires that 19 would like to continue their education, do you have a program, some sort of agreement with Georgia Tech or 20 somewhere that they can go to night school or get off 21 22 from work? MR. McCREE: The agency has a program that 23 we benefit from that's called 368 Training that we do 24 25 take advantage of. What you'll find out in a few

minutes when I show you're the Division of Reactor Safety Skills matrix is while those opportunities are available -- and we have done that, for example, in the digital systems, digital controls, we sent several of our electrical/INC inspectors over to Georgia Tech to get that type of training -- there is, on the other hand, an abundance of training that the NRC offers through our Technical Training Center and the Technical Training Center can contract out for, should there be sufficient interest in that area from all the regions.

MR. KRESS: I had in mind something like a BS engineer wanting to get a master's degree.

MR. McCREE: Right. There are several paths by which a staff member or inspector could pursue that. One would be, as Victor was alluding, sort of on a piece-by-piece approach, course-by-course, you're justifying those courses in the context of their benefit to the agency, but a number of folks have put together advanced degrees through that process.

The other avenue is the agency does have some graduate fellowship program, but those are programs where someone steps out for the period of time, the 18 months or so, to get a degree and then

1 gets that degree and incurs some obligation to the 2 agency and then comes back in. 3 There is a fellow from Region MR. SHEA: 4 III, C.J. Farnham, has gone up to MIT to take on 5 graduate studies. MR. SHACK: I just wanted to ask what 6 7 number of fellowships do you have per year typically? 8 MR. McCREE: Right now I think C.J. is the 9 only one, however, we have two current co-ops for whom we are paying their tuition or at least part of their 10 tuition to complete their undergraduate degree. And 11 12 Joe has a resident inspector out at Harris who is actually completing a master's in nuclear engineering 13 through North Carolina State. 14 15 So it is being done, it is quite challenging, though, particularly as a resident, to 16 have time to do that. You're on call 24/365, so it' 17 makes it very challenging. But that is something that 18 19 we encourage and we support. MR. DENNING: I don't mean to downplay the 20 importance of the things that you're talking about 21 here and the stimulation of inspectors and their 22 23 training, but there must also be people that get into this job that really aren't suited for it that are 24 25 dead wood, and how do you handle that? And I realize

Ü

that's a really difficult problem for the agency, but 1 how do you do that, how do you identify them and move 2 them someplace at least where they're not doing harm? 3 MR. carefully, 4 McCREE: Very very thoughtfully, and certainly using the support and 5 understanding of senior management, as well as the 6 Office of Human Resources and the individual himself. 7 8 And certainly the regions are isolated in that 9 challenge. MR. DENNING: Do you have an annual 10 11 evaluation process that actually works? I mean, does it really work? I've seen lots of them where there's 12 the process but it's done superficially and everybody 13 is afraid to say negative things in these kinds of 14 evaluations. 15 We do have an annual MR. McCREE: 16 evaluation process and that's certainly a formal 17 18 process, but it's certainly not the only one that allows a manger, supervisor to engage an employee to 19 put in place resources to enable them to perform 20 better. 21 22 We try to hire individuals who have the will, that share our values and certainly have the 23 base level of experience and/or knowledge to help us 24 accomplish our mission. Our job then is to provide 25

the access to the skills to enable them to do it. 1 2 When that doesn't happen, then we have to 3 certainly engage that individual and see what job is best for them, and we do that very thoughtfully and 4 5 very carefully. Do you look to the utility 6 MR. DENNING: 7 for - comments the inspectors, on or 8 inconsistent with regulatory? 9 MR. McCREE: The answer is yes. This goes 10 back to the early '90s and the Towers Perrin report, 11 where now we formally, as directed by the EDO, when a 12 branch chief or a senior manager engages with a 13 licensee, when we go out for site visits or certainly when they drop in and visit us, one of the specific 14 15 items that we ask about and we actually document in our trip reports is how our inspectors are performing 16 and if there are any issues that we need to address. 17 So we do get that feedback. 18 19 DR. TRAVERS: We try to encourage at every 20 opportunity when management interacts with management, 21 I always ask: Are there any problems; are there any 22 issues you want to raise with me about how you see our 23 oversight program working? 24 And so I think the best thing you can do 25 is just try to keep those communication lines open.

1 Sometimes we get some information; sometimes we act on 2 it, sometimes we don't see a need to. 3 I think Jack brought up a point earlier that there really is an art, almost, to the 4 5 way inspectors who are serving this regulatory 6 function interact with licensees. It's acquired, it's 7 not just technical, it's a skill set that takes some time to develop, and in some people it takes a little 8 9 longer than in others. But in the main, we think 10 we're pretty successful. Well, I noted when I was 11 MR. SIEBER: 12 working as a licensee that quite often supervision would come and spend a week at our plant sites, 13 14 basically to monitor what goes on with the site-based 15 personnel which I thought was a good thing. They would sit in on all the meetings and 16 17 occasionally I'd be asked what do I think. But 18 licensees are going to be pretty cautious about 19 saying, Well, your resident inspectors are not any I don't recall anybody as ever having said 20 21 that; there may be an instance or two. 22 DR. TRAVERS: It is occasionally said, we have issues that are raised. 23 MR. SIEBER: But I would imagine it's 24 25 pretty rare.

we letillo

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

DR. TRAVERS: It's rare, in large measure,
I think it's not needed all that often because we have
been fairly successful.

MR. SIEBER: I've been flat-out asked by regional administrators what do you think of this person or that person, but the impression that I got, both from outside the agency and inside the agency, is these organizations at the region are basically small enough that the regional administrator and all of the management really know a lot of details about the performance of individuals in that organization. I have always been impressed by that. And I'm sure that this region is the same.

MR. McCREE: And that's not a mistake. I mean, as Bill indicated, people are asked that, certainly the residents and even our base inspectors put a lot of time and energy into their development, their hard technical skills, their soft skills as well that are developed for certainly our seniors, our first-line supervisors. They go through the supervisory courses and that enhances their tool bag as supervisors and their ability to interface with the licensee and certainly senior management in that context.

We reinforce it certainly through the

division directors and the branch chiefs, several of whom spoke with you yesterday, as well as twice a year we have our inspector counterpart meetings involving all the inspectors. So that's another opportunity for Bill, and certainly my colleagues and I reinforce the soft issues, if you would, as well as the important safety issues.

MR. SIEBER: Well, the skill set required for inspectors is quite a bit different than, for example, working in NRR or other places, and if an individual may not be too terrific an inspector, maybe NRR is the place to send them.

MR. SHEA: One last point perhaps on that is that there is an expectation on the first-line supervisors, the branch chiefs who are in the region, that they get out a number of times per year and directly observe the performance of the senior and the residents, both by doing walk-downs of the facility and watching them, observing them doing an inspection, and also attending inspection exit meetings where they can, in the first part, watch their technical inspector skills, on the second forum, watch their communication and ability to communicate regulatory issues directly.

So in addition to the feedback that may or

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

may not come clearly from the licensee through those

other venues, the supervisors first-line and second
line have their own base to make those assessments of

performance.

Let me go to the next item and talk about

Let me go to the next item and talk about some attributes of succession planning that are unique to the Resident Inspector Program.

The staffing requirements for the resident inspector set out in 1999 established the end policy where at the 18 sites across Region II we have approximately just under 40 resident inspectors out there, depending on the number of reactors at the site.

In terms of succession planning, there's one additional element in the resident program that makes managing succession planning, one element more complicated beyond just managing attrition due to retirements or attrition due to folks making midcareer changes.

The agency's relocation policy established in 1998 SECY paper and carried forth in the field policy manual, establishes that to ensure continuity on one hand and objectivity on the other hand, the resident inspectors can be at the site nominally no more than seven years and typically no less than four

years, with provisions for extraordinary circumstances.

And again, that provides for making sure we have continuity so we're not changing folks out so fast that we can't connect the dots as well, and that they don't stay so long as to lose their objectivity.

So management in the region and the branch chief tracks and projects into the future the expected turnover dates for both the residents and the senior residents, and we can get a sense for what years we're going to have gaps starting to open up that we need to plan for.

One management tool or enhancement that has been made in the recent past is our ability to overlap the assignment of residents and senior residents so that they can get a solid turnover of the issues and performance of that licensee before there's a gap.

And there have been instances where that's caused the agency problems over the past few years, and in response to that we've put in place this ability to double encumber for a period of time the coverage at the site -- I think it's a year for a resident and six months for a senior resident -- and allow, again, for a good turnover.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

In the context of looking ahead and projecting when the different sites are going to have openings or change-out of personnel, we can see where we need to keep some surge capacity -- I call it -- in the region of folks who are going through the qualification process, and that is the Resident Inspector Development Program that Vic alluded to earlier. terms of keeping to that expectation.

program to keep that surge capacity.

Currently we have four folks here in the region who are going through their basic qualification program, and that's out of a population of residents of about 40 folks, so that's about a 10 percent surge capacity. And each of those individuals is on a track with expectations about when they're going to timely complete their qualifications and are doing well in In fact, we're getting ready to hire on a fifth person into that

MR. WALLIS: So you have 40 out there and the average resident's time is five or six years, then you're going to have to need eight a year to replace them or something?

> They go someplace else. MR. KRESS: (General talking.)

MR. WALLIS: They just keep rotating them

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 around? I see what you mean, they don't go somewhere 2 else, they just go from plant to plant. 3 MR. SHACK: Can they actually return to a plant after some time? 4 5 MR. McCREE: If I could? MR. SHEA: 6 Sure. 7 MR. McCREE: With respect to surge 8 capacity, that is, if you would, a nominal surge 9 capacity in the Division of Reactor Projects. are also inspectors in the Division of Reactor Safety 10 capable and 11 who certainly are have interest occasionally in being residents as well. So there are 12 actually several that we know of who would like to, at 13 14 some point, become a resident. And in fact, each of 15 them are fully qualified, so there's actually more. It's sort of a strategic 16 MR. WALLIS: 17 reserve. 18 MR. McCREE: It's a strategic reserve. 19 I'll have to write that one down. To answer your question, there is no 20 21 agency policy that would preclude a resident from 22 returning at some subsequent point to serve as a resident or even as a senior at the same site. 23 We have had sub-optimal experiences when 24 25 we have done that. We have a senior who was once the

1 project manager at Browns Ferry, and in fact, his 2 predecessor was employed at TVA at Browns Ferry 17 3 years before we assigned him. But that's the 4 exception rather than the rule. 5 We generally do not do that simply because 6 of the perception by the licensee that that individual 7 may not be open, and even when we had some inspectors 8 who have been employed by a licensee, we will 9 consciously try not to send that individual or assign that individual to that site to avoid that same 10 11 perception and questions about objectivity. 12 MR. SIEBER: I thought that was a hard and fast rule. 13 MR. McCREE: Again, that's not a written 14 15 policy, it's not an institutional policy, but it's one 16 that we try to keep in mind. 17 DR. TRAVERS: But you're correct, very often what happens when people move is they move to 18 19 another site, especially a resident inspector may move up to become senior, for example, at another site. 20 21 MR. SIEBER: On the other hand, again as 22 a licensee, there were instances where I would have 23 liked to have hired my staff, NRC personnel, and of 24 course, the ethics issue would prevent me from doing

that with anybody having anything to do with our

plant, but I could have hired from somebody else's plant.

MR. McCREE: And it's becoming our internal policy not to assign a resident to a licensee, not just to a site but to a licensee for which he or she has served as a resident before. It could become an even greater challenge as licensees combine across regions, and we're aware of that and our policy will have to be reformed by those changes as they occur.

But we've found that policy useful, it's helped us in terms of our personnel assignment

MR. SIEBER: Now, there used to be a rotation policy of five years which was, to my knowledge, never rigorously enforced just because of the difficulty of playing checkers with few checkers on a big board.

MR. SHEA: As I was referring to, it has been revised, it's now actually a seven-year stay time. In fact, the two I was referring to, here's how we track -- this is for senior residents -- who is current at the site and the little red circle shows when their seven-year period would expire, and the X reminds us when we would want to think about advertising that upcoming vacancy and make sure we do

1 that in a timely way so we can get the overlap and the 2 good turnover. 3 MR. McCREE: Just to reiterate, that is rigorously enforced. It's in the EDO's policy field 4 5 manual. In fact, Bill has to request permission from the EDO to extend it beyond that date. 6 7 DR. TRAVERS: I don't think we've done it. MR. WALLIS: You might want to level this 8 9 out a bit. I notice you have no hires in some years and you have a huge number -- or no moves in some 10 years and then a huge number in other years. 11 You 12 might want to level it off so there's about the same changeover each year or something. Just a comment. 13 14 MR. McCREE: This slide here again shows 15 the senior residents, and there are a couple of assumptions -- and again, this is just a tool, there's 16 17 no magic, in this other than experience, logic and 18 reason -- but one assumption is that the seniors would 19 remain at the site until the end of their tour, seven 20 years, which based on our experience, that's rare. As Joe mentioned by policy, we have to 21 22 leave them there for four years unless we get Bill's 23 permission, and again, he has to request the EDO's approval. 24 25 DR. TRAVERS: Sometimes it's just money.

MR. McCREE: It is, it's the cost of relocation. I think it's about \$100,000 per move, and those costs are excessive and we've received guidance. In fact, those waivers that Bill could previously request would not likely be approved unless there's some extraordinary reason.

MR. SIEBER: One practice that you had, and I think you still have, that I think is a really good practice is take a resident from one plant and assign him as a transient inspector to another plant with perhaps similar issues.

DR. TRAVERS: We do that very often with special inspectors, for example. Even in Region III, for example, where David Specie or D.C. Cook has been, we can very often provide team members to some of the team inspections they carry out.

And where people go on vacation, we very often send senior or resident inspectors to those other sites, and in a developmental sense, we're looking for opportunities to broaden the perspective to people to bring in their own jobs.

MR. SIEBER: Among licensees, one of the things that developed a complacency in the organization was a lack of communication in this broad breadth of knowledge of what the industry was doing.

1 You have the potential in the agency to have the same 2 thing occur, and these kinds of thins are efforts that 3 will prevent it or forestall a sense of complacency that develops because the scope is too narrow. 4 5 encourage that. I think that's a very good 6 DR. TRAVERS: 7 point and in an era where the nuclear industry is performing sort of relatively well -- especially in 8 9 comparison to 12-15 years ago -- that guarding against complacency, both within the industry and within NRC, 10 is a very, very key element of what we need to guard 11 12 against. MR. SIEBER: Well, the kind of policies 13 that you're talking about and that you employ are the 14 kinds of things that I think help the agency avoid 15 16 those situations, so that's good. 17 DR. TRAVERS: And I mentioned good 18 performance. If you look at the Southeast, in 19 particular, the performance of the nuclear industry in 20 the Southeast and the potential for that sort of 21 complacency to take over is guite good. 22 certainly recognize your point, it's a good one. 23 MR. SHEA: The point about distribution of rotation times, on that same tool, 24 25 this reflects the projections for the resident

inspectors, and you can see that unlike the seniors where it was a little sort of weighted out there in the 2009-10° time frame, the resident inspector rotation distribution is a little more balanced.

Some of those folks would go to other sites as their times came up, some of them as senior resident or even headquarters positions came open would be looking to move into those kind of positions.

MR. McCREE: So just from an overview, the surge capacity that Joe spoke to within the region is a typical source of new residents to replace the incumbents, and for the most part, the residents within Region II, and in fact, the entire population of the nation of residents, because when a senior resident inspector position is posted, it's posted nationwide.

residents within Region II as well as in other regions, or perhaps even headquarters that there may be some residents who have gone there to gather additional experience and then they come back to the region as a senior resident. And that's always helpful for us to get cross-pollination among the regions and headquarters.

MR. THADANI: Just a quick question, Joe.

2 that would lead to improved morale and so on. Is that 3 the case? MR. McCREE: That is my perception, that's 4 5 been my experience from speaking to the residents and the seniors is that it's helped them to plan their 6 7 lives better, and we've also been able to assure their 8 objectivity through other means. And one of the 9 requirements that we lay upon inspectors every year is 10 that they do an objectivity visit at another site for 11 at least a week, and that's helped us to, again, 12 promote their objectivity, as well as visits by our branch chiefs. But that seven years has been a help. 13 14 MR. THADANI: Is there any study that says 15 seven years is good, nine years is not good? There's nothing scientific 16 MR. McCREE: 17 about that. 18 MR. SHEA: And in the end, any relocation is going to have its challenge for the individual, so 19 20 seven years or eight years. MR. McCREE: But it's a nice round number. 21 22 MR. SHEA: The last piece I was going to 23 mention -- but may in the discussion on DRS show it in a little bit more detail -- is that in the continuing 24 25 development of our inspectors we have a similar web-

Changing the five-year to seven-year policy, I assume

based tool where we track the experiences that the 1 inspectors have, both their prior experience, their 2 internal developmental activities, the classroom and 3 academic training they've had, and from that we 4 5 attempt to make sure that as we're planning training activities and training opportunities for the whole 6 7 inspector corps, make sure that we continue to get a good distribution of all those four basic skills that 8 9 I talked about at the beginning. In the interest of time, perhaps we can 10 look at that tool in the next part of the discussion. 11 MR. McCREE: That's the one I'm about to 12 13 speak to. I think Yogi Bear once said, You've got to 14 be careful if you don't know where you're going 15 because you might not get there. 16 17 Several years ago -- it's been recognized 18 for more than several, about five years ago, and this 19 has been updated certainly since that time -recognized that we have a significant succession plan 20 challenge because of our aging workforce and other 21 22 factors. So we laid out what we thought was a 23 logical tool that would identify the skills that we 24 25 need, and from that, to complete our tasks.

1	MR. WALLIS: So these needs in this column
2	are the needs above what you have now? Because
3	otherwise you might conclude that you have ten people
4	and you only need two. What you mean is you have ten
5	people and you need two more.
6	MR. McCREE: Understand. These are the
7	needs that we need right now.
8	MR. WALLIS: So you have ten people and
9	you only need two of them? Is that what I understand?
10	MR. McCREE: Let me start in the left-most
11	column. The skills needed are the skills that we need
12	right now to implement the Baseline Inspection
13	Program.
14	MR. WALLIS: So in all columns you have
15	c more people than you need?
16	MR. SIEBER: No. Physical security has
17	fewer qualified people.
18	MR. WALLIS: Yes, but in most of them the
19	staff onboard is bigger than the need so you could do
20	away with a lot of these people?
21	° MR. SIEBER: No. Some people have more
22	than one skill.
23	MR. McCREE: Let me use an example. Under
24	structural engineering, the first area, the staff
25	needed to complete integrated leak rate response

testing, the staff needed is one and we have four 1 2 onboard who are capable of doing that. 3 MR. WALLIS: Okay, but they're doing other things too. 4 MR. McCREE: They're doing other things as 5 So we have more than enough. 6 well. 7 Well, this doesn't explain MR. SIEBER: whether you have enough people to do all the work, 8 9 this tells you whether you have enough skills to do 10 individual jobs. 11 MR. McCREE: Correct. 12 MR. SIEBER: The more interesting question 13 is do you have enough overall people with the right skills to do all the work that has to be done. 14 15 that's a different answer than this chart will show 16 you. 17 MR. McCREE: That's correct. What this 18 does do for us, however, is identify skills gaps. In 19 other words, the delta between what we have and what 20 we need or what we project we will need because of 21 anticipated losses, for example, due to primarily retirement. 22 23 DR. TRAVERS: programs ornew 24 construction inspection. 25 MR. McCREE: Yes.

MR. SIEBER: Or physical security where 1 2 you do have a shortfall. 3 Right. MR. McCREE: MR. THADANI: I'm a little bit surprised, 4 5 why is that a special skill, integrated leak rate 6 response testing? 7 MR. POWERS: What do you mean, it's the hardest test I can think of doing. It's unbelievable 8 9 difficult and nobody has done it for ten years. 10 (General talking.) MR. THADANI: But is that a special skill? 11 12 MR. McCREE: It is an activity, it is a 13 line item inspection requirement. Not 14 mechanical or structural inspector can do it by virtue 15 of just being a mechanical or structural, it takes 16 experience. 17 DR. TRAVERS: We just want to make sure 18 we're tracking the capacity to be able to have the 19 right people and skill to do that. MR. POWERS: It's an incredibly difficult 20 21 test to do because just the day-to-day variations is bigger than the leak that you're trying to detect. 22 23 MR. WALLIS: I think it's just words. This is really a task, isn't it; these are task areas 24 25 rather than what you might think of as skills. Ιt

	11
1	doesn't matter, though, I understand what you mean.
2	MR. CARUSO: The staff need, though,
3	that's not an FTE number, that's a bodies number.
4	MR. McCREE: Correct, exactly.
5	MR. CARUSO: I mean, if you add that
6	number of staff needs up, you don't come to the same
7	FTE as you have onboard.
8	MR. SIEBER: No, you don't.
9	MR. McCREE: I've not done that, but if it
10	weren't I the ballpark, I'd question the adequacy of
11	our FTEs. In fact, you won't see a total number at
12	the end because we haven't thought of it that way, but
13	you ask an interesting question.
14	MR. POWERS: On this integrated leak rate
15	test, we are coming up on the ten-year anniversary of
16	the revised Appendix J so there must be some that are
17	coming down the line. Do you know when we scheduling
18	to do these things?
19	MR. McCREE: We could probably change the
20	schedule.
21	MR. POWERS: It would be interesting to
22	witness one of them because they're incredibly
23	difficult to do.
24	MR. THADANI: You could also go to other
25	regions if necessary for stuff like that.

1 2 3 MR. McCREE: 4 5 6 7 career, mid career and late career. 8 9 10 11 12 would, discipline, is 13

MR. POWERS: The agency may want to get a specialist in there to do those things.

Another example I'll point to you, primarily because he's here, under metallurgical engineering, the staff needs are four, staff onboard is four. However, under 2005 as well as 2006, 2007, you'll notice EM&L which stands for early

Again, this was a tool primarily driven by our anticipated loss due to retirement. The fact that one of our metallurgical engineers in that are, if you in the late career, identified the need to hire a mid-career in-service inspection engineer, and he just happens to be here right now, has a good bit of industry experience from PSE&G.

So that's one example of we use this to inform what our needs out, and we went out and got him, so when we update this in a few weeks, we'll be able to remove that. And there are other similar This is a dynamic tool that we use. examples.

For example, on the next page under mechanical engineer, there's a clear abundance, if you would, of mechanical engineers but we did identify under projected new hires to transfer an early-career

14

15

16

17

18

19

20

21

22

23

24

from NRR.

We found out last week that that individual has decided not to come which is good for him because an opportunity is available for him at NRR, and actually good for us too because our assessment in the electrical engineering area has determined that we really need a mid career electrical engineer. So we can use that FTE for that purpose.

So this a tool, DRP has an analogous one, that we use to identify our needs.

And one additional thing that this shows on the far right column you'll see succession action plan and most of what's in there is the training courses that we are specifically targeting to our staff to develop, expand or hone skills that we know we're going to need, particularly among our new hires. You'll see EC, early career, those are training courses for early career.

And the vast majority of our training budget -- we'll have a Training Committee meeting next week, a senior management Training Committee meeting -- the vast majority of our training budget goes to the Division of Reactor Safety, I think about two-thirds, because the DRS staff are recognized as the experts in a number of technical areas so we

leverage our training budget to reflect that.

Go back to the power point slide, please.

In closing on this slide, there are 17 areas here that we focus on, and we're in the process of enriching this, if you would, to address our needs in the anticipated construction inspection program area. It's a very dynamic area for us and there are some needs that we need to refresh with this.

Next slide. I have several slides here really just for your information that provide demographic data, if you would, on Region II staff.

An earlier question was asked about graduate training. We do have a number of employees that hold master's degrees, five who have doctorate degrees. What's not shown on here, and I'll enhance it next time, is the number of professional engineer licensees or EIT holders that we have. We do have quite a few of those, so I apologize for not reflecting that. We do have our one regional counsel too -- we only need one.

MR. WALLIS: The next one is interesting.

Do you actually hire in at age 40? Otherwise you have
a strange population distribution for whenever you say
sustain ability, let's say.

MR. McCREE: Well, certainly to satisfy

NEAL R. GROSS

EEOC laws, we cannot exclude individuals over 40. 1 2 Well, if they just move MR. WALLIS: 3 through, you're going to have a real punch in ten 4 years. 5 MR. McCREE: Right. What we have done -and I can say this -- we have targeted at the entire 6 7 agency new hires to address our age distribution 8 challenge, and we've been very successful. 9 DR. TRAVERS: Twenty-five percent target 10 for new hires. And again, we're not talking age, we're talking experience level as a function. But it 11 12 certainly recognizes this issue that the agency has -some would call it the perfect storm of things --13 14 you've got a profile that looks like this in tandem with some of these new projects that are developing, 15 and if you look at both of those factors, it becomes 16 17 a very difficult situation. Next slide, please. 18 MR. McCREE: 19 another complementary slide that talks about years of 20 federal service, and again, this reflects on the far 21 left our success in the last few years on our new hires in terms of staff with less than ten years 22 23 experience. We've been very aggressive and very 24 successful in that regard.

Next slide. I included this one -- in

1	fact, I just updated it this morning so it's not
2	reflected in the slide that you have there to show
3	the ongoing challenge we have in retirement
4	eligibility and our need to definitely focus on
5	succession planning.
6	There was a dip in optional retirement
7	eligibility in '06, we did have several people retire,
8	some moved to headquarters, but there is an increasing
9	trend in increasing age in our workforce.
10	MR. THADANI: In '04, 60 people did take
11	early retirement?
12	MR. McCREE: No. What that reflects is
13	eligibility for.
14	MR. THADANI: So that's not real.
15	MR. McCREE: No. It's just eligibility
16	MR. WALLIS: How many total employees are
17	there then, because if I look at these other pages, I
18	see the total number of employees is 200 or something?
19	MR. McCREE: Correct, 212.
20	MR. WALLIS: So you have a huge number
21	ready for early retirement.
22	MR. McCREE: Correct. That's the insight
23	that I wanted to share with you.
24	DR. TRAVERS: And one element of that is
25	that it's disproportional in certain areas, so it

becomes even more problematic in certain key areas. 1 2 That's why we want to be as knowledgeable as we can to 3 manage it. I wonder if I could talk a MR. DENNING: 4 5 little bit about fire protection engineer. I notice as far as the skill set going back there that there 6 7 were identified as five fire protection, and are those truly fire protection engineers, people with just fire 8 9 protection skills? MR. McCREE: We have one licensed, 10 guess, if you would, fire protection engineer, we have 11 12 several individuals with electrical or mechanical background who have developed expertise, if you would, 13 in fire protection -- one of whom is sitting in the 14 15 back there, and they lead our fire protection inspections. 16 17 On the other hand, we do have two co-ops who are -- in fact one will join us next spring who 18 19 will have a degree in fire protection engineering, and 20 the other one next fall. So indeed, they are 21 knowledgeable in fire protection engineering. 22 MR. DENNING: When you're inspecting a 23 site, to what extent do you rely on the resident inspector to check on the fire protection elements, or 24 25 are there groups of fire protection engineers that go

1

2

4

3

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

around and do this? How do you actually do that?

MR. McCREE: That's a very good question. The Baseline Inspection Program, there's an inspection procedure for fire protection inspection, and there are two attachments.

One is a quarterly inspection requirement that the resident inspectors implement that's primarily focused on the performance of inspecting the for transient combustibles, for example, inspecting the licensee's fire drills, or if there's an actual fire, to observe the licensee's performance. That's the function of the resident inspectors.

And then we have what's called triennial fire protection inspection which, again, Bob Schin and Charlie Payne will speak to later this will talk about the triennial afternoon, fire protection inspection which is a team inspection composed of at least four individuals and perhaps a contractor, and that's an integrated examination of the licensee's fire protection program.

MR. DENNING: If we move to risk informed performance based fire protection, what we've been told is that the inspectors will be able to go in and look at things and review what the licensee has done in terms of like fire propagation with computer codes

and associated circuits kinds of analyses, things that would really require a great deal of in-depth knowledge. Are those things practical for inspectors to do?

MR. McCREE: May I ask that you hold that?

Well, the answer is yes. We do rely on contractor support for some of the more complex issues, but we have developed, through training, a very sound body of expertise, I believe, by comparison to some of our counterparts in the other regions, probably almost a center of excellence in terms of the quality of our fire protection inspectors.

Again, when Charlie Payne and perhaps Bob, you may want to sit here along with them in a couple of hours to talk about that. I'd ask that you reiterate that question to them.

MR. SCHIN: It's a good question. It's a problem that we're facing, how we're going to do that.

MR. McCREE: Can you go back to that last slide? This is just a demographic slide that shows agency-wide the ongoing challenge. This is an age distribution chart that shows the green-colored area is what the agency-wide age distribution was in 2000, September of 2000, and the blue is the shift that's occurred as of April of this year.

MR. SIEBER: Everybody got older. 1 2 MR. McCREE: The way I like to look at it 3 is much more experienced. (General laughter.) 4 5 MR. McCREE: It just, again, underscores the challenge that faces us right now in terms of our 6 7 hiring strategy and succession planning. 8 course, one of the real factors that we have to deal 9 with here in Region II and in headquarters and other 10 places is we would love to bring aboard to learn from 11 our sage inspectors, to gather that knowledge and hit 12 the deck running, so to speak but we're constrained by 13 office space, so we're having to manage this very, 14 very closely. 15 MR. SIEBER: Thank you. Any questions? 16 If not, we are to the point of a break, and I think if 17 we would come back at ten o'clock by that clock, that 18 would keep us within striking distance of 19 schedule. 20 (Whereupon, a brief recess was taken.) 21 MR. SIEBER: We're ready now to resume. MR. SCHIN: Good morning. I'm Bob Schin, 22 23 senior reactor inspector in Engineering Branch 2 in the Division of Reactor Safety. 24 I've been an 25 inspector with the NRC in Atlanta for 18 years, and

primarily covering plant operations and engineering type areas.

Next slide, please. The purpose of this section of the discussion is to discuss certain white findings, and in particular the recent inspection that we had for a degraded mitigating system cornerstone at Oconee.

This inspection was performed using the inspection procedure 95002 for degraded cornerstone two white findings and during May to June of this year.

Next slide, please. The focus of the inspection, as described in the inspection procedure, is to provide assurance that for the two white findings the causes were understood and root corrective actions adequate. Also, to were independently assess the extent of condition and the extent of cause.

The two white findings, I'll give a little description of what they were. First, there was a 3rd quarter 2003 finding involving inadequate standby shutdown facility pressurizer heater capacity. That's the pressurizer heaters that were powered from the SSF. And this finding had been closed by a previous 95002 inspection that was six months prior to this

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

ll one.

And the second white finding was the 3rd quarter 2004 finding involving inadequate procedural criteria for manning the SSF during a fire. So both of these findings in part involved the SSF.

Now, to give a little technical description of what were the issues. First, the SSF pressurizer heater finding, this issue was licensee-identified during testing development on March 7, 2002. They discovered that they had an insufficient capacity of the pressurizer heaters that were powered by the SSF to assure natural circulation cooling.

What happens is if you don't maintain enough temperature in the pressurizer, then the pressurizer cools down, you lose RCS pressure, and you lose sub-cooling margin.

The way the BMW plants are designed, the hot leg goes into a candy cane which is a high part above the steam generator, and you have flow through the steam generator. The high part there is a hot part and it's subject to voiding, and then once you get voiding, you lose your natural circulation.

They discovered that the pressurizer ambient heat losses were in the range of 143 to 178 kW for each of the units, and that greatly exceeded the

NEAL R. GROSS

1	70 kW that was in the original design basis documents.
2	What happened is that the original design
3	analysis for 70 kW was wrong, the heat loss was really
4	more, and then over the years the amount of heat loss
5	got worse because of poor maintenance of the
6	insulation on the pressurizer, et cetera. So at this
7	point they were greatly exceeding the 70 kW from the
8	original design basis documents and the heat loss
9	exceeded the kW for the pressurizer heaters that were
10	powered by the SSF.
11	MR. WALLIS: So how do you have the
12	insulation degenerate?
L3	MR. SCHIN: Maintenance, they will take it
L4	off, put it back on.
15	MR. WALLIS: They don't put it on
16	properly? It doesn't deteriorate, does it?
۲7	MR. SCHIN: It gets beat up. Pieces might
18	be missing.
19	MR. WALLIS: They take it off and bits of
20	it fall off. Okay.
21	MR. DENNING: It gets beaten up and
22	doesn't work very well. The other kind doesn't get
23	beaten up and it works well, this is why people like
24	it, but metallic particularly.
25	MR. SIEBER: There are a lot of reasons

why they like the metallic. I take it the operators 1 were able to tell by how many they would ordinarily 2 3 have to put in service during a heat-up, that there was a discrepancy between the 70? 4 5 Right. Prior to this 2002, MR. SCHIN: 6 there was a case when they lost power to the normal 7 pressurize heaters and power from the SSF 8 discovered they couldn't maintain pressure. 9 Now, at that time, though, they had 10 reactor coolant pumps running and so the thought was 11 that the spray valve was leaking by and that was 12 affecting it, and they didn't recognize the extent of the problem right off the bat. 13 14 Normally when the SSF is powering the heater, when you're relying on the SSF, you don't have 15 16 reactor coolant pumps running at the same time, so you 17 don't have any spray. Didn't they find at the 18 MR. THADANI: 19 Three Mile Island accident that for the high points 20 they had to have some vent capability to promote natural circulation? Does Oconee not have that? 21 22 MR. SIEBER: They have it. It's supposed 23 to work without only second level safeguards. into venting because of 24 have get design to 25 deficiencies in the basic design, then the design

basis is invalid. 1 2 MR. SCHIN: Right. The procedures are not 3 set up to rely on venting of that candy cane. Not for 4 operation of the SSF, no, they don't rely on that. 5 MR. DENNING: Now, when you talk about SSF powering, you mean that there's a control capability 6 7 only for certain of the electrical heaters from the SSF? 8 9 MR. SCHIN: Right, from the SSF. You can 10 switch over the power; certain heaters can be powered either from the SSF or from the normal power supply. 12 MR. DENNING: When you say powered, do you mean control? SSF isn't the power source, is just is a control capability? MR. SCHIN: No. It is a power source. When the plant is normally operating there's power from the normal 4160-4 kV switch gear out in the turbine building, there's some power that goes over to the SSF and normally powers the SSF. But when you're relying on the SSF in emergency conditions, it can

either use that power which is not well protected,

it's not safety grade power, or you can use the SSF

diesel generator to generate power and power the SSF

That's

So the SSF does generate its own

heaters.

and

power

capability.

these

11

13

14

15

16

17

18

19

20

21

22

23

24

25

design

the

1	electricity.
2	MR. SIEBER: On the other hand, if you
3	require more power than 70 kW, the SSF diesel may not
4	be able to provide that plus everything else.
5	MR. SCHIN: Well, it's probably could,
6	it's a large diesel, I think somewhere around 3,000
7	kW. It's like a normal emergency diesel that other
8	power plants have.
9	MR. SIEBER: But that's not part of the
10	design basis.
11	MR. SCHIN: But the wiring is not such
12	that the SSF diesel can power the other heaters, it's
13	not wired up to be able to do that.
14	MR. SCHIN: So anyway, this was considered
15	to be an inadequate corrective action violation
16	because the licensee had numerous prior opportunities
17	to identify it. It was not considered to be an old
18	design issue.
19	Any more questions about that?
20	MR. DENNING: The words inadequate
21	corrective action, is that what you would call the
22	root cause?
23	MR. SCHIN: That was the violation that
24	was cited by the NRC.
25	MR. DENNING: That's not a root cause.

1	MR. SCHIN: No, that's not the root cause.
2	The root cause would have been the original design
3	analysis was incorrect, the testing was not adequate
4	to pick this up. There were opportunities when the
5	operator should have noticed how many heaters, that
6	they were having to use more than the normal amount of
7	heaters to maintain pressurizer temperature, that type
8	of thing.
9	But there may have been multiple problems.
10	They had a problem with the spray valve leaking and
11	that masked it to some extent.
12	MR. BUNACA: Well, that may have misled
13	them.
14	MR. SCHIN: Right.
15	MR. BUNACA: When you say that there were
16	several opportunities to identify, this was prior to
17	March 2002, I guess.
18	MR. SCHIN: That's true, yes, sir.
19	MR. SIEBER: From day one.
20	MR. SCHIN: Right.
21	MR. BUNACA: I'm just asking because the
22	finding was it the 3rd quarter of 2003, so a year and
23	a half later you cite this finding, but actually the
24	finding that you have in 2003 is for this event in
25	March 2002.

1	MR. SCHIN: I'm not sure about the timing
2	of when we count findings against the action matrix.
3	It's not just when the licensee may have had an
4	inkling of a problem.
5	MR. WALLIS: It's an interesting
6	situation. I think we have other ones like this where
7	a thing has been going on for a very long time.
8	MR. SCHIN: Right.
9	MR. WALLIS: And then the licensee
10	eventually wakes up and says oh, we found this
11	problem, and so you penalize them, so there's no
12	incentive to find the problem.
13	MR. SCHIN: Right.
14	MR. WALLIS: It's kind of counter-
15	intuitive, really. There ought to be some reward for
16	-1 7t +1 1-7
	at least recognizing the problem.
17	MR. SIEBER: The reward is there was no
17 18	
	MR. SIEBER: The reward is there was no
18	MR. SIEBER: The reward is there was no civil penalty.
18	MR. SIEBER: The reward is there was no civil penalty. MR. WALLIS: If they'd waited even longer,
18 19 20	MR. SIEBER: The reward is there was no civil penalty. MR. WALLIS: If they'd waited even longer, there would have been more penalty?
18 19 20 21	MR. SIEBER: The reward is there was no civil penalty. MR. WALLIS: If they'd waited even longer, there would have been more penalty? MR. SHACK: If somebody else had found it
18 19 20 21 22	MR. SIEBER: The reward is there was no civil penalty. MR. WALLIS: If they'd waited even longer, there would have been more penalty? MR. SHACK: If somebody else had found it instead of them, they would have been hammered.

1 we were looking at was manning the SSF during a fire, 2 and this finding was NRC-identified during a triennial 3 fire protection inspection in February of 2002. And in this case the procedures for 4 5 staffing the SSF during a fire did not send operators to the SSF until after fire damage had caused a loss 6 7 of function of steam generator feed water or high pressure injection. 8 9 So they had already sustained considerable to the fire, and consequently, 10 damage due 11 pressurizer relief valves could lift many times and 12 potentially fail open, rendering the SSF inoperable. So the citation was for failure to meet 13 the fire protection licensing basis for properly 14 15 staffing the SSF during a fire before the fire damages the cables. 16 17 MR. WALLIS: Now, it becomes inoperable 18 because it can't function anymore or because there's 19 no access to it, or why is it inoperable? 20 MR. SCHIN: If you don't staff the SSF in time till after these various things fail -- for 21 22 example, if you wait till after you have a loss of all 23 feed water, what happens in a BMW plant when you lose all feed water to the steam generators -- they have 24

small steam generators and within about seven minutes

the steam generators go dry. 1 MR. THADANI: This is a TMI situation. 2 3 MR. SCHIN: Exactly. And then the RCS pressure jumps right up to the relief valve set point 4 5 and you start popping the relief valve. And then 6 within 16 minutes from popping the relief valve, the 7 is heating up and the bubble shifts on the 8 pressurizer over into the reactor vessel. 9 And so the problem is with delayed 10 staffing of the SSF, now you've got some repeated 11 popping of this relief valve for a number of minutes, and that increases the risk of failure of the relief 12 13 If the relief valve fails open, now the SSF 14 won't work. It only has a small reactor coolant system makeup pump that pumps about 30 gallons per 15 16 minute, and it can't handle any kind of leakage. 17 MR. WALLIS: It doesn't have the pressure? 18 MR. SCHIN: It does have the pressure, 19 it's a positive displacement pump, but it doesn't have 20 the volume. MR. SIEBER: So this would have been TMI 21 all over again. 22 23 MR. SCHIN: Could have -- right. 24 open PORV and no --25 MR. DENNING: Main control room assumed

1 inoperable. Main control room is assumed 2 uninhabitable. This is during an Appendix R 3 MR. SCHIN: analysis where you lose control of enough equipment 4 5 that by the design, the safe shutdown analysis, they should be staffing the SSF. 6 7 The idea, and in fact, specific in the 8 9 10

licensing basis was that they would send someone to the SSF -- the licensee made a commitment in a letter to the NRC that they would send someone to the SSF, when they had a fire in certain areas they would send someone promptly to the SSF to be standing by such that if you did lose control, had certain fire damage and lost all feed water to the steam generators, the individual would be at the SSF to promptly transfer control such that your relief valves are not going to be popping open multiple times.

MR. DENNING: Is that an action that you cannot perform from the main control room, or is it assumed that in this fire you lost the main control room?

From the main control room MR. SCHIN: you've either -- the problem comes in where the people are still in the main control room, it's habitable, but you've lost control of the plant because of fire

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

11

12

13

14

15

16

17

18

19

20

21

22

23

24

damage to control cables for various valves and pumps. So that the control room, you've lost either all feed water, main feed water and auxiliary feed water, or you've lost all high pressure injection capability.

Part of the problem is the SSF is designed such that when you go to the SSF to activate it, the first thing you do is transfer control to the SSF. It's like an auxiliary shutdown panel on the other plants, you have all these transfer switches.

And when you transfer control, now those valves and pumps are powered from the SSF and all the cables out in the plant that are subject to fire damage now are out of the picture.

But while they're in the picture before you throw those transfer switches, you could have spurious actuations of valves and potentially cause In other words, you don't want to wait till after you've had fire damage to the cables and spurious actuations until you throw the transfer switch because by then it might be too late.

So why is it only a white

It was only a white finding because our significance determination process came out that way, and it depends largely on the initiating

24

1	event frequency.
2	MR. WALLIS: Because it's so unlikely.
3	MR. SCHIN: Exactly. An initiating event
4	frequency.
5	MR. WALLIS: Because it sounds pretty bad,
6	the scenario you've described.
7	MR. THADANI: I think what you described,
8	to me, is very reasonable way to deal with this issue,
9	but does Appendix R allow you to also assume that
10	relief valve is stuck open or are you postulating
11	certain shorts that create that condition, and if so,
12	then why wait?
13	MR. SCHIN: No, Appendix R is a
14	deterministic design criteria.
15	MR. THADANI: Right, and that's why I
16	don't know if you can postulate.
17	MR. SCHIN: The way our process works,
18	first you have to have a finding where the licensee
19	did something that was contrary to the licensing basis
20	in this case. The licensing basis was that they send
21	someone to the SSF immediately. They didn't do that,
22	they were going to wait till after they had all this
23	fire damage. So that's the finding.
24	Now, when we look at risk, now we can
	1

consider the likelihood of a valve sticking open.

1	MR. WALLIS: So they can be lax if they
2	think that it's not risky? They didn't do what they
3	were supposed to do.
4	DR. TRAVERS: They have to fix that.
5	We're only talking about the classification of the
6	finding as a function of risk and the initiating event
7	probability associated with it.
8	MR. WALLIS: But it's interesting, they
9	obviously were not in compliance, they didn't do what
10	they should have done, but you said well it's okay
11	because it wasn't so risky.
12	(General talking.)
13	MR. SIEBER: I'm with you, I'm a
14	deterministic kind of person.
15	MR. WALLIS: You're a very bad boy but the
16	risk wasn't so bad so it's okay.
17	MR. SIEBER: I would skip that last part.
18	MR. BUNACA: One aggravating circumstance,
19	of course, is the fact that they did not identify
20	this, you found it.
21	MR. SCHIN: Right.
22	MR. BUNACA: I mean, do you account for it
23	when you make a determination of a white is it purely
24	based on the significant determination on a risk
25	basis, or do you have consideration of who identified

this problem?

MR. SCHIN: No. And the risk only considers if the issue had been -- the condition had been in place for various time periods, up to three days or up to 30 days or up to a year. If it had been in place for 10 or 20 years, that doesn't change the risk from the NRC's analysis.

MR. WALLIS: But it obviously does. If you multiply the risk per year by number of years, it was a bigger hazard.

MR. SCHIN: Right, but our process doesn't do that, we stop at one year.

MR. BUNACA: Now, if you had a number of findings, different findings, and was consistently the NRC is the one identifying these technical deficiencies, how would you handle it within the ROP? Does it become a cross-carrying issue? I'm not sure about that. Maybe it would be.

MR. SCHIN: Possibly. It has to do with how we document things and whether they could be cross-cutting issues, but basically we have this action matrix that once we identify something as say a white finding, it goes on the action matrix and it's on there for so long, for let's say a year, and it will drop off if it's been corrected and we've

inspected and verified that the situation has been corrected. So it could stay on for longer than a year.

And then if there's any other issues that come on the action matrix that are say white findings in the mitigating system cornerstone that are on during the same quarter, then that makes two that are on the action matrix at the same time and we have a 95002 inspection.

We've had a number of these at Oconee during the last few years.

MR. BUNACA: I mean, that says something, and I'm sure ROP really deals with it. I'm sure you have ways of dealing at some point with it, that's what I was looking for. I mean, it's like treatment of repeat events where you have an issue, supposed to be corrected, the correction is not adequate, so you have a repeat event again. Those are aggravating factors which are important, may be cultural issues.

MR. SCHIN: Right. Now, when we get involved, though, we identify what the finding is and they have to implement some corrective action. And then we go back for issues that are white or more, we have a follow-up inspection, and it's either a 95001 or 95002 inspection, and we look at what their planned

corrective action is and does it address the issue and 1 2 the causes for the issue, and then we determine if 3 that's adequate and we close the finding. the white goes off the action matrix. 4 But now, that doesn't prevent having some 5 other issue two months later that's another white 6 7 finding that may be in some different piece of equipment or different cause. 8 9 MR. SIEBER: Well, both of these are in 10 the same cornerstone which is mitigating system, so 11 it's not multiple degraded cornerstones. And you look 12 for cross-cutting issues if the root cause for 13 multiple degraded cornerstones is the same. this doesn't appear to fit into that. 14 15 DR. TRAVERS: You can get into trouble by 16 multiple or repetitive. MR. DENNING: What is the root cause here? 17 18 On this one, what do you consider the root cause to 19 be? Was it in the Appendix R analysis? 20 MR. SCHIN: The licensee did a root cause 21 analysis and we reviewed that, and they determined 22 that the root cause was multiple and it was because 23 back during the early 1980s when this Appendix R rule came out and they installed the SSF and they had first 24 25 procedures for the SSF, that the operators who wrote

1 up the first procedures incorrectly interpreted the 2 licensing basis. 3 MR. WALLIS: So it's a procedures problem. 4 MR. SCHIN: Right. MR. WALLIS: Because your description said 5 6 didn't send anybody to the SSF, but 7 procedures didn't ask them to do that. 8 MR. SCHIN: Right. But they had the whole 9 licensing basis and the letters at the time, and they 10 understood that there was what was called a ten-minute 11 rule for the SSF, that if you lost all of the feed 12 water function or all of the high pressure injection function that you had to man the SSF within ten 13 14 minutes and get it in operation. 15 Then the fire protection rules came out 16 and for manning the SSF in the event of a fire, they 17 apparently incorrectly assumed that that was the only 18 ten-minute window. But the description in the letter 19 to the NRC said that one of the concerns was hot 20 shorts and spurious actuations during a fire, and so 21 that they would man the SSF or send someone to the SSF 22 within ten minutes of the start of the fire so that 23 the person would be there before the hot shorts would

actuations that occurred, there would be someone

But if there were hot shorts and spurious

24

12

13

14

15

16

17

18

19

20

21

22

23

24

25

already at the SSF.

But the operators misinterpreted that and they didn't understand apparently that quote, tenminute window from the start of the fire to get to the SSF within ten minutes or promptly, and they just considered there was one ten-minute window.

MR. DENNING: And then to transfer to the

The licensing basis was just MR. SCHIN: that you have someone there promptly from the start of

Now, the licensee's root cause said that there were people at the general office -- most of their engineering in those days was at the general office, not at the plant, so their engineers were in Charlotte and the people at the plant were in South Carolina.

But the electrical engineers at the general office understood what the problem was but they didn't communicate with the people at the plant, the operators. The operators who were writing the procedure apparently went on their own and their root cause was they didn't understand.

What they said was that during the course of many years since that happened, there were multiple

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

1	missed opportunities to identify this, when they did
2	their own different inspections, other various NRC
3	inspections, audits. And this issue of timing the
4	staffing of the SSF was questioned on many different
5	occasions, at least half a dozen. And they had some
6	programmatic breakdown as to why it was not picked up
7	on half a dozen different occasions since the early
8	'80s when the problem originally happened.
9	MR. WALLIS: Is this the only BMW plant
10	you have in this region?
11	MR. SCHIN: No. We have Crystal River
12	too.
13	MR. WALLIS: Is the other one doing it
14	right?
15	MR. SCHIN: Yes, as far as we know. Well,
16	they don't have an SSF, so they have to staff their
17	auxiliary shutdown panel at some point. And to be
18	honest, that's an areas that we're looking at, the
19	timing of staffing the early shutdown panel and could
20	there be other problems with that, maybe there could.
21	We're looking at that in fire protection inspections.
22	MR. CARUSO: When you looked at the risk
23	for these two issues, not manning the SSF, but manning
24	the SSF and he pressurizer, did you consider because
25	they both related to the same starting scenario

synergistic effects between them in determining risk?

MR. SCHIN: Right, we did that. Bob, our senior risk analyst, looked at that and the risk of each one of these and how they would add together, and considered that to correctly assess the risk of both of these being in place at the same time, you would directly add the risk of each one, and it still came out white. It was a high white but it didn't go into the yellow column.

And he evaluated why that was appropriate, and it was because the one issue the concern was an early failure of the pressurizer or safety valve early in the scenario, and the other one, the concern was later in the scenario. The timing wasn't at the same time.

MR. McCREE: Just so that you know the depth of the risk reviews of STPs, when we have a potentially greater than green finding, the SRAs routinely share their analyses with the support risk group at NRR as well as research. And part of that process called the Significance in Enforcement Review Panel, the SERP, focuses primarily the risk analyses. This was a collegial conclusion we reached on the significance of this.

MR. SIEBER: Let me ask a question that

WASHINGTON, D.C. 20005-3701

1 you may know the answer to or maybe not. The agency 2 has a goal, a time goal as to how long it takes them 3 to go through the significance determination process which is sort of a performance measure on the senior 4 5 reactor analysts. How are you folks in Region II doing with 6 7 respect to meeting the time goal to produce the 8 answer? 9 DR. TRAVERS: Good question, and that's 10 the next presentation. MR. SIEBER: I should read ahead, or maybe 11 12 I did and that's where the question came from. (General laughter.) 13 14 SCHIN: Do you have any other 15 questions on that? Okay. We have team composition here. 16 It was a 17 small team. We had a lead inspector which was me, a 18 senior reactor analyst, and basic-qualified 19 inspector who was basically in training for doing this 20 type of inspection. The inspection itself, we had what we call 21 22 a bagman trip -- it's an advance information-gathering 23 trip to the site -- which was done by one person, me. I went for one day and collected all the information 24 25 that we requested.

1 Then we had a prep week in the office, one 2 week on site, and then we had one additional week in 3 the office because we didn't finish everything we needed to do while we were on site but we brought 4 5 enough information back with us to finish the review. The results of the inspection were that we 6 7 didn't have any new findings of significance that we identified. We saw that there were some opportunities 8 9 improvement in the licensee's process determining root causes, contributing causes, extent 10 of cause and corrective actions. 11 12 We concluded that overall, though, corrective actions that were already completed --13 14 which they had done to restore compliance, they had 15 changed the procedures and changed the number of pressurizer heaters that were powered from the SSF --16 17 and the corrective actions that they had planned, if well done, would have been adequate to address the 18 19 issues, and we closed the one open white finding. 20 Any other questions? 21 MR. SIEBER: Thank you very much. 22 MR. SCHIN: If not, I'll turn it over to 23 Scott Freeman. MR. FREEMAN: Good morning, everybody. My 24 name is Scott Freeman and I'm the senior resident at 25

Sequoyah and I'm going to talk about a white finding that occurred at Sequoyah where they had a binding in one of that RHR breakers. To start with a little background, TVA began using ABB Services to refurbish their 6900 breakers in 1996 and between then and 2000 they had numerous problems with these breakers. In fact, at one point they even removed ABB from the authorized supplier list.

It got to the point in September of 2000 that the refurbishment cost for safety-rated breakers reached \$31,000, and based on that, in July of 2001 TVA decided to replace the safety-related breakers with Siemens breakers and began changing the breakers out in November of 2001.

These new breakers were vacuum breakers manufactured by Siemens and modified by Wiley Labs to fit the existing cubicle, and also to make them safety-related.

What I have here is a sketch of the mechanism and you have to excuse the quality of this, I had to do this myself, but over here is a drawing of the breaker, this is the cubicle, and the breaker racks into the cubicle this way.

What I wanted to point out here was when

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 they started using Siemens breakers, problems began 2 almost immediately, and most of them were associated 3 with this MOC switch, the mechanism-operated cell 4 switch. That's this guy right up here at the top. 5 It sits in the top of the cubicle and is 6 operated by this long arm that goes to the bottom of 7 the cubicle, and that little horseshoe thing there mates up with a slot on this mechanism on the breaker 8 that operates off of the breaker itself. 9 10 Most of these problems were due to the extra force from this breaker. Because it's a vacuum 11 12 breaker, it operated about twice as fast as the 13 original which multiplied the forces on this switch up 14 here by four, and that's essentially where most of the 15 problems occurred. 16 MR. SIEBER: That's a cell switch. Right? 17 MR. FREEMAN: The cell switch is up here; 18 it's two of them in parallel. 19 Let's go to the next slide. That's the 20 breaker sitting on the floor, and over on the right there this is one of the buses, there's another one 21 across the room from it. 22 23 Next slide. That's actually the failed 24 breaker and they're looking at in the warehouse. This 25 part down here is where the problem occurred. This is

1 2 3 opens and closes. 4 5 6 7 8 9 occurred. 10 11 12 view of it. 13 elongated notch here. 14 One more. 15 primary goes in there, this

that operating mechanism that's on the breaker. This is the breaker operating shaft and there's a rod that runs here that slides this up and down as the breaker

Next one, that's a closer view of it. There's a slot, a notch right here that mates up with a part of the cubicle, and this spring absorbs some of the force, and then there's a bolt right here and an elongated notch. This is where the binding actually

Let's go to the next one. This is another You can see the slot here and the

This is the cubicle. is the secondary connection, and this is the MOC switch mechanism here. That notch we just showed you meets up right here, it operates this up and down which moves that rod.

One more. And this is the MOC switch up it the top of the cubicle and there's the rod coming up from below. This little device right here is a modification they made after they started refurbishing the breakers to absorb some of the force as the breaker opens.

This goes down when the breaker closes and

16

17

18

19

20

21

22

23

24

when the breaker opens this comes up, and they had 1 2 some problems with so much force here it was breaking 3 these things loose. Next slide. This is the list of problems 4 5 that we looked at that shows eight different failures starting in 2002 going all the way up to the bottom 6 7 one that is the one that actually got the white finding. 8 9 MR. BUNACA: Do they go back to ABB? They did eventually; I'll 10 MR. FREEMAN: come to that. That's their ultimate correction. 11 12 The problems started in 2002 and they started with problems found during initial checks with 13 the breaker in the test position and eventually ended 14 15 up, worked their way through the problems with the 16 breaker in connect position and showing up during PMT, 17 and eventually at the bottom there, an on-demand 18 failure with the RHR pump. 19 MR. WALLIS: If they failed to close in 2002 several times, why didn't they fix it? 20 21 MR. FREEMAN: They thought they did. 22 There were deeper problems. In fact, there were even 23 problems in 2003 that I didn't put up there because 24 they occurred during receipt inspection. 25 And this last problem, this one on the RHR

1 pump, was attributed to a phenomenon called 2 bradding -- which I'm going to get to in just a 3 minute -- and the one right above it was also. MR. SIEBER: It looks like the vendor 4 5 failed to sailor-proof the mechanism. That was part of it. 6 MR. FREEMAN: This 7 is the bracket on the failed breaker, this is where 8 the problem actually occurred, and this bolt right 9 here -- this is the side of the breaker, this bolt screws into the side of the breaker. It's a shoulder 10 11 bolt and it fits up tight against the side, and then 12 this bracket slides up and down in it and there's 13 washers here to take up the space. Well, what happens here is when 14 15 breaker opens, this thing goes down and the very top 16 of that notch hits on the bolt. It was hitting on the 17 bolt and it was causing it to mushroom out a little 18 bit, and you almost had to feel it, but it was just a 19 little bit, and Siemens called that bradding. So now when the breaker closes and it 20 21 tries to go up, this bradding acts as a drag force, 22 and if you et enough drag force, the breaker won't 23 latch, and that's what happened on the RHR pump. 24 The other thing that it depends on is the 25 tolerances between the bolt, the washers and the

1	bracket.
2	MR. WALLIS: What's it made out of, that
3	thing that mushroomed out?
4	MR. FREEMAN: Yes, it's a brass/copper
5	type.
6	MR. WALLIS: Something soft.
7	MR. FREEMAN: Yes, something soft.
8	But what we found was that there was no
9	specs on installation, not tolerance, no clearance, no
10	specs to make sure it would slide.
11	Next one. This is the same bracket
12	disassembled, and actually I'm going to pass these
13	around here. I have some black and white pictures
14	that go with it.
15	You can see right here at the top of the
16	slide, that's the bradding. And it's really hard to
17	see, the only way you really know for sure is run your
18	finger on it and you can feel it.
19	And on these ones going around, I have a
20	picture of this one plus the one previously from the
21	previous failure that they found in the Siemens shop,
22	and we'll come to the Siemens shop in just a minute.
23	MR. WALLIS: Is this the usual kind of
24	thing you get in these boxes?
25	MR. FREEMAN: This one is pretty close to

what ABB had, only it's modified just a little bit to 1 2 absorb the force. This part with the "V" on it 3 actually slides up and down also. 4 But you can see also on these washers up here, marks where the mushrooming had scraped the 5 washers, and there's a good picture of the shoulder 6 7 bolt. The breaker side goes right in this slot right here. 8 9 MR. WALLIS: That's a nice hard hammer 10 you've got up there. Right. Well, Siemens had 11 MR. FREEMAN: 12 actually identified this problem in April of 2004 as part of cause investigation for previous failures, and 13 they recommended TVA do inspections. 14 In fact, on those sheets going around, 15 16 there's ones that describe for the failed breaker and ones for the Siemens breaker they found in the shop. 17 They recommended a visual or a functional 18 19 inspection, and basically they said you could look at 20 it and look for it or you could functionally test 21 meaning you could take the mechanism apart and try to 22 operate it. 23 And they indicated that a visual was 24 somewhat subjective because bradding was normal, so 25 they told TVA that some bradding could be expected,

but they also stated that the functional would be more 1 2 accurate, and the best way is to disconnect the 3 mechanism and operate it through its full range of 4 travel. MR. SIEBER: Even if assembled correctly, 5 the end of that slot will always hit the shoulder on 6 7 that bolt. 8 MR. FREEMAN: Well, that was a little bit 9 It was doing it a lot, I'm not sure it debatable. 10 would do it every time. MR. SIEBER: It looks like it was designed 11 to do it. 12 MR. WALLIS: But you could make it out of 13 14 a different material that was less susceptible to 15 plastic defamation. 16 Well, you know, then you MR. SIEBER: 17 break the bolt. The problem was really in 18 MR. FREEMAN: 19 not anticipating that this force was there. 20 Next slide, please. This is what TVA did 21 about this. Because Siemens had said some bradding was normal, TVA chose to do a visual inspection. They 22 23 had 12 breakers in the warehouse as spare and they did a visual inspection on those by sliding a coin down on 24

that elongated slot to check for bradding and found

some minor bradding and said that was normal. 1 2 They inspected the ones in the plant, 6 in 3 the A train of ECCS and 12 in the B train by using a boroscope. The breakers remained racked into the bus 4 5 and they stuck a boroscope down the side and did a visual inspection with using maintenance personnel 6 7 Engineering wasn't present for the inspection only. and only reviewed one tape. They were recorded but 8 9 they reviewed only one tape. 10 MR. WALLIS: They used the visual inspection but you told us earlier it was rather hard 11 12 to see? 13 MR. FREEMAN: That's my opinion, almost impossible to see. Actually, it's my opinion 14 15 that had they done the functional test here, they would have found the problem, but they chose not to. 16 17 Next slide, please. So what was NRC doing up to this point? Well, we had been monitoring this 18 19 using our baseline modules but because TVA was 20 addressing the problems as they occurred, we had no 21 operability concerns, and what I have up here is a 22 list of the ones we did in 2003 and 2004. 23 The bottom one there, we started doing a

PI&R annual sample because the problems just kept

occurring and we wanted to see, well, what's their

24

corrective action program doing about it. In fact, we 1 2 had exited on that PI&R sample but pulled it from the report because they had two failures between the time 3 of the exit and the time the report went out. 4 After the RHR pump failed, we got a little 5 bit more concerned. DRS sent two inspectors up for a 6 one-week inspection, and they raised questions about 7 qualification testing. They asked them: Did you not 8 9 do the thousand endurance cycles that the triple E standards call for? 10 And the residents, after that happened, 11 12 started looking back for previous problems and we found that an identical problem to this had occurred 13 in June of 2003 where the corrective action document 14 15 said the bolt was too tight and the mechanism was And they basically at that time just 16 binding. loosened the bolt and went on. 17 MR. WALLIS: Even when it was new. 18 MR. FREEMAN: Yes, it was during receipt 19 20 inspection. Also, Chuck Castoe and Steve Cahill came 21 up and had a visit with TVA management to let them 22 know we were really concerned about it. 23 Next slide, please. At that point, TVA 24 really started looking for the causes. Up until this 25

point they had been laying off the cause on the vendor all along, saying vendor problems, vendor problems, vendor problems. But when we got more involved in it, they dug deeper and found some process problems. The this first one was engineering document change process. That's really their likefor-like engineering process. And they did that because it was basically easier to implement. didn't have to sign off a document every time they put one of these breakers in. And this essentially resulted in them not addressing the impact of the faster breaker operation. Because of that process, they didn't look at all these problems with the MOC

14

15

16

switch.

1

2

3

4

5

6

7

8

9

10

11

12

13

17

18

19

20 21

22

23

24 25

The other thing was they didn't hold the vendor accountable for qualification testing. were supposed to be getting documentation approving all the qualification, and the vendor didn't do it and they didn't push it. Consequently, the vendor basically did a technical justification in lieu of qualification testing on the original breaker.

So it basically was not MR. SIEBER: physically tested.

MR. FREEMAN: The first one -- they went through five iterations of design; the very first one

was not tested, after that they started doing them. 1 2 Next slide. Disposition. This was the 3 white finding beginning July 1, 2004: The RHR train 4 was inop for 14 days and the delta CDF came out to be 5 about 1.3E to the minus 6, and the main drivers were the reduced sump recirculation for small or medium 6 7 break loca because of the one RHR pump being out, and no sump recirculation for loss of 125V DC battery 8 9 board 2. 10 That's because losing that battery board would prevent the opposite RHR pump from starting, so 11 12 there would be no RHR. Next one. Conclusions. 13 This is a BWR. 14 MR. SIEBER: Right? 15 MR. FREEMAN: No, it's a PWR. It's an ice 16 condenser. 17 Conclusions. I put there the process worked because as the problems continued to get worse, 18 19 NRC attention got more focused and eventually the 20 licensee dug deep enough and found their own problems. MR. WALLIS: How long did that take? 21 22 MR. FREEMAN: Well, essentially from when 23 they started in 2001 until 2004, but we really started looking in 2003. 24 25 MR. WALLIS: So there's no expectation for

time on your conclusion that the process worked? 1 2 MR. FREEMAN: Well, that's why I have the 3 process didn't work up there. MR. WALLIS: Which conclusion is correct? 4 Well, they're both right 5 MR. FREEMAN: because actually the problem did get solved, but we 6 7 had a suspicion all along and the residents had a 8 suspicion all along that there were problems with 9 these breakers. But to really dig into and find out 10 would have required a very intensive 11 inspection, and in order to continue doing the 12 remainder of the baseline inspections, as long as we felt they didn't have any operability concerns, we 13 kept on doing the baseline inspections. It's kind of 14 15 a resource question. 16 MR. CASTOE: But it's also a 17 question. The previous failures were not greater than green, they were not risk-significant. When the RHR 18 pump failed on demand, that became risk-significant. 19 20 MR. FREEMAN: That's true. That was the first failure 21 MR. SCHIN: that was actually a component in service. 22 23 MR. FREEMAN: Where we had an operability 24 question. 25 And in NASA-speak, that MR. CASTOE:

1 became an out-of-family failure and that's what really got our attention because it was out of family from 2 3 other ones which we knew were not risk-Chuck Castoe, by the way. 4 significant. So by our 5 process, I think the process worked in terms of we engaged when the risk went up. 6 7 MR. WALLIS: This seems to be a problem. 8 When you've got breakers which are poorly designed, 9 they're going to fail, and they failed in various 10 modes and they failed tests and stuff, but nothing is done until it fails in some risk-significant mode, 11 12 although it's waiting to happen. MR. FREEMAN: Well, I think that's kind of 13 my dilemma when I sit and thing about whether this 14 15 worked or not. Well, not optimally, 16 MR. SCHIN: 17 If they had taken the initiative which we felt they should have, then optimally you would have 18 19 had resolution of this well before failure. MR. CAHILL: They did repair a lot of the 20 21 individual problems. They had a myriad of small 22 problems that cropped up but the root driver that 23 being the accelerated force of this different type of 24 breaker and the incompatibility. But they fixed each 25 individual problem and really never stepped back, and

1	like he said, they relied on the vendor and the vendor
2	fixed each problem, and they never stepped back and
3	said we really have a bigger compatibility issue here.
4	MR. WALLIS: Are there other breakers on
5	some other circuit which is even more risky that are
6	the same breakers?
7	MR. FREEMAN: Yes, they had these breakers
8	in all of their essential switch gears.
9	MR. WALLIS: So I would think the delta
10	CDF would be bigger if you said the breakers are going
11	to fail.
12	MR. FREEMAN: Well, this was the only one
13	that was actually inoperable.
14	MR. WALLIS: But the others are waiting to
15	be inoperable.
16	MR. SCHIN: They only had a small portion.
17	They were phasing these in, they weren't in all
18	safety-related locations.
19	MR. CAHILL: The other thing we did was
20	make sure they had one train.
21	MR. SCHIN: And we went through and
22	analyzed where each one of these Siemens breakers was.
23	MR. WALLIS: They could have been on every
24	train and then you lose the whole thing. It's a
25	common cause failure.

MR. CASTOE: We looked at it and NASA 1 2 looked at it and they moved breakers based on risk 3 significance. They took them out οf 4 components and put them in other components to keep the risk significance low. 5 MR. FREEMAN: Yes, after the RHR failure, 6 7 they moved them to where they had them only in one 8 train to eliminate the common cause. But again, that 9 was after the NRC really got looking at it. MR. DENNING: I think there's an important 10 aspect of this, though, if I'm understanding it 11 12 properly, that has something to do with the way we 13 license things versus the way Europeans license 14 things, and I don't know whether it's really that 15 deep. 16 But the problem always comes up when 17 you're taking out a breaker, the breaker that actually 18 was there originally, and you're replace it with some 19 other breaker and you have to have interface equipment 20 that's different, that's new. 21 FREEMAN: other MR. That was my conclusion. 22 23 MR. DENNING: And I'm wondering now and then that has to be made safety grade through 24 25 commercial dedication process.

1 MR. FREEMAN: Exactly what they did, yes. 2 And now, you don't do any MR. DENNING: 3 NRC doesn't inspection of what -the inspection of vendor facilities. Is that true? Like 4 5 in this case, how did they certify it to be nuclear-6 qualified? Did they do like a thousand cycles and this kind of stuff? 7 MR. FREEMAN: Well, it turns out they were 8 9 supposed to and TVA had a contract with Wiley to go 10 through this commercial grade dedication process, and they were supposed to include qualification 11 12 accordance with our Triple E standards. Siemens and Wiley interpreted that and 13 14 said, Well, using this standard -- and I can't 15 remember the number -- they can do a technical 16 specification in lieu of endurance testing. 17 didn't call them on that which they should have done, and they eventually admitted they should have done. 18 19 Had they done that, they would have done the thousand cycle testing and may have found these MOC switch 20 21 force problems. 22 MR. DENNING: The utility has to make 23 sure, it's their responsibility that whatever was done to qualify it was really done. 24 25 MR. FREEMAN: Yes, that's how I see it.

1 MR. THADANI: But the Vendor Inspection Branch also has a responsibility to at least go 2 3 through certain inspections. I don't understand this at 4 MR. WALLIS: 5 I mean, you're hammering a piece of brass with all. a piece of steel, someone must have at a very early 6 7 stage in design asked: Is it going to mushroom? Ι 8 don't understand how it ever got to be designed this 9 It seems very peculiar, but maybe I'm naive. Well, this was actually a 10 MR. FREEMAN: 11 first of a kind type situation. There are other place 12 that are doing this new breaker in existing cubicle situation; they all seem to be different. 13 14 the first one to put Siemens breakers in these ABB 15 cabinets, and because of these two process problems, they actually missed things they should have got. 16 17 result of MR. CARUSO: As this 18 experience, do you have a good sense that TVA watches 19 closely for unforeseen problems when it replaces old equipment with new equipment, especially from a 20 21 different vendor or a different design? 22 MR. FREEMAN: Well, I say they learned a I don't know if they're going to do it every 23 lesson. time, we just have to keep watching them. 24 25 MR. CASTOE: They have the right checks an

balances in their process, they just didn't follow what their own process says in this case. back in their corrective action program and looked at their process and found five other indications, five other modifications where they had used this process and did not follow their process.

MR. CARUSO: If they were replacing a lot of components in a large plant that hadn't operated recently, would you be concerned?

MR. FREEMAN: I would want to check, yes.

MR. CAHILL: This is Steve Cahill. Scott was saying about the first of a kind situation, TVA was alone in their false sense of security about this because -- if you saw all those Siemens breakers you saw at Browns Ferry, those used to be GE Magnablast breakers -- TVA had gone through Wiley and gotten those Siemens breakers to change out all those things in the same type of process, and that's not the first time Wiley had done that, they had done it at two other plants.

So they worked well, TVA had great success with Wiley using Siemens breakers, so they figured we can use them over here at Sequoyah to fix this problem. And what Scott was saying, that's the first time Wiley had ever done those Siemens breakers in an

19

20

21

22

23

24

ABB cabinet, and they got molded in that false sense 1 2 of security and figured they could use less than their 3 normal full design change process and they did the 4 like process, and apparently that was a poor decision in hindsight. 5 MR. SIEBER: Are these breakers unique to 6 7 the combination of the metal-clad switch gear and the breaker body itself, using one vendor for the cubicle 8 9 and another vendor for the breaker? They are unique and Wiley 10 MR. FREEMAN: 11 was supposed to modify them to make them fit, so you 12 could basically just roll the old one out and roll the new one in. 13 The reason they went for like-for-like was 14 15 because at Browns Ferry they didn't use like-for-like, 16 they had to sign off every time they changed a breaker 17 out, 200 or however many times it was, and essentially 18 they didn't want to do that again, they didn't think 19 That was the main reason. it was worthwhile. But do they think it would 20 MR. SIEBER: 21 have been worthwhile at this point in their history? 22 MR. FREEMAN: They do now, yes. 23 MR. SIEBER: Of course, signing off doesn't usually fix anything, it just implicates 24 25 somebody.

MR. FREEMAN: Well, there were some other 1 2 checks too that the system engineer was supposed to 3 do. MR. THADANI: So did they issue a Part 21 4 5 report on this? I don't think so, but I 6 MR. FREEMAN: 7 don't really know, I don't know for sure. CAHILL: You mean at Three Mile 8 MR. 9 Island? There was some other site that was doing the 10 exact same purchase of these breakers for an ABB 11 cubicle and TVA shared information with them, and they 12 had a lot of leverage with Wiley to get these things fixed. They basically weren't going to pay Wiley any 13 14 money now until the TVA problems were addressed, and 15 that was the only example of where this application 16 was going on anywhere else. 17 So to answer your question, the intent of 18 a Part 21 was addressed by that. 19 FREEMAN: Back to what you said 20 earlier, they have now removed all the Siemens 21 breakers from the emergency close positions in the bus 22 and intend to eliminate them completely by spring of 23 They're going back to the ABB breakers. next year. 24 And that's the end of my presentation. 25 Thank you.

1	MR. SIEBER: Thank you very much. Well
2	done.
3	MR. WALLIS: Well, it's a real object
4	lesson how one little tiny detail, the way one little
5	bolt behaves in a little slot can prejudice the safety
6	operation of an important piece of equipment.
7	MR. DENNING: And PRA didn't find it, did
8	it.
9	MR. FREEMAN: That was actually part of my
10	last conclusion was that these new type of designs can
11	result in unforeseen problems, and utilities really
12	need to watch that.
13	MR. RANSOM: Doesn't this equipment have
14	to go through a qualification program?
15	MR. FREEMAN: It was supposed to, yes, and
16	they did a technical justification in lieu of actually
17	operating it, the vendor did. They read a loophole in
18	the code and TVA didn't call them on it.
19	MR. DENNING: Well, it's a subtlety as to
20	what's like.
21	DR. TRAVERS: The other thing that's been
22	touched on here, I think, that's important is this
23	reliance on vendors and the question arose here who do
24	we hold responsible. Well, we hold the licensees
25	responsible and they'll be the ones who are subject,

potentially, to enforcement for matters of this sort, 1 2 and so they really need to be a little bit more proactive and involved, we believe, in these sorts of 3 endeavors. 4 5 MR. SIEBER: Well, strangely enough, we're back on schedule. Thank you very much. 6 7 MR. PAYNE: Good morning. Are we ready to 8 continue? My name is Charlie Payne. I'm the branch 9 chief for Engineering Branch ΙI which 10 responsibility for fire protection. Also, I have both 11 the regional SRAs under my direction. 12 I'd like to start off with covering the types of fire protection findings in general that we 13 have. You're probably familiar that Hemic and MT fire 14 15 wraps have been an issue for several years. We've got 16 four sites that have those. 17 We've had circuit analysis, associated circuit issues, manual actions in lieu of protecting 18 19 the cabling which is actually a subset of circuit analysis -- this is a pretty significant problem here 20 in Region II and I'll discuss that a little bit 21 22 more -- reactor coolant pump seal cooling, and safe 23 shutdown. The circuit analysis is also kind of tied 24 25 to safe shutdown because if we have problems with

1 manual actions, then their ability to achieve safe 2 shutdown is also in question. 3 And then we've got just miscellaneous 4 other things like smoke detectors in the wrong place 5 or oil retention dikes that don't handle the capacity of the tank. 6 7 MR. SIEBER: Do you have instances of where a licensee relies on manual actions but didn't 8 9 ask for NRC approval to do so? We have some occasion where 10 MR. PAYNE: the licensees did that but there's a high number of 11 instances where they didn't. And I'll cover that when 12 I get to the manual actions log. 13 14 The Hemic issue, it's a long standing one, it affects four plants. All four of these licensees 15 are going to NFPA 805, and so that's part of the basis 16 17 for why they're going to NFPA 805 but hopefully that 18 will get resolved when they do their transition. 19 The recent testing that NRR and research have done showed that these fire wraps don't meet the 20 one-hour and three-hour resistance rating. 21 22 has issued a draft generic letter for comment to basically say that this is a problem and require the 23 24 licensees to come up with a plan on how they're going

to address this issue, and they're going to track all

1 | of this nationwide.

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. THADANI: So do they declare these inoperable and pass some compensatory measures in place

That's right. MR. PAYNE: And most of these plants have had fire watches in place, but for example, Harris, we've got our triennial inspection team doing that. They were there for the first week last week, they're going back next week. And one of the things we pointed out to them is that they need to be looking at the bigger picture with compensatory actions. A fire watch isn't necessarily the only thing that they could do to help reduce the risk presented by this.

And also in Harris's situation, they disagreed with the results that we came up with on Hemic. They felt like their Hemic was different, and so they just did a series of tests of their own that I don't have the official results on, but they're trying to demonstrate that their Hemic wrap is actually adequate to maintain a one-hour and three-hour barrier.

MR. SIEBER: Didn't the agency do some tests at Wiley within the last year or so on Hemic, or did they

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

1	MR. PAYNE: Yes. We just completed some
2	testing and issued the results this spring, and that's
3	the basis of the generic letter.
4	MR. WALLIS: I have a couple of questions.
5	What does this stuff wrap and how widespread is it
6	within the plant?
7	MR. PAYNE: Depends on the facility. Some
8	licensees have used it to achieve train separation
9	when they had Train A and Train B.
10	MR. WALLIS: Twenty feet or something,
11	whatever the distance is?
12	MR. PAYNE: Right.
13	MR. SIEBER: Yes, and adjacent cable train
14	MR. PAYNE: But for example, Harris uses
15	it extensively in their plant, and so that's one of
16	the reasons it has a significant impact on them. But
17	McGuire and Catawba, they use it but not extensively.
18	MR. DENNING: Tell me something about 805?
19	Do they use 805 to get around having to suppose you
20	can't demonstrate one-hour and three-hour, we don't
21	believe the tests that they come up with, is the only
22	conclusion then that one would then have to replace
23	those wraps? Or can you use 805 in some way to get
24	around it so that you say you prove that it wasn't
25	risk-significant, or something like that?

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. PAYNE: I think you can prove that if it's not risk-significant, then you don't need to have the wrap there.

requirement Now. there's a also to maintain defense in depth, so I'm not sure how the interface between those will happen. But for example, if you don't have any ignition sources in this compartment but you do have both trains in there, Appendix R would say you've got to wrap them or separate them or something like that. But really, the likelihood of a fire is so small that they're meeting the requirement but it's really a waste of money and they think it's something that is not required. that's what 805 will be able to achieve for them.

MR. SIEBER: And then all you have to do is hope that there really isn't any ignition sources.

MR. PAYNE: That's part of what we do. We go through there and our new inspection process pretty much has us counting all the different ignition sources. We send our SRAs often out on the pre-inspection visit with our team and he walks around all the fires that we're contemplating and inspecting, and helps us decide on whether these are problems or not.

MR. POWERS: Then you have to depend on your hot work permitting requirements during shutdown

to ensure that there are no ignition sources in there. 1 MR. PAYNE: That is correct, we take that 2 3 into account. We'll look at their administrative controls and we'll talk with the senior residents and 4 5 the DRP branch chief. 6 MR. POWERS: The trouble, for instance, 7 when we were at Browns Ferry recently, they were 8 displaying their permitting requirements for work and 9 things like that, and not once did hot work show up on 10 any of their lists. MR. PAYNE: Well, it's certainly a factor. 11 12 When we come up with an issue, they try and one of their responses is okay, we've got an administrative 13 14 control, for example, that says hot work, the 15 likelihood is going to be less than what you're 16 assuming, and then we'll have to evaluate that aspect 17 of it. MR. POWERS: And it's just a persistent 18 19 problem, especially when you get to these things where 20 the argument is made that there are no ignition sources or there are no combustibles. It works either 21 way because trapped combustibles are just a consistent 22 23 problem during shutdown. 24 MR. PAYNE: The circuit analysis, it's 25 again another set of long-standing issues, and it's

primarily related to associated circuits and spurious equipment operations. So the licensees did a pretty good job of identifying these pieces of equipment, the main components are important for safe shutdown and we

need to protect or separate those pieces of equipment.

But the associated circuits, the stuff that helps make sure that that equipment operates correctly, the protective circuitry -- I can't think of what I wanted to say, sorry -- but it's associated with making sure that the equipment will work correctly. Those circuits weren't actually evaluated often by the licensees.

And what we have found is that sometimes those circuits run in the same area, were not protected, and if you had a fire in that, you would get some kind of spurious actuation that they weren't planning on that opened a valve that's normally closed and would divert flow away from where you need it to be.

RIS 2004-03 was issued to resolve this, and it gave the licensees a year of enforcement discretion to let them identify these issues, get them into their corrective action program, and start initiating corrective action. And there would be no risk evaluation done. In other words, no matter what

4 ||

the risk was, as long as they identified them and started getting a program to fix them, we would give them discretion.

We've only been able to close one finding to date out of all of our list of stuff, and that's because the licensee had actually gone out and corrected the issue, and so we gave them discretion on that.

Most of the other issues we have, the licensees have not been very aggressive in trying to come up with a resolution on it. Also, a lot of them are going to NFPA 805, and so they're saying when we go to NFPA 805, we'll fix this issue because it's identified and it will be part of the process.

Part of our concern in that is that some of these plants aren't going to be actually transitioning for another four or six years, so what are they doing in the interim. So when the enforcement discretion expires at the end of the year, we need to be having a plan on is this going to be adequate for the interim for those plants.

MR. WALLIS: This is something that comes up all the time when you've got something which plants should be doing and they're very dilatory about it, and it doesn't seem to be any sort of scale. I would

1 think that as they get later, they get penalized in some way and something happens. 2 Give them an 3 incentive to get on and do the job. 4 MR. McCREE: We do have that capability exercised it in other areas via our 5 6 enforcement policy. 7 MR. WALLIS: But it's up to your judgment to say now you've taken such a long time, we're going 8 9 to whip you into shape. 10 MR. PAYNE: One of the things to remember, though, is that for all of these issues, the licensees 11 12 have instituted compensatory actions. So from a risk 13 perspective, it probably is not an issue, but if you 14 start getting enough of them added together, then you start having to reevaluate whether there's really a 15 16 problem or not. 17 Next I want to talk about the manual 18 operator actions which, like I said, is a subset of circuit analysis, and it's often used to mitigate 19 20 spurious equipment operation in lieu of 21 protection, but on occasions they do have some risksignificant critical operator actions that they're 22 doing instead of trying to operate the equipment from 23 the main control room. 24

Licensees have long believed that it was

25

1	an acceptable alternative to Appendix R3G2
2	requirements, and Region II is one of the first that
3	identified that licensees were doing this and this was
4	a problem, and it's used extensively in Region II.
5	We've got some plants that have tens of
6	not hundreds of manual actions imbedded in their fire
7	protection procedures.
8	MR. WALLIS: This led to something. We
9	had a meeting on this just last year. Didn't this
10	lead to some agency action to clear this matter up,
11	all these plants that were taking credit for manual
12	action without getting permission and so on?
13	MR. SIEBER: Well, we wrote a letter on
14	it.
15	MR. WALLIS: We wrote a letter on that
16	too. Did that lead to some agency action?
L7	MR. SHACK: Well, there's a Nuclear
18	Newsflash that they withdrew that draft rule
19	yesterday.
20	MR. WALLIS: The rule isn't going to come
21	out after all?
22	MR. SHACK: They proposed to remove it,
23	they requested permission to do that.
24	MR. PAYNE: Originally there was a plan
25	for manual actions that were determined to be

1 feasible -- and we had established some proposed 2 criteria for measuring feasible -- that it would be 3 acceptable for those to be used in lieu of protection. 4 But there are a number of problems with that, one of 5 which is if you have enough of them from a risk 6 perspective, the likelihood of 100 percent success all 7 the time is pretty small, even if they are feasible. 8 We've been having problems at some of our 9 sites where we've identified non-feasible actions 10 where the operator just couldn't do the job. And like I said, they often have high human error probability. 11 12 MR. WALLIS: That was a concern we had, I remember, in our meeting with these folks that were 13 presenting this stuff about operator actions, and they 14 15 had to go down these stairs and along here and put 16 some ladder up and do something or other, and we were 17 thinking are they really going to be able to do this with the conditions which are current in the plant. 18 19 MR. And it may be only one PAYNE: 20 operator that they've got dedicated to doing that, and 21 if he breaks his leg climbing up that later. 22 Reactor coolant pump seal issues, to date 23 we have identified five Region II licensees that have this concern, and just to recap, if you lose reactor 24

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

coolant pump seal cooling, Westinghouse has shown that

25

for after 13 minutes or so you don't want to be restoring seal cooling or thermal barrier cooling to that seal because you could get a small break loca through the reactor coolant pump seal, thermal shock and it would cause the seal to dislodge or get tilted, you get popping, numerous different concerns.

And they issued guidance probably about 10 or 15 years ago that ended up getting implemented into the EOPs that if you have a station blackout, when you lose the reactor coolant pump seal cooling as a result of that, do not restore it when you get the power back because you don't know how the reactor coolant pump seal is going to perform, and you may not have your equipment needed to compensate for a small break loca.

And what they recommend is that you cool down the plant and get established and then get established and then do an evaluation on your reactor coolant pump seals before you restart.

Well, we found that some licensees didn't implement that guidance when you have fire that causes you to lose reactor coolant pump seal cooling, and often their mitigation strategy for the fire to achieve safe shutdown required them to go out there and come up with a way to restore charging.

Quite often that's the way they do it is

1 they'll protect one charging pump and that charging pump is going to go through the reactor coolant pump 2 3 They didn't isolate it. 4 And we had some licensees, as you'll see 5 on my slide here, that took 60 to 90 minutes to restore charging flow, and they just turned it back 6 7 on, went right to the reactor coolant pump seal, and we said, How do you know that that's not going to 8 9 cause a seal loca? And we processed one of them at Surry and 10 11 it turned out to be a white finding after we did an 12 extensive Phase 3 analysis of it, and the other four plants were still processing. Well, I take that back. 13 14 We did North Anna already which is the sister plant of Surry. Because of their plant configuration and the 15 way they implemented their fire procedures slightly 16 17 different than Surry, it turned out to be a green 18 finding for them. 19 MR. WALLIS: Do they all have the new seal 20 There was an improved seal material that material? 21 Westinghouse came up with. 22 MR. PAYNE: You mean the high temperature 23 seals? 24 MR. WALLIS: Have they installed that 25 material in all of these plants?

1 MR. SIEBER: That doesn't solve the 2 problem. 3 MR. WALLIS: But it's still an improvement, though. 4 5 MR. PAYNE: That is true. And when we first identified this issue, Surry was the first site 6 7 that we identified this with, our original risk analysis said just losing the seal cooling was going 8 9 to cause a small break loca, and after interactions 10 with NRR and Westinghouse, we came to the conclusion that the analysis with the new high temperature seals 11 12 will protect them adequately. If you just remove the seal cooling you should be all right. 13 MR. SIEBER: And leave it alone. 14 15 MR. PAYNE: Leave it alone, that's right. 16 And we have some licensees that that's their strategy 17 is they make sure that when they lose the seal cooling, they'll go out there and isolate it before 18 19 they restore their charging for later on. The 60 to 90 minutes is tied towards how 20 21 long before they lose pressurizer level, and when it 22 gets down to the bottom, they need to have charging 23 flow coming back. 24 MR. SIEBER: And that's based on tech spec 25 leak rates. Right?

Ţ	MR. PAYNE: That's right.
2	MR. SIEBER: Sixty to 90 minutes. Not a
3	seal leak.
4	MR. PAYNE: That's correct. Well, the
5	actual 60 to 90 minutes include tech spec and up to 25
6	or 21 GPM, the station blackout type of criteria that
7	we applied, but not the 200 or 480 GPM that risk
8	analysis had looked at.
9	MR. THADANI: If the licensees chose in
10	the past to deal with station blackout and the breaks
11	in the service water system where you lose seal
12	cooling most of the time, they would have taken care
13	of not only that issue but also this because they
14	would have had capability for some level of charging
15	fairly quick basis.
16	MR. PAYNE: That's right.
17	MR. BUNACA: So those plants that opted
18	for that option, they would be okay.
19	MR. PAYNE: Yes. If they could come up
20	with some way to quickly restore cooling to the seal,
21	they would have been all right.
22	For example, there are some plants that do
23	that, they recognize that they need to get cooling
24	back and their procedures prioritize some actions to
25	get the seal cooling done, and 13 minutes is generally

the criteria.

You did ask a question about NFPA 805.

All of the plants in the country right now that are going to NFPA 805 are in Region II. That's Duke Energy with their Oconee, McGuire and Catawba plants.

That's the order that they intend to transition to NFPA 805.

Recently Progress Energy has indicated their intent to transition to 805 with Harris first, then Crystal River, Robinson, and Brunswick.

We've gotten some indication that Dominion .

is interested in it, primarily, I think, from a Region

I plant, the Millstone site, but they would transition, obviously, all their plants if they do decide.

MR. SIEBER: Once you do an initial plant, each plant is easier for incorporation.

MR. PAYNE: And then Oconee and Harris are the private plants for the agency and what we'll be doing is actually sending some observation teams three or four times a year during this two-year transition to observe their process, to give them some feedback on are they heading in the right direction or not, what kind of issues do they have with that, and also help us to develop our inspection procedure that we'll

1	have to use with this new process.
2	They'll be getting enforcement discretion
3	during the transition, and that also applies to the
4	old issues that they have if they committed during
5	'05, so they were supposed to be intending to get some
6	more licensees interested in transitioning. So far
7	it's only been progress in Duke Energy.
8	But you do do a risk evaluation on these
9	fire protection issues, but trying to identify any
10	risks of red color or severity level 1.
11	MR. THADANI: But they have to do a fire
12	PRA, don't they, a good quality fire PRA?
13	MR. PAYNE: It is not required, actually.
14	MR. THADANI: I though the reg guide just
15	issued guidance on that.
16	MR. DENNING: I think that was our issue,
17	Ashok.
18	MR. THADANI: And I'm saying I thought the
19	staff agreed to modify the reg guide to include the
20	language, and that's the reason I'm trying to ensure
21	that's in fact what was done.
22	MR. SHACK: I think they agreed for that
23	specific change they would use a PRA-like process to
24	evaluate the change in risk, but you don't have to do
25	a full fire PRA, you only have to do a PRA-like

1	analysis that encompasses the change that you're
2	making.
3	MR. SIEBER: That's right, so you can end
4	up piecemealing it.
5	MR. PAYNE: The licensees that are doing
6	it now recognize the benefit of a fire PRA, and the
7	ones that are transitioning now have a plan of
8	basically developing a fire PRA. But it is not
9	required, as Mr. Shack said, to transition.
10	And the findings are going to be open
11	until the transition is complete, unless we come up
12	with a process to somehow track them outside of our
13	open items list.
14	I'll talk about SDP timeliness. That was
15	a concern that you had. Just a little bit of
16	background, fire protection and SSDPC were in the same
17	branch up until October of last year, and we shared
18	resources between those two inspections, and there's
19	15 required inspections a year in Region II.
20	And often what happens, the inspector that
21	was on the fire protections team would be going on an
22	SSDPC or another fire protection inspection.
23	MR. McCREE: Just to be clear, that's the
24	engineering inspection, that's Safety Systems Design
25	and Performance Capability inspection. These are the

two, quote, largest team inspections that we do under our Baseline Inspection Program, fire protection and the engineering inspection are SSDPC.

MR. PAYNE: So as a result, once we got the report issued, I didn't have any resource to dedicate to working on this, on any open items that we had unless they were simple. If they were pretty easy to disposition, we could get those processed through the SDP and issued either in the report or shortly thereafter.

But the complicated ones, for example, the safe shutdown issues, the reactor coolant pump seal issues, they took much longer to do, and I didn't have anybody to pull off of a team inspection to work on these issues.

It had some long-term effects too because if I did try and start somebody on that issue, they probably couldn't get done with it before they did need to get on the next inspection -- let's say he had four weeks to work on it -- couldn't get through it and then he'd be wrapped up on the next inspection.

And then if I had somebody else that had a month's worth of time available, that person would have to reinvent the wheel, if you will, trying to catch up to where the analysis was and understanding

1 the issue and then trying to make some headway. 2 It was very inefficient, we lost a lot of 3 continuity, and if I tried to keep one inspector on 4 it, then it was hit and miss as another inspector was 5 available over time. And I've got an example if you'd like to 6 7 go through that where that happened. 8 McCREE: So you've got a complete 9 picture, the level of effort required to evaluate the 10 significance of fire protection findings in general, 11 and particularly the complex ones, is rather 12 significant. The SDP Appendix D inspection under 13 Chapter 0609 is -- excuse me -- Appendix F, is very 14 resource-intensive. It requires a combination of 15 certainly our senior more seasoned inspectors to be 16 involved in the data gathering and analyses, as well 17 as the senior reactor analyst. 18 The picture that Charlie is painting for 19 you true one. We've gone through some organizational issues as well as a resource issue and 20 21 the work itself is quite time-consuming. So it takes 22 very deft management and very close coordination to 23 get it done in a timely way. 24 MR. PAYNE: And if you go to the next

slide, you'll see some of the things that Victor was

25

1	talking about. It's very difficult, the SDP is 24
2	pages long; most of the SDPs in the reactor area are
3	only a couple of page long and they're usually fairly
4	cookbookish. And then there's another 116 pages worth
5	of guidance that you don't just learn it and forget
6	about it, you're going to have to keep referring to it
7	because it covers different situations, so the
8	situation you're in, you're going to have to evaluate
9	each of those things independently.
LO	MR. POWERS: Are all your plants are
11	currently Appendix R plants?
12	MR. PAYNE: No. It's a combination.
13	MR. POWERS: You've got them all?
4	MR. PAYNE: Yes.
.5	And as Victor also mentioned, it requires
6	a lot of data collection. One of the things that we
ا 7	found out, and it's on the next page, Step 2.8 is very
L8	difficult to do. It basically says once you're done
L9	with figuring out what the fire risk is, now go back
20	into the reactor SDP and see if you've got any
21	equipment to help mitigate this issue.
22	Well, what a lot of people don't recognize
23	is that that means I've got to go find out where all
24	the cables are for all the mitigation equipment and
25	see if they run through this fire area and are

1 affected by the fire, because they obviously didn't 2 protect them because that's not part of their safe 3 shutdown strategy. 4 And trying to figure that out and then 5 also figuring out does this equipment really work or not is difficult. 6 7 And as Victor also mentioned, it requires 8 someone with a lot of plant operational understanding 9 to integrate all of that. Most of my inspectors are 10 electrical inspectors. We've taught them about integrated plant operations, but they haven't operated 11 12 they don't plant and know some 13 interrelationships between that. 14 only really have one inspector that has integrated plan operations, and 15 that's Bob. You've heard from him. I've got another 16 17 senior mechanical inspector that he does a good job of it but he's really a mechanical inspector, he's not an 18 19 ops inspector. 20 MR. McCREE: This goes to the earlier 21 question where we were looking at the succession 22 planning strategy. We asked about what that meant, how many, quote, fire protection experts we have. Charlie has one senior, quote, licensed

fire protection engineer, but Bob and McKenzie Thomas,

23

24

25

of

the

we've developed into fire protection experts, but what they also bring, and it's absolutely essential to implementing this inspection in a quality way is the integrated plant operations knowledge that allows us to not only find things but then evaluate the significance of it.

MR. PAYNE: In particular, the 90-day time limits goal that you were discussing with Bob earlier, it's really kind of unrealistic for complicated fire protection issues.

If you figure out all the different things that need to be done in order to process a greater than green finding to final determination, that 90-day goal, it basically requires the SDP to be done within two weeks. I have a hard time getting it done in two months, let alone two weeks, unless it's a fairly simple fire protection issue.

MR. POWERS: And this problem just doesn't go away, does it, and we started off with an SDP that was okay, to say the least, and now we've gone to one you can understand, you just can't do. It's like they don't want us to find fire issues in the plant.

MR. PAYNE: Yes, and we recognize that, and as a matter of fact, we just got done with a team going to V.C. Sumner to work on one of the reactor

coolant pump seal issues at V.C. Sumner, and we had on that team Bob, my senior reactor analyst, a reactor analyst from NRR, a fire protection expert from NRR, plus a contractor from Sandia who is probably the fire protection expert -- you may know him, Steve Nolan -- he was on the team.

And they went through to process these open issues that we had with V.C. Sumner, and it took them a full week of time, and the intent was to do a Phase 2 analysis so we could proceed on with the SDP, and they ended up doing basically a Phase 3 analysis because it was going to come out greater than green, it was going to be yellow or white, and then we'd have to do a Phase 3 probably to make sure it was right.

So they went ahead and worked on it and it came out the issues were green. And that was a success, but it required special organization to get this talent pool together to make it work.

On some of our simpler issues, for example, the smoke detector, it requires basically that you have very low degradation in order for you to screen it out green. If you look at Phase 1 of our SDP, anything that's greater than low degradation requires you to go to a Phase 2 analysis. And most of those issues will probably screen out in the Phase 2

fairly easily, like the smoke detector or the alarm, but the other ones that require you to go to the end to 2.8 which are the safe shutdown ones, they're the ones that take a long time to do.

MR. McCREE: We've had a significant amount of discussion with NRR and other folks in headquarters about the timeliness goal and the implications for fire protection, and I believe we're at a level of understanding now where our process is being changed. In fact, the metric will recognize that for some issues like fire protection, 90 days is really not realistic, that it would take longer, and in fact, the overall goal will be 180 days, but the process will take this into account.

We also had discussions last week -- in fact, we did our lessons learned on this visit at Sumner that Charlie was just talking about, and what did we learn from that that could help us to evaluate in a more timely manner other more similar findings. And developed the understanding that may indeed allow Steve Nolan to be involved in some other thorny findings that we have and areas where we need to train our inspectors and SRAs to help them to deal with other issues.

MR. POWERS: The problem with extending

1 the time is it doesn't eliminate your basic problem, you just don't have the manpower to do it, and bringing in contractors is great, except now on your succession planning you have to take into account contractors which is quickly becoming a formidable problem for you, and there's no obligation on the contractor to have succession planning there either. MR. McCREE: We also discussed that and the need to transfer or develop our own expertise such as that which Steve Nolan has, and that's going to take a while, but there's an integrated way to get there. One is sending people along with Steve to develop that knowledge and classroom training. need to have that in-house. MR. POWERS: Do you need it in-house or is the better solution is anything that you can screen out in an expeditious way -- and I mean literally in a day -- that you can toss over the fence to NRR and let them handle We have some ideas and we MR. PAYNE: tossed them around also in the lessons learned meeting that we had and we're making some proposals to them that would help expedite the SDP, simplify it,

particular with Step 2.8, and we're going to forward

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

that as a recommendation to change it.

And they were open to the idea, and they're going to evaluate and see if maybe that's something we could do where Step 2.8 is actually a go/no-go kind of step, and if we're okay with that, we'll go forward with that as being a final result, and if everybody in the circ decides that we need a better answer, this is a little bit too complex, then we'll commit to going to a Phase 3 type of analysis and committing the resources to doing that.

DR. TRAVERS: But having those resources centered as opposed to distributed.

MR. POWERS: And it's not a criticism of you but if every region tries to set up the kind of expertise and divert the manpower that's going to be required -- because you could send a guy and say work 180 days on this but you're going to do it one month, then two weeks off doing something else, then one month, you'll end up in the same problem. You'll come back and say it's going to take 270 days to do this. I mean, you'll never get out of this problem.

And if it's an integrated analysis where you have to look at plant ops, electronics, mechanical and fire all at the same time, you're never going to get there. I mean, it's not your fault, I'm not being

critical of you guys, it's just that they're asking you to do the infeasible here.

MR. SIEBER: It's an agency-wide problem, and as I see it, you have a moratorium on associated circuits, you have the introduction of 805, and in fact, the triennial exams have not covered every issue. You have operator manual actions to deal with. And to me it looks like the day after a huge snowstorm and there's a lot of work that needs to be done to get back to normal, and the question is how vulnerable are during the months and years that it will take to get to a backlog that is normal.

MR. SCHIN: And that's a good question. We addressed that in this recent meeting with the licensees that are going to NFPA 805 and what they have for compensatory actions for all of these non-conforming conditions that they're finding is fire watches. So like Oconee has fire watches roving all over the plant covering all the different areas.

So what we're going to have to get into when we next meet with them over the next few months is how many of these non-conforming conditions, we have to look at what type of things they are.

In all cases, a fire watch may not cut it.

You may have, even after you have the fire watch,

1	there may be some net increase in risk, and so you
2	don't want to have too much of that.
3	MR. SIEBER: You know, a fire watch is a
4	guy with a day's training and eight bucks an hour, and
5	he may be a roving fire watch but he's watching five
6	fire areas or ten fire areas.
7	MR. SCHIN: Right, exactly.
8	MR. SIEBER: To me there are better ways
9	to do that
10	MR. SCHIN: Right, but by our regulations
11	they're not clearly required.
12	MR. SIEBER: It says it's okay.
13	MR. POWERS: This story on the SDP for
14	fire has just been going on since the start of ROP,
15	it's just a very difficult area and it does not seem
16	to me that it's getting the kind of management
17	attention at headquarters that it deserves. I mean,
18	they keep coming up with "Well, it satisfies this" all
19	the time. I mean, I think you guys have got a real
20	problem.
21	MR. McCREE: What we have is this tool
22	that, as Charlie indicated, is good for screening
23	relatively straightforward issues. It's a bit more
24	resource-intensive when the issue is more complex.
25	We've been working very closely with NPR on this

1	issue, as I indicated, and the resources and
2	timeliness, all those factors, we have understanding
3	and we have what we have, and we'll just work our way
4	through it.
5	MR. POWERS: Like I say, I think you guys
6	are doing better than I would have ever expected.
7	Actually, I'd expect you to be screamingly angry over
8	this.
9	MR. THADANI: There is a focus on the
10	timeliness issue at headquarters, but I'm not
11	convinced of this focus on really understanding how
12	complex this is.
13	(General talking.)
14	MR. POWERS: I mean, I think that's the
15	take-home lesson here
16	MR. McCREE: It's the reason why we
17	leveraged this visit at Sumner is to develop that
18	understanding and have the lessons learned.
19	MR. McCREE: It's going to take what it's
20	going to take to get a quality answer, and to get a
21	quality answer, I think there needs to be a broader
22	understanding of what it takes to get there.
23	MR. POWERS: Well, you do this trip to
24	Sumner and you come up with some interesting
25	conclusions, I think it will be useful to us if you

	131
1	come share it with us like at a Fire Protection
2	Subcommittee or something like that and just focus in
3	on this whole step here. I mean, I think that would
4	fun. Don't you, Richard?
5	MR. DENNING: Absolutely.
6	MR. POWERS: And see what the strategy is
7	for handling this.
8	MR. WALLIS: I would like to know what's
9	going on in the other regions. Presumably they have
10	the same situations.
11	MR. SIEBER: In three more years we'll
12	know
13	MR. PAYNE: The NEI is sponsoring a fire
14	protection information forum next week, and all the
15	branch chiefs, except for one, and some NRR
16	representatives are going to be there. And while
17	we're there, I've asked them to have a meeting to talk
18	about this, because I've got the same impression that
19	are we an outlier, are we the only ones that have
20	problems or not.
21	And just anecdotally, I found that at
22	least Region IV has a long list of fire protection
23	issues.
24	MR. POWERS: Based on historical evidence,
25	you guys are better prepared in fire protection than

1	the other regions, if you ask me.
2	MR. PAYNE: I would like to try and get
3	that feedback from them as well.
4	MR. SIEBER: You're on easy street,
5	relatively speaking.
6	(General laughter.)
7	MR. PAYNE: We'll, we'd at least like to
8	think that we've got a plan for moving forward, it's
9	just that it's not something we can implement
10	instantaneously.
11	MR. SIEBER: Well, there's a tremendous
12	amount of work and it's complex work, and I think
13	those are the two keys, and I think that there's a
14	failure to recognize how important fire protection is.
15	If we add all modes, all pipe PRAs, all of a sudden it
16	would stick out, but fire is probably in the same
17	realm of importance as normal day-to-day operation or
18	shutdown operation. That being the case, maybe the
19	resources need to follow.
20	MR. WALLIS: What needs to happen in
21	Washington to solve this problem.
22	MR. PAYNE: The interesting thing is if
23	you look at the amount of time they expect us to spend
24	on the triennial inspection, it's 200 hours every
25	three years, we spend well over that because that's

1	assuming three inspectors for two weeks basically, and
2	I need more than three inspectors on that team to do
3	an adequate inspection.
4	And that's what I tell them, we need to
5	focus on finding safety-significant issues, we'll work
6	out the risks afterwards. It's not something we can
7	ignore, obviously, but he priority is making sure that
8	the plants are safe.
9	MR. SIEBER: My impression, just working
10	with a few licensees, is the licensees aren't prepared
11	from a documentation standpoint to make your job
12	efficient.
13	MR. PAYNE: That is true, we have found
14	that out during our inspections.
15	MR. SIEBER: I mean, it's one of these
16	paper-shuffle deals.
17	MR. SCHIN: My experience is that our
18	inspection procedures and the number of hours for the
19	inspectors for two weeks would work out fine if we
20	didn't have any findings. So our problem is we're
21	always having findings.
22	MR. PAYNE: I've got just a couple more
23	slides, if you don't mind.
24	The next slide is just a current status.
25	We have 31 open items, seven of them are new this

year. That doesn't include LERs that the licensees open if they've got a fire protection issue. Seventeen of them are tied to plants that are going to NFPA 805; four of them are Hemic, as I mentioned; seven circuit analysis issues; seven of them we're working pending SDP; and three of them are potentially greater than green.

That's the Turkey Point findings that are on headquarters' tracking list and I've got my senior reactor analyst and the project engineer from DRP at Turkey Point today. They're working on identifying the information they need to do this SDP, with the goal of completing it by the end of September.

We have four other issues that are pending additional inspection or information from the licensee. I've got eight of them that we've resolved but we just haven't documented them in the report, we're in the process of doing that. And one of them we've done a regulatory conference and we're pending the final significance determination which we hope to do next Tuesday.

Corrective actions, we've covered some of this. We've obtained help from DRP as well as NRR to help us work on these open items. We've obtained additional contractor support in FY '06 to free up

some of my inspectors to work on SDP stuff.

Also, as we staff up we're planning to have two separate fire protection inspection teams, one team is doing an inspection, the team that just finished is working on any open items, any URIs that they identified, and they'll have 6 to 8 weeks to work on this and it will be the whole team that's going to be available to do that.

MR. McCREE: Going back to contractor support very briefly. You mentioned earlier on the engineering inspection, the SSDPCs were going from about five a year to 18. In the past, Charlie would get one, maybe two contractors a year to train for the fire protection school program.

We've got NRR's attention and they're going to give us four this year which is twice. It was very difficult but we've convinced them that that's needed to not only address a backlog but to allow Charlie some flexibility in scheduling his inspections.

MR. PAYNE: Correct. Right now I don't have the staff to do two full teams independently. Plus like this year, we're still supporting the engineering inspections, but starting this coming fiscal year, we've got dedicated people, I'm staffing

up, and while I'm still staffing up, I've got the 1 2 contractors to help us out. 3 And part of that, like I said, we're 4 restricting our support of other inspections to really 5 high priority issues like special inspections or AITs, that kind of thing. 6 7 And that's all I have. 8 MR. SIEBER: I think we're at the end of 9 the agenda. 10 DR. TRAVERS: We're very suspiciously on 11 time, Chairman. I think you laid down a challenge to 12 us, and perhaps to the committee as well. We're on time here. 13 14 I guess I'll just sum up by saying I think we've covered a pretty broad range of topics. I think 15 they were arranged in advance with your staff so there 16 would be items that the committee was interested in. 17 18 And so we certainly do appreciate the 19 opportunity to have a dialogue with you, not just 20 today but on an ongoing basis as is appropriate for 21 any of the issues at hand. Whether they be Browns 22 Ferry or wherever, we can hopefully support your 23 activities by providing some of the insights that we 24 gain from our conduct of the inspection program here in Region II and throughout the regions, actually. 25

1 SIEBER: I can tell you, without reservation, that the meeting and the reports that 2 3 your folks gave us are excellent, and they really add to the perspective that we have in the functioning of 4 5 the agency, because in the regions this is where the 6 rubber meets the road. And individual inspectors and 7 branch chiefs see in more detail the issues and the problems and give us a very good perspective of the 8 9 kinds of things that we ought to be focusing on and 10 directing our attention. 11 So I, personally, and my colleagues truly 12 appreciate your spending the effort to be our hosts, 13 and I'm sure that we will meet again, perhaps pretty 14 soon or at least with some or your personnel because 15 there are a lot of activities that are going on. 16 I also think, having met a number of your 17 folks either here or on other occasions, that you have 18 an excellent staff and very talented and very 19 knowledgeable, and I think that's a tribute to the 20 many good years of management of the Region II office. So I wish, on behalf of my colleagues and 21 22 the full committee and our staff, to thank you very 23 much for hosting our visit here. 24 DR. TRAVERS: It was our pleasure.

you could come.

25

1	MR.	SIEBER:	Thank	you.	
2	And	with th	at, I wou	ald like to	adjourn the
3	meeting.				
4	(Whe	ereupon,	at 11:50	0 a.m., the	meeting was
5	concluded.)				
6					
7					
8					
9			٠		
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

Name of Proceeding: Advisory Committee on

Reactor Safeguards

Plant Operations and Fire

Protection Subcommittees

Region II Visit

Docket Number:

n/a

Location:

Atlanta, GA

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and, thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

Laurel Stoddard Official Reporter

Neal R. Gross & Co., Inc.

. Cree + Shea division of reactor safety & LS MATRIX - SUCCESSION PLAN

SKILLS NEEDED	STAFF NEED	STAFF ON BOARD		2005			2006			2007		PROJECTED NEW HIRES	SUCCESSION ACTION PLAN
			E	M	Ļ	E	M	L	E.	M	L		
STRUCTURAL ENGINEERING	2	2	1. TO	1(1)		1	1(1)		1/1/3 1/1/3/1	1(1)			Qualify EC in 2005 Transfer a DRP Insp to DRS in 2006
		Non-DRS 1											Train EC on ASME B31.1 Piping in 2005
ILRT /LLRT /Containment	1	4	1	1(1)	2	1	1(1)	2	1.13	1(1)	2		Train EC in 2006
ISFSI	1	3	(1),	1(1)	1.	1	1(1)	1	1- ::	.1(1) ∷ <u>_</u>	1		Train EC in 2006 (Soil Engineering)
SEISMIC	2	4	1	1(1)	2	1	1(1)	2	1	1(1)	2		Train EC on GeoTech Eng in 2005
Heavy Loads	2	4	100	1(1)	2	1	1	2	, i **;	1/1	2		
METAL. ENGINEERING	4	4	3		1	3		1	3		15.	Hire ISI Eng in 2005	Qualify EC as Eng Inspector by 7/06 Qualify EC as Eng Inspector by 8/06 Train EC on Stainless Steels in 2005
Erosion/ Corrosion/MIC Mechanisms	2	4	3	1(1)		3	1(1)		3 3 4 4 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	1(1)			
NDE / ISI / Welding	3	7	4	1(1)	2	4	1(1)	3	4	1(1)			Train ECs in ASME Sec IX in 2005 Train EC in Metal Welding in 05 Train EC on UT Level 1 in 05 Train EC on UT Level 1 in 2005 Train EC on UT Level 1 in 2005 Train EC on ASME Sec IX and Sec XI in 2005 Train EC on ASME Sec XI in 05 Train EC on ASME B31.1 piping in 2005 Train EC on ASME B31.1 Piping in 2005
Non-Code Repairs (GL-90-05)	3	4	2	1(1)	1	2	1(1)	1	2	1(1)*	1 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3		
BWR Internals	3	3	.1007		2	1		2	10	r je jajir a jyrir si	2		
Steam Generators	3	4	3	1(1)	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	3	1(1)	1	3	1(1)	1	·	Train EC on Zetec Eddy Current in 2005

SKILLS NEEDED	STAFF NEED	STAFF ON BOARD		2005			2006			2007		PROJECTED NEW HIRES	SUCCESSION ACTION A
	د دو وځودې شد خومه د رو وغواو د وليمياړ د د رو وغواو د	الم المراجع المراجع المستقدم المراجع المراجع المراجع المراجع المراجع المستقدم المراجع المستقدم المراجع المراجع المراجع المراجع المراجع المراجع المراجع	E	M	L	E	M	L	E	M	Ľ.		
MECHANICAL ENGINEERING	7	12	6	2(2)	4	6	2(2)	4	6	2(2)	4	Hire Mid-Career Mechanical in 2005	Qualify EC as Eng Insp 6/05 Qualify EC as Eng Inspector 6/07
												Transfer EC From NRR in 1/05	
Design and Operation of Pumps/IST	4	7	3	2(2)	2	3	2(2)	2	3)	2(2)	2		Train EC on ASME Pump/Valve in 2005
Valves/IST	4	9	3	3(3)	3	3	3(3)	3	3	4(4)	3		MC Attend MOV/AOV Conf in 2005 Train EC on ASME Pump/Valve in 2005
Heat Exchangers	2	10	3 , 3	4(4)	3	3	4(4)*	3	3	4(4)*	3		Train EC in Service Water Eng in 05 Train EC on Service Water Eng in 2005
Water Hammer	2	3	1	1(1)	1	1	1(1)	1	1	1(1)	1.		Train EC on Waterhammer in 2005
Safety/Relief Valves	3	3	1	1(1)	1 75.5 20.25	1	1(1)	1	1	1(1)	1		
Emergency Diesels	2	4	.2	1(1)	1	2	1(1)	1	2.	1(1)	18. 18.		
Spent Fuel Pool Cooling	2	5	3	2(1)		3	2(1)		3 N	2(1)			
HVAC	2	2	` 2 5, 1.	1(1)	1		1(1)	1	1.50	1(1)	1		
Coatings	2	3	1	1(1)	1	1	1(1)	1	1 %3	1(1)	1		
Freeze Seals	2	3	2	30 m	1:	2		1	2	N3 /2	1 ,		
Governors	2	4	2		2.7	2		2	2	gi.Yr	2		
Bearing Lubrication	2	4	2	1(1)		2	1(1)	1	2	1(1)	1 1		
Ice Condensers	1	1	State of the	entringer.	1			1			157		

SKILL() NEEDED	STAFF NEED	STAFF ON BOARD	A Town of Son	2005		The state of the s	2006	J		2007	And you have	PROJECTED NEW HIRES	SUCCESSION ACTION (
			E	M	L.	(A)	M	ĽŅ.	E	M			
		Non-DRP											
		2								1 1 1 1			
ELECTRICAL ENGINEERING #	5	10	6	2(2)	1.	6	2(2)	1	6	2(2)	1	Hire Mid Career in 2005 Transfer DRP Insp 1/05	Qualify EC as Eng Inspector 6/06 Qualify EC as Eng Insp 7/06 Qualify EC as Eng Insp 7/05
Distribution Systems (Breakers/Switc hgear)	2	6	3	2(2)	1	3	2(2)	1	3	2(2)	1		Train EC in Power Sys Relays in 2005 Train EC in Substation Eng in 2005 Train MC in Power Cables in 2005 Train EC in Substation Eng in 2005 Train EC on Prot Relaying in 05
Instrumentation and Controls - Digital and Analog	2	7	4	2(2)	(10)	4	2(2)	1	4	2(2)	1		
V/V of Software	2	5	3	(1(1));;s	1	3	1(1)	1	3	1(1)	1		•
Instrument Setpoint Calculations	2	5	2	2(1)	1.7	2	2(2)	1	2	2(2)	1		
EQ	2	3	11:1	1(1)	1 ;	1	1(1)	1	.1	(1(1)	1		
MOV/SOV	2	4	2	1(1)	10 200	2	1(1)	1	2	1(1)	16		EC attend AOV/MOV Users Group Conf in 2005
Batteries	2.	2 ·	1000	1		1	1		1	4.00	or A. ₹1.		
Logic Circuit Testing (GL96-01)	3	3	11.33. 32.22	1(1)	1	1	1(1)	1	1	1(1)*	1 3		
EHC (Turbine Control)	1	1	वेश्वीहरू अस्त्रिक्	1(1)			1(1)		25 ps.	.1(1)			
Maintenance Rule	2	4	2	1(1)	1	2	1(1)	1	2	1(1)	1.1		

.

• •

.

.

SKILLS NEEDED	STAFF NEED	STAFF ON BOARD		2005			2006 (1		2007		PROJECTED NEW HIRES	SUCCESSION ACTION F
			E	M (35)		E	M	L	E	M	L		
RISK ANALYSIS	2	2		2(1)			2(1)			2(1)			Train MC on Quant Risk/Reliability in 2005 Train MC on PRA Application in 05
Risk Expertise	3	1			1			1		12 3 X	1		
		Non- DRS						 -					
		2					,						
NUCLEAR ENG. (Reactor Physics)	1	5	2 1	3(2)	1	1	3(2)	1	1	3(2)	1 \\ \(\) \	Hire Co-Op in 2005 Hire Co-OP in 2005	Qualify EC as Eng Insp 6/06
Operations Inspectors	2	3		2(2)	1		2(2)	1		2(2)	1:		
EOP's(Excludes OL personnel)								<u>.</u>				_	
OPERATOR LICENSING	9	9	(1 650 3476	8(3)		1	8(3)			8(3)		Hire Two Examiners in	Qualify MC as Examiner 5/05
EXAMINATION		(Non-OL)			***		}					2005	
		2				<u></u>							
Licensing Assistant	1	1			1			1			1		Train a backup LA in 2005
HEALTH	6	8	3	4(1)	2	3	4(2)	3	1	4(2)	3		One Insp attend the REMP Conf in
PHYSICS		Non-PSB1											2005
	·	3											

.

.

SKILLS NEEDED	STAFF NEED	STAFF ON BOARD	A Company of the comp	2005	The serve that the se		2006			2007		PROJECTED NEW HIRES	SUCCESSION ACTION P.
		Bandania (k. 1944), spila Nama (k. 1944), spila Nama (k. 1944)	E	M	L.	E	Milita	L		M (S)	Ľ		
CHEMISTRY	1	2		2(1)			2(1)			2(1)		·	Train MC in RadioChem in 2005
EMERGENCY	2	2	2(2)	2(2)			2(2)			2(2)			
PLANNING		Non-PSB2										·	
FIRE PROTECTION	3	5	2	5(2)		2	5(2)		2	5(2)		Hire Co-OP Fire Protect Engineer in 2005 Hire Mid-Career Fire Protection Engineer in 2005	Train MC in NFPA Sprinklers in 2005 Train EC on Fire Alarm Codes in 2005 MC attend NFPA Sprinkler Seminar in 2005 Two Insp to NEI Fire Prot Conf in 05
10CFR50.59	1	4	3	\$1.55g	1	3		1	3-3		1.5		
License Renewal	4	5	1	1(1)	3	1	1(1)	3	1 (2.5)	1(1)	3		
Pre-Op Testing	1	1		1.			1			1	75. 1 75. 1		
PHYSICAL SECURITY .	8	6		6(1)			6(1)			6(1)		Hire a Security Inspector in 2005	Qualify MC as Security Inspector 5/05 Qualify MC Security Inspector 5/05 Train MC in Adv Security in 2005

E: Early Career (EC); Less than 40 years Old
M: Mid Career (MC); Greater than 40 years Old and less than Optional Retirement Eligible: () / *; Eligible for Early Retirement
L: Late Career (LC); Eligible for Optional Retirement

Back to Index