

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.18</p> <p style="text-align: center;">-----NOTE-----</p> <p>This Surveillance shall not normally be performed in MODE 1, 2, 3, or 4. However, this Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the unit is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.</p> <hr/> <p>Verify that the automatic sequence timing relays are OPERABLE with each load sequence time within $\pm 5\%$ of its required value and that each load is sequenced on within the design allowable time limit.</p>	<p>24 months</p>

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.18</p> <p>-----NOTE----- This Surveillance shall not normally be performed in MODE 1, 2, 3, or 4. However, this Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the unit is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.</p> <p>-----</p> <p>Verify that the automatic sequence timing relays are OPERABLE with each load sequence time within $\pm 5\%$ of its required value and that each load is sequenced on within the design allowable time limit.</p>	<p>24 months</p>