

TABLE 3.3-10 (Continued)

ACCIDENT MONITORING INSTRUMENTATION

| <u>INSTRUMENT</u>                                | <u>TOTAL<br/>NO. OF<br/>CHANNELS</u> | <u>MINIMUM<br/>CHANNELS<br/>OPERABLE</u> |
|--|--------------------------------------|--|
| 14. Intermediate Range Neutron Flux              | 2                                    | 1  |
| 15. Intermediate Range Neutron Flux Rate         | 2                                    | 1  |
| 16. Containment Isolation Valve Position*        | 2/Penetration                        | 1/Penetration                            |
| 17. Containment Enclosure Negative Pressure      | 2                                    | 1  |
| 18. Condensate Storage Tank Water Level**        | 2                                    | 1  |
| 19. Reactor Vessel Level Indication System       | 2                                    | 1  |
| 20. Containment Sump Isolation Valve Position*** | 2 (1 per valve)                      | 1  |

\*Applies to penetrations with 2 active valves in series. These valves are moved to the closed position by automatic signals.

\*\*Calculated on basis of pressure sensed at suction to the Emergency Feedwater Pumps.

\*\*\*Applies to CBS-V8 and CBS-V14 open indication on UL indicators.