

INDEX

SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

<u>SECTION</u>	<u>PAGE</u>
<u>2.1 SAFETY LIMITS</u>	
2.1.1 REACTOR CORE.....	2-1
2.1.1.1 DNBR	2-1
2.1.1.2 DELETE	
2.1.2 REACTOR COOLANT SYSTEM PRESSURE	2-1
<u>2.2 LIMITING SAFETY SYSTEM SETTINGS</u>	
2.2.1 REACTOR TRIP SETPOINTS.....	2-2

TABLE 3.3-6

RADIATION MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ALARM/TRIP SETPOINT</u>	<u>MEASUREMENT RANGE</u>	<u>ACTION</u>
1. AREA MONITORS					
a. Fuel Storage Pool Area					
i. Criticality and Ventilation System Isolation Monitor	4	*	≤ 20 mR/hr	10 ⁻¹ – 10 ⁴ mR/hr	22
b. Containment Isolation	3	****	≤ 90 mR/hr	1 – 10 ⁷ mR/hr	25
c. Control Room Isolation	1 per intake	ALL MODES	≤ 2x background	10 ⁻⁷ – 10 ⁻² μCi/cc	26
d. Containment Area – Hi Range	1	1, 2, 3 & 4	Not Applicable	1 - 10 ⁷ R/hr	27
2. PROCESS MONITORS					
a. Fuel Storage Pool Area Ventilation System					
i. Gaseous Activity	1	**	***	10 ⁻⁷ – 10 ⁻² μCi/cc	24
ii. Particulate Activity	1	**	***	1 – 10 ⁶ cpm	24
b. Containment					
i. Gaseous Activity RCS Leakage Detection	1	1, 2, 3 & 4	Not Applicable	10 ⁻⁷ – 10 ⁻² μCi/cc	23
ii. Particulate Activity RCS Leakage Detection	1	1, 2, 3 & 4	Not Applicable	1 – 10 ⁶ cpm	23

* With fuel in the storage pool or building.

** During movement of recently irradiated fuel assemblies or during crane operations with loads over recently irradiated fuel assemblies in the spent fuel storage pool.

*** The Alarm/Trip Setpoints are determined and set in accordance with requirements of the Offsite Dose Calculation Manual.

**** During movement of recently irradiated fuel assemblies within containment.

TABLE 3.3-6 (Continued)

ACTION STATEMENTS

- ACTION 22 -** With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, perform area surveys of the monitored area with portable monitoring instrumentation at least once per 24 hours.
- ACTION 23 -** With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, comply with the ACTION requirements of Specification 3.4.6.1.
- ACTION 24 -** With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, suspend all operations involving movement of recently irradiated fuel within the spent fuel storage pool or crane operations with loads over recently irradiated fuel assemblies in the spent fuel storage pool.
- ACTION 25 -** With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, comply with the ACTION requirements of Specification 3.9.9.
- ACTION 26 -** With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirements, within 1 hour initiate and maintain operation of the control room emergency ventilation system in the recirculation mode of operation.
- ACTION 27 -** With the number of OPERABLE Channels less than required by the Minimum Channels OPERABLE requirement, either restore the inoperable Channel(s) to OPERABLE status within 72 hours, or:
- 1) Initiate the preplanned alternate method of monitoring the appropriate parameter(s), and
 - 2) Prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 14 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.

PLANT SYSTEMS

3/4.7.7 CONTROL ROOM EMERGENCY AIR CLEANUP SYSTEM (CREACS)

LIMITING CONDITION FOR OPERATION

3.7.7 Two independent control room emergency air cleanup systems shall be OPERABLE with:

- a. A filter train and its associated fan per system, and
- b. At least one air conditioning unit per system, and
- c. Two isolation valves in the kitchen area exhaust duct, and
- d. Two isolation valves in the toilet area exhaust duct, and
- e. Two isolation valves in each (North and South) air intake duct.

APPLICABILITY: MODES 1, 2, 3, 4, 5 and 6 or during movement of irradiated fuel assemblies. |

ACTION:

MODES 1, 2, 3, and 4:

- a. With one control room emergency air cleanup system inoperable, restore the inoperable system to OPERABLE status within 7 days or be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With both control room emergency air cleanup systems inoperable, restore at least one system to OPERABLE status within 24 hours or be in at least HOT STANDBY within the next 6 hours and COLD SHUTDOWN within the next 30 hours.
- c. With an isolation valve in an air intake duct or air exhaust duct inoperable, operation may continue provided the other isolation valve in the same air intake or air exhaust duct is maintained closed; otherwise be in at least HOT STANDBY in the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

MODES 5 and 6 or during movement of irradiated fuel assemblies: |

- a. With one control room emergency air cleanup system inoperable, restore the inoperable system to OPERABLE status within 7 days or initiate and maintain operation of the remaining OPERABLE control room emergency air cleanup system in the recirculation mode or suspend movement of irradiated fuel assemblies. |
- b. With both control room emergency air cleanup systems inoperable, suspend movement of irradiated fuel assemblies. |
- c. With an isolation valve in an air intake duct or air exhaust duct inoperable, maintain the other isolation valve in the same air intake or air exhaust duct closed or suspend movement of irradiated fuel assemblies. |

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS

- 4.7.7 Each control room emergency air cleanup system shall be demonstrated OPERABLE:
- a. At least once per 12 hours by verifying that the control room air temperature is $\leq 120^{\circ}\text{F}$.
 - b. At least once per 31 days by (1) initiating, from the control room, flow through the HEPA filters and charcoal adsorbers and verifying that the system operates for at least 15 minutes and (2) starting, unless already operating each air conditioning unit and verifying that it operates for at least 8 hours.
 - c. By performing required control room emergency air cleanup system filter testing in accordance with the Ventilation Filter Testing Program.

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- d. At least once per 18 months by:
 - 1. Verifying that on a containment isolation test signal from Unit 2, the system automatically switches into a recirculation mode of operation with flow through the HEPA filters and charcoal adsorber banks.
 - 2. Verifying that the system maintains the control room at a positive pressure of greater than or equal to 1/8 inch Water Gauge relative to the outside atmosphere during system operation with ≤ 450 cfm outside air intake.
 - 3. Verifying that on a containment isolation test signal from Unit 1 the system automatically switches into a recirculation mode of operation with flow through the HEPA filters and charcoal adsorber banks.

REFUELING OPERATIONS

LOW WATER LEVEL

LIMITING CONDITION FOR OPERATION

3.9.8.2 Two independent shutdown cooling loops shall be OPERABLE and at least one shutdown cooling loop shall be in operation.

APPLICABILITY: MODE 6 when the water level above the top of the reactor pressure vessel flange is less than 23 feet.

ACTION:

- a. With less than the required shutdown cooling loops OPERABLE, within 1 hour initiate corrective action to return the required loops to OPERABLE status, or to establish greater than or equal to 23 feet of water above the reactor pressure vessel flange, as soon as possible.
- b. With no shutdown cooling loop in operation, suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet the boron concentration of Technical Specification 3.9.1 and within 1 hour initiate corrective action to return the required shutdown cooling loop to operation. Close all containment penetrations providing direct access from the containment atmosphere to the outside atmosphere within 4 hours.

SURVEILLANCE REQUIREMENTS

4.9.8.2 At least once per 12 hours:

- a. At least one shutdown cooling loop shall be verified to be in operation.
- b. The total flow rate of reactor coolant to the reactor pressure vessel shall be verified to be greater than or equal to 3000 gpm.*

* The reactor coolant flow rate requirement may be reduced to 1850 gpm if the following conditions are satisfied before the reduced requirement is implemented: the reactor has been determined to have been subcritical for at least 125 hours, the maximum RCS temperature is $\leq 117^{\circ}\text{F}$, and the temperature of CCW to the shutdown cooling heat exchanger is $\leq 87^{\circ}\text{F}$.

ADMINISTRATIVE CONTROLS (continued)

j. Technical Specifications (TS) Bases Control Program

This program provides a means for processing changes to the Bases of these Technical Specifications.

1. Changes to the Bases of the TS shall be made under appropriate administrative controls and reviews.
2. Licensees may make changes to Bases without prior NRC approval provided the changes do not require either of the following:
 - a. a change in the TS incorporated in the license; or
 - b. a change to the updated UFSAR or Bases that requires NRC approval pursuant to 10 CFR 50.59.
3. The Bases Control Program shall contain provisions to ensure that the Bases are maintained consistent with the UFSAR.
4. Proposed changes that meet the criteria of Specification 6.8.4.j.2.a or 6.8.4.j.2.b, above, shall be reviewed and approved by the NRC prior to implementation. Changes to the Bases implemented without prior NRC approval shall be provided to the NRC on a frequency consistent with 10 CFR 50.71(e).

k. Ventilation Filter Testing Program (VFTP)

A program shall be established to implement the following required testing of Engineered Safety Feature (ESF) filter ventilation systems at the frequencies specified in Regulatory Guide 1.52, Revision 2.

1. Demonstrate for each of the ESF systems that an inplace test of the high efficiency particulate air (HEPA) filters shows a penetration and system bypass $\leq 0.05\%$ when tested in accordance with ANSI N510-1980 at the system flowrate specified below.

<u>ESF Ventilation System</u>	<u>Flowrate</u>
Control Room Emergency Air Cleanup	2000 \pm 200 cfm

2. Demonstrate for each of the ESF systems that an inplace test of the charcoal adsorber shows a penetration and system bypass $\leq 0.05\%$ when tested in accordance with ANSI N510-1980 at the system flowrate specified below.

<u>ESF Ventilation System</u>	<u>Flowrate</u>
Control Room Emergency Air Cleanup	2000 \pm 200 cfm

3. Demonstrate for each of the ESF systems that a laboratory test of a sample of the charcoal adsorber, when obtained as described in Regulatory Guide 1.52, Revision 2, shows the methyl iodide penetration less than the value specified below when tested in accordance with ASTM D3803-1989 at a temperature of 30°C and the relative humidity specified below.

<u>ESF Ventilation System</u>	<u>Penetration</u>	<u>RH</u>
Control Room Emergency Air Cleanup	$\leq 0.175\%$	95%

ADMINISTRATIVE CONTROLS (continued)

k. Ventilation Filter Testing Program (VFTP) (continued)

4. Demonstrate for each of the ESF systems that the pressure drop across the combined HEPA filters and charcoal adsorbers is less than the value specified below when tested at the system flowrate specified below.

<u>ESF Ventilation System</u>	<u>Delta P</u>	<u>Flowrate</u>
Control Room Emergency Air Cleanup	< 7.4" W.G.	2000 ± 200 cfm

The provisions of SR 4.0.2 and SR 4.0.3 are applicable to the VFTP test frequencies.