

2005-421 _____ BWR Vessel & Internals Project (BWRVIP)

September 28, 2005

Document Control Desk
U. S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, MD 20852

Attention: Meena Khanna

Subject: Project 704- Errata to BWRVIP-139: Revised Table 5-1

Reference: "Project No. 704 – BWRVIP-139: BWR Vessel and Internals Project, Steam Dryer Inspection and Flaw Evaluation Guidelines," letter from William A. Eaton (BWRVIP Chairman) to Document Control Desk (NRC) dated May 11, 2005

BWRVIP-139 was transmitted to the NRC by the letter referenced above. Subsequently, an error was identified in Table 5-1 of the report. The table has been revised to indicate that, for square hood stream dryer designs, interior as well as exterior inspections of the outer bank hoods, hood end plates and cover plate are recommended. The need for interior inspections is discussed in the text of the document, but was not reflected in Table 5-1. The words "and Interior" have been added to the first "Inspection Components" column of Table 5-1. Enclosed are 5 copies of the revised table.

We regret any inconvenience this may have caused the NRC. Please note that the enclosed item contains proprietary information. Therefore, the request to withhold the BWRVIP-139 report from public disclosure transmitted to the NRC by the letter referenced above also applies to the enclosed item.

If you have any questions on the subject please contact George Inch (Constellation Generation Group, BWRVIP Assessment Committee Chairman) by telephone at 315-349-2441.

Sincerely,



William A. Eaton
Entergy Operations
Chairman, BWR Vessel and Internals Project



Together . . . Shaping the Future of Electricity