

October 14, 2005

Mr. Michael R. Kansler
President
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

SUBJECT: INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 - REQUEST FOR
ADDITIONAL INFORMATION REGARDING AUTHORIZATION TO EXTEND
THE THIRD 10-YEAR INSERVICE INSPECTION (ISI) INTERVAL FOR
REACTOR VESSEL WELD EXAMINATION (TAC NO. MC7306)

Dear Mr. Kansler:

On June 8, 2005, Entergy Nuclear Operations, Inc. (Entergy), submitted a relief request for Indian Point Nuclear Generating Unit No. 2 which requested authorization to extend the third 10-year ISI interval for reactor pressure vessel weld examinations.

The Nuclear Regulatory Commission staff is reviewing the submittal and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information (RAI). During a telephone call on October 5, 2005, the Entergy staff indicated that a response to the RAI would be provided within 30 days of receipt of this letter.

Please contact me at (301) 415-2901 if you have any questions on this issue.

Sincerely,

/RA/

John P. Boska, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-247

Enclosure: RAI

cc w/encl: See next page

October 14, 2005

Mr. Michael R. Kansler
President
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

SUBJECT: INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 - REQUEST FOR
ADDITIONAL INFORMATION REGARDING AUTHORIZATION TO EXTEND
THE THIRD 10-YEAR INSERVICE INSPECTION (ISI) INTERVAL FOR
REACTOR VESSEL WELD EXAMINATION (TAC NO. MC7306)

Dear Mr. Kansler:

On June 8, 2005, Entergy Nuclear Operations, Inc. (Entergy), submitted a relief request for Indian Point Nuclear Generating Unit No. 2 which requested authorization to extend the third 10-year ISI interval for reactor pressure vessel weld examinations.

The Nuclear Regulatory Commission staff is reviewing the submittal and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information (RAI). During a telephone call on October 5, 2005, the Entergy staff indicated that a response to the RAI would be provided within 30 days of receipt of this letter.

Please contact me at (301) 415-2901 if you have any questions on this issue.

Sincerely,

/RA/

John P. Boska, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-247
Enclosure: RAI
cc w/encl: See next page

DISTRIBUTION:

PUBLIC	RLaufer	JBoska	OGC
PDI-1 Reading File	ACRS	SLittle	SDinsmore
DLPM DPR	BMcDermott, RI	MRubin	

ADAMS ACCESSION NUMBER: ML052840030

OFFICE	PDI-1/PM	PDI-1/LA	PDI-1/SC
NAME	JBoska	SLittle	PMilano for RLaufer
DATE	10/13/05	10/13/05	10/13/05

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION

REGARDING REQUEST FOR AUTHORIZATION TO EXTEND THE THIRD 10-YEAR
INSERVICE INSPECTION (ISI) INTERVAL FOR REACTOR VESSEL WELD EXAMINATION

ENTERGY NUCLEAR OPERATIONS, INC.

INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

DOCKET NO. 50-247

In a letter dated June 8, 2005, Entergy Nuclear Operations, Inc. (Entergy), submitted a relief request for authorization to extend the third 10-year ISI interval for reactor pressure vessel weld examinations for Indian Point Nuclear Generating Unit No. 2 (IP2). The Nuclear Regulatory Commission (NRC) staff is reviewing the submittal and has the following question:

You stated that the technical justification for your request was consistent with the guidance provided in a January 27, 2005, letter from the NRC to Westinghouse Electric Company (Summary of Teleconference with the Westinghouse Owners Group Regarding Potential One Cycle Relief of Reactor Pressure Vessel Shell Weld Inspections at Pressurized-Water Reactors Related to WCAP-16168-NP, "Risk Informed Extension of Reactor Vessel In-Service Inspection Intervals"). Item number six of this guidance is repeated below:

The licensee could then provide a discussion of how, based on its plant operational experience, fleet-wide operational experience, and plant characteristics, the likelihood of an event (in particular, a significant pressurized thermal shock event) over the next operating cycle which could challenge the integrity of the reactor vessel pressure vessel (RPV), if a flaw was present, is very low.

Section 5.5 of your submittal includes general statements indicating that the likelihood of pressurized thermal shock (PTS) events is small and briefly describes an Entergy operating procedure that provides actions to avoid, or limit thermal shock to the reactor pressure vessel.

The NRC staff is re-evaluating the risk from PTS events in a study done to develop a technical basis for revising Title 10 of the *Code of Federal Regulations*, Part 50, Section 61 (10 CFR 50.61). Although the NRC staff has not yet completed its evaluation, the current results indicate that the following three types of accident sequences cause the more severe PTS events and thereby dominate the risk. Please describe the characteristics of your plant (design and operating procedures) that provide assurance that the likelihood of a severe PTS event over the next operating cycle which could challenge the integrity of the RPV, if a flaw was present, is very low.

Enclosure

Sequence 1:

Any transient with reactor trip followed by one stuck-open pressurizer safety relief valve that re-closes after about 1 hour. Severe PTS events also require the failure to properly control high-head injection.

Sequence 2:

Large loss of secondary steam from steam line break or stuck-open atmospheric dump valves. Severe PTS events also require the failure to properly control auxiliary feedwater flow rate and destination (e.g., away from affected steam generators) and failure to properly control high pressure injection.

Sequence 3:

Four to nine-inch loss-of-coolant accidents. Severity of PTS event depends on break location (worst location appears to be in the pressurizer surge line) and primary injection systems flow rate and water temperature.

Indian Point Nuclear Generating Unit No. 2

cc:

Mr. Gary J. Taylor
Chief Executive Officer
Entergy Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213

Mr. John T. Herron
Senior Vice President and
Chief Operating Officer
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Fred R. Dacimo
Site Vice President
Entergy Nuclear Operations, Inc.
Indian Point Energy Center
295 Broadway, Suite 1
P.O. Box 249
Buchanan, NY 10511-0249

Mr. Paul Rubin
General Manager, Plant Operations
Entergy Nuclear Operations, Inc.
Indian Point Energy Center
295 Broadway, Suite 2
P.O. Box 249
Buchanan, NY 10511-0249

Mr. Oscar Limpias
Vice President Engineering
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Brian O'Grady
Vice President, Operations Support
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. John F. McCann
Director, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Ms. Charlene D. Faison
Manager, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Michael J. Columb
Director of Oversight
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. James Comiotes
Director, Nuclear Safety Assurance
Entergy Nuclear Operations, Inc.
Indian Point Energy Center
295 Broadway, Suite 1
P.O. Box 249
Buchanan, NY 10511-0249

Mr. Patric Conroy
Manager, Licensing
Entergy Nuclear Operations, Inc.
Indian Point Energy Center
295 Broadway, Suite 1
P. O. Box 249
Buchanan, NY 10511-0249

Mr. Travis C. McCullough
Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Senior Resident Inspector's Office
Indian Point 2
U. S. Nuclear Regulatory Commission
P.O. Box 59
Buchanan, NY 10511-0038

Indian Point Nuclear Generating Unit No. 2

cc:

Mr. Peter R. Smith, President
New York State Energy, Research, and
Development Authority
17 Columbia Circle
Albany, NY 12203-6399

Mr. Paul Eddy
Electric Division
New York State Department
of Public Service
3 Empire State Plaza, 10th Floor
Albany, NY 12223

Mr. Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, NY 10511

Mr. Ray Albanese
Executive Chair
Four County Nuclear Safety Committee
Westchester County Fire Training Center
4 Dana Road
Valhalla, NY 10592

Ms. Stacey Lousteau
Treasury Department
Entergy Services, Inc.
639 Loyola Avenue
Mail Stop: L-ENT-15E
New Orleans, LA 70113

Mr. William DiProfio
PWR SRC Consultant
139 Depot Road
East Kingston, NH 03827

Mr. Daniel C. Poole
PWR SRC Consultant
P.O. Box 579
Inglis, FL 34449

Mr. William T. Russell
PWR SRC Consultant
400 Plantation Lane
Stevensville, MD 21666-3232

Mr. Jim Riccio
Greenpeace
702 H Street, NW
Suite 300
Washington, DC 20001