


# NRC Executive Overview of the ESBWR



September, 27, 2005


Steve Hucik

General Manager, New Plant Projects


# Presentation Content

- BWR Design Evolution
- DCD Status
- ESBWR Primary Characteristics
- ESBWR Passive Systems
  - > Changes since start of pre-application
- ESBWR Active Systems
  - > Differences from previous BWRs
- Digital Control and Instrumentation
- Summary

# BWR Evolution



# Containment Evolution




# ESBWR

- ABWR design certified
  - > Current project in progress in Lungmen
  - > Experience base developed from Lungmen and operating ABWRs at TEPCO's K6/7 site
- GE is committed to producing a quality product
- Continuing to build using experience and technology
- GE committed to work closely with the NRC to ensure sufficient detail and information exchange to support NRC licensing review—excellent interaction to date on pre-application review

# Lungmen Equipment Delivery & Installation



**Main Control Room Panels Testing**



**RHR Heat Exchanger Installation**




**Simulator testing at GENE San Jose**



**Installation of Reactor Pedestal Module**



# NRC Executive Overview of the ESBWR



September, 27, 2005

David Hinds

Manager, ESBWR Engineering



# ESBWR DCD Submittal

- Comprehensive DCD Submitted
  - > Reg Guide 1.70 format
  - > Built on experience of SBWR & ABWR
  - > Incorporated lessons learned from AP-1000 review

# Status of DCD Submittal

- DCD submitted 8/24/05
- Prompt and thorough review of application
- Acceptance review letter received
  - > Identified areas requiring further detailed information
- GE is committed to aggressively provide the necessary details to accomplish the review
  - > Plans and schedules to be submitted to review team


# ESBWR Basic Parameters

- 4,500 Megawatt Core Thermal Power
- ~1,580 Megawatt Electric Gross
  - > ~1,520 Megawatt Electrical Net
- Natural Circulation
- Passive Safety Systems
  - > 72 hours passive capability

# Site Parameters

- EPRI Utility Requirements Document Plus (+)
  - > Tornado
    - 330 mph
  - > Extreme Winds
    - 140 mph for safety-related
  - > Temperatures
    - Bound the 3 ESP sites
  - > Seismic
    - Reg Guide 1.60 plus a CEUS hard rock site

# Site Plan




**NOTES:**



1. THIS PLOT PLAN REPRESENTS THE STANDARD ESBWR CONFIGURATION. THIS CONFIGURATION WILL BE MODIFIED FOR SITE SPECIFIC REQUIREMENTS DURING COMBINED OPERATING LICENSE APPLICATIONS.
2. THE REFERENCE NORMAL HEAT SINK IS SHOWN AS NATURAL DRAFT COOLING TOWERS; HOWEVER, SITE SPECIFIC AVAILABLE WET BILLS AND COOLING WATER TEMPERATURES, ENVIRONMENTAL LIMITATIONS AND SPECIFIC TURBINE CONFIGURATION MAY DICTATE EITHER ONCE THROUGH OR MECHANICAL DRAFT TOWER COOLING. THESE SITE SPECIFIC ALTERNATE COOLING METHODS MAY ALSO CHANGE THE PLOT PLAN, CONDENSER AND CIRCULATING WATER SYSTEM DESIGN.

**BUILDING LEGEND:**


AB = AUXILIARY BOILER	OSC = OPERATION SUPPORT CENTER
AD = ADMINISTRATION BUILDING	PH = PUMP HOUSE
AT = UNIT AUXILIARY TRANSFORMER	PL = PARKING LOT
CB = CONTROL BUILDING	PS = PLANT STACK (NOT SHOWN-LOCATION WILL BE SITE SPECIFIC)
CM = COLD MACHINE SHOP	RAT = RESERVE AUXILIARY TRANSFORMER
CS = CONDENSATE STORAGE TANK	RB = REACTOR BUILDING
CT = MAIN COOLING TOWER	RW = RADWASTE BUILDING
DS = INDEPENDENT SPENT FUEL STORAGE INSTALLATION	SB = SERVICE BUILDING
EB = ELECTRICAL BUILDING	SF = SERVICE WATER BUILDING
EBAS = EMERGENCY BREATHING AIR SYSTEM (UNDERGROUND)	ST = SPARE TRANSFORMER
FB = FUEL BUILDING	STP = SEWAGE TREATMENT PLANT
FO = DIESEL FUEL OIL STORAGE TANK	SY = SWITCH YARD
FPE = FIRE PUMP ENCLOSURE	TB = TURBINE BUILDING
FWS = FIRE WATER STORAGE TANK	TC = TRAINING CENTER
HM = HOT MACHINE SHOP & STORAGE	TSC = TECHNICAL SUPPORT CENTER
LDA = LAY DOWN AREA	WD = WASH DOWN BAYS (EQUIPMENT ENTRY)
LO = DIRTY/CLEAN LUBE OIL STORAGE TANK	WH = WAREHOUSE
MS = MISCELLANEOUS SERVICE AREA	WS = WATER STORAGE
MT = MAIN TRANSFORMER	WT = WATER TREATMENT
NT = NITROGEN STORAGE TANK	




# Power Block Arrangement



# NRC Executive Overview of the ESBWR



September, 27, 2005  
J. Alan Beard






# What's different about ESBWR

ABWR	ESBWR
Recirculation System + support systems	Eliminated
HPCF System (2 each)	} Eliminated need for ECCS pumps Utilize passive and stored energy
LPFL (3 each)	
Residual Heat Removal (3 each)	
Safety Grade Diesel Generators (3 each)	Non-safety, combined with cleanup system
RCIC	Eliminated – only 2 non-safety grade diesels
SLC –2 pumps	Replaced with IC heat exchangers
Reactor Building Service Water (Safety Grade) And Plant Service Water (Safety Grade)	Replaced pumps with accumulators
	Made non-safety grade

# Optimized Parameters for ESBWR


<u>Parameter</u>	<u>BWR/4-Mk I</u> (Browns Ferry 3)	<u>BWR/6-Mk III</u> (Grand Gulf)	<u>ABWR</u>	<u>ESBWR</u>
Power (MWt/GrossMWe)	3293/1098	3900/1360	3926/1350	4500/1580
Vessel height/dia. (m)	21.9/6.4	21.8/6.4	21.1/7.1	27.7/7.1
Fuel Bundles (number)	764	800	872	1132
Active Fuel Height (m)	3.7	3.7	3.7	3.0
Power density (kw/l)	50	54.2	51	54
Recirculation pumps	2(large)	2(large)	10	zero
Number of CRDs/type	185/LP	193/LP	205/FM	269/FM
Safety system pumps	9	9	18	zero
Safety diesel generator	2	3	3	zero
Core damage freq./yr	1E-5	1E-6	1E-7	3E-8
Safety Bldg Vol (m <sup>3</sup> /MWe)	115	150	160	~ 130




# Natural Circulation

Simplification without performance loss ..

- **Passive safety/natural circulation**
  - Increase the volume of water in the vessel
  - Increase driving head
- **Significant reduction in components**
  - Pumps, motors, controls, HXers
- **Power Changes with Control Rod Drives**
  - Minimal impact on maintenance




# Passive Safety




# Passive Safety Systems ...


## Isolation Condenser System



## Passive Containment Cooling





# 72 Hours Passive Capability



# Gravity Driven Cooling System ...

Simple design  
Simple analyses

Extensive testing  
Large safety margins



**Gravity driven flow keeps core covered**




# Anticipated Operational Occurrences

- Reliable controls eliminate most limiting AOOs
- Large steam volume in reactor mitigates pressure increases
  - > No pressure overshoot in any AOO
- IC prevents SRV opening in all AOOs
- CPR change lower than forced circ. BWRs
  - > Loss of FW Heating is Limiting CPR, slow quasi-static response
- Loss of Coolant Accidents (LOCA)
  - > Large margin to fuel uncover in all pipe breaks
    - Only Passive systems credited
    - Designed for 72 hrs w/o external AC power or operator action


# AOO Without Scram (ATWS)

- Scram discharge volume eliminated
  - > Eliminates common mode failure
- Electric Control Blade insertion diverse from hydraulic scram
- FW runback results in decreased water level, core flow, & power reduction; automated and diverse from scram logic
- Boron Injection is direct to core bypass
  - Eliminates lower plenum boron stratification
- Boron accumulator initial flowrate exceeds 10CFR50 requirement
  - > Shutdown achieved quickly w/o depressurizing
- After shutdown IC operation terminates steam flow to suppression pool and pool heatup


# LOCA Water Level Response



# Reactor and Fuel Building




# Containment



# Isolation Condensers


- ICs provide passive decay heat removal
  - > Single Failure Criteria apply
  - > No lift of the Safety Relief Valves (SRVs)
  - > Operates in all Design Basis Conditions except medium and large break LOCAs
  - > ICs transport decay heat direct from NSSS to the Ultimate Heat Sink
    - No steaming in the primary containment
  - > Rapidly reduces RPV pressure
  - > Redundant Active Components



# Passive Containment Cooling

- PCCs provide passive decay heat removal from the primary containment
  - > Operates in medium and large break LOCAs
  - > Provides backup of ICs if needed
    - RPV is fully depressurized using DPVs
  - > Entirely Passive
    - > ~40 hours
    - > Opening of four valves to extend to 72 hours
  - > PCCs transport decay heat direct from Primary Containment to the Ultimate Heat Sink





imagination at work


# Emergency Core Cooling (ECC)


- Gravity Driven Cooling System (GDACS)
  - Three Pools
  - Four Trains
- Automatic Depressurization System (ADS)
  - 10 of 18 Safety Relief Valves (SRV)
    - Pneumatic actuation
  - 8 Depressurization Valves (DPV)
    - Squib actuated

# Emergency Core Cooling (cont)

- Core remains covered for entire range of Design Basis Accidents
  - > No fuel heat-up
- Complies with 10 CFR 50.46
  - > Codes have been approved by NRC
- Stored water is sufficient to flood RPV and containment (lower drywell) to above the top of fuel

# MSIV, SRV and DPV Arrangement





**Gravity-Driven Cooling System**

# Other Safety-Related Passive Systems

- DC Power Supplies
  - > Battery banks
  - > Inverters
  - > Battery Chargers
- Emergency Breathing Air System
  - > Main Control Room Habitability
- Standby Liquid Control (SLC)
  - > Two Pressurized Tanks of Boron

# Safety-Related Electrical

- Four Divisions
- DC Backed
  - > Inverted power for AC loads
  - > 4 Divisions with 24 hours Capability
    - Monitor
    - Control
  - > 2 divisions with 72 hours Capability
    - Monitor

# Regulatory Treatment of Non-Safety Systems (RTNSS)

- Enhanced QA will be imposed on some systems
  - Based on PSA insights
  - Post 72 hours through 7 days
- Fire Protection Systems
  - > IC/PCC pool fill
  - > Spent Fuel Pool makeup



# Plant Investment Protection (PIP)

- Non-safety systems provide for defense in depth
  - > Two redundant trains (active)
    - Significant contributors to plant availability
    - Asset Protection
  - > On-Site AC Power (Diesel Generators)
    - Electrical Distribution
  - > CRD Hydraulics
  - > Reactor Water Cleanup
  - > Fuel and Auxiliary Pool Cooling and Cleanup

# Instrumentation & Control Systems


- Key Design Features
  - > Digital data network for plant-wide control & display
    - Separate sub-systems
  - > Intelligent multiplexing system & fiber optics
  - > Standardized I&C equipment and components
  - > Plant Computer System supports extensive plant automation
  - > Online diagnostics
  - > Advanced control room design

# Digital Control and Instrumentation

- Diversity
  - > Four divisions of RPS
    - Manual scram and isolation
  - > Four divisions of ECCS
  - > Four divisions on non microprocessor based ATWS/SLCS
  - > Triple redundant controller for diverse RPS and ECCS
  - > Triple redundant controllers for major nuclear control functions
  - > Redundant controllers for investment protection and BOP control


# Digital Control and Instrumentation

## SAFETY RELATED



Note:  
each enclosed box represents a different hardware/software platform

## NON SAFETY RELATED



Segmented systems are networked but can work independently

# Reactor Protection

- Based on ABWR design
  - > 2/4 logic
  - > Fail safe
  - > Deterministic
  - > Diverse from ECCS
- Any two un-bypassed same parameters that exceed limits will always cause a scram with:
  - > Any single logic failure
  - > Any division of sensors bypass status
  - > Any division of logic bypass status
  - > Any single power failure
  - > Any possible main control room RPS control configuration

# Engineered Safety Feature I&C

- Based on ABWR design
  - > 2/4 logic
  - > Fail As Is
  - > Deterministic
  - > Diverse from RPS
- Any two un-bypassed same parameters that exceed limits will always initiate ECCS with:
  - > Any single logic failure
  - > Any division of sensors bypass status
  - > Any single power failure
  - > Any possible main control room ECCS control configuration




# Summary

- Enhanced Safety
  - > Continues improvement of BWR line
- Leverages ABWR design where appropriate
  - > Utilizes proven technologies
- Transient response is significantly improved
  - > No Safety Relief Valve (SRV) openings



# NRC Executive Overview of the ESBWR



September, 27, 2005  
Rick Wachowiak


# PRA Overview

Organization of the Documents

Attributes of the PRA

Summary of Results

# Document Relationships



# PRA Scope

## Internal Events, Power Operation

- > Level 1, 2, and 3

## Internal Events, Shutdown

- > Level 1
- > 99% SDCDF in mode 6, so no level 2 required

## External Events (non-Seismic)

- > Screening shows no impact on risk

## Seismic

- > Seismic margins analysis identified no outliers

# PRA Quality

Follows ASME Standard Principles

- > Where applicable, meets capability category 3
- > Some plant specific information not available until COL or construction

Certification PRA Capability

- > Determine that ESBWR meets risk goals
- > Determine importance at a system level
- > Determine overall importance of operator action

Each Element Appropriate for Certification

# Comprehensive System Analysis

## Detailed Fault Tree Model

- > 24 systems modeled
- > Major components included
- > Fully linked support systems
- > Intra-system common cause
- > Inter-system common cause for squib valves

# Containment Performance

Level 2 Linked Directly to Level 1

Phenomena Probabilities from ROAAM

- > High confidence, rather than mean, values used

# Shutdown

## Detailed Model

- > Loss of decay heat removal
- > LOCA
- > Loss of Preferred Power


Includes Manual Shutdown for Refueling




# The Bottom Line

Internal Events CDF	$3.2 \times 10^{-8}$
Internal Events LRF	$1 \times 10^{-9}$
CCFP	0.025
Probability of Exceeding 25 Rem at 1/2 Mile	$2 \times 10^{-9}$
External Events Contribution	negligible
Shutdown CDF	$4 \times 10^{-9}$

# Breakdown By Initiating Event



# Breakdown By Accident Class



# Attributes of ESBWR Risk

## **Redundancy and Diversity!!**

At Least 3 I&C Systems Need to Fail for Core Damage

Top Cutsets Involve

- > CCF of Batteries
- > CCF of Squib Valves

Loss of All Electric Power (AC & DC) Itself Does Not Cause Core Damage

Containment Failure Does Not Lead to Core Damage within 72 Hours

Containment Can Be Flooded Above Core Using Passive Systems

# Attributes Affecting Risk (continued)

## High Containment Ultimate Strength

- > High confidence pressure 1.2 MPaG
- > Most scenarios well below 0.9 MPaG

## Ex-Vessel Explosion

- > Does not occur if water in lower drywell less than 0.7 m. This is the likely case.
- > Containment survives EVE pressure pulse
- > Consideration for localized failures included

# Attributes Affecting Risk (continued)

## Direct Containment Heating


- > Containment survives initial pressurization
- > Long term high temperatures do not fail liner or penetrations
- > Lower to upper drywell configuration minimizes relocation of core debris
- > Containment spray added as defense-in-depth

# Attributes Affecting Risk (continued)

## Basemat Melt Penetration

- > Precluded by BiMAC (see next slide)
- > Diverse actuation
- > Cools debris from above, below, and on sides

# Basemat Internal Melt Arrest and Coolability (BiMAC)





# Regulatory Treatment of Non-Safety Systems

## One System Identified

- > Fire water refill of IC/PCC pools

## Sensitivity Analysis Provides Basis

- > Calculated CDF using only safety-related and special treatment systems
- >  $CDF = 4.0 \times 10^{-5}$
- >  $LRF = 2.6 \times 10^{-7}$

# Other Sensitivities

Case	Core Damage Frequency (yr <sup>-1</sup> )	Large Release Frequency (yr <sup>-1</sup> )
Base	$3.2 \times 10^{-8}$	$8 \times 10^{-10}$
Safety + RTNSS	$4.0 \times 10^{-5}$	$2.6 \times 10^{-7}$
No Operator Credit	$1.9 \times 10^{-6}$	$4.0 \times 10^{-7}$
Squib Failure x 5	$1.4 \times 10^{-7}$	$2.4 \times 10^{-9}$
Squib Failure x 10	$2.8 \times 10^{-7}$	$4.2 \times 10^{-9}$
Truncation @ $10^{-14}$	$3.4 \times 10^{-8}$	$9 \times 10^{-10}$

# Conclusions

PRA Report Provides a Comprehensive Assessment of ESBWR Mitigation Capabilities

Incorporating Risk Insights During Design Drives Reliability

ESBWR Satisfies Risk Goals With Significant Margin