



Constellation Energy

Nine Mile Point Nuclear Station

P.O. Box 63
Lycoming, NY 13093

September 30, 2005
NMP2L 2124

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

SUBJECT: Nine Mile Point Unit 2
Docket No. 50-410
Facility Operating License No. NPF-69

Withdrawal of License Amendment Request to Extend the Completion
Time for One Emergency Uninterruptible Power Supply Inverter
Inoperable (TAC No. MC6561)

Gentlemen:

By letter NMP2L 2120 dated April 1, 2005, Nine Mile Point Nuclear Station, LLC (NMPNS) requested an amendment to Nine Mile Point Unit 2 Operating License NPF-69. The proposed amendment would have revised Required Action A.1 of Technical Specification (TS) 3.8.7, "Inverters – Operating," to extend the Completion Time for one emergency uninterruptible power supply (UPS) inverter inoperable from 24 hours to 7 days.

Subsequent to the amendment request submittal, NMPNS has installed a redundant emergency UPS inverter unit in each of the two safety-related electrical divisions. This plant modification reduces the potential for a TS-required plant shutdown due to an inoperable inverter, since the redundant inverter unit can now be placed in service. Therefore, NMPNS hereby withdraws the license amendment request referenced above.

If you have any questions regarding this submittal, please contact James A. Hutton, Director Licensing, at (315) 349-1041.

Very truly yours,

Timothy J. O'Connor
Plant General Manager

TJO/DEV/sac

A001

