

From: Rick Ennis
To: Devender Reddy; James Tatum; Steve Jones
Date: 10/14/05 12:46PM
Subject: Entergy proposed change to license condition 3.L

Steve/Jim/Devender,

The letter we sent Entergy on 10/12/05 included the following wording for license condition 3.L, "Transient Testing:"

"During the extended power uprate (EPU) power ascension test program and prior to exceeding 168 hours of plant operation at the nominal full EPU reactor power level, with feedwater and condensate flow rates stabilized at approximately the EPU full power level, Entergy Nuclear Operations, Inc. shall confirm (1) through performance of transient testing that the loss of one condensate pump will not result in a complete loss of reactor feedwater and (2) through performance of additional transient testing, or analysis of the results of the testing conducted in (1) above, that the loss of one reactor feedwater pump will not result in a reactor trip."

Entergy plans to respond to the 10/12/05 letter by COB on Monday 10/17. The attached email provides their proposed changes to the license condition. Since you're not available today, Entergy would like to discuss the proposed changes with SPLB on Monday morning. Please let me know if you can support a call at 8:30 am.

thanks,

Rick
301-415-1420

CC: Catherine Haney; Cornelius Holden; Darrell Roberts; James Lyons; John Hannon; Tad Marsh; Thomas Martin

Mail Envelope Properties (434FE101.E4A : 11 : 372)

Subject: Entergy proposed change to license condition 3.L
Creation Date: 10/14/05 12:46PM
From: Rick Ennis
Created By: RXE@nrc.gov

Recipients	Action	Date & Time
OWGWPO02.HQGWDO01 SRJ (Steve Jones)	Delivered	10/14/05 12:47 PM
TWGWPO01.HQGWDO01 DKR2 (Devender Reddy)	Delivered	10/14/05 12:47 PM
owf2_po.OWFN_DO JET1 (James Tatum)	Delivered	10/14/05 12:47 PM
owf4_po.OWFN_DO CFH CC (Cornelius Holden) DJR CC (Darrell Roberts) JEL CC (James Lyons) JNH CC (John Hannon) LBM CC (Tad Marsh) RXE BC (Rick Ennis)	Delivered Opened	10/14/05 12:47 PM 10/14/05 12:47 PM
owf5_po.OWFN_DO CXH CC (Catherine Haney)	Delivered	10/14/05 12:47 PM
twf4_po.TWFN_DO TOM2 CC (Thomas Martin)	Delivered	10/14/05 12:47 PM

Post Office	Delivered	Route
OWGWPO02.HQGWDO01	10/14/05 12:47 PM	
TWGWPO01.HQGWDO01	10/14/05 12:47 PM	
owf2_po.OWFN_DO	10/14/05 12:47 PM	
owf4_po.OWFN_DO	10/14/05 12:47 PM	
owf5_po.OWFN_DO	10/14/05 12:47 PM	
twf4_po.TWFN_DO	10/14/05 12:47 PM	

Files	Size	Date & Time
MESSAGE Mail	1873	10/14/05 12:46PM

Options

Auto Delete:	No
Expiration Date:	None
Notify Recipients:	Yes
Priority:	High
Reply Requested:	No
Return Notification:	None
Concealed Subject:	No
Security:	Standard
To Be Delivered:	Immediate
Status Tracking:	Delivered & Opened

From: "Daflucas, Ronda" <rdafluc@entergy.com>
To: "Rick Ennis" <RXE@nrc.gov>
Date: 10/14/05 12:33PM
Subject: DRAFT for discussion, only

Rick -

Following is a DRAFT proposed rewrite of "L: Transient testing" for discussion purposes:

During the [EPU]...[ENO] shall: (1) confirm through performance of transient testing that the loss of one condensate pump will not result in a complete loss of reactor feedwater. (2) Within 30 days at nominal full-power operation following successful performance of the test in (1) above, through performance of additional transient testing, or analysis of the results of the testing conducted in (1) above, confirm that the loss of one reactor feedwater pump will not result in a reactor trip.

Thanks,

Ronda