

A subsidiary of Pinnacle West Capitol Corporation

Palo Verde Nuclear Generating Station Cliff Eubanks Vice President Nuclear Operations

Tel (623) 393-6116 Fax (623) 393-6077 Mail Station 7602 PO Box 52034 Phoenix, Arizona 85072-2034

102-05354-CE/CKS/DLK October 7, 2005

ATTN: Document Control Desk U.S. Nuclear Regulatory Commission Washington, DC 20555-0001

Dear Sirs:

Subject: Palo Verde Nuclear Generating Station (PVNGS) Unit 1 Docket No. STN 50-528 License No. NPF 41 Licensee Event Report 2005-004-00

Attached please find Licensee Event Report (LER) 50-528/2005-004-00 prepared and submitted pursuant to 10 CFR 50.73. This LER reports a shutdown required by Technical Specifications based on the inability to return "B" Emergency Diesel Generator to operable status following a failed routine surveillance test within the required action completion time.

In accordance with 10 CFR 50.73(d), copies of this LER are being forwarded to the NRC Regional Office, NRC Region IV and the Senior Resident Inspector. If you have questions regarding this submittal, please contact Daniel G. Marks, Section Leader, Regulatory Affairs, at (623) 393-6492.

The corrective actions described in this LER are not necessary to maintain compliance with regulations. Arizona Public Service Company makes no commitments in this letter.

Sincerely,

Debab

CE/CKS/DLK/ca

Attachment

cc: B. S. Mallett M. B. Fields G. G. Warnick NRC Region IV Regional Administrator NRC NRR Project Manager - (send electronic and paper) NRC Senior Resident Inspector for PVNGS

NRC FO	RM 366	_		U.S. NUCLE	AR RI	EGULATO	RY COMM	ISSION	APPRC	OVED BY OMB	NO. 3150-01	04	EXPIRES:	06/30/2007
(6-2004)									Estimat request	ted burden per t: 50 hours. F	r response to Reported lesso	comply with thing learned are	is mandato incorporat	ry collection ted into the
	1		SFF F		POR				estimat	te to the Record Regulatory Co	ds and FOIA/I	rivacy Service shington, DC 20	Branch (T- 555-0001, c	5 F52), U.S. br by internet
	I						1		e-mail t and Re	to infocollects@ gulatory Affairs,	nrc.gov, and to NEOB-10202,	o the Desk Offic (3150-0104), Of	er, Office o fice of Mana	f Information agement and
		ر See) digit	everse s/chara	for require acters for ea	d nur ach b	nber of lock)			collection not cor informa	t, Washington, on does not disp nduct or spons ation collection.	DC 20503. If a play a currently for, and a per	valid OMB contro son is not requ	impose ar pl number, t ired to resp	h information he NRC may pond to, the
1. FACI		ME	Nuelee		:		-		2. DOC		ER	3. PAGE		
	Palo	verde	Nuclea	ir General	ing a		JNICT			05000528	<u> </u>		OF 4	
	Tech	nical S	pecific	ation Requ	uired	Reacto	r Shutd	lown c	n ED	G "B" Vol	tage Reg	ulator Fail	ure	
5. E	VENT D	ATE	6.	LER NUMBER	2	7. R	EPORT D	ATE		8.	OTHER FAC	ILITIES INVO	LVED	
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REV NO.	MONTH	DAY	YEAR	FACII NO:				050	UMBER 00
08	12	2005	2005	- 004 -	00	10	07	2005					DOCKET N 050	NUMBER
9. OPER	RATING	MODE	11	. THIS REPO	RTIS	SUBMITTI	ED PURS	UANT T	O THE	REQUIREM	ENTS OF 10	CFR§: (Chec	k all that a	apply)
	1		□ 20.2 □ 20.2 □ 20.2 □ 20.2	201(b) 201(d) 203(a)(1) 203(a)(2)(i)			0.2203(a) 0.2203(a) 0.2203(a) 0.36(c)(1)	(3)(i) (3)(ii) (4) (i)(A)		 50.73(a) 50.73(a) 50.73(a) 50.73(a) 50.73(a) 	(2)(i)(C) (2)(ii)(A) (2)(ii)(B) (2)(iii)	□ 50.73 □ 50.73 □ 50.73 □ 50.73	8(a)(2)(vii) 8(a)(2)(viii) 8(a)(2)(viii) 8(a)(2)(ix)()(A))(B) (A)
10. POV	VER LEV	'ÉL		203(a)(2)(ii) 203(a)(2)(iii)			0.36(c)(1)	(ii)(A)		\Box 50.73(a)	(2)(iv)(A) (2)(v)(A)		8(a)(2)(x)	
	04		20.2	203(a)(2)(iv)			0.46(a)(3))(ii)		50.73(a)	(2)(v)(B)	□ 73.7 ⁴	l(a)(5)	
	94		20.2 20.2	203(a)(2)(v) 203(a)(2)(vi)			0.73(a)(2) 0.73(a)(2)	(i)(A) (i)(B)		50.73(a)	(2)(v)(C) (2)(v)(D)	OTH Speci or in t	ER fy in Abstra JRC Form 3	ct below 366A
			L		1	2. LICENS		FACT FO	DR THI	IS LER				
FACILITY	name Danio	el G. M	arks. S	Section Lea	ader.	Regula	atory Af	fairs			TEL (6)	EPHONE NUMBER 23) 393-64	R (Include Are	ea Code)
<u> </u>			13. COM	PLETE ONE	LINE	FOR EACH	I COMPO	NENT F	AILUR	E DESCRIBI	ED IN THIS F	REPORT		
CAL	JSE	SYSTEM	СОМРО		1U- JRER	REPOR TO E	TABLE EPIX	C/	USE	SYSTEM	COMPONENT	MANU- FACTURER	REPC	ORTABLE DEPIX
E	3	EK	DO	G C6	34	١	(
	ı	14	. SUPPL	EMENTAL RE	POR	TEXPECT	ED			15. E	PECTED	MONTH	DAY	YEAR
	ES (If yes	, complet	e 15. EXI	PECTED SUB	MISSI	ON DATE,)		NO		DATE			
ABSTRA	ACT (Lim	it to 1400	spaces,	i.e., approxim	ately 1	5 single-s	paced type	written i	ines)	l		<u> </u>		<u> </u>
	On August 12, 2005 at 0019 Palo Verde Unit 1 was in Mode 1 (Power Operations), operating at approximately 94 percent power, when Control Room personnel commenced a reactor shutdown required by Technical Specification 3.8.1.							t						
	Prior to the event, on August 9, 2005, Emergency Diesel Generator "B" failed to maintain proper steady state output voltage during the performance of a routine monthly surveillance test. Engineering and Maintenance personnel were unable to identify and correct the cause of the							r						
	fluctu	lating g	enerat	or output	volta	ge withi	n the 72		requ	lired actio	n complet	tion time	10	
1	2005	at 042	0. At (0216 on A	ugus	t 12, 20	05 Con	trol R	som r	personnel	manually	r tripped th	۱ <i>೭</i> , e	
	react	or from	23 pe	rcent reac	tor p	ower. A	At 0217	, Palo	Verd	le Unit 1 e	ntered M	ode 3 (Hot		
	Stand Augu	dby), co ist 12. 2	ompleti 2005. L	ing a react Jnit 1 ente	or sl red I	nutdowr Mode 5	require (Cold S	ed by Shutda	Tech wn) a	nical Spe and exited	cification : d LCO 3.	3.8.1. At 2 8.1.	237 or	า
	All tir	nes in f	his rer	ort are an	prox	imate a	nd Mou	Intain	Stand	dard Time	unless n	oted other	wise.	
	An unles in this report are approximate and mountain Standard. Time unless noted otherwise.													
	In the past three years, Palo Verde reported reactor shutdowns required by Technical Specifications but none associated with the same root cause.													
		_												

• •

,

NRC FORM 366A U.S. NUCLEAR REGULATORY COMMISS (7-2001) LICENSEE EVENT REPORT (LER)	ON				
1. FACILITY NAME	2. DOCKET	I	6. LER NUMBE	R	3. PAGE
Palo Verde Nuclear Generating Station	05000528	YEAR	SEQUENTAL NUMBER	REVISION NUMBER	
Unit 1		2005 ·	004 -	2 OF 4	

17. NARRATIVE (*If more space is required, use additional copies of NRC Form* 366A)

1. REPORTING REQUIREMENT(S):

This LER (50-528/2005-004-00) is being submitted pursuant to 10 CFR 50.73(a)(2)(i)(A), to report the completion of a reactor shutdown required by Technical Specifications. Specifically, on August 12, 2005 Control Room personnel completed a reactor shutdown to avoid exceeding the 72 hour required action completion time associated with Technical Specification Limiting Condition for Operation (LCO) 3.8.1 condition "B". LCO 3.8.1 condition "B" requires two Emergency Diesel Generators (EDG) (EIIS code: EK, DG), each capable of supplying one train of the onsite class 1E alternating current (ac) power distribution system, be operable. On August 12, 2005 at 0026 a 4-hour NRC notification was made per 10 CFR 50.72 to report a plant shutdown required by Technical Specifications (re: ENS 41913).

2. DESCRIPTION OF STRUCTURE(S), SYSTEM(S) AND COMPONENT(S):

The standby power supply (EIIS code: EK) for each safety-related load group consists of one EDG, complete with its accessories and fuel storage and transfer systems. The standby power supply functions as a source of alternating current (ac) power for safe plant shutdown in the event of loss of preferred power and for post-accident operation of engineered safety feature (ESF) loads.

3. INITIAL PLANT CONDITIONS:

On August 12, 2005 Palo Verde Unit 1 was in Mode 1 (Power Operations), operating at approximately 94 percent power. At the start of the event EDG "B" was inoperable. No other major structures, systems, or components were inoperable that contributed to the event.

4. EVENT DESCRIPTION:

Prior to the event, on August 9, 2005, voltage anomalies (steady state voltage fluctuations) were observed immediately after EDG "B" was started for a routine monthly surveillance. At 0420 on August 9, Control Room personnel declared EDG "B" inoperable and entered Technical Specification 3.8.1 condition "B." EDG "B" was quarantined and a work mechanism was initiated to troubleshoot the voltage anomalies.

Technical Specification 3.8.1 condition "B" requires the following actions to be completed with one EDG inoperable:

1. FACILITY NAME	2. DOCKET		6. LER NUMBE	3. PAGE	
Palo Verde Nuclear Generating Station	05000528	YEAR		NUMBER	3 OF 4
Unit 1		2005 -	- 004 -	- 00	
7. NARRATIVE (If more space is required, use additional copie	es of NRC Form 3	56A)			
B.1 Perform SR 3.8.1.1 for 1 hour and once per 8 hours	r the operabl thereafter ar	e require nd,	ed offsite cire	cuit(s) with	hin
B.2 Declare required featu inoperable when its redundar hours from discovery of cond redundant required feature(s)	re(s) suppor nt required fe ition B conce) and,	ted by th eature(s) urrent wit	e inoperable is inoperabl h inoperabl	e DG e within 4 ity of	
B.3.1 Determine OPERABLE failure within 24 hours (or)	E DG is not i	noperab	e due to co	mmon cau	lse
B.3.2 Perform SR 3.8.1.2 for	OPERABLI	E DG wit	hin 24 hours	s and,	
B.4 Restore DG to OPERA days from discovery of failure	ABLE status to meet LC	within 72 O.	hours and	within 6	
Engineering and Maintenance perso "B" and correct the voltage anomalie the problem within the 72 hour requi Specification 3.8.1. Unable to resto 0019 on August 12, 2005 Control Re commenced a normal reactor shutde in Mode 3 (Hot Standby) within 6 ho At 0216 on August 12, 2005, Control	onnel develo es but were i ired action c re EDG "B" f oom personi own. LCO 3 ours and Moo	ped an a not succe ompletio o operat nel enter .8.1 con le 5 (Col	ction plan to essful in iden n time allow ole status wi ed LCO 3.8. dition "H" rea d Shutdown enformed a p	o troubles ntifying the ed by Tec thin 72 hc 1 conditio quires Un) within 30 papual res	hoot EDG e cause of chnical ours, at on "H" and it 1 to be 6 hours. actor trip

5. ASSESSMENT OF SAFETY CONSEQUENCES:

at 2237, Unit 1 entered Mode 5 and exited LCO 3.8.1.

With one EDG inoperable, the remaining operable EDG and offsite circuits are adequate to supply electrical power to the onsite class 1E ac power distribution system. The 72 hour required action completion time takes into account the capacity and capability of the remaining ac sources, a reasonable time for repairs, and the low probability of a Design Basis Accident.

from 23 percent reactor power. At 0217, Unit 1 entered Mode 3. On August 12, 2005,

The event did not result in any challenges to the fission product barriers or result in the release of radioactive materials. Therefore, there were no adverse safety consequences or implications as a result of this event and the event did not adversely affect the safe operation of the plant or health and safety of the public.

		· · · · · · · · · · · · · · · · · · ·	
IRC FORM 366A U.S. NUCLEAR REGULATORY COMMISSI 7-2001)	ON		
LICENSEE EVENT REPORT (LER)			
1. FACILITY NAME	2. DOCKET	6. LER NUMBER	3. PAGE
Palo Verde Nuclear Generating Station	05000528	YEAR SEQUENTAL REVISION NUMBER NUMBER	
Unit 1		2005 004 00	4 06 4
7. NARRATIVE (If more space is required, use additional cop	ies of NRC Form 3	56A)	<u></u>
result in a safety system functional	failure as de	ined by 10 CFR 50.73(a)(2)(v)	
6. CAUSE OF THE EVENT:			
The cause of the event was the inal 72 hour required action completion	bility to return time allowed	n EDG "B" to operable status w by LCO 3.8.1 condition "B."	vithin the
The root cause of the EDG "B" volta Regulator (AVR) (EIIS code: EK, D0 Peebles/Portec, model number 72-0	age anomalie G, RG). The 08300-100.	s was a failed Automatic Volta AVR manufacturer is NEI	ige
The engineering action plan to troub	pleshoot the	voltage anomalies attempted to	o first rule

out possible causes not associated with the AVR in part because replacement of the AVR would require post maintenance load rejection surveillance testing in accordance with Technical Specification Surveillance Requirement (SR) 3.8.1.9. Performance of this surveillance is prohibited in Modes 1 through 4.

7. CORRECTIVE ACTIONS:

On August 12, 2005 the reactor was manually shutdown. The AVR on EDG "B" was replaced and all retests were completed satisfactorily. On August 14, 2005, at 1232, EDG "B" was returned to operable status.

A significant investigation into the EDG "B" voltage anomalies is currently in progress. If results from the significant investigation identify substantial information that would change the reader's perception of the event or corrective actions described in this LER, a supplemental LER will be submitted.

8. PREVIOUS SIMILAR EVENTS:

In the past three years, Palo Verde reported reactor shutdowns required by Technical Specifications but none associated with the same root cause.