



October 21, 2005

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Serial No. 05-716  
NLOS/vlh  
Docket No. 50-339  
License No. NPF-7

**VIRGINIA ELECTRIC AND POWER COMPANY**  
**NORTH ANNA POWER STATION UNIT 2**  
**STEAM GENERATOR TUBE PLUGGING REPORT**

Scheduled eddy current inspections of the North Anna Unit 2 "B" steam generator were completed during the Fall 2005 Refueling Outage. In accordance with North Anna Power Station Technical Specifications, Reporting Requirement 5.6.7.a, this letter provides notification that no steam generator tubes were plugged during the outage.

This letter intends no new commitments. If you should have any questions or require additional information, please contact Mr. Thomas Shaub at (804) 273-2763.

Very truly yours,

A handwritten signature in black ink, appearing to read "C. L. Funderburk", is written over a large, light-colored circular scribble.

C. L. Funderburk, Director  
Nuclear Licensing and Operations Support  
Dominion Resources Services, Inc. for  
Virginia Electric and Power Company

cc: U. S. Nuclear Regulatory Commission  
Region II  
Sam Nunn Atlanta Federal Center  
61 Forsyth Street, SW  
Suite 23T85  
Atlanta, Georgia 30303

Mr. Stephen R. Monarque  
NRC Project Manager – Surry and North Anna  
U. S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852

Mr. J. E. Reasor, Jr.  
Old Dominion Electric Cooperative  
Innsbrook Corporate Center  
4201 Dominion Boulevard  
Suite 300  
Glen Allen, Virginia 23060

Mr. J. T. Reece  
NRC Senior Resident Inspector  
North Anna Power Station

Mr. M. M. Grace  
Authorized Nuclear Inspector  
North Anna Power Station